

Nova Scotia Community Feed-in Tariffs
2010 NSUARB-BRD-E-R-10

Undertaking: U-9

Provide a corrected version of B-1, “E”

In the first column of this exhibit (for small wind), the figures were offset from the row titles, such that the cost of NSPI equipment (\$10,200) was shown in the row titled “Studies.” A corrected version is attached. None of the sums in the bottom row of this table have changed due to this correction.

Synapse U-9, 4/12/11

Corrected Exhibit E:

Submitted with the Evidence of Bruce Biewald, Wilson Rickerson,
Geoff Keith and Susan Shaw

Interconnection Costs Included in the Tariff Modeling (\$2012)

	Wind ≤50 kW	Wind >50 kW	Biomass CHP	Hydro	Tidal
Studies	\$0	\$7,600	\$7,600	\$7,600	\$7,600
NSPI Equip.	\$10,200	\$84,100	\$84,100	\$84,100	\$84,100
Customer Equip. (Transformer)	\$3,100	\$0	\$102,000	\$76,400	\$51,000
Customer Equip. (Other)	\$0	\$5,100	\$5,100	\$5,100	\$5,100
Line Extension	\$0	\$112,000	\$0	\$112,000	\$112,000
Total	\$13,300	\$209,000	\$199,000	\$285,000	\$260,000

Notes: Totals have been rounded.