


April 20, 2026

Jaspal Singh



Dear Jaspal Singh,

Re: Account No. [REDACTED]

Meter No. [REDACTED]

We are writing to confirm the results of your recent meter test. This test was conducted following your inquiry about electrical usage at your premises. Per our meter test process, NS Power requested your meter (noted above) be tested in NS Power's accredited (approved by Measurement Canada) testing facility.

Your meter has now been tested and the results indicate this meter is operating within prescribed accuracy limits.

Should you wish to further pursue this matter, you have the option to request a meter test by Measurement Canada within 6 months of the date of this letter. Please note, the current fee is \$46.00 for this additional testing.

The local office for Measurement Canada can be reached at 902-426-2525. Upon receipt of your request, they will formalize a written process of notification to both you and NS Power to obtain this meter for an official test. If the meter is found to be outside the allowable limits, Measurement Canada will provide details as to the level of inaccuracy for an account adjustment. Should this occur, the \$46.00 fee would be credited to your electrical account (noted above).

Should you wish to discuss this matter further, please do not hesitate to contact one of our Customer Care representatives by calling 1-800-428-6230. Our representatives can also suggest tips to help reduce your energy usage or offer programs such as our Equal Billing program that make it easier to budget for your electricity bill throughout the year through equal monthly payments.

Yours truly,

Teri

Comments Screen Inquiry Mode - -

File Edit Functions Help

Comments Screen Inquiry Mode

Equip Type	MTRE	Equip ID	2039876
Date	2026/04/20	Op Code	TEST

TESTED OK, EVENTS OK

OK Cancel

Electric Meter Test Results - Screen One - MTR01 - * * * NOVA SCOTIA POWER IN... — □ ×

File Edit Functions Help

Electric Meter Test Results - Screen One

Equip Type	MTRE	Date	2026/04/20 17
Equip ID	2039876	Op Code	TEST
Tester's User ID	AH549		
Standard Code	813		
As Found kWh	102823.00		
Lot Number			
Damage Code			
Firmware Version			
OTHER			

Next Screen Delete

OK Cancel

Electric Meter Test Results - Screen Two - MTR02 - ***NOVA SCOTIA POWER IN...

FileEditFunctionsHelp

Electric Meter Test Results - Screen Two

Equip Type

MTRE

Equip ID

2039876

Date

2026/04/2017

Op Code

TEST

FLSASF^KWH

0.05

FLAASF^KWH

FLCASF^KWH

FLBAS^KWH

LLSASF^KWH

0.05

LLAASF^KWH

LLCASF^KWH

LLBAS^KWH

PFSASF^KWH

0.01

PFAASF^KWH

PFCASF^KWH

PFBASF^KWH

FLSASF^KQH

FLAASF^KQH

FLCASF^KQH

FLBAS^KQH

LLSASF^KQH

LLAASF^KQH

LLCASF^KQH

LLBAS^KQH

PFSASF^KQH

PFAASF^KQH

PFCASF^KQH

PFBASF^KQH

Next Screen

Delete

OK

Cancel

Electric Meter Test Results - Screen Three - - *** NOVA SCOTIA POWER INC. *...

File Edit Functions Help

Electric Meter Test Results - Screen Three

Equip TypeMTRE

Equip ID2039876

Date2026/04/2017

Op CodeTEST

FLSASLKWH		FLSASLKQH		FLAASLKWH	
FLAASLKQH		FLCASLKWH		FLCASLKQH	
FLBASLKWH		FLBASLKQH		LLSASLKWH	
LLSASLKQH		LLAASLKWH		LLAASLKQH	
LLCASLKWH		LLCASLKQH		LLBASLKWH	
LLBASLKQH		PFSASLKWH		PFSASLKQH	
PFAASLKWH		PFAASLKQH		PFCASLKWH	
PFCASLKQH		PFBASLKWH		PFBASLKQH	
PULASLKWH		PULASLKVA		PULASLKQH	
REGRATIO		CRCHECK		LOSSCOMP	

Next Screen

Delete

OK

Cancel

Electric Meter Test Results - Screen Four - - *** NOVA SCOTIA POWER INC. ***

File Edit Functions Help

Electric Meter Test Results - Screen Four

Equip Type	MTRE	Date	2026/04/20 17
Equip ID	2039876	Op Code	TEST

Creep Test Performed	☒	Replaced Base	☐
Dial Check Performed	☒	Replaced Cover	☐
Phase Test Performed	☐	Replaced Register	☐
Short Test Performed	☐	Replaced Idle Pointe	☐
Hand Test Performed	☐	Replaced Battery	☐
Replace Up Bearing	☐	Replaced Thermal elm	☐
Replace Lower Bearin	☐	As Left kWh	102825.00
Replaced Disk	☐		

Delete

OK Cancel

*** NOVA SCOTIA POWER INC. ***
Usage Information Report

Account # [REDACTED] JASPAL SINGH
Premises # [REDACTED]
Meter # [REDACTED]
Utility E [REDACTED]

Bill Date	Utl	Meter #	U/R	Read Date	Reading	Usage
2026/03/12	E	[REDACTED]	R	2026/02/25	96042.73	13835.73
2025/12/31	E	[REDACTED]	U	2025/12/31	82207.00	1032.00