

Comments Screen Inquiry Mode - -

File Edit Functions Help

Comments Screen Inquiry Mode

Equip Type	MTRE	Equip ID	2561954
Date	2026/09/01	Op Code	TEST

TESTS OK

OK Cancel

Electric Meter Test Results - Screen One - MTR01 - * * *NOVA SCOTIA POWER IN...

FileEditFunctionsHelp

Electric Meter Test Results - Screen One

Equip TypeMTRE

Equip ID2561954

Date2026/09/0117

Op CodeTEST

Tester's User IDAE577

Standard Code

As Found kWh24899.00

Lot Number

Damage Code

Firmware Version

OTHER

Next Screen

Delete

OK

Cancel

Electric Meter Test Results - Screen Two - MTR02 - * * *

NOVA SCOTIA POWER IN...

File

Edit

Functions

Help

Electric Meter Test Results - Screen Two

Equip Type

MTRE

Equip ID

2561954

Date

2026/09/01

17

Op Code

TEST

FLSASFKWH

0.01

FLSASFKQH

FLAASFKWH

FLAASFKQH

FLCASFKWH

FLCASFKQH

FLBASFKWH

FLBASFKQH

LLSASFKWH

0.04

LLSASFKQH

LLAASFKWH

LLAASFKQH

LLCASFKWH

LLCASFKQH

LLBASFKWH

LLBASFKQH

PFSASFKWH

0.06

PFSASFKQH

PFAASFKWH

PFAASFKQH

PFCASFKWH

PFCASFKQH

PFBASFKWH

PFBASFKQH

Next Screen

Delete

OK

Cancel

Electric Meter Test Results - Screen Four - - *** NOVA SCOTIA POWER INC. ***

File Edit Functions Help

Electric Meter Test Results - Screen Four

Equip Type	MTRE	Date	2026/09/0117
Equip ID	2561954	Op Code	TEST
Creep Test Performed	☒	Replaced Base	☐
Dial Check Performed	☒	Replaced Cover	☐
Phase Test Performed	☐	Replaced Register	☐
Short Test Performed	☐	Replaced Idle Pointe	☐
Hand Test Performed	☐	Replaced Battery	☐
Replace Up Bearing	☐	Replaced Thermal elm	☐
Replace Lower Bearin	☐	As Left kWh	24901.00
Replaced Disk	☐		

Delete

OKCancel