

2026 Load Forecast Report (NSEB M12861)
NSPI Responses to Synapse Energy Economics Inc. Information Requests

PARTIALLY CONFIDENTIAL (Attachment Only)

Request IR-1:

Report Tables and Graphs

(a) Please provide in electronic spreadsheet format all tables and graphs with identification of the data source(s) that appear in the load forecast report and appendices, retaining all formulas and calculations. To the extent that any tables and graphs have already been provided in electronic spreadsheet format in one of the report attachments, please provide references to the associated attachment.

Response IR-1:

(a) Please find data locations for all figures and tables included in the 2026 Load Forecast Report and appendices in the table below:

Figure	Location
Figure 1-3, 40, 47, 51, 55-58, 65-68	2026 LFR Attachment 4, tab Graphs
Figure 5-7, 15-21, 25, 32-33, 38-39, 42, 45-46, 50, 54, 59-64, 71-74, 77, A2, C1-C6, D5-D7, D8	Synapse IR-1 Confidential Attachment 1
Figure 8-14	CA IR-5, Attachment 1
Figure 22	2026 LFR Attachment 1, tab HP, Shares, Intensities
Figure 23-24	Synapse IR-8 Attachment 1
Figure 26	Synapse IR-9 Attachment 1
Figure 27	2026 LFR Attachment 1, tab Shares, Intensities
Figure 28-30	NSEB IR-6 Attachment 1
Figure 31	2026 LFR Attachment 4, tab Solar
Figure 34	2026 LFR Attachment 1, tab Intensities
Figure 35	2026 LFR Attachment 2, tab Intensity
Figure 36	2026 LFR Attachment 3, tab Intensity
Figure 37	2026 LFR Attachment 4, tab CommGrowth
Figure 41	2026 LFR Attachment 4, tab Tables
Figure 43	2026 LFR Attachment 4, tab Residential
Figure 44	2026 LFR Attachment 1, tab StructuralVars
Figure 48	2026 LFR Attachment 4, tab Small General
Figure 49	2026 LFR Attachment 4, tab General Demand
Figure 52	2026 LFR Attachment 4, tab Small Industrial

2026 Load Forecast Report (NSEB M12861)
NSPI Responses to Synapse Energy Economics Inc. Information Requests

PARTIALLY CONFIDENTIAL (Attachment Only)

Figure	Location
Figure 53	2026 LFR Attachment 4, tab Medium Industrial
Figure 69	2026 LFR Attachment 4, tab DR
Figure 70	Synapse IR-13 Attachment 1
Figure 75-76	Synapse IR-19 Attachment 1
A1	2026 LFR Attachment 4, tab Sector Summary
Regression breakdowns in Appendix B	Synapse IR-1 Attachments 2-4

1

Month	Average of large customer co-incident peak load, 2015-2024 (MW)
Jan	175
Feb	172
Mar	170
Apr	160
May	153
Jun	161
Jul	175
Aug	183
Sep	180
Oct	165
Nov	173
Dec	154

Peak date	Peak less Actual large customer load (MW)	Peak less estimated large customer load (MW)
6-Jan-15 18:00	1,792	1,775
16-Dec-16 18:00	1,911	1,946
28-Dec-17 18:00	1,857	1,852
7-Jan-18 18:00	1,896	1,887
27-Feb-19 8:00	1,844	1,876
17-Jan-20 18:00	1,850	1,862
2-Mar-21 19:00	1,784	1,785
11-Jan-22 18:00	1,968	1,971
4-Feb-23 12:00	2,302	2,274
21-Feb-24 8:00	1,908	1,901

Year	Month	HDD18	CDD18
2006	1	552.2	0.0
2006	2	594.2	0.0
2006	3	520.5	0.0
2006	4	369.5	0.0
2006	5	228.3	0.0
2006	6	95.1	2.1
2006	7	5.8	41.0
2006	8	22.7	29.5
2006	9	65.0	5.5
2006	10	231.1	0.0
2006	11	323.2	0.0
2006	12	513.6	0.0
2007	1	643.3	0.0
2007	2	661.6	0.0
2007	3	566.3	0.0
2007	4	433.4	0.0
2007	5	276.4	1.4
2007	6	122.5	4.9
2007	7	34.9	41.1
2007	8	54.0	21.3
2007	9	91.1	3.5
2007	10	217.7	0.0
2007	11	416.4	0.0
2007	12	659.1	0.0
2008	1	632.1	0.0
2008	2	597.6	0.0
2008	3	604.5	0.0
2008	4	390.1	0.0
2008	5	298.2	0.0
2008	6	143.8	6.6
2008	7	18.7	23.7
2008	8	27.7	8.8
2008	9	110.8	0.0
2008	10	260.8	0.0
2008	11	396.0	0.0
2008	12	557.4	0.0
2009	1	737.6	0.0
2009	2	588.1	0.0
2009	3	577.9	0.0
2009	4	390.2	0.0
2009	5	280.3	2.9
2009	6	146.5	0.0
2009	7	77.7	6.3
2009	8	32.9	37.0

Year	Month	HDD18	CDD18
2009	9	118.5	0.3
2009	10	315.8	0.0
2009	11	353.5	0.0
2009	12	572.6	0.0
2010	1	634.7	0.0
2010	2	558.1	0.0
2010	3	484.3	0.0
2010	4	331.5	0.0
2010	5	217.9	2.6
2010	6	105.9	6.0
2010	7	5.6	44.5
2010	8	3.5	43.5
2010	9	66.5	30.4
2010	10	232.1	2.2
2010	11	380.7	0.0
2010	12	488.1	0.0
2011	1	632.2	0.0
2011	2	590.3	0.0
2011	3	552.5	0.0
2011	4	384.6	0.0
2011	5	271.4	0.0
2011	6	148.3	1.5
2011	7	26.7	23.3
2011	8	14.1	28.4
2011	9	59.7	12.1
2011	10	198.2	3.5
2011	11	339.4	0.0
2011	12	482.2	0.0
2012	1	601.9	0.0
2012	2	571.4	0.0
2012	3	471.6	2.1
2012	4	363.7	0.0
2012	5	217.6	0.0
2012	6	129.9	4.1
2012	7	4.7	47.0
2012	8	1.0	62.9
2012	9	58.1	3.8
2012	10	198.2	0.0
2012	11	386.4	0.0
2012	12	515.1	0.0
2013	1	686.5	0.0
2013	2	578.2	0.0
2013	3	530.4	0.0
2013	4	402.0	0.0


Year	Month	HDD18	CDD18
2013	5	263.8	3.2
2013	6	92.0	5.0
2013	7	6.3	75.7
2013	8	14.2	16.4
2013	9	88.3	4.5
2013	10	228.0	0.0
2013	11	414.4	0.0
2013	12	615.8	0.0
2014	1	651.3	0.0
2014	2	591.0	0.0
2014	3	624.5	0.0
2014	4	408.6	0.0
2014	5	298.8	0.0
2014	6	110.5	6.0
2014	7	15.0	18.6
2014	8	9.3	27.5
2014	9	82.6	14.1
2014	10	171.7	0.8
2014	11	379.8	0.0
2014	12	498.4	0.0
2015	1	686.7	0.0
2015	2	716.0	0.0
2015	3	640.0	0.0
2015	4	458.9	0.0
2015	5	233.3	0.0
2015	6	148.4	2.6
2015	7	18.2	16.0
2015	8	3.1	64.2
2015	9	39.5	28.3
2015	10	248.2	0.0
2015	11	360.8	0.0
2015	12	462.2	0.0
2016	1	620.5	0.0
2016	2	536.4	0.0
2016	3	549.2	0.0
2016	4	413.3	0.0
2016	5	250.3	0.4
2016	6	129.9	1.7
2016	7	22.7	40.1
2016	8	0.7	49.8
2016	9	71.2	21.6
2016	10	211.5	0.0
2016	11	364.0	0.0
2016	12	612.1	0.0

Year	Month	HDD18	CDD18
2017	1	616.0	0.0
2017	2	564.2	0.0
2017	3	622.0	0.0
2017	4	381.8	0.0
2017	5	270.4	0.1
2017	6	107.6	5.5
2017	7	29.9	23.4
2017	8	14.5	33.6
2017	9	45.8	12.2
2017	10	149.3	2.2
2017	11	372.1	0.0
2017	12	581.4	0.0
2018	1	639.6	0.0
2018	2	497.9	0.0
2018	3	523.1	0.0
2018	4	411.0	0.0
2018	5	232.9	0.0
2018	6	143.8	3.8
2018	7	15.0	53.2
2018	8	0.1	78.7
2018	9	61.2	21.1
2018	10	262.2	0.0
2018	11	429.3	0.0
2018	12	626.0	0.0
2019	1	650.0	0.0
2019	2	631.6	0.0
2019	3	574.4	0.0
2019	4	399.3	0.0
2019	5	323.4	0.0
2019	6	129.9	1.1
2019	7	10.2	59.3
2019	8	7.6	53.3
2019	9	87.2	5.6
2019	10	238.3	0.0
2019	11	402.7	0.0
2019	12	562.9	0.0
2020	1	631.1	0.0
2020	2	570.5	0.0
2020	3	534.2	0.0
2020	4	417.5	0.0
2020	5	273.4	0.0
2020	6	117.4	12.1
2020	7	29.1	47.7
2020	8	10.0	52.4


Year	Month	HDD18	CDD18
2020	9	79.5	8.1
2020	10	229.4	0.0
2020	11	333.8	0.0
2020	12	455.7	0.0
2021	1	590.2	0
2021	2	547.8	0
2021	3	535.0	0
2021	4	341.4	0
2021	5	263.7	0
2021	6	67.2	15.39
2021	7	26.0	21.77
2021	8	6.2	58.13
2021	9	39.9	9.9
2021	10	182.8	0
2021	11	356.0	0
2021	12	527.3	0
2022	1	649.7	0.0
2022	2	559.0	0.0
2022	3	516.7	0.0
2022	4	369.5	0.0
2022	5	240.5	2.4
2022	6	96.6	0.5
2022	7	9.8	37.2
2022	8	0.0	69.7
2022	9	58.2	15.7
2022	10	165.1	0.0
2022	11	333.3	0.0
2022	12	487.6	0.0
2023	1	509.6	0.0
2023	2	590.4	0.0
2023	3	535.4	0.0
2023	4	366.2	0.0
2023	5	261.4	1.6
2023	6	121.3	10.3
2023	7	4.9	80.5
2023	8	2.1	34.1
2023	9	54.6	27.9
2023	10	169.1	0.0
2023	11	420.3	0.0
2023	12	494.7	0.0
2024	1	625.0	0.0
2024	2	563.5	0.0
2024	3	481.1	0.0
2024	4	385.1	0.0

Year	Month	HDD18	CDD18
2024	5	237.4	0.0
2024	6	80.8	15.3
2024	7	10.7	47.2
2024	8	10.8	39.8
2024	9	54.4	11.5
2024	10	214.4	0.0
2024	11	344.1	0.0
2024	12	553.7	0.0
2025	1	654.1	0.0
2025	2	617.4	0.0
2025	3	505.3	0.0
2025	4	383.5	0.0
2025	5	224.8	2.3
2025	6	88.3	15.8
2025	7	5.3	39.6
2025	8	8.9	33.6
2025	9	43.4	10.1
2025	10	180.7	1.6
2025	11	383.7	0.0
2025	12	602.8	0.0


	Normal HDD	Normal CDD
Jan	618.6	0.0
Feb	563.2	0.0
Mar	537.6	0.0
Apr	386.9	0.0
May	257.8	0.7
Jun	108.3	8.2
Jul	16.4	45.0
Aug	6.1	50.3
Sep	59.5	14.4
Oct	200.3	0.4
Nov	373.9	0.0
Dec	550.4	0.0



Year	Cust Count	Change in Res Customers	Population	Change in Population	Housing Completions	Starts	Household Size
2015	456655		937.29		3,333	3,825.0	2.20
2016	459875	3220	942.26	4,974.00	3,468	3,767.0	2.19
2017	463739	3864	951.05	8,787.50	3,858	3,984.0	2.19
2018	468049	4310	961.06	10,010.75	4,214	4,786.0	2.19
2019	472369	4320	974.45	13,387.75	4,207	4,719.0	2.20
2020	477035	4666	987.16	12,715.25	4,470	4,865.0	2.20
2021	482771	5736	997.61	10,446.25	4,503	5,975.0	2.20
2022	488654	5883	1019.97	22,361.25	4,966	5,714.0	2.21
2023	495055	6401	1049.11	29,133.75	6,075	7,159.0	2.24
2024	502855	7800	1078.24	29,129.75	7,862	7,381.0	2.26
2025	509966	7111	1091.33	13,096.50	6,607	9,760.0	2.26
2026	518257	8291	1089.61	(1,719.88)	8,291	8,180.5	2.21
2027	525720	7462	1084.75	(4,863.98)	7,462	7,362.5	2.16
2028	532436	6716	1082.82	(1,930.34)	6,716	6,626.2	2.13
2029	538480	6044	1084.52	1,701.56	6,044	5,963.6	2.10
2030	543920	5440	1086.93	2,407.39	5,440	5,367.3	2.08
2031	548816	4896	1088.82	1,897.31	4,896	4,830.5	2.06
2032	553222	4406	1091.31	2,490.53	4,406	4,347.5	2.05
2033	557188	3966	1093.49	2,179.44	3,966	3,912.7	2.03
2034	560757	3569	1095.36	1,868.50	3,569	3,521.5	2.02
2035	563969	3212	1096.94	1,573.24	3,212	3,169.3	2.01
2036	566861	2891	1098.23	1,292.33	2,891	2,852.4	2.00



Year	Month	HHSize	Household Size
2000	1	2.55	2.54
2000	2	2.55	2.52
2000	3	2.55	2.48
2000	4	2.55	2.46
2000	5	2.55	2.44
2000	6	2.55	2.41
2000	7	2.55	2.37
2000	8	2.54	2.34
2000	9	2.54	2.32
2000	10	2.53	2.31
2000	11	2.53	2.30
2000	12	2.53	2.28
2001	1	2.53	2.26
2001	2	2.53	2.23
2001	3	2.53	2.22
2001	4	2.53	2.20
2001	5	2.53	2.19
2001	6	2.53	2.19
2001	7	2.53	2.19
2001	8	2.52	2.20
2001	9	2.52	2.20
2001	10	2.52	2.20
2001	11	2.51	2.21
2001	12	2.51	2.24
2002	1	2.49	2.26
2002	2	2.49	2.26
2002	3	2.49	2.21
2002	4	2.49	2.16
2002	5	2.49	2.13
2002	6	2.48	2.10
2002	7	2.48	2.08
2002	8	2.48	2.06
2002	9	2.47	2.05
2002	10	2.47	2.03
2002	11	2.47	2.02
2002	12	2.47	2.01
2003	1	2.47	2.00
2003	2	2.47	
2003	3	2.47	
2003	4	2.47	
2003	5	2.47	
2003	6	2.47	
2003	7	2.46	
2003	8	2.46	
2003	9	2.46	
2003	10	2.46	
2003	11	2.45	
2003	12	2.45	
2004	1	2.45	
2004	2	2.45	
2004	3	2.45	
2004	4	2.45	
2004	5	2.45	
2004	6	2.45	
2004	7	2.45	
2004	8	2.44	



REDACTED (CONFIDENTIAL INFORMATION REMOVED)

REDACTED 2026 Load Forecast Report Synapse IR-1 Attachment 1 Page 12 of 196

Year	Cust Count	Change in Res Customers	Population	Change in Population	Housing Completions	Starts	Household Size	Year	Month	HHSize	Household Size
								2004	9	2.44	
								2004	10	2.43	
								2004	11	2.43	
								2004	12	2.43	
								2005	1	2.42	
								2005	2	2.42	
								2005	3	2.42	
								2005	4	2.42	
								2005	5	2.42	
								2005	6	2.42	
								2005	7	2.42	
								2005	8	2.41	
								2005	9	2.39	
								2005	10	2.39	
								2005	11	2.39	
								2005	12	2.38	
								2006	1	2.38	
								2006	2	2.38	
								2006	3	2.38	
								2006	4	2.38	
								2006	5	2.38	
								2006	6	2.38	
								2006	7	2.38	
								2006	8	2.37	
								2006	9	2.37	
								2006	10	2.36	
								2006	11	2.36	
								2006	12	2.36	
								2007	1	2.35	
								2007	2	2.35	
								2007	3	2.35	
								2007	4	2.35	
								2007	5	2.35	
								2007	6	2.35	
								2007	7	2.35	
								2007	8	2.34	
								2007	9	2.34	
								2007	10	2.34	
								2007	11	2.33	
								2007	12	2.33	
								2008	1	2.33	
								2008	2	2.33	
								2008	3	2.33	
								2008	4	2.33	
								2008	5	2.33	
								2008	6	2.33	
								2008	7	2.33	
								2008	8	2.32	
								2008	9	2.32	
								2008	10	2.32	
								2008	11	2.31	
								2008	12	2.31	
								2009	1	2.31	
								2009	2	2.31	
								2009	3	2.31	
								2009	4	2.31	

REDACTED (CONFIDENTIAL INFORMATION REMOVED)

REDACTED 2026 Load Forecast Report Synapse IR-1 Attachment 1 Page 13 of 196

Year	Cust Count	Change in Res Customers	Population	Change in Population	Housing Completions	Starts	Household Size	Year	Month	HHSize	Household Size
								2009	5	2.31	
								2009	6	2.31	
								2009	7	2.31	
								2009	8	2.31	
								2009	9	2.31	
								2009	10	2.30	
								2009	11	2.30	
								2009	12	2.30	
								2010	1	2.30	
								2010	2	2.30	
								2010	3	2.30	
								2010	4	2.30	
								2010	5	2.30	
								2010	6	2.30	
								2010	7	2.30	
								2010	8	2.30	
								2010	9	2.29	
								2010	10	2.29	
								2010	11	2.29	
								2010	12	2.29	
								2011	1	2.29	
								2011	2	2.28	
								2011	3	2.28	
								2011	4	2.28	
								2011	5	2.28	
								2011	6	2.28	
								2011	7	2.28	
								2011	8	2.28	
								2011	9	2.28	
								2011	10	2.28	
								2011	11	2.27	
								2011	12	2.27	
								2012	1	2.27	
								2012	2	2.27	
								2012	3	2.26	
								2012	4	2.27	
								2012	5	2.26	
								2012	6	2.26	
								2012	7	2.26	
								2012	8	2.26	
								2012	9	2.26	
								2012	10	2.25	
								2012	11	2.25	
								2012	12	2.24	
								2013	1	2.24	
								2013	2	2.24	
								2013	3	2.24	
								2013	4	2.24	
								2013	5	2.24	
								2013	6	2.24	
								2013	7	2.24	
								2013	8	2.23	
								2013	9	2.23	
								2013	10	2.23	
								2013	11	2.22	
								2013	12	2.22	

REDACTED (CONFIDENTIAL INFORMATION REMOVED)

REDACTED 2026 Load Forecast Report Synapse IR-1 Attachment 1 Page 14 of 196

Year	Cust Count	Change in Res Customers	Population	Change in Population	Housing Completions	Starts	Household Size	Year	Month	HHSize	Household Size
								2014	1	2.22	
								2014	2	2.22	
								2014	3	2.22	
								2014	4	2.22	
								2014	5	2.22	
								2014	6	2.22	
								2014	7	2.22	
								2014	8	2.21	
								2014	9	2.21	
								2014	10	2.21	
								2014	11	2.21	
								2014	12	2.20	
								2015	1	2.20	
								2015	2	2.20	
								2015	3	2.20	
								2015	4	2.20	
								2015	5	2.20	
								2015	6	2.20	
								2015	7	2.20	
								2015	8	2.20	
								2015	9	2.20	
								2015	10	2.20	
								2015	11	2.19	
								2015	12	2.19	
								2016	1	2.19	
								2016	2	2.19	
								2016	3	2.19	
								2016	4	2.19	
								2016	5	2.19	
								2016	6	2.19	
								2016	7	2.19	
								2016	8	2.19	
								2016	9	2.19	
								2016	10	2.19	
								2016	11	2.19	
								2016	12	2.19	
								2017	1	2.19	
								2017	2	2.19	
								2017	3	2.19	
								2017	4	2.19	
								2017	5	2.19	
								2017	6	2.19	
								2017	7	2.19	
								2017	8	2.19	
								2017	9	2.19	
								2017	10	2.19	
								2017	11	2.19	
								2017	12	2.19	
								2018	1	2.19	
								2018	2	2.19	
								2018	3	2.19	
								2018	4	2.19	
								2018	5	2.19	
								2018	6	2.19	
								2018	7	2.19	
								2018	8	2.19	

REDACTED (CONFIDENTIAL INFORMATION REMOVED)

REDACTED 2026 Load Forecast Report Synapse IR-1 Attachment 1 Page 15 of 196

Year	Cust Count	Change in Res Customers	Population	Change in Population	Housing Completions	Starts	Household Size	Year	Month	HHSize	Household Size
								2018	9	2.19	
								2018	10	2.19	
								2018	11	2.19	
								2018	12	2.19	
								2019	1	2.19	
								2019	2	2.19	
								2019	3	2.19	
								2019	4	2.20	
								2019	5	2.20	
								2019	6	2.20	
								2019	7	2.20	
								2019	8	2.20	
								2019	9	2.20	
								2019	10	2.20	
								2019	11	2.20	
								2019	12	2.20	
								2020	1	2.20	
								2020	2	2.20	
								2020	3	2.20	
								2020	4	2.20	
								2020	5	2.20	
								2020	6	2.20	
								2020	7	2.20	
								2020	8	2.20	
								2020	9	2.20	
								2020	10	2.20	
								2020	11	2.20	
								2020	12	2.20	
								2021	1	2.20	
								2021	2	2.20	
								2021	3	2.20	
								2021	4	2.20	
								2021	5	2.20	
								2021	6	2.20	
								2021	7	2.20	
								2021	8	2.20	
								2021	9	2.20	
								2021	10	2.20	
								2021	11	2.20	
								2021	12	2.20	
								2022	1	2.20	
								2022	2	2.20	
								2022	3	2.21	
								2022	4	2.21	
								2022	5	2.21	
								2022	6	2.21	
								2022	7	2.21	
								2022	8	2.21	
								2022	9	2.21	
								2022	10	2.22	
								2022	11	2.22	
								2022	12	2.23	
								2023	1	2.22	
								2023	2	2.22	
								2023	3	2.23	
								2023	4	2.23	

REDACTED (CONFIDENTIAL INFORMATION REMOVED)

REDACTED 2026 Load Forecast Report Synapse IR-1 Attachment 1 Page 16 of 196

Year	Cust Count	Change in Res Customers	Population	Change in Population	Housing Completions	Starts	Household Size	Year	Month	HHSize	Household Size
								2023	5	2.24	
								2023	6	2.24	
								2023	7	2.24	
								2023	8	2.25	
								2023	9	2.24	
								2023	10	2.25	
								2023	11	2.25	
								2023	12	2.25	
								2024	1	2.25	
								2024	2	2.26	
								2024	3	2.26	
								2024	4	2.26	
								2024	5	2.26	
								2024	6	2.26	
								2024	7	2.26	
								2024	8	2.26	
								2024	9	2.26	
								2024	10	2.26	
								2024	11	2.26	
								2024	12	2.26	
								2025	1	2.26	
								2025	2	2.26	
								2025	3	2.26	
								2025	4	2.26	
								2025	5	2.26	
								2025	6	2.26	
								2025	7	2.26	
								2025	8	2.26	
								2025	9	2.25	
								2025	10	2.25	
								2025	11	2.24	
								2025	12	2.24	
								2026	1	2.23	
								2026	2	2.23	
								2026	3	2.22	
								2026	4	2.22	
								2026	5	2.21	
								2026	6	2.21	
								2026	7	2.21	
								2026	8	2.21	
								2026	9	2.20	
								2026	10	2.20	
								2026	11	2.20	
								2026	12	2.19	
								2027	1	2.18	
								2027	2	2.18	
								2027	3	2.18	
								2027	4	2.17	
								2027	5	2.17	
								2027	6	2.16	
								2027	7	2.16	
								2027	8	2.16	
								2027	9	2.15	
								2027	10	2.15	
								2027	11	2.15	
								2027	12	2.15	

REDACTED (CONFIDENTIAL INFORMATION REMOVED)

REDACTED 2026 Load Forecast Report Synapse IR-1 Attachment 1 Page 17 of 196


Year	Cust Count	Change in Res Customers	Population	Change in Population	Housing Completions	Starts	Household Size	Year	Month	HHSize	Household Size
								2028	1	2.14	
								2028	2	2.14	
								2028	3	2.14	
								2028	4	2.13	
								2028	5	2.13	
								2028	6	2.13	
								2028	7	2.12	
								2028	8	2.12	
								2028	9	2.12	
								2028	10	2.12	
								2028	11	2.12	
								2028	12	2.11	
								2029	1	2.11	
								2029	2	2.11	
								2029	3	2.11	
								2029	4	2.11	
								2029	5	2.10	
								2029	6	2.10	
								2029	7	2.10	
								2029	8	2.10	
								2029	9	2.10	
								2029	10	2.09	
								2029	11	2.09	
								2029	12	2.09	
								2030	1	2.09	
								2030	2	2.09	
								2030	3	2.09	
								2030	4	2.08	
								2030	5	2.08	
								2030	6	2.08	
								2030	7	2.08	
								2030	8	2.08	
								2030	9	2.08	
								2030	10	2.07	
								2030	11	2.07	
								2030	12	2.07	
								2031	1	2.07	
								2031	2	2.07	
								2031	3	2.07	
								2031	4	2.06	
								2031	5	2.06	
								2031	6	2.06	
								2031	7	2.06	
								2031	8	2.06	
								2031	9	2.06	
								2031	10	2.06	
								2031	11	2.05	
								2031	12	2.05	
								2032	1	2.05	
								2032	2	2.05	
								2032	3	2.05	
								2032	4	2.05	
								2032	5	2.05	
								2032	6	2.05	
								2032	7	2.04	
								2032	8	2.04	

REDACTED (CONFIDENTIAL INFORMATION REMOVED)

REDACTED 2026 Load Forecast Report Synapse IR-1 Attachment 1 Page 18 of 196

Year	Cust Count	Change in Res Customers	Population	Change in Population	Housing Completions	Starts	Household Size	Year	Month	HHSize	Household Size
								2032	9	2.04	
								2032	10	2.04	
								2032	11	2.04	
								2032	12	2.04	
								2033	1	2.04	
								2033	2	2.04	
								2033	3	2.04	
								2033	4	2.03	
								2033	5	2.03	
								2033	6	2.03	
								2033	7	2.03	
								2033	8	2.03	
								2033	9	2.03	
								2033	10	2.03	
								2033	11	2.03	
								2033	12	2.03	
								2034	1	2.03	
								2034	2	2.02	
								2034	3	2.02	
								2034	4	2.02	
								2034	5	2.02	
								2034	6	2.02	
								2034	7	2.02	
								2034	8	2.02	
								2034	9	2.02	
								2034	10	2.02	
								2034	11	2.02	
								2034	12	2.02	
								2035	1	2.01	
								2035	2	2.01	
								2035	3	2.01	
								2035	4	2.01	
								2035	5	2.01	
								2035	6	2.01	
								2035	7	2.01	
								2035	8	2.01	
								2035	9	2.01	
								2035	10	2.01	
								2035	11	2.01	
								2035	12	2.00	
								2036	1	2.00	
								2036	2	2.00	
								2036	3	2.00	
								2036	4	2.00	
								2036	5	2.00	
								2036	6	2.00	
								2036	7	2.00	
								2036	8	2.00	
								2036	9	2.00	
								2036	10	2.00	
								2036	11	2.00	
								2036	12	2.00	

Signal49 Fcst (20yr)														
Fcst Year	2020	2021	2022	2023	2024	2025 CBoC	2026 Signal49	2025	2024 Completion F	Actual Additions		Adjusted Completions Forecast		
2019	4.2	4.2	4.2	4.2	4.2	4207.6	4207.3			4182.5	3605	-14%		
2020	4.3	4.4	4.3	4.4	4.4	4470.1	4470.1			4,365	5,334	19%		
2021	3.7	4.8	4.6	4.6	4.6	4509.2	4503.0	5.54	4,614	6,579	46%			
2022	3.4	3.9	4.3	4.6	5.2	4949.4	4966.3	6.20	5,167	4,993	1%			
2023	3.1	3.5	3.9	6.1	6.2	6056.6	6074.9	7.45	6,206	7,354	21%			
2024	2.8	3.2	3.6	6.0	6.8	7399.3	7861.5	8.19	6,826	8,188	11%			
2025	2.6	2.9	3.2	5.8	6.5	6438.4	6606.8	7.82		6,811	6%			
2026	2.5	2.5	2.9	5.5	6.2	6085.0	8291.4	7.49			17%	8291.4		
2027	2.4	2.4	2.3	5.1	6.0	5722.5	6791.2	7.18				7462.2	-18%	-10%
2028	2.2	2.2	2.1	4.8	5.7	5382.2	5417.6	6.86				6716.0	-20%	-10%
2029	2.1	2.1	2.0	4.4	5.5	5044.9	4051.5	6.58				6044.4	-25%	-10%
2030	1.9	1.9	1.8	4.1	5.0	4760.6	2835.8	6.05				5440.0	-30%	-10%
2031						4431.6	2248.7					4896.0	-21%	-10%
2032						4089.1	1527.1					4406.4	-32%	-10%
2033						3753.0	1000.6					3965.7	-34%	-10%
2034						3430.9	721.4					3569.2	-28%	-10%
2035						3149.6	589.7					3212.2	-18%	-10%
2036						2909.2	536.9					2891.0	-9%	-10%



REDACTED (CONFIDENTIAL INFORMATION REMOVED)



REDACTED 2026 Load Forecast Report Synapse IR-1 Attachment 1 Page 20 of 196

	CPI	HouseholdIncome	Household Income (mil \$2002)	% change	SFCompletions	MUCompletions	HousingCompletions	% change	GDP	ManGDP		NManGDP	% change	Emp	ManEmp		NManEmp	% change
2016	1.31	22,405	17,118		1.45	2.02	3,468		38,542	2,762		35,780		441.9	44.5		397.4	
2017	1.32	23,189	17,517	2.3%	1.63	2.23	3,858	11.2%	39,329	2,794	1.2%	36,535	2.1%	445.1	45.4	1.9%	399.7	0.6%
2018	1.35	24,407	18,036	3.0%	1.90	2.31	4,214	9.2%	40,022	2,894	3.6%	37,128	1.6%	451.6	46.3	2.0%	405.3	1.4%
2019	1.37	24,830	18,061	0.1%	1.86	2.35	4,207	-0.2%	41,404	3,090	6.8%	38,314	3.2%	463.9	48.1	3.9%	415.8	2.6%
2020	1.38	24,929	18,077	0.1%	1.96	2.51	4,470	6.2%	39,525	2,920	-5.5%	36,605	-4.5%	447.1	48.5	0.9%	398.6	-4.1%
2021	1.44	27,145	18,915	4.6%	1.94	2.56	4,503	0.7%	42,101	3,252	11.4%	38,849	6.1%	475.7	50.5	4.1%	425.1	6.7%
2022	1.54	29,623	19,198	1.5%	1.93	3.03	4,966	10.3%	43,555	3,162	-2.8%	40,393	4.0%	492.3	50.6	0.2%	441.7	3.9%
2023	1.61	32,546	20,276	5.6%	2.38	3.70	6,075	22.3%	44,453	3,137	-0.8%	41,316	2.3%	505.6	50.3	-0.7%	455.3	3.1%
2024	1.64	34,862	21,226	4.7%	2.46	5.40	7,862	29.4%	45,645	3,331	6.2%	42,314	2.4%	521.3	50.5	0.4%	470.8	3.4%
2025	1.68	36,123	21,552	1.5%	1.93	4.67	6,607	-16.0%	46,351	3,359	0.9%	42,991	1.6%	523.9	50.4	-0.1%	473.4	0.6%
2026	1.71	37,076	21,671	0.6%	2.55	5.74	8,291	25.5%	46,941	3,399	1.2%	43,542	1.3%	527.1	50.5	0.2%	476.6	0.7%
2027	1.75	38,063	21,808	0.6%	2.29	5.17	7,462	-10.0%	47,792	3,466	2.0%	44,326	1.8%	528.2	50.1	-0.9%	478.2	0.3%
2028	1.78	39,007	21,904	0.4%	2.06	4.65	6,716	-10.0%	48,633	3,537	2.0%	45,096	1.7%	528.5	49.4	-1.3%	479.1	0.2%
2029	1.82	40,114	22,079	0.8%	1.86	4.19	6,044	-10.0%	49,504	3,611	2.1%	45,893	1.8%	529.5	48.8	-1.2%	480.7	0.3%
2030	1.85	41,318	22,293	1.0%	1.67	3.77	5,440	-10.0%	50,358	3,683	2.0%	46,674	1.7%	531.7	48.4	-1.0%	483.3	0.5%
2031	1.89	42,304	22,414	0.5%	1.50	3.39	4,896	-10.0%	51,182	3,781	2.7%	47,401	1.6%	532.3	48.1	-0.5%	484.2	0.2%
2032	1.93	43,280	22,475	0.3%	1.35	3.05	4,406	-10.0%	51,946	3,896	3.0%	48,050	1.4%	533.2	48.1	-0.1%	485.1	0.2%
2033	1.96	44,302	22,552	0.3%	1.22	2.75	3,966	-10.0%	52,688	4,006	2.8%	48,682	1.3%	534.3	48.1	0.0%	486.2	0.2%
2034	2.00	45,386	22,647	0.4%	1.10	2.47	3,569	-10.0%	53,420	4,113	2.7%	49,307	1.3%	535.7	48.1	0.0%	487.7	0.3%
2035	2.04	46,488	22,739	0.4%	0.99	2.22	3,212	-10.0%	54,133	4,219	2.6%	49,914	1.2%	536.9	48.0	-0.1%	488.9	0.3%
2036	2.09	47,628	22,836	0.4%	0.89	2.00	2,891	-10.0%	54,824	4,326	2.5%	50,498	1.2%	538.0	47.9	-0.2%	490.1	0.3%

	GDP		Emp		Housing	
	2026	2027	2026	2027	2026	2027
Signal49	1.3%	1.8%	0.6%	0.2%	8181	6771
BMO	1.4%	1.8%	0.5%	0.6%	8500	8000
RBC	1.5%	1.6%	0.4%	0.4%	7800	6000
TD	1.6%	1.2%	0.3%	0.4%	6900	6600
Scotiabank	1.5%	1.9%	0.3%	0.6%	8400	8000

Year	Peak Reduction (MW)			Energy Reduction (GWh)		
	Total	Included in peak model	Adjustment required to match total	Total	Included in residential end use model	Adjustment required to match total
2028	-6	-2	-5	-10	-4	-7
2029	-13	-4	-9	-21	-9	-12
2030	-19	-7	-12	-31	-16	-15
2031	-26	-11	-14	-41	-24	-17
2032	-32	-16	-16	-51	-34	-17
2033	-36	-20	-16	-60	-43	-17
2034	-40	-24	-16	-68	-51	-17
2035	-44	-28	-16	-76	-59	-17
2036	-48	-32	-16	-83	-67	-16

Winter	0	2.186373	1.277909
Winter	1	2.124798	1.229468
Winter	2	2.117177	1.213654
Winter	3	2.13476	1.213541
Winter	4	2.188288	1.232286
Winter	5	2.32981	1.295537
Winter	6	2.597101	1.423216
Winter	7	2.762431	1.562786
Winter	8	2.333574	1.602994
Winter	9	1.574048	1.588883
Winter	10	0.836076	1.563994
Winter	11	0.373818	1.543224
Winter	12	0.160042	1.517728
Winter	13	0.204278	1.470706
Winter	14	0.574464	1.447444
Winter	15	1.286647	1.488657
Winter	16	2.129146	1.631858
Winter	17	2.723232	1.770846
Winter	18	2.884854	1.773592
Winter	19	2.901814	1.745808
Winter	20	2.844116	1.700083
Winter	21	2.725202	1.619016
Winter	22	2.518121	1.497773
Winter	23	2.319551	1.371267
Non-Winter	0	1.210424	0.713177
Non-Winter	1	1.120562	0.657668
Non-Winter	2	1.07951	0.631132
Non-Winter	3	1.063341	0.619799
Non-Winter	4	1.073001	0.624297
Non-Winter	5	1.143094	0.667705
Non-Winter	6	1.231065	0.773263
Non-Winter	7	0.986878	0.886507
Non-Winter	8	0.12344	0.923421
Non-Winter	9	-1.08485	0.935044
Non-Winter	10	-2.20413	0.941047
Non-Winter	11	-2.94985	0.949684
Non-Winter	12	-3.2633	0.952205
Non-Winter	13	-3.34327	0.926769
Non-Winter	14	-3.11522	0.910455
Non-Winter	15	-2.49204	0.932937
Non-Winter	16	-1.41696	1.020649
Non-Winter	17	-0.13259	1.105616
Non-Winter	18	0.90867	1.108119
Non-Winter	19	1.529243	1.099591
Non-Winter	20	1.786711	1.089609
Non-Winter	21	1.762036	1.043996
Non-Winter	22	1.576664	0.9347
Non-Winter	23	1.361716	0.806482



Year	Residential	Small General	General Demand
2026	3.1	3.0	-0.5
2027	3.9	3.8	1.0

Year	Month	Res	SmlGen	Gen
2016	1	0.1244	0.1211	0.1017
2016	2	0.1244	0.1208	0.1018
2016	3	0.1243	0.1205	0.1017
2016	4	0.1242	0.1203	0.1017
2016	5	0.1241	0.1201	0.1016
2016	6	0.1240	0.1198	0.1014
2016	7	0.1238	0.1194	0.1010
2016	8	0.1236	0.1191	0.1009
2016	9	0.1234	0.1188	0.1008
2016	10	0.1232	0.1184	0.1005
2016	11	0.1230	0.1180	0.1003
2016	12	0.1228	0.1176	0.1002
2017	1	0.1228	0.1174	0.1002
2017	2	0.1224	0.1169	0.0998
2017	3	0.1224	0.1169	0.0998
2017	4	0.1224	0.1169	0.0998
2017	5	0.1225	0.1170	0.1001
2017	6	0.1225	0.1170	0.1002
2017	7	0.1225	0.1169	0.1002
2017	8	0.1225	0.1170	0.1001
2017	9	0.1226	0.1170	0.1001
2017	10	0.1226	0.1171	0.1000
2017	11	0.1227	0.1172	0.1000
2017	12	0.1227	0.1173	0.0999
2018	1	0.1227	0.1174	0.0999
2018	2	0.1227	0.1174	0.0999
2018	3	0.1227	0.1173	0.0996
2018	4	0.1227	0.1173	0.0996
2018	5	0.1226	0.1173	0.0993
2018	6	0.1226	0.1173	0.0991
2018	7	0.1226	0.1174	0.0990
2018	8	0.1226	0.1174	0.0990
2018	9	0.1224	0.1173	0.0988
2018	10	0.1223	0.1172	0.0988
2018	11	0.1222	0.1171	0.0988
2018	12	0.1221	0.1169	0.0987
2019	1	0.1219	0.1168	0.0986
2019	2	0.1218	0.1167	0.0984
2019	3	0.1218	0.1167	0.0984
2019	4	0.1217	0.1165	0.0981
2019	5	0.1216	0.1165	0.0981
2019	6	0.1216	0.1165	0.0980

Year	Month	Res	SmlGen	Gen
2019	7	0.1215	0.1164	0.0979
2019	8	0.1215	0.1164	0.0978
2019	9	0.1215	0.1165	0.0978
2019	10	0.1215	0.1165	0.0978
2019	11	0.1216	0.1166	0.0980
2019	12	0.1217	0.1168	0.0979
2020	1	0.1218	0.1170	0.0980
2020	2	0.1219	0.1171	0.0979
2020	3	0.1220	0.1171	0.0980
2020	4	0.1221	0.1172	0.0983
2020	5	0.1222	0.1172	0.0982
2020	6	0.1223	0.1173	0.0987
2020	7	0.1225	0.1177	0.0993
2020	8	0.1225	0.1177	0.0995
2020	9	0.1224	0.1178	0.0996
2020	10	0.1225	0.1179	0.0998
2020	11	0.1224	0.1178	0.0997
2020	12	0.1224	0.1177	0.0998
2021	1	0.1224	0.1176	0.0998
2021	2	0.1223	0.1175	0.0999
2021	3	0.1223	0.1174	0.1000
2021	4	0.1221	0.1172	0.0999
2021	5	0.1220	0.1169	0.0999
2021	6	0.1218	0.1166	0.0995
2021	7	0.1215	0.1161	0.0990
2021	8	0.1213	0.1157	0.0988
2021	9	0.1210	0.1152	0.0986
2021	10	0.1206	0.1147	0.0983
2021	11	0.1202	0.1141	0.0980
2021	12	0.1198	0.1136	0.0977
2022	1	0.1194	0.1131	0.0973
2022	2	0.1189	0.1125	0.0970
2022	3	0.1184	0.1119	0.0966
2022	4	0.1179	0.1113	0.0962
2022	5	0.1174	0.1107	0.0959
2022	6	0.1169	0.1100	0.0954
2022	7	0.1163	0.1093	0.0949
2022	8	0.1157	0.1086	0.0944
2022	9	0.1151	0.1078	0.0940
2022	10	0.1146	0.1072	0.0934
2022	11	0.1141	0.1066	0.0933
2022	12	0.1136	0.1061	0.0930
2023	1	0.1132	0.1056	0.0927
2023	2	0.1128	0.1051	0.0925
2023	3	0.1126	0.1047	0.0922

REDACTED (CONFIDENTIAL INFORMATION REMOVED)


REDACTED 2026 Load Forecast Report Synapse IR-1 Attachment 1 Page 27 of 196


Year	Month	Res	SmlGen	Gen
2023	4	0.1124	0.1048	0.0923
2023	5	0.1125	0.1051	0.0924
2023	6	0.1126	0.1054	0.0928
2023	7	0.1129	0.1054	0.0931
2023	8	0.1132	0.1057	0.0934
2023	9	0.1135	0.1060	0.0936
2023	10	0.1140	0.1065	0.0940
2023	11	0.1144	0.1068	0.0941
2023	12	0.1147	0.1071	0.0943
2024	1	0.1149	0.1074	0.0945
2024	2	0.1152	0.1079	0.0949
2024	3	0.1156	0.1087	0.0955
2024	4	0.1162	0.1091	0.0960
2024	5	0.1165	0.1096	0.0965
2024	6	0.1170	0.1099	0.0965
2024	7	0.1174	0.1107	0.0970
2024	8	0.1180	0.1112	0.0975
2024	9	0.1184	0.1117	0.0979
2024	10	0.1189	0.1122	0.0985
2024	11	0.1194	0.1128	0.0989
2024	12	0.1199	0.1133	0.0993
2025	1	0.1204	0.1138	0.0998
2025	2	0.1206	0.1142	0.1000
2025	3	0.1208	0.1142	0.1001
2025	4	0.1209	0.1143	0.1003
2025	5	0.1211	0.1145	0.1005
2025	6	0.1213	0.1149	0.1007
2025	7	0.1215	0.1147	0.1009
2025	8	0.1217	0.1145	0.1011
2025	9	0.1219	0.1147	0.1014
2025	10	0.1220	0.1148	0.1016
2025	11	0.1222	0.1149	0.1019
2025	12	0.1224	0.1149	0.1021
2026	1	0.1226	0.1147	0.1023
2026	2	0.1227	0.1148	0.1021
2026	3	0.1228	0.1149	0.1019
2026	4	0.1229	0.1149	0.1017
2026	5	0.1230	0.1150	0.1015
2026	6	0.1231	0.1151	0.1012
2026	7	0.1232	0.1152	0.1010
2026	8	0.1233	0.1153	0.1008
2026	9	0.1234	0.1154	0.1006
2026	10	0.1235	0.1155	0.1004
2026	11	0.1237	0.1156	0.1002
2026	12	0.1238	0.1157	0.0999


Year	Month	Res	SmlGen	Gen
2027	1	0.1239	0.1157	0.0997
2027	2	0.1240	0.1159	0.0997
2027	3	0.1242	0.1161	0.0996
2027	4	0.1244	0.1162	0.0995
2027	5	0.1246	0.1164	0.0994
2027	6	0.1248	0.1166	0.0993
2027	7	0.1250	0.1167	0.0992
2027	8	0.1252	0.1169	0.0991
2027	9	0.1254	0.1171	0.0991
2027	10	0.1256	0.1173	0.0990
2027	11	0.1258	0.1174	0.0989
2027	12	0.1259	0.1176	0.0988
2028	1	0.1261	0.1178	0.0987
2028	2	0.1264	0.1180	0.0990
2028	3	0.1267	0.1183	0.0992
2028	4	0.1270	0.1186	0.0994
2028	5	0.1273	0.1189	0.0997
2028	6	0.1276	0.1192	0.0999
2028	7	0.1279	0.1195	0.1002
2028	8	0.1282	0.1197	0.1004
2028	9	0.1286	0.1200	0.1006
2028	10	0.1289	0.1203	0.1009
2028	11	0.1292	0.1206	0.1011
2028	12	0.1295	0.1209	0.1014
2029	1	0.1298	0.1212	0.1016
2029	2	0.1301	0.1215	0.1018
2029	3	0.1304	0.1218	0.1021
2029	4	0.1307	0.1220	0.1023
2029	5	0.1310	0.1223	0.1026
2029	6	0.1313	0.1226	0.1028
2029	7	0.1316	0.1229	0.1031
2029	8	0.1320	0.1232	0.1033
2029	9	0.1323	0.1235	0.1036
2029	10	0.1326	0.1238	0.1038
2029	11	0.1330	0.1241	0.1041
2029	12	0.1333	0.1244	0.1043
2030	1	0.1336	0.1247	0.1046
2030	2	0.1336	0.1247	0.1046
2030	3	0.1336	0.1247	0.1046
2030	4	0.1336	0.1247	0.1046
2030	5	0.1336	0.1247	0.1046
2030	6	0.1336	0.1247	0.1046
2030	7	0.1336	0.1247	0.1046
2030	8	0.1336	0.1247	0.1046
2030	9	0.1336	0.1247	0.1046

Year	Month	Res	SmlGen	Gen
2030	10	0.1336	0.1247	0.1046
2030	11	0.1336	0.1247	0.1046
2030	12	0.1336	0.1247	0.1046
2031	1	0.1336	0.1247	0.1046
2031	2	0.1336	0.1247	0.1045
2031	3	0.1336	0.1247	0.1045
2031	4	0.1336	0.1247	0.1045
2031	5	0.1336	0.1247	0.1045
2031	6	0.1336	0.1247	0.1045
2031	7	0.1336	0.1247	0.1045
2031	8	0.1336	0.1247	0.1045
2031	9	0.1336	0.1247	0.1045
2031	10	0.1336	0.1247	0.1045
2031	11	0.1336	0.1247	0.1045
2031	12	0.1336	0.1247	0.1045
2032	1	0.1335	0.1247	0.1045
2032	2	0.1335	0.1247	0.1045
2032	3	0.1335	0.1247	0.1045
2032	4	0.1335	0.1247	0.1045
2032	5	0.1335	0.1247	0.1045
2032	6	0.1335	0.1247	0.1045
2032	7	0.1335	0.1247	0.1045
2032	8	0.1335	0.1247	0.1045
2032	9	0.1335	0.1247	0.1045
2032	10	0.1335	0.1247	0.1045
2032	11	0.1335	0.1246	0.1045
2032	12	0.1335	0.1246	0.1045
2033	1	0.1335	0.1246	0.1045
2033	2	0.1335	0.1246	0.1045
2033	3	0.1335	0.1246	0.1045
2033	4	0.1335	0.1246	0.1045
2033	5	0.1335	0.1246	0.1045
2033	6	0.1335	0.1246	0.1045
2033	7	0.1335	0.1246	0.1045
2033	8	0.1335	0.1246	0.1045
2033	9	0.1335	0.1246	0.1045
2033	10	0.1335	0.1246	0.1045
2033	11	0.1335	0.1246	0.1045
2033	12	0.1335	0.1246	0.1045
2034	1	0.1335	0.1246	0.1045
2034	2	0.1335	0.1246	0.1045
2034	3	0.1335	0.1246	0.1045
2034	4	0.1335	0.1246	0.1045
2034	5	0.1335	0.1246	0.1045
2034	6	0.1335	0.1246	0.1045

Year	Month	Res	SmlGen	Gen
2034	7	0.1335	0.1246	0.1045
2034	8	0.1335	0.1246	0.1045
2034	9	0.1335	0.1246	0.1045
2034	10	0.1335	0.1246	0.1045
2034	11	0.1335	0.1246	0.1045
2034	12	0.1335	0.1246	0.1045
2035	1	0.1335	0.1246	0.1045
2035	2	0.1335	0.1246	0.1045
2035	3	0.1335	0.1246	0.1045
2035	4	0.1335	0.1246	0.1045
2035	5	0.1335	0.1246	0.1045
2035	6	0.1335	0.1246	0.1045
2035	7	0.1335	0.1246	0.1045
2035	8	0.1335	0.1246	0.1045
2035	9	0.1335	0.1246	0.1045
2035	10	0.1335	0.1246	0.1045
2035	11	0.1335	0.1246	0.1045
2035	12	0.1335	0.1246	0.1045
2036	1	0.1334	0.1246	0.1045
2036	2	0.1334	0.1246	0.1045
2036	3	0.1334	0.1246	0.1044
2036	4	0.1334	0.1246	0.1044
2036	5	0.1334	0.1246	0.1044
2036	6	0.1334	0.1246	0.1044
2036	7	0.1334	0.1246	0.1044
2036	8	0.1334	0.1246	0.1044
2036	9	0.1334	0.1246	0.1044
2036	10	0.1334	0.1246	0.1044
2036	11	0.1334	0.1246	0.1044
2036	12	0.1334	0.1246	0.1044







	2023	2024	2025 billed	2025 accrued	2026
Forecast Sales	4830	5180	5289	5289	5315
Residential Weather variance	-126	-104	44	44	
Non-weather variance	230	-12	-106	-41	
Actual Sales	4934	5064	5227	5292	
Weather-adjusted Sales	5060	5167	5183	5248	5315

Month	Jan-23	Feb-23	Mar-23	Apr-23	May-23	Jun-23
Year	2023	2023	2023	2023	2023	2023
Residential WN (kWh)	(91,584,351)	7,346,431	(17,983,763)	(18,251,255)	574,450	2,450,464

Forecast Sales
 Residential Weather variance
 Non-weather variance
 Actual Sales
 Weather-adjusted Sales

Month	Jul-23	Aug-23	Sep-23	Oct-23	Nov-23	Dec-23
Year	2023	2023	2023	2023	2023	2023
Residential WN (kWh)	15,546,870	(3,249,558)	2,333,081	(14,431,634)	23,770,814	(32,137,252)

Forecast Sales
 Residential Weather variance
 Non-weather variance
 Actual Sales
 Weather-adjusted Sales

Month	Jan-24	Feb-24	Mar-24	Apr-24	May-24	Jun-24
Year	2024	2024	2024	2024	2024	2024
Residential WN (kWh)	-2,256,566	-21,585,096	-53,513,968	-7,023,864	-10,135,769	-3,477,906

Forecast Sales
 Residential Weather variance
 Non-weather variance
 Actual Sales
 Weather-adjusted Sales

Month	Jul-24	Aug-24	Sep-24	Oct-24	Nov-24	Dec-24
Year	2024	2024	2024	2024	2024	2024
Residential WN (kWh)	4,485,993	-4,371,461	-3,736,363	848,444	-17,351,041	14,413,639

Forecast Sales
 Residential Weather variance
 Non-weather variance
 Actual Sales
 Weather-adjusted Sales

Month	Jan-25	Feb-25	Mar-25	Apr-25	May-25	Jun-25
Year	2025	2025	2025	2025	2025	2025
Residential WN (kWh)	21,157,507	33,365,662	-29,778,051	-5,732,680	-10,861,808	168,329

Forecast Sales
 Residential Weather variance
 Non-weather variance
 Actual Sales
 Weather-adjusted Sales

Month	Jul-25	Aug-25	Sep-25	Oct-25	Nov-25	Dec-25
Year	2025	2025	2025	2025	2025	2025
Residential WN (kWh)	3,121,388	-7,516,547	-1,236,247	-12,365,217	2,453,334	51,293,066

REDACTED (CONFIDENTIAL INFORMATION REMOVED)

REDACTED 2026 Load Forecast Report Synapse IR-1 Attachment 1 Page 40 of 196

	Regression	New	Hybrid	Solar Impact	EV Impact	RTR Sales	DSM	Total Sales	Total Res DSM	DSM Captured by
Year	Model Output	Customer	Adjustment	(GWh)	(GWh)	(GWh)	Adjustment	(GWh)	(GWh)	End Uses (GWh)
2026	5,292	61	0	-24	-24	8	-2	-19	5,315	-36
2027	5,299	115	0	-51	-51	19	-41	-32	5,310	-60
2028	5,315	165	-7	-80	-80	36	-49	-45	5,335	-84
2029	5,284	209	-12	-112	-112	59	-49	-58	5,321	-108
2030	5,266	248	-15	-147	-147	95	-49	-70	5,327	-132
2031	5,266	283	-17	-189	-189	146	-49	-83	5,357	-156
2032	5,280	314	-17	-233	-233	215	-49	-118	5,393	-222
2033	5,258	342	-17	-276	-276	302	-49	-152	5,408	-286
2034	5,261	368	-17	-320	-320	406	-49	-185	5,464	-348
2035	5,269	390	-17	-361	-361	529	-49	-216	5,545	-407
2036	5,288	411	-16	-394	-394	653	-49	-246	5,646	-464

Year	HP Heat (GWh)	HP Cool (GWh)	Baseboard Heat (GWh)	Water Heat (GWh)
2026	1157	153	1054	743
2027	1199	160	985	746
2028	1251	166	935	751
2029	1292	173	870	757
2030	1341	179	809	762
2031	1391	186	758	766
2032	1449	193	708	773
2033	1492	199	652	774
2034	1542	206	604	778
2035	1591	212	558	782
2036	1635	218	515	788

Year	2026	2027	2028	2029	2030
2026 Forecast	1	5	4	1	2

Year	2026	2027	2028	2029	2030
2026 Forecast	0.8	6.2	0.5	0.0	0.0

Coldest 24-h lag average (Jan 2000 - Jan 2026)

Rank	Date	24h lag average (deg C)
1	Jan 25th 2026	-15.11
2	Feb 4th 2023	-15.09
3	Jan 12th 2022	-14.59
4	Feb 5th 2023	-14.26
5	Feb 15th 2020	-13.87
6	Dec 17th 2016	-13.81

Coldest 12-h lag average (Jan 2000 - Jan 2026)

Rank	Date	12h lag average (deg C)
1	Feb 4th 2023	-21.61
2	Feb 15th 2020	-15.84
3	Jan 12th 2020	-15.53
4	Jan 16th 2017	-15.34
5	Dec 16th 2016	-15.07
6	Jan 25th 2026	-14.94

	Using peak model from 2025 load forecast, with updated input data (MW)	Using improved peak model from this load forecast (MW)
2026 Forecast Peak	2,442	2,484
Interruptible	-42	-42
Weather (-14.9C 12hr lag avg, -15.1C 24hr lag avg)	38	38
Wind (14.1 km/h daily avg)	-16	-16
Morning peak impact (est)	0	0
Weekend Peak	-41	-41
Unexplained	78	36
2026 Actual Peak	2,459	2,459

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLag	Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLag	Weekdays	
2022-01-01	2022		1	1	1	6	2.1	4	2.3	1183.4	8.6	3.1	1.041667	0
2022-01-01	2022		1	1	2	6	2.2	3.9	3	1132.8	8.6	3.3	1.133333	0
2022-01-01	2022		1	1	3	6	2.3	4	3.2	1083.8	8.6	3.4	1.2	0
2022-01-01	2022		1	1	4	6	2.4	4.2	3.1	1055.2	8.6	3.5	1.35	0
2022-01-01	2022		1	1	5	6	2.6	4.2	3	1044.9	8.6	3.6	1.566667	0
2022-01-01	2022		1	1	6	6	2.7	4.3	3.2	1055.5	8.6	3.7	1.766667	0
2022-01-01	2022		1	1	7	6	2.9	4.4	3	1085.7	8.6	3.8	1.983333	0
2022-01-01	2022		1	1	8	6	3.0	4.8	3.3	1122.7	8.6	3.9	2.191667	0
2022-01-01	2022		1	1	9	6	3.2	4.8	3.3	1172.0	8.6	4.0	2.375	0
2022-01-01	2022		1	1	10	6	3.4	4.8	3.8	1230.2	8.6	4.1	2.583333	0
2022-01-01	2022		1	1	11	6	3.5	5.1	4	1288.3	8.6	4.3	2.766667	0
2022-01-01	2022		1	1	12	6	3.7	5.4	4	1316.8	8.6	4.4	2.941667	0
2022-01-01	2022		1	1	13	6	3.8	5.7	3.9	1321.0	8.6	4.5	3.108333	0
2022-01-01	2022		1	1	14	6	4.0	5.9	4	1293.3	8.6	4.6	3.266667	0
2022-01-01	2022		1	1	15	6	4.1	5.5	4.2	1271.8	8.6	4.8	3.4	0
2022-01-01	2022		1	1	16	6	4.2	5	4.2	1302.0	8.6	4.9	3.483333	0
2022-01-01	2022		1	1	17	6	4.3	4.5	4.3	1376.3	8.6	5.0	3.566667	0
2022-01-01	2022		1	1	18	6	4.3	4.8	4.4	1417.3	8.6	5.0	3.658333	0
2022-01-01	2022		1	1	19	6	4.4	4.9	4.8	1362.8	8.6	5.1	3.766667	0
2022-01-01	2022		1	1	20	6	4.5	5.4	4.8	1312.7	8.6	5.1	3.866667	0
2022-01-01	2022		1	1	21	6	4.6	5.7	4.8	1258.8	8.6	5.2	4.016667	0
2022-01-01	2022		1	1	22	6	4.7	6.1	5.1	1202.0	8.6	5.2	4.141667	0
2022-01-01	2022		1	1	23	6	4.8	6.5	5.4	1123.6	8.6	5.3	4.266667	0
2022-01-01	2022		1	1	24	6	4.9	6.4	5.7	1053.5	8.6	5.5	4.375	0
2022-01-02	2022		1	2	1	7	5.0	7	5.9	1001.1	10.5	5.5	4.491667	0
2022-01-02	2022		1	2	2	7	5.1	7.3	5.5	968.8	10.5	5.6	4.633333	0
2022-01-02	2022		1	2	3	7	5.3	7.9	5	946.8	10.5	5.8	4.8	0
2022-01-02	2022		1	2	4	7	5.4	7.2	4.5	945.6	10.5	6.0	4.925	0
2022-01-02	2022		1	2	5	7	5.6	7	4.8	947.6	10.5	6.1	4.991667	0
2022-01-02	2022		1	2	6	7	5.7	7.1	4.9	956.4	10.5	6.4	5.016667	0
2022-01-02	2022		1	2	7	7	5.8	7.2	5.4	993.6	10.5	6.5	5.058333	0
2022-01-02	2022		1	2	8	7	5.9	7.3	5.7	1049.4	10.5	6.7	5.1	0
2022-01-02	2022		1	2	9	7	6.0	7.3	6.1	1119.6	10.5	6.9	5.15	0
2022-01-02	2022		1	2	10	7	6.1	7.6	6.5	1191.4	10.5	7.0	5.225	0
2022-01-02	2022		1	2	11	7	6.2	7.7	6.4	1243.2	10.5	7.2	5.333333	0
2022-01-02	2022		1	2	12	7	6.4	8.2	7	1279.6	10.5	7.3	5.45	0
2022-01-02	2022		1	2	13	7	6.5	8.1	7.3	1299.3	10.5	7.4	5.533333	0
2022-01-02	2022		1	2	14	7	6.6	8.2	7.9	1291.7	10.5	7.5	5.641667	0
2022-01-02	2022		1	2	15	7	6.7	8.8	7.2	1292.3	10.5	7.6	5.758333	0
2022-01-02	2022		1	2	16	7	6.8	8.9	7	1319.0	10.5	7.6	5.958333	0
2022-01-02	2022		1	2	17	7	7.0	8.6	7.1	1410.6	10.5	7.8	6.141667	0
2022-01-02	2022		1	2	18	7	7.1	4.8	7.2	1478.7	10.5	7.9	6.35	0
2022-01-02	2022		1	2	19	7	7.1	2.9	7.3	1439.8	10.5	7.7	6.541667	0
2022-01-02	2022		1	2	20	7	7.1	2.3	7.3	1405.8	10.5	7.4	6.733333	0
2022-01-02	2022		1	2	21	7	6.9	1.7	7.6	1368.9	10.5	7.0	6.891667	0
2022-01-02	2022		1	2	22	7	6.8	1.5	7.7	1328.3	10.5	6.5	7.025	0
2022-01-02	2022		1	2	23	7	6.6	1.3	8.2	1272.9	10.5	6.0	7.15	0
2022-01-02	2022		1	2	24	7	6.3	0.9	8.1	1229.5	10.5	5.4	7.25	0
2022-01-03	2022		1	3	1	1	6.1	0.5	8.2	1182.1	15.6	4.8	7.4	0
2022-01-03	2022		1	3	2	1	5.8	0	8.8	1162.5	15.6	4.2	7.491667	0
2022-01-03	2022		1	3	3	1	5.5	-0.6	8.9	1161.7	15.6	3.5	7.566667	0
2022-01-03	2022		1	3	4	1	5.2	-1	8.6	1173.5	15.6	2.7	7.641667	0
2022-01-03	2022		1	3	5	1	4.8	-1.4	4.8	1195.7	15.6	1.9	7.783333	0
2022-01-03	2022		1	3	6	1	4.5	-1.5	2.9	1249.4	15.6	1.1	7.916667	0
2022-01-03	2022		1	3	7	1	4.1	-2.1	2.3	1336.8	15.6	0.6	7.725	0
2022-01-03	2022		1	3	8	1	3.8	-3.1	1.7	1419.9	15.6	0.1	7.366667	0
2022-01-03	2022		1	3	9	1	3.3	-4.6	1.5	1513.9	15.6	-0.3	6.95	0
2022-01-03	2022		1	3	10	1	2.8	-6.1	1.3	1569.7	15.6	-0.8	6.483333	0
2022-01-03	2022		1	3	11	1	2.3	-5.6	0.9	1601.4	15.6	-1.5	5.975	0
2022-01-03	2022		1	3	12	1	1.7	-5	0.5	1625.6	15.6	-2.1	5.441667	0
2022-01-03	2022		1	3	13	1	1.1	-4.6	0	1636.7	15.6	-2.5	4.833333	0
2022-01-03	2022		1	3	14	1	0.6	-4.7	-0.6	1638.5	15.6	-3.0	4.2	0
2022-01-03	2022		1	3	15	1	0.1	-4.6	-1	1635.7	15.6	-3.4	3.516667	0
2022-01-03	2022		1	3	16	1	-0.5	-4.9	-1.4	1675.1	15.6	-3.7	2.733333	0
2022-01-03	2022		1	3	17	1	-1.1	-5.1	-1.5	1765.2	15.6	-4.0	1.908333	0
2022-01-03	2022		1	3	18	1	-1.6	-5.3	-2.1	1832.4	15.6	-4.3	1.075	0
2022-01-03	2022		1	3	19	1	-2.0	-5.5	-3.1	1781.7	15.6	-4.6	0.55	0
2022-01-03	2022		1	3	20	1	-2.4	-5.5	-4.6	1740.0	15.6	-4.9	0.133333	0
2022-01-03	2022		1	3	21	1	-2.7	-6	-6.1	1691.8	15.6	-5.1	-0.31667	0
2022-01-03	2022		1	3	22	1	-3.0	-6.1	-5.6	1624.7	15.6	-5.2	-0.84167	0
2022-01-03	2022		1	3	23	1	-3.4	-6.3	-5	1529.5	15.6	-5.2	-1.475	0
2022-01-03	2022		1	3	24	1	-3.7	-6.5	-4.6	1479.5	15.6	-5.3	-2.05	0
2022-01-04	2022		1	4	1	2	-4.0	-6.7	-4.7	1439.3	18.2	-5.4	-2.54167	1
2022-01-04	2022		1	4	2	2	-4.3	-6.7	-4.6	1415.7	18.2	-5.6	-2.96667	1
2022-01-04	2022		1	4	3	2	-4.6	-6.7	-4.9	1403.2	18.2	-5.8	-3.35833	1
2022-01-04	2022		1	4	4	2	-4.8	-7.1	-5.1	1406.2	18.2	-5.9	-3.69167	1
2022-01-04	2022		1	4	5	2	-5.1	-7.2	-5.3	1423.5	18.2	-6.1	-4.01667	1
2022-01-04	2022		1	4	6	2	-5.3	-7.1	-5.5	1482.3	18.2	-6.3	-4.325	1
2022-01-04	2022		1	4	7	2	-5.5	-7.2	-5.5	1596.6	18.2	-6.5	-4.64167	1
2022-01-04	2022		1	4	8	2	-5.8	-7.7	-6	1702.2	18.2	-6.6	-4.925	1
2022-01-04	2022		1	4	9	2	-6.0	-8.1	-6.1	1766.2	18.2	-6.8	-5.125	1
2022-01-04	2022		1	4	10	2	-6.1	-7.8	-6.3	1789.3	18.2	-7.0	-5.24167	1
2022-01-04	2022		1	4	11	2	-6.2	-6.7	-6.5	1791.3	18.2	-7.1	-5.24167	1
2022-01-04	2022		1	4	12	2	-6.2	-6.2	-6.7	1792.6	18.2	-7.1	-5.3	1
2022-01-04	2022		1	4	13	2	-6.3	-5.6	-6.7	1806.8	18.2	-7.1	-5.425	1
2022-01-04	2022		1	4	14	2	-6.3	-5.6	-6.7	1799.7	18.2	-7.0	-5.6	1
2022-01-04	2022		1	4	15	2	-6.3	-5.7	-7.1	1767.8	18.2	-6.9	-5.76667	1
2022-01-04	2022		1	4	16	2	-6.4	-5.3	-7.2	1755.7	18.2	-6.8	-5.94167	1
2022-01-04	2022		1	4	17	2	-6.4	-6.1	-7.1	1833.4	18.2	-6.7	-6.125	1
2022-01-04	2022		1	4	18	2	-6.4	-6.4	-7.2	1934.3	18.2	-6.6	-6.3	1
2022-01-04	2022		1	4	19	2	-6.5	-6.4	-7.7	1906.0	18.2	-6.5	-6.45	1
2022-01-04	2022		1	4	20	2	-6.5	-6.8	-8.1	1868.6	18.2	-6.5	-6.59167	1
2022-01-04	2022		1	4	21	2	-6.6	-7	-7.8	1799.4	18.2	-6.4	-6.775	1
2022-01-04	2022		1	4	22	2	-6.6	-7.5	-6.7	1709.8	18.2	-6.3	-6.95	1
2022-01-04	2022		1	4	23	2	-6.7	-6.1	-6.2	1612.4	18.2	-6.3	-7.09167	1
2022-01-04	2022		1	4	24	2	-6.7	-5.8	-5.6	1578.2	18.2	-6.2	-7.125	1
2022-01-05</														

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLag	Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLag	Weekdays	
2022-01-05	2022		1	5	12	3	-4.1	3.5	-5.5	1602.5	21.3	-1.9	-6.225	1
2022-01-05	2022		1	5	13	3	-3.7	3.4	-5	1615.6	21.3	-1.2	-6.19167	1
2022-01-05	2022		1	5	14	3	-3.3	3.9	-4.3	1582.4	21.3	-0.4	-6.18333	1
2022-01-05	2022		1	5	15	3	-2.9	4.2	-3.4	1548.0	21.3	0.3	-6.13333	1
2022-01-05	2022		1	5	16	3	-2.5	5.4	-2.4	1530.3	21.3	1.0	-6.01667	1
2022-01-05	2022		1	5	17	3	-2.1	5.5	-1.3	1578.9	21.3	1.8	-5.85833	1
2022-01-05	2022		1	5	18	3	-1.6	5.6	-0.6	1629.0	21.3	2.4	-5.55	1
2022-01-05	2022		1	5	19	3	-1.1	6	0	1570.4	21.3	3.0	-5.125	1
2022-01-05	2022		1	5	20	3	-0.5	6.1	1.1	1515.4	21.3	3.5	-4.64167	1
2022-01-05	2022		1	5	21	3	0.0	6.2	1.9	1447.9	21.3	4.1	-4.075	1
2022-01-05	2022		1	5	22	3	0.5	5.9	2	1364.3	21.3	4.5	-3.4	1
2022-01-05	2022		1	5	23	3	1.1	7.7	3.5	1267.1	21.3	4.8	-2.61667	1
2022-01-05	2022		1	5	24	3	1.7	8	3.4	1209.7	21.3	5.3	-1.94167	1
2022-01-06	2022		1	6	1	4	2.2	8	3.9	1162.0	19.3	5.7	-1.16667	1
2022-01-06	2022		1	6	2	4	2.8	8.4	4.2	1107.5	19.3	6.0	-0.425	1
2022-01-06	2022		1	6	3	4	3.4	9.1	5.4	1067.3	19.3	6.4	0.316667	1
2022-01-06	2022		1	6	4	4	3.9	8.5	5.5	1054.2	19.3	6.8	1.025	1
2022-01-06	2022		1	6	5	4	4.4	8.1	5.6	1058.5	19.3	7.1	1.758333	1
2022-01-06	2022		1	6	6	4	4.9	8.7	6	1089.8	19.3	7.3	2.416667	1
2022-01-06	2022		1	6	7	4	5.3	9.5	6.1	1180.3	19.3	7.6	2.991667	1
2022-01-06	2022		1	6	8	4	5.7	9.7	6.2	1262.9	19.3	7.9	3.541667	1
2022-01-06	2022		1	6	9	4	6.1	8.7	5.9	1313.9	19.3	8.2	4.05	1
2022-01-06	2022		1	6	10	4	6.4	9.3	7.7	1331.3	19.3	8.4	4.475	1
2022-01-06	2022		1	6	11	4	6.7	8	8	1321.2	19.3	8.6	4.808333	1
2022-01-06	2022		1	6	12	4	7.0	7.7	8	1310.6	19.3	8.7	5.283333	1
2022-01-06	2022		1	6	13	4	7.2	8.1	8.4	1315.9	19.3	8.6	5.658333	1
2022-01-06	2022		1	6	14	4	7.3	8.5	9.1	1297.8	19.3	8.7	6.041667	1
2022-01-06	2022		1	6	15	4	7.5	8.5	8.5	1282.6	19.3	8.7	6.416667	1
2022-01-06	2022		1	6	16	4	7.7	7.3	8.1	1311.5	19.3	8.6	6.825	1
2022-01-06	2022		1	6	17	4	7.8	5.5	8.7	1390.6	19.3	8.5	7.083333	1
2022-01-06	2022		1	6	18	4	7.8	4.4	9.5	1510.8	19.3	8.3	7.3	1
2022-01-06	2022		1	6	19	4	7.7	3.4	9.7	1499.7	19.3	7.9	7.558333	1
2022-01-06	2022		1	6	20	4	7.6	2.9	8.7	1470.7	19.3	7.4	7.85	1
2022-01-06	2022		1	6	21	4	7.5	1.1	9.3	1441.9	19.3	6.9	8.15	1
2022-01-06	2022		1	6	22	4	7.3	-0.6	8	1383.8	19.3	6.2	8.358333	1
2022-01-06	2022		1	6	23	4	7.0	-0.8	7.7	1307.3	19.3	5.4	8.641667	1
2022-01-06	2022		1	6	24	4	6.7	0	8.1	1281.9	19.3	4.7	8.666667	1
2022-01-07	2022		1	7	1	5	6.3	1.1	8.5	1258.2	20.3	4.0	8.641667	1
2022-01-07	2022		1	7	2	5	6.0	1.1	8.5	1220.1	20.3	3.4	8.65	1
2022-01-07	2022		1	7	3	5	5.7	1	7.3	1189.5	20.3	2.8	8.658333	1
2022-01-07	2022		1	7	4	5	5.4	0.7	5.5	1175.4	20.3	2.2	8.608333	1
2022-01-07	2022		1	7	5	5	5.1	0.9	4.4	1182.3	20.3	1.7	8.508333	1
2022-01-07	2022		1	7	6	5	4.8	0.7	3.4	1228.3	20.3	1.3	8.291667	1
2022-01-07	2022		1	7	7	5	4.4	0.7	2.9	1324.9	20.3	1.0	7.933333	1
2022-01-07	2022		1	7	8	5	4.1	0.6	1.1	1417.9	20.3	0.7	7.425	1
2022-01-07	2022		1	7	9	5	3.7	0.5	-0.6	1493.5	20.3	0.5	6.858333	1
2022-01-07	2022		1	7	10	5	3.4	1	-0.8	1534.4	20.3	0.5	6.225	1
2022-01-07	2022		1	7	11	5	3.0	1.5	0	1571.8	20.3	0.6	5.4	1
2022-01-07	2022		1	7	12	5	2.7	2.4	1.1	1621.3	20.3	0.8	4.666667	1
2022-01-07	2022		1	7	13	5	2.5	3.1	1.1	1646.5	20.3	1.0	4.025	1
2022-01-07	2022		1	7	14	5	2.3	2.8	1	1649.8	20.3	1.2	3.441667	1
2022-01-07	2022		1	7	15	5	2.1	0.3	0.7	1589.9	20.3	1.3	2.825	1
2022-01-07	2022		1	7	16	5	1.7	0.2	0.9	1465.8	20.3	1.3	2.2	1
2022-01-07	2022		1	7	17	5	1.4	0.4	0.7	1467.3	20.3	1.2	1.65	1
2022-01-07	2022		1	7	18	5	1.2	1.2	0.7	1503.8	20.3	1.2	1.266667	1
2022-01-07	2022		1	7	19	5	1.1	2.5	0.6	1464.1	20.3	1.2	0.958333	1
2022-01-07	2022		1	7	20	5	1.1	5.9	0.5	1427.3	20.3	1.4	0.733333	1
2022-01-07	2022		1	7	21	5	1.2	3.9	1	1380.8	20.3	1.8	0.541667	1
2022-01-07	2022		1	7	22	5	1.3	2.7	1.5	1337.9	20.3	2.1	0.491667	1
2022-01-07	2022		1	7	23	5	1.4	0	2.4	1281.7	20.3	2.2	0.625	1
2022-01-07	2022		1	7	24	5	1.5	-1.3	3.1	1269.0	20.3	2.1	0.816667	1
2022-01-08	2022		1	8	1	6	1.4	-1.8	2.8	1241.2	20.9	1.8	1.016667	0
2022-01-08	2022		1	8	2	6	1.3	-2.6	0.3	1232.5	20.9	1.4	1.183333	0
2022-01-08	2022		1	8	3	6	1.1	-4	0.2	1215.3	20.9	1.0	1.325	0
2022-01-08	2022		1	8	4	6	0.9	-4.4	0.4	1213.0	20.9	0.6	1.266667	0
2022-01-08	2022		1	8	5	6	0.7	-5	1.2	1225.4	20.9	0.2	1.225	0
2022-01-08	2022		1	8	6	6	0.5	-5.2	2.5	1256.6	20.9	-0.2	1.183333	0
2022-01-08	2022		1	8	7	6	0.2	-5	5.9	1309.3	20.9	-0.8	1.225	0
2022-01-08	2022		1	8	8	6	0.0	-5	3.9	1383.4	20.9	-1.4	1.375	0
2022-01-08	2022		1	8	9	6	-0.2	-5.2	2.7	1470.7	20.9	-2.3	1.816667	0
2022-01-08	2022		1	8	10	6	-0.5	-4.8	0	1541.4	20.9	-3.1	2.1	0
2022-01-08	2022		1	8	11	6	-0.7	-4.9	-1.3	1568.3	20.9	-3.7	2.241667	0
2022-01-08	2022		1	8	12	6	-1.0	-4.5	-1.8	1585.3	20.9	-4.1	2.116667	0
2022-01-08	2022		1	8	13	6	-1.3	-4.8	-2.6	1590.5	20.9	-4.4	1.808333	0
2022-01-08	2022		1	8	14	6	-1.6	-5.1	-4	1574.0	20.9	-4.6	1.4	0
2022-01-08	2022		1	8	15	6	-1.9	-5.2	-4.4	1557.7	20.9	-4.8	0.95	0
2022-01-08	2022		1	8	16	6	-2.2	-5.1	-5	1587.5	20.9	-4.9	0.591667	0
2022-01-08	2022		1	8	17	6	-2.4	-5.3	-5.2	1686.9	20.9	-5.0	0.208333	0
2022-01-08	2022		1	8	18	6	-2.6	-6	-5	1807.8	20.9	-5.0	-0.24167	0
2022-01-08	2022		1	8	19	6	-2.9	-6.6	-5	1780.1	20.9	-5.1	-0.775	0
2022-01-08	2022		1	8	20	6	-3.3	-6.9	-5.2	1744.9	20.9	-5.2	-1.4	0
2022-01-08	2022		1	8	21	6	-3.8	-7.5	-4.8	1698.2	20.9	-5.4	-2.30833	0
2022-01-08	2022		1	8	22	6	-4.3	-8.2	-4.9	1646.1	20.9	-5.6	-3.06667	0
2022-01-08	2022		1	8	23	6	-4.8	-8.1	-4.5	1580.1	20.9	-5.8	-3.69167	0
2022-01-08	2022		1	8	24	6	-5.1	-8.4	-4.8	1535.0	20.9	-6.1	-4.1	0
2022-01-09	2022		1	9	1	7	-5.4	-9.2	-5.1	1490.5	18.2	-6.4	-4.36667	0
2022-01-09	2022		1	9	2	7	-5.7	-10.4	-5.2	1470.8	18.2	-6.8	-4.61667	0
2022-01-09	2022		1	9	3	7	-6.0	-8.9	-5.1	1465.2	18.2	-7.2	-4.825	0
2022-01-09	2022		1	9	4	7	-6.2	-8.7	-5.3	1464.8	18.2	-7.6	-4.925	0
2022-01-09	2022		1	9	5	7	-6.4	-9.6	-6	1456.8	18.2	-7.9	-4.98333	0
2022-01-09	2022		1	9	6	7	-6.6	-6.7	-6.6	1460.1	18.2	-8.2	-5.00833	0
2022-01-09	2022		1	9	7	7	-6.7	-5.5	-6.9	1487.7	18.2	-8.3	-5.075	0
2022-01-09	2022		1	9	8	7	-6.7	-4.7	-7.5	1532.3	18.2	-8.2	-5.20833	0
2022-01-09	2022		1	9	9	7	-6.7	-4	-8.2	1596.0	18.2	-8.0	-5.36667	0
2022-01-09	2022		1	9	10	7	-6.6	-2.5	-8.1	1651.7	18.2	-7.7	-5.55833	0
2022-01-09	2022		1	9	11	7	-6.5	-0.6	-8.4	1676.3	18.2	-7.2	-5.84167	0

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLag	Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLag	Weekdays	
2022-01-09	2022		1	9	24	7	-1.3	6.8	1.9	1218.6	18.2	3.9	-6.6	0
2022-01-10	2022		1	10	1	1	-0.7	6.8	2.5	1149.6	19.1	4.4	-5.81667	1
2022-01-10	2022		1	10	2	1	0.0	7	2.7	1120.8	19.1	4.8	-4.89167	1
2022-01-10	2022		1	10	3	1	0.7	6.8	3	1107.6	19.1	5.2	-3.81667	1
2022-01-10	2022		1	10	4	1	1.3	5.8	3.3	1108.8	19.1	5.5	-2.85	1
2022-01-10	2022		1	10	5	1	1.9	5.3	3.9	1120.5	19.1	5.8	-1.875	1
2022-01-10	2022		1	10	6	1	2.6	4.9	4.5	1176.6	19.1	5.9	-0.8	1
2022-01-10	2022		1	10	7	1	3.1	4.8	5.3	1296.1	19.1	6.0	0.083333	1
2022-01-10	2022		1	10	8	1	3.5	2.8	6	1414.2	19.1	6.0	0.916667	1
2022-01-10	2022		1	10	9	1	3.8	2.4	6.7	1511.7	19.1	5.8	1.75	1
2022-01-10	2022		1	10	10	1	4.1	1.1	6.3	1558.7	19.1	5.5	2.583333	1
2022-01-10	2022		1	10	11	1	4.2	0.6	6.8	1582.5	19.1	5.1	3.35	1
2022-01-10	2022		1	10	12	1	4.3	-0.2	6.8	1602.6	19.1	4.6	3.925	1
2022-01-10	2022		1	10	13	1	4.2	-1.3	7	1629.8	19.1	4.0	4.408333	1
2022-01-10	2022		1	10	14	1	4.1	-1.8	6.8	1634.1	19.1	3.3	4.816667	1
2022-01-10	2022		1	10	15	1	3.9	-2.2	5.8	1642.9	19.1	2.6	5.191667	1
2022-01-10	2022		1	10	16	1	3.7	-3.3	5.3	1672.4	19.1	1.9	5.533333	1
2022-01-10	2022		1	10	17	1	3.4	-4.1	4.9	1744.9	19.1	1.1	5.766667	1
2022-01-10	2022		1	10	18	1	3.1	-4.9	4.8	1831.6	19.1	0.3	5.933333	1
2022-01-10	2022		1	10	19	1	2.8	-5.3	2.8	1810.1	19.1	-0.5	6.016667	1
2022-01-10	2022		1	10	20	1	2.3	-5.8	2.4	1773.6	19.1	-1.4	6.041667	1
2022-01-10	2022		1	10	21	1	1.9	-6	1.1	1724.2	19.1	-2.1	5.833333	1
2022-01-10	2022		1	10	22	1	1.4	-6.5	0.6	1661.4	19.1	-2.8	5.533333	1
2022-01-10	2022		1	10	23	1	0.8	-8	-0.2	1586.9	19.1	-3.4	5.066667	1
2022-01-10	2022		1	10	24	1	0.2	-8.7	-1.3	1582.4	19.1	-4.1	4.591667	1
2022-01-11	2022		1	11	1	2	-0.4	-9.6	-1.8	1566.3	16.5	-4.8	4.008333	1
2022-01-11	2022		1	11	2	2	-1.1	-9.8	-2.2	1552.8	16.5	-5.5	3.333333	1
2022-01-11	2022		1	11	3	2	-1.8	-10.2	-3.3	1544.6	16.5	-6.2	2.6	1
2022-01-11	2022		1	11	4	2	-2.5	-10.9	-4.1	1557.1	16.5	-6.9	1.85	1
2022-01-11	2022		1	11	5	2	-3.2	-11.5	-4.9	1581.3	16.5	-7.5	1.091667	1
2022-01-11	2022		1	11	6	2	-3.9	-12.1	-5.3	1646.5	16.5	-8.1	0.308333	1
2022-01-11	2022		1	11	7	2	-4.6	-12.9	-5.8	1769.9	16.5	-8.7	-0.50833	1
2022-01-11	2022		1	11	8	2	-5.3	-14.3	-6	1891.3	16.5	-9.3	-1.35	1
2022-01-11	2022		1	11	9	2	-6.1	-14	-6.5	1972.0	16.5	-10.0	-2.06667	1
2022-01-11	2022		1	11	10	2	-6.7	-14.1	-8	1993.8	16.5	-10.7	-2.76667	1
2022-01-11	2022		1	11	11	2	-7.4	-13.9	-8.7	1982.4	16.5	-11.3	-3.4	1
2022-01-11	2022		1	11	12	2	-8.0	-14.1	-9.6	1980.4	16.5	-11.8	-4.11667	1
2022-01-11	2022		1	11	13	2	-8.6	-13.9	-9.8	1970.2	16.5	-12.3	-4.825	1
2022-01-11	2022		1	11	14	2	-9.1	-12.7	-10.2	1932.6	16.5	-12.6	-5.51667	1
2022-01-11	2022		1	11	15	2	-9.5	-13.5	-10.9	1906.8	16.5	-12.9	-6.18333	1
2022-01-11	2022		1	11	16	2	-10.0	-13.2	-11.5	1940.8	16.5	-13.2	-6.85	1
2022-01-11	2022		1	11	17	2	-10.4	-13.4	-12.1	2033.9	16.5	-13.4	-7.48333	1
2022-01-11	2022		1	11	18	2	-10.8	-14.6	-12.9	2145.6	16.5	-13.5	-8.1	1
2022-01-11	2022		1	11	19	2	-11.2	-14.8	-14.3	2115.7	16.5	-13.7	-8.7	1
2022-01-11	2022		1	11	20	2	-11.6	-14.7	-14	2083.1	16.5	-13.9	-9.33333	1
2022-01-11	2022		1	11	21	2	-12.0	-14.8	-14.1	2045.4	16.5	-13.9	-10.0417	1
2022-01-11	2022		1	11	22	2	-12.3	-14.9	-13.9	1971.4	16.5	-14.0	-10.7083	1
2022-01-11	2022		1	11	23	2	-12.7	-15.4	-14.1	1877.7	16.5	-14.0	-11.3417	1
2022-01-11	2022		1	11	24	2	-13.0	-15.5	-13.9	1854.1	16.5	-14.2	-11.8333	1
2022-01-12	2022		1	12	1	3	-13.3	-15.6	-12.7	1831.7	17.6	-14.3	-12.2833	1
2022-01-12	2022		1	12	2	3	-13.5	-16	-13.5	1804.7	17.6	-14.4	-12.6417	1
2022-01-12	2022		1	12	3	3	-13.8	-16.1	-13.2	1793.4	17.6	-14.7	-12.8833	1
2022-01-12	2022		1	12	4	3	-14.0	-16.2	-13.4	1797.5	17.6	-14.9	-13.1583	1
2022-01-12	2022		1	12	5	3	-14.3	-16.2	-14.6	1812.9	17.6	-15.2	-13.35	1
2022-01-12	2022		1	12	6	3	-14.5	-15.7	-14.8	1865.7	17.6	-15.4	-13.5083	1
2022-01-12	2022		1	12	7	3	-14.6	-15.3	-14.7	1964.9	17.6	-15.5	-13.7167	1
2022-01-12	2022		1	12	8	3	-14.7	-14.7	-14.8	2036.7	17.6	-15.5	-13.875	1
2022-01-12	2022		1	12	9	3	-14.7	-13.5	-14.9	2097.2	17.6	-15.5	-13.9083	1
2022-01-12	2022		1	12	10	3	-14.7	-11.4	-15.4	2078.6	17.6	-15.4	-13.975	1
2022-01-12	2022		1	12	11	3	-14.6	-9.6	-15.5	2050.3	17.6	-15.1	-14.0417	1
2022-01-12	2022		1	12	12	3	-14.4	-7.1	-15.6	2032.0	17.6	-14.7	-14.1667	1
2022-01-12	2022		1	12	13	3	-14.1	-5.9	-16	2040.2	17.6	-14.0	-14.2833	1
2022-01-12	2022		1	12	14	3	-13.8	-4.7	-16.1	2001.3	17.6	-13.1	-14.425	1
2022-01-12	2022		1	12	15	3	-13.5	-4	-16.2	1968.7	17.6	-12.2	-14.7	1
2022-01-12	2022		1	12	16	3	-13.1	-2.9	-16.2	1935.7	17.6	-11.2	-14.9167	1
2022-01-12	2022		1	12	17	3	-12.6	-2	-15.7	1940.9	17.6	-10.1	-15.1667	1
2022-01-12	2022		1	12	18	3	-12.2	-1.1	-15.3	1966.7	17.6	-8.9	-15.4	1
2022-01-12	2022		1	12	19	3	-11.6	-0.7	-14.7	1885.4	17.6	-7.7	-15.4917	1
2022-01-12	2022		1	12	20	3	-11.0	0.9	-13.5	1803.1	17.6	-6.5	-15.5333	1
2022-01-12	2022		1	12	21	3	-10.4	1.1	-11.4	1713.3	17.6	-5.2	-15.5333	1
2022-01-12	2022		1	12	22	3	-9.7	2	-9.6	1614.9	17.6	-4.0	-15.425	1
2022-01-12	2022		1	12	23	3	-9.0	2.7	-7.1	1504.5	17.6	-2.8	-15.1333	1
2022-01-12	2022		1	12	24	3	-8.2	3.3	-5.9	1447.3	17.6	-1.8	-14.65	1
2022-01-13	2022		1	13	1	4	-7.4	3.6	-4.7	1404.2	8.4	-0.9	-13.95	1
2022-01-13	2022		1	13	2	4	-6.6	3.8	-4	1359.1	8.4	-0.2	-13.1417	1
2022-01-13	2022		1	13	3	4	-5.8	4	-2.9	1319.3	8.4	0.6	-12.2	1
2022-01-13	2022		1	13	4	4	-5.0	3	-2	1305.8	8.4	1.2	-11.1917	1
2022-01-13	2022		1	13	5	4	-4.2	2.2	-1.1	1309.0	8.4	1.7	-10.0833	1
2022-01-13	2022		1	13	6	4	-3.4	0.9	-0.7	1350.4	8.4	2.1	-8.9	1
2022-01-13	2022		1	13	7	4	-2.7	1.2	0.9	1451.1	8.4	2.2	-7.68333	1
2022-01-13	2022		1	13	8	4	-2.0	0.9	1.1	1541.0	8.4	2.4	-6.46667	1
2022-01-13	2022		1	13	9	4	-1.4	1.3	2	1610.2	8.4	2.4	-5.16667	1
2022-01-13	2022		1	13	10	4	-0.8	1.4	2.7	1620.6	8.4	2.4	-3.95	1
2022-01-13	2022		1	13	11	4	-0.2	1.7	3.3	1610.9	8.4	2.4	-2.83333	1
2022-01-13	2022		1	13	12	4	0.2	1.5	3.6	1605.3	8.4	2.3	-1.80833	1
2022-01-13	2022		1	13	13	4	0.6	2	3.8	1598.4	8.4	2.1	-0.94167	1
2022-01-13	2022		1	13	14	4	0.9	2.4	4	1548.2	8.4	2.0	-0.15	1
2022-01-13	2022		1	13	15	4	1.2	2.7	3	1520.8	8.4	1.9	0.558333	1
2022-01-13	2022		1	13	16	4	1.5	2.8	2.2	1530.7	8.4	1.8	1.225	1
2022-01-13	2022		1	13	17	4	1.7	1.9	0.9	1586.5	8.4	1.8	1.716667	1
2022-01-13	2022		1	13	18	4	1.9	0.7	1.2	1668.0	8.4	1.7	2.066667	1
2022-01-13	2022		1	13	19	4	2.0	-0.2	0.9	1651.9	8.4	1.7	2.233333	1
2022-01-13	2022		1	13	20	4	2.0	-0.7	1.3	1621.5	8.4	1.6	2.391667	1
2022-01-13	2022		1	13	21	4	1.9	-1.2	1.4	1578.9	8.4	1.5	2.391667	1
2022-01-13	2022		1	13</										

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLag	Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLag	Weekdays	
2022-01-14	2022		1	14	12	5	0.7	4	0.1	1584.3	17.1	0.6	0.916667	1
2022-01-14	2022		1	14	13	5	0.8	4.7	0.3	1598.4	17.1	0.9	0.775	1
2022-01-14	2022		1	14	14	5	1.0	5	0.7	1570.9	17.1	1.3	0.616667	1
2022-01-14	2022		1	14	15	5	1.1	4.9	0.4	1552.4	17.1	1.7	0.441667	1
2022-01-14	2022		1	14	16	5	1.2	5	0	1558.0	17.1	2.0	0.275	1
2022-01-14	2022		1	14	17	5	1.2	5.1	-0.1	1596.7	17.1	2.4	0.075	1
2022-01-14	2022		1	14	18	5	1.4	3.2	0.2	1640.4	17.1	2.8	-0.08333	1
2022-01-14	2022		1	14	19	5	1.5	3	0.6	1618.0	17.1	3.1	-0.15	1
2022-01-14	2022		1	14	20	5	1.6	2.3	0.8	1588.6	17.1	3.4	-0.11667	1
2022-01-14	2022		1	14	21	5	1.7	1.9	1.5	1544.2	17.1	3.5	-0.00833	1
2022-01-14	2022		1	14	22	5	1.9	1.4	2.4	1493.4	17.1	3.6	0.158333	1
2022-01-14	2022		1	14	23	5	2.0	1.5	4	1430.6	17.1	3.6	0.333333	1
2022-01-14	2022		1	14	24	5	2.0	0.2	4.7	1395.8	17.1	3.5	0.558333	1
2022-01-15	2022		1	15	1	6	2.0	-1.2	5	1361.2	35.7	3.2	0.908333	0
2022-01-15	2022		1	15	2	6	2.0	-2.3	4.9	1324.4	35.7	2.7	1.291667	0
2022-01-15	2022		1	15	3	6	1.9	-3	5	1308.1	35.7	2.1	1.683333	0
2022-01-15	2022		1	15	4	6	1.7	-3.9	5.1	1316.5	35.7	1.4	2.033333	0
2022-01-15	2022		1	15	5	6	1.6	-4.1	3.2	1329.8	35.7	0.7	2.416667	0
2022-01-15	2022		1	15	6	6	1.4	-4.6	3	1359.3	35.7	-0.1	2.841667	0
2022-01-15	2022		1	15	7	6	1.2	-5.6	2.3	1403.0	35.7	-0.7	3.116667	0
2022-01-15	2022		1	15	8	6	1.0	-7.1	1.9	1450.1	35.7	-1.5	3.35	0
2022-01-15	2022		1	15	9	6	0.6	-7.9	1.4	1529.3	35.7	-2.2	3.491667	0
2022-01-15	2022		1	15	10	6	0.3	-8.6	1.5	1629.8	35.7	-3.1	3.583333	0
2022-01-15	2022		1	15	11	6	-0.2	-10.1	0.2	1688.3	35.7	-3.9	3.575	0
2022-01-15	2022		1	15	12	6	-0.7	-10.8	-1.2	1732.5	35.7	-4.9	3.5	0
2022-01-15	2022		1	15	13	6	-1.3	-10.6	-2.3	1775.7	35.7	-5.8	3.183333	0
2022-01-15	2022		1	15	14	6	-1.9	-11	-3	1791.7	35.7	-6.6	2.691667	0
2022-01-15	2022		1	15	15	6	-2.6	-11.5	-3.9	1808.5	35.7	-7.3	2.083333	0
2022-01-15	2022		1	15	16	6	-3.3	-11.8	-4.1	1851.9	35.7	-8.0	1.425	0
2022-01-15	2022		1	15	17	6	-4.0	-11.6	-4.6	1948.1	35.7	-8.6	0.683333	0
2022-01-15	2022		1	15	18	6	-4.7	-12.2	-5.6	2072.0	35.7	-9.3	-0.08333	0
2022-01-15	2022		1	15	19	6	-5.3	-13	-7.1	2054.3	35.7	-9.9	-0.73333	0
2022-01-15	2022		1	15	20	6	-6.0	-13.7	-7.9	2013.1	35.7	-10.5	-1.45	0
2022-01-15	2022		1	15	21	6	-6.7	-14.8	-8.6	1963.1	35.7	-11.1	-2.23333	0
2022-01-15	2022		1	15	22	6	-7.3	-15.4	-10.1	1909.9	35.7	-11.6	-3.05	0
2022-01-15	2022		1	15	23	6	-8.0	-15.5	-10.8	1844.5	35.7	-12.2	-3.88333	0
2022-01-15	2022		1	15	24	6	-8.8	-15.7	-10.6	1787.3	35.7	-12.7	-4.85	0
2022-01-16	2022		1	16	1	7	-9.4	-15.5	-11	1737.6	14.2	-13.1	-5.76667	0
2022-01-16	2022		1	16	2	7	-10.0	-15.2	-11.5	1710.6	14.2	-13.5	-6.55	0
2022-01-16	2022		1	16	3	7	-10.6	-14.6	-11.8	1690.1	14.2	-13.8	-7.275	0
2022-01-16	2022		1	16	4	7	-11.0	-14.2	-11.6	1689.8	14.2	-14.1	-7.98333	0
2022-01-16	2022		1	16	5	7	-11.5	-14.4	-12.2	1708.2	14.2	-14.3	-8.64167	0
2022-01-16	2022		1	16	6	7	-11.9	-14.5	-13	1731.0	14.2	-14.5	-9.26667	0
2022-01-16	2022		1	16	7	7	-12.3	-13.9	-13.7	1777.6	14.2	-14.7	-9.9	0
2022-01-16	2022		1	16	8	7	-12.7	-13.5	-14.8	1837.2	14.2	-14.8	-10.5167	0
2022-01-16	2022		1	16	9	7	-12.9	-13.2	-15.4	1900.3	14.2	-14.8	-11.0667	0
2022-01-16	2022		1	16	10	7	-13.1	-12.3	-15.5	1919.8	14.2	-14.6	-11.6417	0
2022-01-16	2022		1	16	11	7	-13.3	-11.1	-15.7	1908.4	14.2	-14.4	-12.2083	0
2022-01-16	2022		1	16	12	7	-13.3	-9.8	-15.5	1885.5	14.2	-14.0	-12.6583	0
2022-01-16	2022		1	16	13	7	-13.3	-8.7	-15.2	1848.9	14.2	-13.5	-13.0667	0
2022-01-16	2022		1	16	14	7	-13.2	-7.4	-14.6	1793.6	14.2	-13.0	-13.475	0
2022-01-16	2022		1	16	15	7	-13.1	-7	-14.2	1756.3	14.2	-12.3	-13.825	0
2022-01-16	2022		1	16	16	7	-12.9	-6	-14.4	1767.6	14.2	-11.7	-14.0833	0
2022-01-16	2022		1	16	17	7	-12.6	-6.2	-14.5	1852.3	14.2	-11.0	-14.2833	0
2022-01-16	2022		1	16	18	7	-12.4	-7.2	-13.9	1991.5	14.2	-10.3	-14.5167	0
2022-01-16	2022		1	16	19	7	-12.2	-7.8	-13.5	1983.5	14.2	-9.7	-14.7083	0
2022-01-16	2022		1	16	20	7	-12.0	-8.7	-13.2	1963.6	14.2	-9.2	-14.7833	0
2022-01-16	2022		1	16	21	7	-11.8	-9.5	-12.3	1919.4	14.2	-8.8	-14.7667	0
2022-01-16	2022		1	16	22	7	-11.6	-11	-11.1	1861.4	14.2	-8.5	-14.6333	0
2022-01-16	2022		1	16	23	7	-11.4	-11.6	-9.8	1770.6	14.2	-8.4	-14.375	0
2022-01-16	2022		1	16	24	7	-11.2	-8.5	-8.7	1697.7	14.2	-8.4	-14.0083	0
2022-01-17	2022		1	17	1	1	-10.9	-8.2	-7.4	1647.9	23.0	-8.3	-13.5167	1
2022-01-17	2022		1	17	2	1	-10.6	-8.9	-7	1634.4	23.0	-8.3	-12.95	1
2022-01-17	2022		1	17	3	1	-10.3	-9	-6	1637.6	23.0	-8.4	-12.3	1
2022-01-17	2022		1	17	4	1	-10.1	-11.2	-6.2	1647.9	23.0	-8.6	-11.6667	1
2022-01-17	2022		1	17	5	1	-10.0	-10.7	-7.2	1672.0	23.0	-9.0	-10.9833	1
2022-01-17	2022		1	17	6	1	-9.8	-10.5	-7.8	1729.6	23.0	-9.4	-10.3	1
2022-01-17	2022		1	17	7	1	-9.7	-9.3	-8.7	1849.4	23.0	-9.6	-9.69167	1
2022-01-17	2022		1	17	8	1	-9.5	-9.7	-9.5	1934.8	23.0	-9.8	-9.18333	1
2022-01-17	2022		1	17	9	1	-9.3	-8.8	-11	1957.7	23.0	-9.8	-8.78333	1
2022-01-17	2022		1	17	10	1	-9.1	-6.1	-11.6	1938.1	23.0	-9.8	-8.475	1
2022-01-17	2022		1	17	11	1	-8.9	0.1	-8.5	1910.4	23.0	-9.4	-8.36667	1
2022-01-17	2022		1	17	12	1	-8.4	0.8	-8.2	1897.9	23.0	-8.4	-8.40833	1
2022-01-17	2022		1	17	13	1	-8.0	1.4	-8.9	1907.8	23.0	-7.6	-8.3	1
2022-01-17	2022		1	17	14	1	-7.5	1.9	-9	1874.2	23.0	-6.8	-8.25833	1
2022-01-17	2022		1	17	15	1	-7.2	1.2	-11.2	1836.6	23.0	-5.9	-8.38333	1
2022-01-17	2022		1	17	16	1	-6.8	2.2	-10.7	1836.4	23.0	-5.1	-8.55	1
2022-01-17	2022		1	17	17	1	-6.5	2.9	-10.5	1857.9	23.0	-4.0	-8.98333	1
2022-01-17	2022		1	17	18	1	-6.1	4.2	-9.3	1865.9	23.0	-2.8	-9.35833	1
2022-01-17	2022		1	17	19	1	-5.6	5.2	-9.7	1784.8	23.0	-1.6	-9.63333	1
2022-01-17	2022		1	17	20	1	-5.1	6.4	-8.8	1688.8	23.0	-0.4	-9.75833	1
2022-01-17	2022		1	17	21	1	-4.4	6.5	-6.1	1581.0	23.0	1.0	-9.84167	1
2022-01-17	2022		1	17	22	1	-3.8	6.5	0.1	1485.3	23.0	2.2	-9.78333	1
2022-01-17	2022		1	17	23	1	-3.1	6.3	0.8	1362.7	23.0	3.3	-9.375	1
2022-01-17	2022		1	17	24	1	-2.3	5.7	1.4	1298.1	23.0	3.8	-8.4	1
2022-01-18	2022		1	18	1	2	-1.7	5.6	1.9	1254.4	15.6	4.2	-7.625	1
2022-01-18	2022		1	18	2	2	-1.1	4.9	1.2	1225.3	15.6	4.6	-6.825	1
2022-01-18	2022		1	18	3	2	-0.6	4.5	2.2	1182.8	15.6	4.8	-5.925	1
2022-01-18	2022		1	18	4	2	0.0	4.7	2.9	1155.2	15.6	5.1	-5.075	1
2022-01-18	2022		1	18	5	2	0.7	4.8	4.2	1148.3	15.6	5.3	-3.95833	1
2022-01-18	2022		1	18	6	2	1.3	4.5	5.2	1189.8	15.6	5.4	-2.825	1
2022-01-18	2022		1	18	7	2	1.9	4	6.4	1300.2	15.6	5.5	-1.6	1
2022-01-18	2022		1	18	8	2	2.5	4.1	6.5	1402.9	15.6	5.4	-0.39167	1
2022-01-18	2022		1	18	9	2	3.1	4.7	6.5	1449.3	15.6	5.2	0.95	1
2022-01-18	2022		1	18										

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLag	Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLag	Weekdays	
2022-01-18	2022		1	18	24	2	2.5	-6	4.3	1545.9	15.6	0.3	4.741667	1
2022-01-19	2022		1	19	1	3	2.0	-7.1	4.1	1540.4	17.8	-0.7	4.7	1
2022-01-19	2022		1	19	2	3	1.5	-7.8	3.9	1539.0	17.8	-1.6	4.591667	1
2022-01-19	2022		1	19	3	3	1.0	-9.3	2.3	1546.3	17.8	-2.6	4.525	1
2022-01-19	2022		1	19	4	3	0.4	-10.2	0.5	1564.4	17.8	-3.7	4.475	1
2022-01-19	2022		1	19	5	3	-0.2	-10.8	-0.6	1602.0	17.8	-4.8	4.275	1
2022-01-19	2022		1	19	6	3	-0.9	-11.2	-2.1	1668.3	17.8	-5.7	3.916667	1
2022-01-19	2022		1	19	7	3	-1.6	-11.7	-2.4	1802.5	17.8	-6.6	3.491667	1
2022-01-19	2022		1	19	8	3	-2.2	-11.7	-3	1929.0	17.8	-7.4	2.983333	1
2022-01-19	2022		1	19	9	3	-2.9	-11.7	-4.2	1966.3	17.8	-8.2	2.441667	1
2022-01-19	2022		1	19	10	3	-3.5	-10.8	-5	1917.4	17.8	-8.9	1.8	1
2022-01-19	2022		1	19	11	3	-4.2	-9.2	-6	1861.5	17.8	-9.4	1.091667	1
2022-01-19	2022		1	19	12	3	-4.8	-8.3	-7.1	1818.0	17.8	-9.8	0.25	1
2022-01-19	2022		1	19	13	3	-5.3	-6.2	-7.8	1781.7	17.8	-10.0	-0.68333	1
2022-01-19	2022		1	19	14	3	-5.8	-4.8	-9.3	1740.9	17.8	-9.9	-1.63333	1
2022-01-19	2022		1	19	15	3	-6.1	-4.5	-10.2	1735.6	17.8	-9.7	-2.625	1
2022-01-19	2022		1	19	16	3	-6.5	-4.4	-10.8	1750.9	17.8	-9.3	-3.725	1
2022-01-19	2022		1	19	17	3	-6.8	-4.1	-11.2	1811.4	17.8	-8.8	-4.76667	1
2022-01-19	2022		1	19	18	3	-7.0	-3.5	-11.7	1878.6	17.8	-8.2	-5.70833	1
2022-01-19	2022		1	19	19	3	-7.1	-1.1	-11.7	1828.0	17.8	-7.6	-6.59167	1
2022-01-19	2022		1	19	20	3	-7.0	0.5	-11.7	1761.9	17.8	-6.7	-7.39167	1
2022-01-19	2022		1	19	21	3	-6.9	1.8	-10.8	1691.7	17.8	-5.7	-8.16667	1
2022-01-19	2022		1	19	22	3	-6.7	2.4	-9.2	1593.7	17.8	-4.6	-8.89167	1
2022-01-19	2022		1	19	23	3	-6.4	2.9	-8.3	1474.5	17.8	-3.5	-9.44167	1
2022-01-19	2022		1	19	24	3	-6.1	3.4	-6.2	1409.8	17.8	-2.4	-9.79167	1
2022-01-20	2022		1	20	1	4	-5.7	4.9	-4.8	1357.3	12.9	-1.5	-9.98333	1
2022-01-20	2022		1	20	2	4	-5.2	5.8	-4.5	1301.3	12.9	-0.5	-9.90833	1
2022-01-20	2022		1	20	3	4	-4.7	5.9	-4.4	1252.0	12.9	0.3	-9.65833	1
2022-01-20	2022		1	20	4	4	-4.0	5.6	-4.1	1224.5	12.9	1.2	-9.25833	1
2022-01-20	2022		1	20	5	4	-3.4	5.2	-3.5	1216.2	12.9	2.0	-8.775	1
2022-01-20	2022		1	20	6	4	-2.7	5	-1.1	1245.9	12.9	2.8	-8.21667	1
2022-01-20	2022		1	20	7	4	-2.0	4.9	0.5	1353.8	12.9	3.5	-7.575	1
2022-01-20	2022		1	20	8	4	-1.3	4.8	1.8	1456.3	12.9	4.0	-6.69167	1
2022-01-20	2022		1	20	9	4	-0.6	4.5	2.4	1491.1	12.9	4.4	-5.675	1
2022-01-20	2022		1	20	10	4	0.0	5	2.9	1497.3	12.9	4.6	-4.55	1
2022-01-20	2022		1	20	11	4	0.7	5.2	3.4	1500.2	12.9	4.8	-3.45	1
2022-01-20	2022		1	20	12	4	1.3	5.1	4.9	1519.2	12.9	5.0	-2.44167	1
2022-01-20	2022		1	20	13	4	1.8	4.6	5.8	1549.5	12.9	5.2	-1.46667	1
2022-01-20	2022		1	20	14	4	2.3	4.4	5.9	1555.8	12.9	5.1	-0.54167	1
2022-01-20	2022		1	20	15	4	2.7	4	5.6	1565.4	12.9	5.0	0.341667	1
2022-01-20	2022		1	20	16	4	3.0	1.1	5.2	1584.2	12.9	4.9	1.208333	1
2022-01-20	2022		1	20	17	4	3.3	0.7	5	1642.8	12.9	4.5	2.041667	1
2022-01-20	2022		1	20	18	4	3.5	0.5	4.9	1716.1	12.9	4.1	2.816667	1
2022-01-20	2022		1	20	19	4	3.6	0	4.8	1693.9	12.9	3.7	3.525	1
2022-01-20	2022		1	20	20	4	3.7	-0.6	4.5	1658.2	12.9	3.3	4.025	1
2022-01-20	2022		1	20	21	4	3.6	-1	5	1614.5	12.9	2.9	4.383333	1
2022-01-20	2022		1	20	22	4	3.5	-2	5.2	1557.2	12.9	2.4	4.608333	1
2022-01-20	2022		1	20	23	4	3.3	-2.6	5.1	1487.1	12.9	1.8	4.825	1
2022-01-20	2022		1	20	24	4	3.1	-3.1	4.6	1478.2	12.9	1.2	5.016667	1
2022-01-21	2022		1	21	1	5	2.8	-4.2	4.4	1474.8	17.2	0.5	5.158333	1
2022-01-21	2022		1	21	2	5	2.5	-5.1	4	1466.0	17.2	-0.2	5.133333	1
2022-01-21	2022		1	21	3	5	2.0	-6.9	1.1	1468.4	17.2	-1.0	5.016667	1
2022-01-21	2022		1	21	4	5	1.5	-9	0.7	1489.8	17.2	-1.9	4.858333	1
2022-01-21	2022		1	21	5	5	0.9	-10.5	0.5	1527.7	17.2	-2.8	4.483333	1
2022-01-21	2022		1	21	6	5	0.2	-11.6	0	1594.6	17.2	-3.7	4.108333	1
2022-01-21	2022		1	21	7	5	-0.5	-12	-0.6	1739.0	17.2	-4.7	3.733333	1
2022-01-21	2022		1	21	8	5	-1.2	-12.2	-1	1858.9	17.2	-5.7	3.325	1
2022-01-21	2022		1	21	9	5	-1.9	-13.1	-2	1930.9	17.2	-6.7	2.875	1
2022-01-21	2022		1	21	10	5	-2.6	-13.2	-2.6	1937.7	17.2	-7.7	2.416667	1
2022-01-21	2022		1	21	11	5	-3.4	-13	-3.1	1906.7	17.2	-8.6	1.833333	1
2022-01-21	2022		1	21	12	5	-4.2	-12.1	-4.2	1861.2	17.2	-9.5	1.183333	1
2022-01-21	2022		1	21	13	5	-4.9	-10.4	-5.1	1845.7	17.2	-10.2	0.5	1
2022-01-21	2022		1	21	14	5	-5.5	-10.1	-6.9	1788.5	17.2	-10.8	-0.23333	1
2022-01-21	2022		1	21	15	5	-6.1	-9.6	-9	1755.5	17.2	-11.2	-1.025	1
2022-01-21	2022		1	21	16	5	-6.7	-9.5	-10.5	1777.6	17.2	-11.4	-1.93333	1
2022-01-21	2022		1	21	17	5	-7.1	-9.9	-11.6	1849.9	17.2	-11.4	-2.775	1
2022-01-21	2022		1	21	18	5	-7.6	-11.2	-12	1969.1	17.2	-11.4	-3.70833	1
2022-01-21	2022		1	21	19	5	-8.0	-12	-12.2	1974.7	17.2	-11.4	-4.71667	1
2022-01-21	2022		1	21	20	5	-8.5	-12.6	-13.1	1950.0	17.2	-11.4	-5.71667	1
2022-01-21	2022		1	21	21	5	-9.0	-13.3	-13.2	1904.6	17.2	-11.4	-6.68333	1
2022-01-21	2022		1	21	22	5	-9.6	-13.8	-13	1860.6	17.2	-11.4	-7.69167	1
2022-01-21	2022		1	21	23	5	-10.0	-14.3	-12.1	1792.8	17.2	-11.5	-8.625	1
2022-01-21	2022		1	21	24	5	-10.5	-14.6	-10.4	1785.0	17.2	-11.6	-9.49167	1
2022-01-22	2022		1	22	1	6	-11.0	-14.7	-10.1	1775.0	12.5	-11.8	-10.2417	0
2022-01-22	2022		1	22	2	6	-11.4	-14.6	-9.6	1749.6	12.5	-12.1	-10.7583	0
2022-01-22	2022		1	22	3	6	-11.8	-14	-9.5	1735.5	12.5	-12.5	-11.175	0
2022-01-22	2022		1	22	4	6	-12.1	-13.6	-9.9	1730.9	12.5	-12.9	-11.4	0
2022-01-22	2022		1	22	5	6	-12.3	-13.3	-11.2	1735.3	12.5	-13.2	-11.4417	0
2022-01-22	2022		1	22	6	6	-12.4	-12.6	-12	1759.9	12.5	-13.5	-11.3917	0
2022-01-22	2022		1	22	7	6	-12.5	-12.7	-12.6	1816.8	12.5	-13.6	-11.3583	0
2022-01-22	2022		1	22	8	6	-12.5	-12.7	-13.3	1887.4	12.5	-13.7	-11.3583	0
2022-01-22	2022		1	22	9	6	-12.5	-12.9	-13.8	1966.1	12.5	-13.7	-11.3917	0
2022-01-22	2022		1	22	10	6	-12.5	-11.8	-14.3	2018.8	12.5	-13.7	-11.4083	0
2022-01-22	2022		1	22	11	6	-12.5	-10.8	-14.6	2030.2	12.5	-13.5	-11.4583	0
2022-01-22	2022		1	22	12	6	-12.4	-9.4	-14.7	2001.0	12.5	-13.2	-11.5667	0
2022-01-22	2022		1	22	13	6	-12.3	-7.6	-14.6	1971.4	12.5	-12.8	-11.775	0
2022-01-22	2022		1	22	14	6	-12.2	-7.1	-14	1915.0	12.5	-12.2	-12.1333	0
2022-01-22	2022		1	22	15	6	-12.0	-6.9	-13.6	1888.1	12.5	-11.5	-12.5083	0
2022-01-22	2022		1	22	16	6	-11.9	-6.7	-13.3	1882.8	12.5	-11.0	-12.875	0
2022-01-22	2022		1	22	17	6	-11.8	-6.9	-12.6	1927.8	12.5	-10.4	-13.2167	0
2022-01-22	2022		1	22	18	6	-11.7	-7.3	-12.7	1990.5	12.5	-9.8	-13.5	0
2022-01-22	2022		1	22	19	6	-11.5	-7.1	-12.7	1953.6	12.5	-9.4	-13.6167	0
2022-01-22	2022		1	22	20	6	-11.3	-7.4	-12.9	1897.2	12.5	-8.9	-13.675	0
2022-01-22	2022		1	22	21	6	-11.1	-7.4	-11.8	1829.5	12.5	-8.5	-13.6833	0
2022-01-22</														

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLag	Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLag	Weekdays	
2022-01-23	2022		1	23	12	7	-7.0	-0.9	-8.5	1662.2	12.5	-6.6	-7.39167	0
2022-01-23	2022		1	23	13	7	-6.7	0	-8.1	1619.9	12.5	-6.1	-7.24167	0
2022-01-23	2022		1	23	14	7	-6.3	0.7	-7.5	1563.7	12.5	-5.4	-7.31667	0
2022-01-23	2022		1	23	15	7	-6.0	0.7	-7	1561.7	12.5	-4.6	-7.4	0
2022-01-23	2022		1	23	16	7	-5.7	0.5	-6.6	1606.6	12.5	-3.9	-7.45	0
2022-01-23	2022		1	23	17	7	-5.4	0.8	-6.5	1688.6	12.5	-3.3	-7.475	0
2022-01-23	2022		1	23	18	7	-5.1	0.8	-6.4	1764.4	12.5	-2.7	-7.45	0
2022-01-23	2022		1	23	19	7	-4.7	1	-6.2	1729.9	12.5	-2.1	-7.38333	0
2022-01-23	2022		1	23	20	7	-4.4	1.3	-6.8	1682.6	12.5	-1.5	-7.325	0
2022-01-23	2022		1	23	21	7	-4.0	1.5	-5	1623.4	12.5	-0.9	-7.225	0
2022-01-23	2022		1	23	22	7	-3.7	0.4	-3.3	1549.1	12.5	-0.2	-7.175	0
2022-01-23	2022		1	23	23	7	-3.3	0.7	-0.9	1445.3	12.5	0.3	-6.98333	0
2022-01-23	2022		1	23	24	7	-3.0	0.5	0	1367.5	12.5	0.6	-6.625	0
2022-01-24	2022		1	24	1	1	-2.7	0.5	0.7	1319.0	11.3	0.7	-6.06667	1
2022-01-24	2022		1	24	2	1	-2.3	0.4	0.7	1308.4	11.3	0.8	-5.35833	1
2022-01-24	2022		1	24	3	1	-1.9	0.3	0.5	1295.6	11.3	0.8	-4.625	1
2022-01-24	2022		1	24	4	1	-1.6	0.3	0.8	1303.5	11.3	0.7	-3.94167	1
2022-01-24	2022		1	24	5	1	-1.3	-0.2	0.8	1337.7	11.3	0.7	-3.31667	1
2022-01-24	2022		1	24	6	1	-1.0	-2.3	1	1396.3	11.3	0.6	-2.7	1
2022-01-24	2022		1	24	7	1	-0.9	-2.9	1.3	1529.6	11.3	0.4	-2.09167	1
2022-01-24	2022		1	24	8	1	-0.7	-3.3	1.5	1656.6	11.3	0.0	-1.475	1
2022-01-24	2022		1	24	9	1	-0.6	-3.4	0.4	1713.8	11.3	-0.3	-0.85	1
2022-01-24	2022		1	24	10	1	-0.5	-3.4	0.7	1732.2	11.3	-0.8	-0.15833	1
2022-01-24	2022		1	24	11	1	-0.4	-3.4	0.5	1738.0	11.3	-1.1	0.291667	1
2022-01-24	2022		1	24	12	1	-0.4	-3.2	0.5	1728.1	11.3	-1.4	0.625	1
2022-01-24	2022		1	24	13	1	-0.5	-3.5	0.4	1720.0	11.3	-1.7	0.741667	1
2022-01-24	2022		1	24	14	1	-0.6	-3.1	0.3	1676.1	11.3	-2.1	0.783333	1
2022-01-24	2022		1	24	15	1	-0.8	-2.4	0.3	1643.6	11.3	-2.3	0.758333	1
2022-01-24	2022		1	24	16	1	-0.9	-1.8	-0.2	1660.1	11.3	-2.6	0.725	1
2022-01-24	2022		1	24	17	1	-1.0	-2.6	-2.3	1716.9	11.3	-2.7	0.708333	1
2022-01-24	2022		1	24	18	1	-1.2	-3.1	-2.9	1806.9	11.3	-2.9	0.625	1
2022-01-24	2022		1	24	19	1	-1.3	-3.9	-3.3	1789.3	11.3	-3.0	0.366667	1
2022-01-24	2022		1	24	20	1	-1.5	-4.4	-3.4	1759.8	11.3	-3.1	0.041667	1
2022-01-24	2022		1	24	21	1	-1.8	-4.8	-3.4	1714.5	11.3	-3.2	-0.34167	1
2022-01-24	2022		1	24	22	1	-2.0	-5.6	-3.4	1660.0	11.3	-3.3	-0.75	1
2022-01-24	2022		1	24	23	1	-2.3	-7.1	-3.2	1587.0	11.3	-3.5	-1.06667	1
2022-01-24	2022		1	24	24	1	-2.6	-7.7	-3.5	1582.8	11.3	-3.8	-1.40833	1
2022-01-25	2022		1	25	1	2	-2.9	-8.2	-3.1	1577.1	13.5	-4.2	-1.71667	1
2022-01-25	2022		1	25	2	2	-3.3	-8	-2.4	1555.4	13.5	-4.6	-2.05	1
2022-01-25	2022		1	25	3	2	-3.7	-8.2	-1.8	1528.3	13.5	-5.0	-2.34167	1
2022-01-25	2022		1	25	4	2	-4.0	-7.2	-2.6	1520.8	13.5	-5.5	-2.56667	1
2022-01-25	2022		1	25	5	2	-4.3	-6.5	-3.1	1527.6	13.5	-5.9	-2.74167	1
2022-01-25	2022		1	25	6	2	-4.6	-6.5	-3.9	1564.9	13.5	-6.2	-2.94167	1
2022-01-25	2022		1	25	7	2	-4.8	-5.5	-4.4	1672.0	13.5	-6.5	-3.00833	1
2022-01-25	2022		1	25	8	2	-4.9	-4.5	-4.8	1766.1	13.5	-6.6	-3.09167	1
2022-01-25	2022		1	25	9	2	-4.9	-1.7	-5.6	1786.7	13.5	-6.7	-3.18333	1
2022-01-25	2022		1	25	10	2	-4.8	0	-7.1	1758.3	13.5	-6.4	-3.3	1
2022-01-25	2022		1	25	11	2	-4.7	0.6	-7.7	1722.9	13.5	-5.9	-3.48333	1
2022-01-25	2022		1	25	12	2	-4.5	1.3	-8.2	1709.7	13.5	-5.3	-3.79167	1
2022-01-25	2022		1	25	13	2	-4.4	1.4	-8	1726.8	13.5	-4.5	-4.16667	1
2022-01-25	2022		1	25	14	2	-4.1	2.1	-8.2	1705.4	13.5	-3.7	-4.55833	1
2022-01-25	2022		1	25	15	2	-3.9	1.8	-7.2	1682.7	13.5	-2.9	-4.96667	1
2022-01-25	2022		1	25	16	2	-3.8	2.6	-6.5	1674.3	13.5	-2.1	-5.45	1
2022-01-25	2022		1	25	17	2	-3.6	3.2	-6.5	1691.3	13.5	-1.2	-5.9	1
2022-01-25	2022		1	25	18	2	-3.3	3.5	-5.5	1730.0	13.5	-0.4	-6.225	1
2022-01-25	2022		1	25	19	2	-3.1	3.5	-4.5	1687.4	13.5	0.4	-6.50833	1
2022-01-25	2022		1	25	20	2	-2.7	3.1	-1.7	1629.6	13.5	1.2	-6.64167	1
2022-01-25	2022		1	25	21	2	-2.4	2.9	0	1558.9	13.5	1.8	-6.65	1
2022-01-25	2022		1	25	22	2	-2.1	2.7	0.6	1480.9	13.5	2.2	-6.39167	1
2022-01-25	2022		1	25	23	2	-1.8	3	1.3	1386.6	13.5	2.4	-5.925	1
2022-01-25	2022		1	25	24	2	-1.3	2.8	1.4	1353.9	13.5	2.6	-5.28333	1
2022-01-26	2022		1	26	1	3	-0.9	2.3	2.1	1336.6	13.4	2.7	-4.53333	1
2022-01-26	2022		1	26	2	3	-0.5	0.9	1.8	1326.3	13.4	2.8	-3.73333	1
2022-01-26	2022		1	26	3	3	-0.1	-0.4	2.6	1321.4	13.4	2.7	-2.89167	1
2022-01-26	2022		1	26	4	3	0.2	-1.5	3.2	1332.0	13.4	2.5	-2.05833	1
2022-01-26	2022		1	26	5	3	0.5	-2.4	3.5	1361.3	13.4	2.2	-1.24167	1
2022-01-26	2022		1	26	6	3	0.6	-3.1	3.5	1433.4	13.4	1.7	-0.43333	1
2022-01-26	2022		1	26	7	3	0.8	-4	3.1	1575.5	13.4	1.2	0.4	1
2022-01-26	2022		1	26	8	3	0.8	-5.2	2.9	1702.4	13.4	0.5	1.15	1
2022-01-26	2022		1	26	9	3	0.8	-6	2.7	1748.4	13.4	-0.2	1.783333	1
2022-01-26	2022		1	26	10	3	0.6	-5.1	3	1712.0	13.4	-0.9	2.166667	1
2022-01-26	2022		1	26	11	3	0.4	-3.4	2.8	1678.9	13.4	-1.6	2.391667	1
2022-01-26	2022		1	26	12	3	0.3	-2.5	2.3	1642.6	13.4	-2.1	2.591667	1
2022-01-26	2022		1	26	13	3	0.1	-1.4	0.9	1629.0	13.4	-2.5	2.716667	1
2022-01-26	2022		1	26	14	3	0.0	-1.3	-0.4	1598.1	13.4	-2.8	2.791667	1
2022-01-26	2022		1	26	15	3	-0.2	-2.2	-1.5	1585.1	13.4	-3.0	2.691667	1
2022-01-26	2022		1	26	16	3	-0.3	-2.4	-2.4	1608.5	13.4	-3.2	2.508333	1
2022-01-26	2022		1	26	17	3	-0.5	-2.9	-3.1	1691.4	13.4	-3.3	2.166667	1
2022-01-26	2022		1	26	18	3	-0.8	-3.4	-4	1812.0	13.4	-3.3	1.7	1
2022-01-26	2022		1	26	19	3	-1.1	-4.3	-5.2	1829.3	13.4	-3.3	1.15	1
2022-01-26	2022		1	26	20	3	-1.4	-6.8	-6	1823.2	13.4	-3.3	0.525	1
2022-01-26	2022		1	26	21	3	-1.8	-9	-5.1	1794.5	13.4	-3.5	-0.16667	1
2022-01-26	2022		1	26	22	3	-2.3	-10.3	-3.4	1749.9	13.4	-3.7	-0.90833	1
2022-01-26	2022		1	26	23	3	-2.9	-11.2	-2.5	1675.9	13.4	-4.2	-1.55833	1
2022-01-26	2022		1	26	24	3	-3.5	-12	-1.4	1674.0	13.4	-4.8	-2.09167	1
2022-01-27	2022		1	27	1	4	-4.1	-12.7	-1.3	1667.8	11.8	-5.6	-2.53333	1
2022-01-27	2022		1	27	2	4	-4.7	-13.5	-2.2	1664.6	11.8	-6.5	-2.84167	1
2022-01-27	2022		1	27	3	4	-5.3	-14.6	-2.4	1668.2	11.8	-7.6	-3.025	1
2022-01-27	2022		1	27	4	4	-5.9	-15.8	-2.9	1685.4	11.8	-8.6	-3.175	1
2022-01-27	2022		1	27	5	4	-6.5	-16.3	-3.4	1720.1	11.8	-9.7	-3.25	1
2022-01-27	2022		1	27	6	4	-7.1	-16.7	-4.3	1795.6	11.8	-10.8	-3.29167	1
2022-01-27	2022		1	27	7	4	-7.6	-16.9	-6.8	1932.8	11.8	-11.9	-3.31667	1
2022-01-27	2022		1	27	8	4	-8.2	-17.1	-9	2019.7	11.8	-13.0	-3.34167	1
2022-01-27	2022		1	27	9	4	-8.7	-16.9	-10.3	2029.4	11.8	-13.8	-3.475	1
2022-01-27	2022		1	27	10	4	-9.1	-15.7	-11.2	1976.8	11.8	-14.5	-3.725	1
202														

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLag	Temp	LagTemp12	Load	Wind	12hrAvg	12hrAvgLag	Weekdays	
2022-01-27	2022		1	27	24	4	-11.9	-7.4	-10.3	1732.6	11.8	-8.7	-15.1583	1
2022-01-28	2022		1	28	1	5	-11.7	-7	-8.7	1704.7	13.9	-8.3	-15.1667	1
2022-01-28	2022		1	28	2	5	-11.5	-6.4	-7.6	1664.3	13.9	-8.0	-14.9667	1
2022-01-28	2022		1	28	3	5	-11.2	-7.3	-7.2	1627.9	13.9	-7.8	-14.5667	1
2022-01-28	2022		1	28	4	5	-10.9	-7.5	-7.1	1609.6	13.9	-7.8	-13.9833	1
2022-01-28	2022		1	28	5	5	-10.5	-7.5	-7.8	1599.1	13.9	-7.8	-13.2667	1
2022-01-28	2022		1	28	6	5	-10.2	-7.2	-8.8	1625.6	13.9	-7.9	-12.5	1
2022-01-28	2022		1	28	7	5	-9.8	-6.7	-9.1	1717.9	13.9	-7.8	-11.7583	1
2022-01-28	2022		1	28	8	5	-9.4	-7	-9.2	1786.9	13.9	-7.6	-11.0833	1
2022-01-28	2022		1	28	9	5	-8.9	-2.5	-8.2	1817.7	13.9	-7.5	-10.4167	1
2022-01-28	2022		1	28	10	5	-8.3	-1.6	-8	1808.9	13.9	-6.9	-9.775	1
2022-01-28	2022		1	28	11	5	-7.7	-0.7	-7.4	1788.6	13.9	-6.3	-9.15	1
2022-01-28	2022		1	28	12	5	-7.2	-0.3	-7	1772.8	13.9	-5.7	-8.675	1
2022-01-28	2022		1	28	13	5	-6.7	0.1	-6.4	1763.3	13.9	-5.1	-8.28333	1
2022-01-28	2022		1	28	14	5	-6.3	0.9	-7.3	1702.4	13.9	-4.6	-8.00833	1
2022-01-28	2022		1	28	15	5	-5.9	1.4	-7.5	1670.6	13.9	-3.9	-7.81667	1
2022-01-28	2022		1	28	16	5	-5.5	1.5	-7.5	1661.6	13.9	-3.2	-7.79167	1
2022-01-28	2022		1	28	17	5	-5.1	0.8	-7.2	1678.3	13.9	-2.5	-7.81667	1
2022-01-28	2022		1	28	18	5	-4.8	1.6	-6.7	1728.8	13.9	-1.8	-7.85	1
2022-01-28	2022		1	28	19	5	-4.4	1.8	-7	1700.6	13.9	-1.0	-7.8	1
2022-01-28	2022		1	28	20	5	-4.0	1.9	-2.5	1642.4	13.9	-0.3	-7.625	1
2022-01-28	2022		1	28	21	5	-3.5	2.3	-1.6	1577.9	13.9	0.4	-7.45	1
2022-01-28	2022		1	28	22	5	-3.0	2.3	-0.7	1518.1	13.9	0.8	-6.89167	1
2022-01-28	2022		1	28	23	5	-2.6	1.9	-0.3	1441.4	13.9	1.1	-6.34167	1
2022-01-28	2022		1	28	24	5	-2.2	1	0.1	1427.4	13.9	1.4	-5.73333	1
2022-01-29	2022		1	29	1	6	-1.8	-0.6	0.9	1398.8	21.6	1.5	-5.14167	0
2022-01-29	2022		1	29	2	6	-1.6	-1.1	1.4	1376.2	21.6	1.4	-4.55	0
2022-01-29	2022		1	29	3	6	-1.4	-1.3	1.5	1351.4	21.6	1.2	-3.94167	0
2022-01-29	2022		1	29	4	6	-1.1	-2.4	0.8	1341.5	21.6	1.0	-3.21667	0
2022-01-29	2022		1	29	5	6	-0.9	-2.6	1.6	1347.3	21.6	0.7	-2.46667	0
2022-01-29	2022		1	29	6	6	-0.7	-2.7	1.8	1381.8	21.6	0.4	-1.775	0
2022-01-29	2022		1	29	7	6	-0.5	-3.1	1.9	1445.3	21.6	0.0	-1.04167	0
2022-01-29	2022		1	29	8	6	-0.4	-3.7	2.3	1534.4	21.6	-0.4	-0.33333	0
2022-01-29	2022		1	29	9	6	-0.2	-3.8	2.3	1626.0	21.6	-0.8	0.408333	0
2022-01-29	2022		1	29	10	6	-0.3	-3.4	1.9	1700.0	21.6	-1.3	0.808333	0
2022-01-29	2022		1	29	11	6	-0.3	-2.7	1	1761.3	21.6	-1.8	1.133333	0
2022-01-29	2022		1	29	12	6	-0.4	-2.3	-0.6	1814.5	21.6	-2.2	1.35	0
2022-01-29	2022		1	29	13	6	-0.5	-2	-1.1	1832.6	21.6	-2.5	1.458333	0
2022-01-29	2022		1	29	14	6	-0.6	-1.3	-1.3	1812.2	21.6	-2.6	1.4	0
2022-01-29	2022		1	29	15	6	-0.7	0.4	-2.4	1768.0	21.6	-2.6	1.233333	0
2022-01-29	2022		1	29	16	6	-0.7	1.2	-2.6	1731.4	21.6	-2.5	1.008333	0
2022-01-29	2022		1	29	17	6	-0.7	2	-2.7	1727.4	21.6	-2.2	0.683333	0
2022-01-29	2022		1	29	18	6	-0.7	1.5	-3.1	1767.0	21.6	-1.8	0.4	0
2022-01-29	2022		1	29	19	6	-0.7	1.1	-3.7	1719.9	21.6	-1.4	0.041667	0
2022-01-29	2022		1	29	20	6	-0.7	0.6	-3.8	1640.7	21.6	-1.1	-0.36667	0
2022-01-29	2022		1	29	21	6	-0.8	0.1	-3.4	1563.5	21.6	-0.7	-0.83333	0
2022-01-29	2022		1	29	22	6	-0.9	0.2	-2.7	1481.7	21.6	-0.4	-1.34167	0
2022-01-29	2022		1	29	23	6	-1.0	0.4	-2.3	1402.9	21.6	-0.1	-1.81667	0
2022-01-29	2022		1	29	24	6	-1.0	0.5	-2	1334.1	21.6	0.2	-2.2	0
2022-01-30	2022		1	30	1	7	-1.0	1	-1.3	1267.6	26.4	0.4	-2.475	0
2022-01-30	2022		1	30	2	7	-1.0	1.4	0.4	1224.5	26.4	0.6	-2.59167	0
2022-01-30	2022		1	30	3	7	-0.9	3.5	1.2	1201.0	26.4	0.9	-2.60833	0
2022-01-30	2022		1	30	4	7	-0.7	2.3	2	1212.1	26.4	1.1	-2.46667	0
2022-01-30	2022		1	30	5	7	-0.5	0.3	1.5	1270.5	26.4	1.2	-2.16667	0
2022-01-30	2022		1	30	6	7	-0.4	-1.2	1.1	1324.0	26.4	1.1	-1.78333	0
2022-01-30	2022		1	30	7	7	-0.3	-1.6	0.6	1370.7	26.4	0.9	-1.43333	0
2022-01-30	2022		1	30	8	7	-0.2	-2	0.1	1424.3	26.4	0.6	-1.08333	0
2022-01-30	2022		1	30	9	7	-0.2	-1.8	0.2	1527.3	26.4	0.4	-0.725	0
2022-01-30	2022		1	30	10	7	-0.1	-3.6	0.4	1621.0	26.4	0.3	-0.4	0
2022-01-30	2022		1	30	11	7	-0.1	-4.7	0.5	1689.9	26.4	-0.1	-0.1	0
2022-01-30	2022		1	30	12	7	-0.2	-4.5	1	1730.5	26.4	-0.5	0.158333	0
2022-01-30	2022		1	30	13	7	-0.3	-4.4	1.4	1708.1	26.4	-0.9	0.391667	0
2022-01-30	2022		1	30	14	7	-0.4	-4	3.5	1663.4	26.4	-1.4	0.641667	0
2022-01-30	2022		1	30	15	7	-0.5	-4.5	2.3	1640.1	26.4	-1.8	0.866667	0
2022-01-30	2022		1	30	16	7	-0.7	-4.3	0.3	1657.7	26.4	-2.5	1.125	0
2022-01-30	2022		1	30	17	7	-0.9	-4.7	-1.2	1718.6	26.4	-3.0	1.216667	0
2022-01-30	2022		1	30	18	7	-1.2	-4.8	-1.6	1827.5	26.4	-3.4	1.075	0
2022-01-30	2022		1	30	19	7	-1.4	-5.6	-2	1819.3	26.4	-3.7	0.85	0
2022-01-30	2022		1	30	20	7	-1.7	-5.2	-1.8	1781.4	26.4	-4.1	0.625	0
2022-01-30	2022		1	30	21	7	-2.0	-4.3	-3.6	1723.5	26.4	-4.3	0.408333	0
2022-01-30	2022		1	30	22	7	-2.2	-4.1	-4.7	1655.5	26.4	-4.6	0.25	0
2022-01-30	2022		1	30	23	7	-2.3	-4.2	-4.5	1564.1	26.4	-4.6	-0.06667	0
2022-01-30	2022		1	30	24	7	-2.5	-4.6	-4.4	1494.2	26.4	-4.6	-0.49167	0
2022-01-31	2022		1	31	1	1	-2.7	-5.3	-4	1456.0	10.4	-4.6	-0.90833	1
2022-01-31	2022		1	31	2	1	-3.0	-6.2	-4.5	1444.4	10.4	-4.6	-1.35833	1
2022-01-31	2022		1	31	3	1	-3.3	-6.9	-4.3	1460.0	10.4	-4.8	-1.80833	1
2022-01-31	2022		1	31	4	1	-3.7	-7.6	-4.7	1485.8	10.4	-5.0	-2.475	1
2022-01-31	2022		1	31	5	1	-4.2	-8	-4.8	1523.1	10.4	-5.3	-3.025	1
2022-01-31	2022		1	31	6	1	-4.5	-8.8	-5.6	1597.9	10.4	-5.6	-3.44167	1
2022-01-31	2022		1	31	7	1	-4.8	-9.1	-5.2	1739.4	10.4	-5.9	-3.74167	1
2022-01-31	2022		1	31	8	1	-5.1	-9.4	-4.3	1867.4	10.4	-6.2	-4.075	1
2022-01-31	2022		1	31	9	1	-5.4	-9.7	-4.1	1896.4	10.4	-6.5	-4.34167	1
2022-01-31	2022		1	31	10	1	-5.8	-8.7	-4.2	1822.5	10.4	-7.0	-4.55	1
2022-01-31	2022		1	31	11	1	-6.0	-7.7	-4.6	1762.3	10.4	-7.4	-4.59167	1
2022-01-31	2022		1	31	12	1	-6.1	-6.8	-5.3	1709.9	10.4	-7.7	-4.55	1
2022-01-31	2022		1	31	13	1	-6.2	-5.3	-6.2	1688.2	10.4	-7.9	-4.55833	1
2022-01-31	2022		1	31	14	1	-6.2	-4.9	-6.9	1638.3	10.4	-7.9	-4.63333	1
2022-01-31	2022		1	31	15	1	-6.3	-4.3	-7.6	1596.8	10.4	-7.7	-4.81667	1
2022-01-31	2022		1	31	16	1	-6.3	-3.9	-8	1604.5	10.4	-7.5	-5.01667	1
2022-01-31	2022		1	31	17	1	-6.3	-3.9	-8.8	1677.3	10.4	-7.2	-5.29167	1
2022-01-31	2022		1	31	18	1	-6.2	-4.3	-9.1	1808.0	10.4	-6.9	-5.56667	1
2022-01-31	2022		1	31	19	1	-6.2	-5	-9.4	1842.3	10.4	-6.5	-5.9	1
2022-01-31	2022		1	31	20	1	-6.2	-5.4	-9.7	1835.8	10.4	-6.2	-6.19167	1
2022-01-31	2022		1	31	21	1	-6.2	-5.8	-8.7	1792.6	10.4	-5.8	-6.54167	1
2022-01-31	2022		1	31	22	1	-6.2	-6.3	-7.7	1736.4	10.4	-5.5	-6.99167	1
2022-01-31														

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLag	Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLag	Weekdays	
2022-02-01	2022	2	1	12	12	2	-7.9	-8.8	-8	1782.4	9.5	-10.5	-5.25	1
2022-02-01	2022	2	1	13	13	2	-7.9	-8.3	-9.1	1753.3	9.5	-10.6	-5.3	1
2022-02-01	2022	2	1	14	14	2	-8.1	-6.9	-10	1693.7	9.5	-10.6	-5.525	1
2022-02-01	2022	2	1	15	15	2	-8.2	-6.5	-11.1	1647.4	9.5	-10.4	-5.875	1
2022-02-01	2022	2	1	16	16	2	-8.2	-5.9	-11.7	1646.0	9.5	-10.1	-6.35	1
2022-02-01	2022	2	1	17	17	2	-8.3	-5.9	-12.3	1710.9	9.5	-9.7	-6.95	1
2022-02-01	2022	2	1	18	18	2	-8.4	-6.7	-10.4	1834.6	9.5	-9.2	-7.6	1
2022-02-01	2022	2	1	19	19	2	-8.5	-8.3	-11.9	1887.2	9.5	-8.8	-8.26667	1
2022-02-01	2022	2	1	20	20	2	-8.6	-9	-12.4	1885.7	9.5	-8.6	-8.71667	1
2022-02-01	2022	2	1	21	21	2	-8.8	-9.5	-11.4	1857.8	9.5	-8.3	-9.25833	1
2022-02-01	2022	2	1	22	22	2	-9.0	-10.1	-9.9	1806.8	9.5	-8.1	-9.80833	1
2022-02-01	2022	2	1	23	23	2	-9.1	-10.6	-8.8	1741.7	9.5	-8.0	-10.2333	1
2022-02-01	2022	2	1	24	24	2	-9.3	-11.2	-8.3	1739.2	9.5	-8.0	-10.4667	1
2022-02-02	2022	2	2	1	3	3	-9.4	-11.4	-6.9	1735.2	10.8	-8.2	-10.5833	1
2022-02-02	2022	2	2	2	3	3	-9.6	-11.3	-6.5	1729.7	10.8	-8.5	-10.6083	1
2022-02-02	2022	2	2	3	3	3	-9.6	-11.3	-5.9	1728.0	10.8	-8.9	-10.425	1
2022-02-02	2022	2	2	4	3	3	-9.7	-10.5	-5.9	1736.2	10.8	-9.3	-10.1333	1
2022-02-02	2022	2	2	5	3	3	-9.7	-11.6	-6.7	1757.6	10.8	-9.7	-9.7	1
2022-02-02	2022	2	2	6	3	3	-9.7	-13.6	-8.3	1809.0	10.8	-10.1	-9.21667	1
2022-02-02	2022	2	2	7	3	3	-9.7	-14.2	-9	1932.7	10.8	-10.7	-8.75	1
2022-02-02	2022	2	2	8	3	3	-9.9	-13	-9.5	2026.6	10.8	-11.2	-8.575	1
2022-02-02	2022	2	2	9	3	3	-9.9	-12.1	-10.1	2037.6	10.8	-11.5	-8.33333	1
2022-02-02	2022	2	2	10	3	3	-9.9	-9.3	-10.6	1994.8	10.8	-11.7	-8.09167	1
2022-02-02	2022	2	2	11	3	3	-9.8	-6.7	-11.2	1919.6	10.8	-11.7	-7.98333	1
2022-02-02	2022	2	2	12	3	3	-9.7	-3.6	-11.4	1833.7	10.8	-11.4	-8.04167	1
2022-02-02	2022	2	2	13	3	3	-9.5	-0.2	-11.3	1765.2	10.8	-10.7	-8.24167	1
2022-02-02	2022	2	2	14	3	3	-9.1	0.4	-11.3	1692.3	10.8	-9.8	-8.5	1
2022-02-02	2022	2	2	15	3	3	-8.8	0.7	-10.5	1638.4	10.8	-8.8	-8.86667	1
2022-02-02	2022	2	2	16	3	3	-8.5	1.6	-11.6	1635.0	10.8	-7.8	-9.26667	1
2022-02-02	2022	2	2	17	3	3	-8.2	1.2	-13.6	1682.5	10.8	-6.8	-9.65	1
2022-02-02	2022	2	2	18	3	3	-7.9	1.2	-14.2	1745.7	10.8	-5.7	-10.125	1
2022-02-02	2022	2	2	19	3	3	-7.6	1.3	-13	1734.2	10.8	-4.5	-10.7	1
2022-02-02	2022	2	2	20	3	3	-7.2	1.4	-12.1	1690.2	10.8	-3.2	-11.1917	1
2022-02-02	2022	2	2	21	3	3	-6.8	1.5	-9.3	1622.2	10.8	-2.0	-11.525	1
2022-02-02	2022	2	2	22	3	3	-6.3	1.5	-6.7	1541.7	10.8	-0.9	-11.7417	1
2022-02-02	2022	2	2	23	3	3	-5.8	2	-3.6	1438.0	10.8	0.0	-11.675	1
2022-02-02	2022	2	2	24	3	3	-5.3	2.1	-0.2	1388.3	10.8	0.8	-11.35	1
2022-02-03	2022	2	3	1	4	4	-4.7	2	0.4	1345.4	14.0	1.2	-10.7167	1
2022-02-03	2022	2	3	2	4	4	-4.2	2.2	0.7	1304.5	14.0	1.4	-9.78333	1
2022-02-03	2022	2	3	3	4	4	-3.6	2.4	1.6	1262.0	14.0	1.6	-8.80833	1
2022-02-03	2022	2	3	4	4	4	-3.1	2.6	1.2	1226.5	14.0	1.7	-7.80833	1
2022-02-03	2022	2	3	5	4	4	-2.5	2.6	1.2	1205.4	14.0	1.8	-6.8	1
2022-02-03	2022	2	3	6	4	4	-1.9	2.9	1.3	1227.8	14.0	1.9	-5.73333	1
2022-02-03	2022	2	3	7	4	4	-1.2	3.2	1.4	1332.2	14.0	2.0	-4.5	1
2022-02-03	2022	2	3	8	4	4	-0.5	3.5	1.5	1427.8	14.0	2.2	-3.20833	1
2022-02-03	2022	2	3	9	4	4	0.2	3.4	1.5	1459.8	14.0	2.4	-2.00833	1
2022-02-03	2022	2	3	10	4	4	0.8	4	2	1461.2	14.0	2.5	-0.875	1
2022-02-03	2022	2	3	11	4	4	1.4	4.3	2.1	1478.9	14.0	2.7	0.025	1
2022-02-03	2022	2	3	12	4	4	1.8	5.3	2	1496.2	14.0	2.9	0.75	1
2022-02-03	2022	2	3	13	4	4	2.2	6.4	2.2	1516.6	14.0	3.2	1.225	1
2022-02-03	2022	2	3	14	4	4	2.5	6.6	2.4	1485.2	14.0	3.6	1.408333	1
2022-02-03	2022	2	3	15	4	4	2.7	6.2	2.6	1453.3	14.0	3.9	1.558333	1
2022-02-03	2022	2	3	16	4	4	3.0	5.7	2.6	1448.5	14.0	4.3	1.7	1
2022-02-03	2022	2	3	17	4	4	3.1	6.1	2.9	1474.8	14.0	4.5	1.783333	1
2022-02-03	2022	2	3	18	4	4	3.4	5.9	3.2	1537.9	14.0	4.8	1.9	1
2022-02-03	2022	2	3	19	4	4	3.5	4.7	3.5	1529.3	14.0	5.1	2.041667	1
2022-02-03	2022	2	3	20	4	4	3.7	3.8	3.4	1489.8	14.0	5.2	2.2	1
2022-02-03	2022	2	3	21	4	4	3.8	3.7	4	1443.5	14.0	5.2	2.375	1
2022-02-03	2022	2	3	22	4	4	3.9	3.4	4.3	1384.0	14.0	5.2	2.533333	1
2022-02-03	2022	2	3	23	4	4	4.0	3.6	5.3	1304.7	14.0	5.2	2.741667	1
2022-02-03	2022	2	3	24	4	4	4.0	3.3	6.4	1267.1	14.0	5.1	2.933333	1
2022-02-04	2022	2	4	1	5	5	4.1	2.9	6.6	1242.3	9.5	5.0	3.2	1
2022-02-04	2022	2	4	2	5	5	4.1	2.5	6.2	1219.9	9.5	4.7	3.566667	1
2022-02-04	2022	2	4	3	5	5	4.1	3.1	5.7	1206.5	9.5	4.3	3.933333	1
2022-02-04	2022	2	4	4	5	5	4.2	3.6	6.1	1206.7	9.5	4.1	4.25	1
2022-02-04	2022	2	4	5	5	5	4.2	2.4	5.9	1227.2	9.5	3.9	4.508333	1
2022-02-04	2022	2	4	6	5	5	4.2	0.7	4.7	1280.3	9.5	3.6	4.8	1
2022-02-04	2022	2	4	7	5	5	4.1	0.3	3.8	1382.0	9.5	3.1	5.05	1
2022-02-04	2022	2	4	8	5	5	4.0	0	3.7	1472.8	9.5	2.8	5.175	1
2022-02-04	2022	2	4	9	5	5	3.8	0	3.4	1544.7	9.5	2.5	5.2	1
2022-02-04	2022	2	4	10	5	5	3.7	0.1	3.6	1596.3	9.5	2.2	5.225	1
2022-02-04	2022	2	4	11	5	5	3.5	0.3	3.3	1620.4	9.5	1.9	5.175	1
2022-02-04	2022	2	4	12	5	5	3.4	0.5	2.9	1649.5	9.5	1.6	5.116667	1
2022-02-04	2022	2	4	13	5	5	3.2	0.7	2.5	1674.8	9.5	1.4	4.95	1
2022-02-04	2022	2	4	14	5	5	2.9	0.7	3.1	1645.4	9.5	1.2	4.658333	1
2022-02-04	2022	2	4	15	5	5	2.7	1	3.6	1610.4	9.5	1.0	4.316667	1
2022-02-04	2022	2	4	16	5	5	2.5	1	2.4	1591.6	9.5	0.9	4.058333	1
2022-02-04	2022	2	4	17	5	5	2.3	0.9	0.7	1590.2	9.5	0.6	3.883333	1
2022-02-04	2022	2	4	18	5	5	2.0	0.6	0.3	1625.9	9.5	0.5	3.575	1
2022-02-04	2022	2	4	19	5	5	1.8	0.4	0	1570.9	9.5	0.5	3.141667	1
2022-02-04	2022	2	4	20	5	5	1.6	0.4	0	1518.4	9.5	0.5	2.775	1
2022-02-04	2022	2	4	21	5	5	1.5	0	0.1	1447.5	9.5	0.6	2.458333	1
2022-02-04	2022	2	4	22	5	5	1.4	-0.3	0.3	1384.4	9.5	0.6	2.15	1
2022-02-04	2022	2	4	23	5	5	1.2	-0.8	0.5	1344.4	9.5	0.5	1.875	1
2022-02-04	2022	2	4	24	5	5	1.0	-1.6	0.7	1340.3	9.5	0.4	1.6	1
2022-02-05	2022	2	5	1	6	6	0.8	-1.6	0.7	1332.8	6.1	0.3	1.366667	0
2022-02-05	2022	2	5	2	6	6	0.6	-1.3	1	1299.5	6.1	0.1	1.183333	0
2022-02-05	2022	2	5	3	6	6	0.5	-1.4	1	1258.7	6.1	-0.1	1.033333	0
2022-02-05	2022	2	5	4	6	6	0.3	-1.9	0.9	1237.2	6.1	-0.3	0.858333	0
2022-02-05	2022	2	5	5	6	6	0.0	-2.4	0.6	1252.8	6.1	-0.6	0.641667	0
2022-02-05	2022	2	5	6	6	6	-0.2	-2.8	0.4	1276.1	6.1	-0.8	0.516667	0
2022-02-05	2022	2	5	7	6	6	-0.3	-2.7	0.4	1321.6	6.1	-1.1	0.508333	0
2022-02-05	2022	2	5	8	6	6	-0.4	-2.6	0	1365.4	6.1	-1.4	0.516667	0
2022-02-05	2022	2	5	9	6	6	-0.5	-2.5	-0.3	1445.2	6.1	-1.6	0.55	0
2022-02-05	2022	2	5	10	6	6	-0.6	-2.7	-0.8</					

DATE	Year	Month	Day	HOUR	DOW	24hrAvgLag	Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLag	Weekdays	
2022-02-05	2022		2	5	24	6	-4.2	-9.4	-3.3	1632.2	6.1	-6.3	-2.20833	0
2022-02-06	2022		2	6	1	7	-4.6	-10.2	-3.2	1596.3	7.2	-6.8	-2.33333	0
2022-02-06	2022		2	6	2	7	-4.9	-11.1	-3.9	1588.5	7.2	-7.4	-2.475	0
2022-02-06	2022		2	6	3	7	-5.3	-12.2	-5.1	1595.0	7.2	-8.0	-2.63333	0
2022-02-06	2022		2	6	4	7	-5.8	-12.8	-5.9	1599.9	7.2	-8.7	-2.84167	0
2022-02-06	2022		2	6	5	7	-6.2	-13.1	-6.8	1621.8	7.2	-9.3	-3.10833	0
2022-02-06	2022		2	6	6	7	-6.7	-13.6	-7.8	1654.7	7.2	-9.9	-3.4	0
2022-02-06	2022		2	6	7	7	-7.1	-13.8	-8.8	1711.5	7.2	-10.5	-3.73333	0
2022-02-06	2022		2	6	8	7	-7.6	-14.1	-9.3	1781.0	7.2	-11.0	-4.15833	0
2022-02-06	2022		2	6	9	7	-8.1	-13.9	-8.8	1838.9	7.2	-11.5	-4.675	0
2022-02-06	2022		2	6	10	7	-8.5	-13.3	-9	1851.1	7.2	-11.8	-5.24167	0
2022-02-06	2022		2	6	11	7	-9.0	-12.2	-9.4	1841.3	7.2	-12.2	-5.75	0
2022-02-06	2022		2	6	12	7	-9.4	-11.2	-10.2	1829.0	7.2	-12.5	-6.25	0
2022-02-06	2022		2	6	13	7	-9.7	-10	-11.1	1797.2	7.2	-12.6	-6.775	0
2022-02-06	2022		2	6	14	7	-10.0	-8.9	-12.2	1731.5	7.2	-12.6	-7.35	0
2022-02-06	2022		2	6	15	7	-10.2	-8.2	-12.8	1687.5	7.2	-12.4	-8.00833	0
2022-02-06	2022		2	6	16	7	-10.4	-7.7	-13.1	1692.8	7.2	-12.1	-8.7	0
2022-02-06	2022		2	6	17	7	-10.5	-7.7	-13.6	1767.8	7.2	-11.7	-9.34167	0
2022-02-06	2022		2	6	18	7	-10.6	-8.3	-13.8	1883.5	7.2	-11.2	-9.94167	0
2022-02-06	2022		2	6	19	7	-10.6	-9.3	-14.1	1945.9	7.2	-10.8	-10.5083	0
2022-02-06	2022		2	6	20	7	-10.7	-9.6	-13.9	1951.7	7.2	-10.4	-11.0083	0
2022-02-06	2022		2	6	21	7	-10.7	-9.6	-13.3	1914.9	7.2	-10.0	-11.45	0
2022-02-06	2022		2	6	22	7	-10.8	-10.5	-12.2	1852.4	7.2	-9.7	-11.8333	0
2022-02-06	2022		2	6	23	7	-10.8	-10.3	-11.2	1756.2	7.2	-9.4	-12.2083	0
2022-02-06	2022		2	6	24	7	-10.9	-9.8	-10	1680.8	7.2	-9.3	-12.475	0
2022-02-07	2022		2	7	1	1	-10.9	-9.1	-8.9	1619.8	6.3	-9.2	-12.625	1
2022-02-07	2022		2	7	2	1	-10.8	-9.1	-8.2	1600.5	6.3	-9.1	-12.6083	1
2022-02-07	2022		2	7	3	1	-10.8	-8.4	-7.7	1591.9	6.3	-9.1	-12.425	1
2022-02-07	2022		2	7	4	1	-10.6	-8.8	-7.7	1591.7	6.3	-9.1	-12.0917	1
2022-02-07	2022		2	7	5	1	-10.4	-7.9	-8.3	1602.1	6.3	-9.2	-11.6667	1
2022-02-07	2022		2	7	6	1	-10.2	-4.7	-9.3	1646.3	6.3	-9.2	-11.2167	1
2022-02-07	2022		2	7	7	1	-9.9	-4.3	-9.6	1761.8	6.3	-8.9	-10.775	1
2022-02-07	2022		2	7	8	1	-9.5	-4.5	-9.6	1870.4	6.3	-8.5	-10.4	1
2022-02-07	2022		2	7	9	1	-9.1	-5.4	-10.5	1908.1	6.3	-8.1	-10.025	1
2022-02-07	2022		2	7	10	1	-8.7	-5.1	-10.3	1895.9	6.3	-7.7	-9.66667	1
2022-02-07	2022		2	7	11	1	-8.4	-3.6	-9.8	1856.5	6.3	-7.3	-9.43333	1
2022-02-07	2022		2	7	12	1	-8.0	-2.5	-9.1	1808.4	6.3	-6.7	-9.275	1
2022-02-07	2022		2	7	13	1	-7.6	-1	-9.1	1773.6	6.3	-6.1	-9.15833	1
2022-02-07	2022		2	7	14	1	-7.3	0.3	-8.4	1712.5	6.3	-5.4	-9.08333	1
2022-02-07	2022		2	7	15	1	-6.9	0.8	-8.8	1669.7	6.3	-4.7	-9.1	1
2022-02-07	2022		2	7	16	1	-6.5	0.9	-7.9	1674.4	6.3	-3.9	-9.11667	1
2022-02-07	2022		2	7	17	1	-6.1	0.8	-4.7	1707.9	6.3	-3.1	-9.20833	1
2022-02-07	2022		2	7	18	1	-5.8	0.7	-4.3	1771.4	6.3	-2.4	-9.225	1
2022-02-07	2022		2	7	19	1	-5.4	0.2	-4.5	1762.1	6.3	-1.9	-8.925	1
2022-02-07	2022		2	7	20	1	-5.0	-0.2	-5.4	1710.9	6.3	-1.5	-8.50833	1
2022-02-07	2022		2	7	21	1	-4.6	0.3	-5.1	1641.3	6.3	-1.2	-8.08333	1
2022-02-07	2022		2	7	22	1	-4.2	0.4	-3.6	1562.6	6.3	-0.7	-7.73333	1
2022-02-07	2022		2	7	23	1	-3.8	0.3	-2.5	1472.8	6.3	-0.2	-7.28333	1
2022-02-07	2022		2	7	24	1	-3.3	0.4	-1	1454.4	6.3	0.1	-6.725	1
2022-02-08	2022		2	8	1	2	-2.9	0.2	0.3	1413.9	19.2	0.3	-6.11667	1
2022-02-08	2022		2	8	2	2	-2.5	0.5	0.8	1369.4	19.2	0.4	-5.44167	1
2022-02-08	2022		2	8	3	2	-2.1	0.6	0.9	1326.6	19.2	0.4	-4.65833	1
2022-02-08	2022		2	8	4	2	-1.7	0.6	0.8	1305.1	19.2	0.4	-3.89167	1
2022-02-08	2022		2	8	5	2	-1.3	1.2	0.7	1304.5	19.2	0.4	-3.08333	1
2022-02-08	2022		2	8	6	2	-1.0	1.4	0.2	1341.4	19.2	0.4	-2.35833	1
2022-02-08	2022		2	8	7	2	-0.7	2.3	-0.2	1449.3	19.2	0.5	-1.90833	1
2022-02-08	2022		2	8	8	2	-0.4	3.2	0.3	1548.5	19.2	0.7	-1.53333	1
2022-02-08	2022		2	8	9	2	-0.1	3.8	0.4	1588.3	19.2	1.0	-1.175	1
2022-02-08	2022		2	8	10	2	0.3	4.5	0.3	1597.4	19.2	1.2	-0.7	1
2022-02-08	2022		2	8	11	2	0.7	5.2	0.4	1608.4	19.2	1.6	-0.24167	1
2022-02-08	2022		2	8	12	2	1.0	4.9	0.2	1618.7	19.2	2.0	0.083333	1
2022-02-08	2022		2	8	13	2	1.3	5	0.5	1640.8	19.2	2.4	0.325	1
2022-02-08	2022		2	8	14	2	1.6	5.2	0.6	1612.5	19.2	2.8	0.425	1
2022-02-08	2022		2	8	15	2	1.8	5.6	0.6	1595.2	19.2	3.2	0.441667	1
2022-02-08	2022		2	8	16	2	2.0	5.2	1.2	1605.4	19.2	3.6	0.425	1
2022-02-08	2022		2	8	17	2	2.2	5.4	1.4	1633.5	19.2	4.0	0.4	1
2022-02-08	2022		2	8	18	2	2.4	5.6	2.3	1662.7	19.2	4.3	0.433333	1
2022-02-08	2022		2	8	19	2	2.6	4.1	3.2	1639.8	19.2	4.7	0.491667	1
2022-02-08	2022		2	8	20	2	2.7	4.3	3.8	1592.4	19.2	4.8	0.666667	1
2022-02-08	2022		2	8	21	2	2.9	4.3	4.5	1535.1	19.2	4.9	0.95	1
2022-02-08	2022		2	8	22	2	3.1	2.1	5.2	1461.1	19.2	4.9	1.241667	1
2022-02-08	2022		2	8	23	2	3.2	2	4.9	1366.0	19.2	4.7	1.583333	1
2022-02-08	2022		2	8	24	2	3.2	2.2	5	1333.9	19.2	4.5	1.991667	1
2022-02-09	2022		2	9	1	3	3.3	2.5	5.2	1300.8	13.7	4.3	2.366667	1
2022-02-09	2022		2	9	2	3	3.4	2.7	5.6	1266.4	13.7	4.0	2.766667	1
2022-02-09	2022		2	9	3	3	3.5	2.3	5.2	1238.4	13.7	3.8	3.158333	1
2022-02-09	2022		2	9	4	3	3.6	2.5	5.4	1230.9	13.7	3.6	3.575	1
2022-02-09	2022		2	9	5	3	3.6	2.7	5.6	1247.7	13.7	3.3	3.958333	1
2022-02-09	2022		2	9	6	3	3.7	2.2	4.1	1304.7	13.7	3.1	4.308333	1
2022-02-09	2022		2	9	7	3	3.7	2.1	4.3	1424.1	13.7	2.8	4.658333	1
2022-02-09	2022		2	9	8	3	3.7	1.9	4.3	1535.4	13.7	2.7	4.808333	1
2022-02-09	2022		2	9	9	3	3.7	1.8	2.1	1575.4	13.7	2.5	4.9	1
2022-02-09	2022		2	9	10	3	3.6	2.1	2	1549.0	13.7	2.3	4.941667	1
2022-02-09	2022		2	9	11	3	3.5	2.5	2.2	1530.8	13.7	2.3	4.741667	1
2022-02-09	2022		2	9	12	3	3.4	3.2	2.5	1504.5	13.7	2.3	4.475	1
2022-02-09	2022		2	9	13	3	3.3	4.2	2.7	1508.7	13.7	2.4	4.25	1
2022-02-09	2022		2	9	14	3	3.3	4.2	2.3	1480.9	13.7	2.5	4.041667	1
2022-02-09	2022		2	9	15	3	3.2	4.3	2.5	1458.7	13.7	2.6	3.833333	1
2022-02-09	2022		2	9	16	3	3.2	4.7	2.7	1470.3	13.7	2.8	3.558333	1
2022-02-09	2022		2	9	17	3	3.2	3.9	2.2	1531.3	13.7	3.0	3.333333	1
2022-02-09	2022		2	9	18	3	3.1	3.5	2.1	1616.2	13.7	3.1	3.108333	1
2022-02-09	2022		2	9	19	3	3.0	2.7	1.9	1633.2	13.7	3.2	2.825	1
2022-02-09	2022		2	9	20	3	3.0	2.1	1.8	1601.7	13.7	3.3	2.658333	1
2022-02-09	2022		2	9	21	3	2.9	1.2	2.1	1556.5	13.7	3.3	2.458333	1
2022-02-09	2022		2	9	22	3	2.7	0.2	2.5	1485.0	13.7	3.2	2.25	1
2022-02-09	2022		2	9	23	3	2.7	0.5	3					

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLa	g Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLa	Weekdays	
2022-02-10	2022	2	10	12	12	4	1.4	1.7	0	1517.4	9.8	-0.2	2.891667	1
2022-02-10	2022	2	10	13	13	4	1.3	2.1	-0.3	1518.1	9.8	-0.1	2.641667	1
2022-02-10	2022	2	10	14	14	4	1.2	2.9	-0.3	1486.5	9.8	0.1	2.291667	1
2022-02-10	2022	2	10	15	15	4	1.1	3	-0.3	1451.4	9.8	0.4	1.916667	1
2022-02-10	2022	2	10	16	16	4	1.1	3	-0.1	1454.6	9.8	0.7	1.533333	1
2022-02-10	2022	2	10	17	17	4	1.0	3.2	0	1487.4	9.8	0.9	1.116667	1
2022-02-10	2022	2	10	18	18	4	1.0	2.6	-0.2	1560.7	9.8	1.2	0.783333	1
2022-02-10	2022	2	10	19	19	4	1.0	2.3	-1.2	1590.6	9.8	1.4	0.491667	1
2022-02-10	2022	2	10	20	20	4	0.9	2.2	-1.3	1567.2	9.8	1.6	0.25	1
2022-02-10	2022	2	10	21	21	4	0.9	2	0.2	1521.0	9.8	1.9	-0.025	1
2022-02-10	2022	2	10	22	22	4	1.0	1.9	1	1451.2	9.8	2.2	-0.23333	1
2022-02-10	2022	2	10	23	23	4	1.0	2.1	1.7	1360.9	9.8	2.3	-0.23333	1
2022-02-10	2022	2	10	24	24	4	1.1	2.4	2.1	1324.7	9.8	2.4	-0.19167	1
2022-02-11	2022	2	11	1	5	5	1.2	2.3	2.9	1287.9	12.7	2.5	-0.06667	1
2022-02-11	2022	2	11	2	5	5	1.3	3.2	3	1251.1	12.7	2.5	0.108333	1
2022-02-11	2022	2	11	3	5	5	1.4	3.2	3	1209.0	12.7	2.5	0.375	1
2022-02-11	2022	2	11	4	5	5	1.6	4	3.2	1178.2	12.7	2.5	0.65	1
2022-02-11	2022	2	11	5	5	5	1.8	3.5	2.6	1188.0	12.7	2.6	0.925	1
2022-02-11	2022	2	11	6	5	5	1.9	3.5	2.3	1246.3	12.7	2.6	1.2	1
2022-02-11	2022	2	11	7	5	5	2.1	3	2.2	1367.4	12.7	2.7	1.416667	1
2022-02-11	2022	2	11	8	5	5	2.2	2.4	2	1472.9	12.7	2.8	1.625	1
2022-02-11	2022	2	11	9	5	5	2.4	2.1	1.9	1473.0	12.7	2.8	1.908333	1
2022-02-11	2022	2	11	10	5	5	2.5	3.2	2.1	1414.9	12.7	2.8	2.183333	1
2022-02-11	2022	2	11	11	5	5	2.6	4.8	2.4	1363.6	12.7	2.9	2.325	1
2022-02-11	2022	2	11	12	5	5	2.8	6	2.3	1339.3	12.7	3.1	2.416667	1
2022-02-11	2022	2	11	13	5	5	3.0	7.1	3.2	1327.4	12.7	3.4	2.475	1
2022-02-11	2022	2	11	14	5	5	3.2	6.5	3.2	1288.8	12.7	3.8	2.491667	1
2022-02-11	2022	2	11	15	5	5	3.3	6.6	4	1264.8	12.7	4.1	2.516667	1
2022-02-11	2022	2	11	16	5	5	3.5	8.3	3.5	1265.5	12.7	4.4	2.533333	1
2022-02-11	2022	2	11	17	5	5	3.7	7.1	3.5	1304.7	12.7	4.8	2.616667	1
2022-02-11	2022	2	11	18	5	5	3.8	6	3	1388.8	12.7	5.1	2.641667	1
2022-02-11	2022	2	11	19	5	5	4.0	3.7	2.4	1441.4	12.7	5.3	2.716667	1
2022-02-11	2022	2	11	20	5	5	4.0	2.9	2.1	1430.8	12.7	5.3	2.775	1
2022-02-11	2022	2	11	21	5	5	4.1	2.9	3.2	1393.7	12.7	5.4	2.791667	1
2022-02-11	2022	2	11	22	5	5	4.1	2.8	4.8	1344.4	12.7	5.4	2.8	1
2022-02-11	2022	2	11	23	5	5	4.2	1.7	6	1283.7	12.7	5.4	2.908333	1
2022-02-11	2022	2	11	24	5	5	4.1	2.4	7.1	1266.2	12.7	5.1	3.133333	1
2022-02-12	2022	2	12	1	6	6	4.1	3.3	6.5	1237.0	17.1	4.8	3.433333	0
2022-02-12	2022	2	12	2	6	6	4.2	3.6	6.6	1196.5	17.1	4.5	3.833333	0
2022-02-12	2022	2	12	3	6	6	4.2	3.8	8.3	1151.3	17.1	4.3	4.108333	0
2022-02-12	2022	2	12	4	6	6	4.2	5.1	7.1	1129.8	17.1	4.0	4.391667	0
2022-02-12	2022	2	12	5	6	6	4.3	5.9	6	1127.8	17.1	3.8	4.75	0
2022-02-12	2022	2	12	6	6	6	4.4	5	3.7	1142.5	17.1	3.7	5.05	0
2022-02-12	2022	2	12	7	6	6	4.4	4.5	2.9	1190.9	17.1	3.6	5.258333	0
2022-02-12	2022	2	12	8	6	6	4.5	3.5	2.9	1260.8	17.1	3.7	5.316667	0
2022-02-12	2022	2	12	9	6	6	4.5	2.9	2.8	1310.4	17.1	3.7	5.358333	0
2022-02-12	2022	2	12	10	6	6	4.6	3.6	1.7	1307.8	17.1	3.7	5.425	0
2022-02-12	2022	2	12	11	6	6	4.6	5.4	2.4	1282.0	17.1	3.8	5.391667	0
2022-02-12	2022	2	12	12	6	6	4.6	7.2	3.3	1259.5	17.1	4.1	5.133333	0
2022-02-12	2022	2	12	13	6	6	4.7	8.3	3.6	1223.8	17.1	4.5	4.833333	0
2022-02-12	2022	2	12	14	6	6	4.7	8.8	3.8	1178.8	17.1	4.9	4.516667	0
2022-02-12	2022	2	12	15	6	6	4.8	11.2	5.1	1154.4	17.1	5.3	4.275	0
2022-02-12	2022	2	12	16	6	6	5.0	11.2	5.9	1169.2	17.1	6.0	4.041667	0
2022-02-12	2022	2	12	17	6	6	5.1	10.1	5	1232.8	17.1	6.5	3.775	0
2022-02-12	2022	2	12	18	6	6	5.2	8.7	4.5	1323.6	17.1	6.8	3.675	0
2022-02-12	2022	2	12	19	6	6	5.4	7.5	3.5	1353.4	17.1	7.1	3.591667	0
2022-02-12	2022	2	12	20	6	6	5.5	7	2.9	1324.2	17.1	7.4	3.658333	0
2022-02-12	2022	2	12	21	6	6	5.7	7	3.6	1281.5	17.1	7.7	3.708333	0
2022-02-12	2022	2	12	22	6	6	5.9	5.9	5.4	1236.7	17.1	8.0	3.708333	0
2022-02-12	2022	2	12	23	6	6	6.0	5.3	7.2	1182.0	17.1	8.2	3.775	0
2022-02-12	2022	2	12	24	6	6	6.1	4.9	8.3	1140.6	17.1	8.2	4.083333	0
2022-02-13	2022	2	13	1	7	7	6.2	4.3	8.8	1095.3	10.7	8.0	4.483333	0
2022-02-13	2022	2	13	2	7	7	6.3	4.8	11.2	1078.6	10.7	7.7	4.9	0
2022-02-13	2022	2	13	3	7	7	6.3	4.1	11.2	1074.9	10.7	7.3	5.333333	0
2022-02-13	2022	2	13	4	7	7	6.3	3.9	10.1	1089.2	10.7	6.7	5.95	0
2022-02-13	2022	2	13	5	7	7	6.3	3.6	8.7	1104.7	10.7	6.1	6.458333	0
2022-02-13	2022	2	13	6	7	7	6.2	2.6	7.5	1130.2	10.7	5.6	6.808333	0
2022-02-13	2022	2	13	7	7	7	6.1	2.6	7	1189.8	10.7	5.1	7.116667	0
2022-02-13	2022	2	13	8	7	7	6.0	2	7	1275.1	10.7	4.7	7.366667	0
2022-02-13	2022	2	13	9	7	7	6.0	1.5	5.9	1359.9	10.7	4.3	7.658333	0
2022-02-13	2022	2	13	10	7	7	5.9	2	5.3	1427.9	10.7	3.8	8	0
2022-02-13	2022	2	13	11	7	7	5.8	2.4	4.9	1482.6	10.7	3.5	8.191667	0
2022-02-13	2022	2	13	12	7	7	5.7	2.8	4.3	1541.4	10.7	3.2	8.183333	0
2022-02-13	2022	2	13	13	7	7	5.5	1.8	4.8	1572.6	10.7	3.1	7.991667	0
2022-02-13	2022	2	13	14	7	7	5.3	1.2	4.1	1568.4	10.7	2.8	7.658333	0
2022-02-13	2022	2	13	15	7	7	4.9	0.4	3.9	1575.0	10.7	2.5	7.325	0
2022-02-13	2022	2	13	16	7	7	4.5	0.1	3.6	1604.1	10.7	2.2	6.733333	0
2022-02-13	2022	2	13	17	7	7	4.0	-0.4	2.6	1672.3	10.7	1.9	6.125	0
2022-02-13	2022	2	13	18	7	7	3.6	-1.7	2.6	1733.5	10.7	1.6	5.583333	0
2022-02-13	2022	2	13	19	7	7	3.2	-2.2	2	1732.9	10.7	1.2	5.075	0
2022-02-13	2022	2	13	20	7	7	2.7	-3.8	1.5	1698.7	10.7	0.8	4.666667	0
2022-02-13	2022	2	13	21	7	7	2.3	-5.3	2	1648.8	10.7	0.3	4.25	0
2022-02-13	2022	2	13	22	7	7	1.8	-6.2	2.4	1585.8	10.7	-0.2	3.791667	0
2022-02-13	2022	2	13	23	7	7	1.3	-6.2	2.8	1514.0	10.7	-0.9	3.466667	0
2022-02-13	2022	2	13	24	7	7	0.8	-6.1	1.8	1460.7	10.7	-1.6	3.225	0
2022-02-14	2022	2	14	1	1	1	0.3	-6	1.2	1411.6	19.4	-2.4	3.05	1
2022-02-14	2022	2	14	2	1	1	-0.1	-6.2	0.4	1393.8	19.4	-3.0	2.841667	1
2022-02-14	2022	2	14	3	1	1	-0.5	-6.3	0.1	1389.3	19.4	-3.6	2.541667	1
2022-02-14	2022	2	14	4	1	1	-1.0	-6.5	-0.4	1400.7	19.4	-4.2	2.233333	1
2022-02-14	2022	2	14	5	1	1	-1.4	-6.6	-1.7	1431.0	19.4	-4.7	1.916667	1
2022-02-14	2022	2	14	6	1	1	-1.8	-6.6	-2.2	1486.9	19.4	-5.3	1.583333	1
2022-02-14	2022	2	14	7	1	1	-2.2	-6.7	-3.8	1590.8	19.4	-5.7	1.225	1
2022-02-14	2022	2	14	8	1	1	-2.6	-7	-5.3	1671.6	19.4	-6.0	0.825	1
2022-02-14	2022	2	14	9	1	1								

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLag	Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLag	Weekdays	
2022-02-14	2022		2	14	24	1	-6.9	-10.6	-6	1655.1	19.4	-7.1	-6.63333	1
2022-02-15	2022		2	15	1	2	-7.1	-11.4	-5.9	1641.1	16.0	-7.5	-6.7	1
2022-02-15	2022		2	15	2	2	-7.3	-12	-5.7	1626.6	16.0	-7.9	-6.7	1
2022-02-15	2022		2	15	3	2	-7.5	-12.3	-5.9	1616.9	16.0	-8.4	-6.675	1
2022-02-15	2022		2	15	4	2	-7.8	-12.4	-6.3	1623.8	16.0	-9.0	-6.625	1
2022-02-15	2022		2	15	5	2	-8.0	-12.7	-6.5	1644.1	16.0	-9.5	-6.575	1
2022-02-15	2022		2	15	6	2	-8.3	-11.7	-7	1699.9	16.0	-10.0	-6.55	1
2022-02-15	2022		2	15	7	2	-8.5	-11.8	-7.2	1826.5	16.0	-10.5	-6.54167	1
2022-02-15	2022		2	15	8	2	-8.7	-12.1	-8.6	1937.8	16.0	-10.9	-6.56667	1
2022-02-15	2022		2	15	9	2	-8.9	-12.7	-9.6	1945.2	16.0	-11.3	-6.58333	1
2022-02-15	2022		2	15	10	2	-9.2	-12.6	-10.1	1884.1	16.0	-11.6	-6.725	1
2022-02-15	2022		2	15	11	2	-9.4	-11.8	-10.6	1840.6	16.0	-11.9	-6.90833	1
2022-02-15	2022		2	15	12	2	-9.6	-11.3	-11.4	1829.8	16.0	-12.0	-7.14167	1
2022-02-15	2022		2	15	13	2	-9.8	-10.1	-12	1824.1	16.0	-12.1	-7.45	1
2022-02-15	2022		2	15	14	2	-9.9	-9.8	-12.3	1793.8	16.0	-12.0	-7.9	1
2022-02-15	2022		2	15	15	2	-10.1	-10.3	-12.4	1772.3	16.0	-11.8	-8.40833	1
2022-02-15	2022		2	15	16	2	-10.3	-10.3	-12.7	1800.7	16.0	-11.6	-8.95833	1
2022-02-15	2022		2	15	17	2	-10.5	-9.9	-11.7	1867.9	16.0	-11.4	-9.5	1
2022-02-15	2022		2	15	18	2	-10.6	-10.5	-11.8	1971.1	16.0	-11.2	-10.0333	1
2022-02-15	2022		2	15	19	2	-10.8	-11	-12.1	2020.1	16.0	-11.1	-10.4667	1
2022-02-15	2022		2	15	20	2	-11.0	-11.4	-12.7	1999.8	16.0	-11.0	-10.8667	1
2022-02-15	2022		2	15	21	2	-11.1	-11.4	-12.6	1958.6	16.0	-11.0	-11.275	1
2022-02-15	2022		2	15	22	2	-11.2	-11.3	-11.8	1896.9	16.0	-10.9	-11.6167	1
2022-02-15	2022		2	15	23	2	-11.3	-11.5	-11.3	1805.9	16.0	-10.8	-11.8667	1
2022-02-15	2022		2	15	24	2	-11.4	-10.9	-10.1	1780.2	16.0	-10.7	-12.0083	1
2022-02-16	2022		2	16	1	3	-11.4	-10.8	-9.8	1759.2	14.3	-10.7	-12.0667	1
2022-02-16	2022		2	16	2	3	-11.4	-11.1	-10.3	1738.6	14.3	-10.8	-11.9583	1
2022-02-16	2022		2	16	3	3	-11.3	-11.5	-10.3	1730.2	14.3	-10.9	-11.775	1
2022-02-16	2022		2	16	4	3	-11.3	-11.9	-9.9	1733.8	14.3	-11.0	-11.6083	1
2022-02-16	2022		2	16	5	3	-11.3	-12.1	-10.5	1756.6	14.3	-11.1	-11.4333	1
2022-02-16	2022		2	16	6	3	-11.2	-12.2	-11	1818.2	14.3	-11.3	-11.2	1
2022-02-16	2022		2	16	7	3	-11.3	-12.4	-11.4	1954.8	14.3	-11.4	-11.1	1
2022-02-16	2022		2	16	8	3	-11.3	-12.6	-11.4	2060.5	14.3	-11.5	-11.0333	1
2022-02-16	2022		2	16	9	3	-11.3	-12.4	-11.3	2043.0	14.3	-11.6	-10.975	1
2022-02-16	2022		2	16	10	3	-11.3	-11	-11.5	1947.6	14.3	-11.7	-10.8667	1
2022-02-16	2022		2	16	11	3	-11.2	-8.9	-10.9	1861.5	14.3	-11.7	-10.7583	1
2022-02-16	2022		2	16	12	3	-11.1	-7.1	-10.8	1790.8	14.3	-11.5	-10.7333	1
2022-02-16	2022		2	16	13	3	-10.9	-5.5	-11.1	1749.9	14.3	-11.2	-10.7	1
2022-02-16	2022		2	16	14	3	-10.7	-4.7	-11.5	1672.6	14.3	-10.7	-10.7583	1
2022-02-16	2022		2	16	15	3	-10.5	-4.7	-11.9	1615.5	14.3	-10.2	-10.8667	1
2022-02-16	2022		2	16	16	3	-10.3	-5	-12.1	1619.3	14.3	-9.6	-10.9667	1
2022-02-16	2022		2	16	17	3	-10.1	-5	-12.2	1680.7	14.3	-9.1	-11.1	1
2022-02-16	2022		2	16	18	3	-9.9	-4.8	-12.4	1781.6	14.3	-8.5	-11.2833	1
2022-02-16	2022		2	16	19	3	-9.6	-4.2	-12.6	1822.1	14.3	-7.8	-11.425	1
2022-02-16	2022		2	16	20	3	-9.4	-3.3	-12.4	1791.7	14.3	-7.2	-11.5417	1
2022-02-16	2022		2	16	21	3	-9.0	-1.5	-11	1736.6	14.3	-6.4	-11.6417	1
2022-02-16	2022		2	16	22	3	-8.6	-0.4	-8.9	1647.3	14.3	-5.5	-11.725	1
2022-02-16	2022		2	16	23	3	-8.1	0.3	-7.1	1540.4	14.3	-4.6	-11.7	1
2022-02-16	2022		2	16	24	3	-7.7	1.1	-5.5	1502.7	14.3	-3.8	-11.4833	1
2022-02-17	2022		2	17	1	4	-7.2	1.4	-4.7	1448.7	33.5	-3.1	-11.1667	1
2022-02-17	2022		2	17	2	4	-6.6	2.4	-4.7	1397.7	33.5	-2.6	-10.725	1
2022-02-17	2022		2	17	3	4	-6.1	2.7	-5	1354.1	33.5	-2.0	-10.1917	1
2022-02-17	2022		2	17	4	4	-5.5	3.3	-5	1328.7	33.5	-1.4	-9.625	1
2022-02-17	2022		2	17	5	4	-4.9	3.9	-4.8	1322.3	33.5	-0.7	-9.05	1
2022-02-17	2022		2	17	6	4	-4.2	4.3	-4.2	1349.5	33.5	0.1	-8.45833	1
2022-02-17	2022		2	17	7	4	-3.5	4.6	-3.3	1444.7	33.5	0.8	-7.84167	1
2022-02-17	2022		2	17	8	4	-2.8	4.7	-1.5	1533.6	33.5	1.6	-7.15833	1
2022-02-17	2022		2	17	9	4	-2.1	5.3	-0.4	1543.9	33.5	2.2	-6.38333	1
2022-02-17	2022		2	17	10	4	-1.3	6	0.3	1519.8	33.5	2.8	-5.475	1
2022-02-17	2022		2	17	11	4	-0.6	6.3	1.1	1475.1	33.5	3.3	-4.59167	1
2022-02-17	2022		2	17	12	4	0.0	7.2	1.4	1435.1	33.5	3.8	-3.825	1
2022-02-17	2022		2	17	13	4	0.6	7.9	2.4	1402.5	33.5	4.3	-3.14167	1
2022-02-17	2022		2	17	14	4	1.2	7.8	2.7	1375.2	33.5	4.9	-2.56667	1
2022-02-17	2022		2	17	15	4	1.7	7.6	3.3	1352.7	33.5	5.3	-1.975	1
2022-02-17	2022		2	17	16	4	2.2	7.9	3.9	1360.1	33.5	5.7	-1.35833	1
2022-02-17	2022		2	17	17	4	2.7	7.6	4.3	1409.8	33.5	6.1	-0.66667	1
2022-02-17	2022		2	17	18	4	3.3	7.1	4.6	1470.8	33.5	6.4	0.075	1
2022-02-17	2022		2	17	19	4	3.8	7.2	4.7	1485.9	33.5	6.7	0.833333	1
2022-02-17	2022		2	17	20	4	4.2	7	5.3	1450.3	33.5	6.9	1.566667	1
2022-02-17	2022		2	17	21	4	4.7	6.7	6	1389.7	33.5	7.1	2.233333	1
2022-02-17	2022		2	17	22	4	5.0	6.7	6.3	1313.4	33.5	7.2	2.8	1
2022-02-17	2022		2	17	23	4	5.3	6.6	7.2	1225.7	33.5	7.3	3.333333	1
2022-02-17	2022		2	17	24	4	5.6	7	7.9	1187.4	33.5	7.3	3.833333	1
2022-02-18	2022		2	18	1	5	5.8	7.3	7.8	1145.5	37.1	7.3	4.341667	1
2022-02-18	2022		2	18	2	5	6.0	7.5	7.6	1103.8	37.1	7.2	4.883333	1
2022-02-18	2022		2	18	3	5	6.3	7.9	7.9	1075.5	37.1	7.2	5.333333	1
2022-02-18	2022		2	18	4	5	6.5	8	7.6	1063.5	37.1	7.2	5.741667	1
2022-02-18	2022		2	18	5	5	6.7	8.1	7.1	1076.6	37.1	7.2	6.125	1
2022-02-18	2022		2	18	6	5	6.8	8.4	7.2	1120.2	37.1	7.3	6.433333	1
2022-02-18	2022		2	18	7	5	7.0	8.5	7	1214.5	37.1	7.4	6.666667	1
2022-02-18	2022		2	18	8	5	7.2	8.9	6.7	1309.1	37.1	7.5	6.883333	1
2022-02-18	2022		2	18	9	5	7.4	9	6.7	1366.7	37.1	7.6	7.075	1
2022-02-18	2022		2	18	10	5	7.5	9.4	6.6	1380.2	37.1	7.8	7.191667	1
2022-02-18	2022		2	18	11	5	7.7	9.6	7	1392.4	37.1	8.1	7.25	1
2022-02-18	2022		2	18	12	5	7.8	9.8	7.3	1405.0	37.1	8.3	7.275	1
2022-02-18	2022		2	18	13	5	7.9	9.5	7.5	1407.7	37.1	8.5	7.258333	1
2022-02-18	2022		2	18	14	5	8.0	9.8	7.9	1363.3	37.1	8.7	7.208333	1
2022-02-18	2022		2	18	15	5	8.0	10.4	8	1348.0	37.1	8.9	7.183333	1
2022-02-18	2022		2	18	16	5	8.2	9.9	8.1	1342.4	37.1	9.1	7.208333	1
2022-02-18	2022		2	18	17	5	8.2	9	8.4	1399.6	37.1	9.3	7.216667	1
2022-02-18	2022		2	18	18	5	8.3	6.4	8.5	1470.9	37.1	9.4	7.258333	1
2022-02-18	2022		2	18	19	5	8.3	2	8.9	1519.2	37.1	9.2	7.366667	1
2022-02-18	2022		2	18	20	5	8.1	0.3	9	1513.9	37.1	8.6	7.475	1
2022-02-18	2022		2	18	21	5	7.8	-0.6	9.4	1492.9	37.1	7.9	7.633333	1
2022-02-18	2022													

DATE	Year	Month	Day	HOUR	DOW	24hrAvgLa	g Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLa	g Weekdays	
2022-02-19	2022		2	19	12	6	-0.1	-5.1	-3	1552.4	13.4	-5.7	5.358333	0
2022-02-19	2022		2	19	13	6	-0.8	-4.4	-4.3	1514.5	13.4	-5.9	4.35	0
2022-02-19	2022		2	19	14	6	-1.3	-3.9	-4.9	1474.6	13.4	-6.0	3.308333	0
2022-02-19	2022		2	19	15	6	-1.9	-2.1	-5.5	1470.4	13.4	-6.0	2.133333	0
2022-02-19	2022		2	19	16	6	-2.4	-2.8	-5.8	1506.9	13.4	-5.7	0.858333	0
2022-02-19	2022		2	19	17	6	-3.0	-2.8	-6.2	1572.3	13.4	-5.5	-0.425	0
2022-02-19	2022		2	19	18	6	-3.5	-2.9	-6.9	1655.5	13.4	-5.3	-1.65833	0
2022-02-19	2022		2	19	19	6	-3.8	-2.4	-7.4	1669.0	13.4	-5.0	-2.70833	0
2022-02-19	2022		2	19	20	6	-4.0	-2.1	-8.2	1628.3	13.4	-4.6	-3.45	0
2022-02-19	2022		2	19	21	6	-4.1	-1.5	-7.1	1580.9	13.4	-4.2	-4.09167	0
2022-02-19	2022		2	19	22	6	-4.2	-1.2	-6.2	1520.1	13.4	-3.6	-4.725	0
2022-02-19	2022		2	19	23	6	-4.2	-1.3	-5.1	1448.4	13.4	-3.1	-5.24167	0
2022-02-19	2022		2	19	24	6	-4.2	-0.2	-4.4	1387.9	13.4	-2.7	-5.65	0
2022-02-20	2022		2	20	1	7	-4.1	0.3	-3.9	1338.6	18.6	-2.3	-5.88333	0
2022-02-20	2022		2	20	2	7	-4.0	0.6	-2.1	1315.1	18.6	-1.9	-6	0
2022-02-20	2022		2	20	3	7	-3.8	1.4	-2.8	1307.8	18.6	-1.5	-5.96667	0
2022-02-20	2022		2	20	4	7	-3.5	-2.4	-2.8	1331.0	18.6	-1.2	-5.73333	0
2022-02-20	2022		2	20	5	7	-3.4	-2.2	-2.9	1351.8	18.6	-1.2	-5.50833	0
2022-02-20	2022		2	20	6	7	-3.2	-2.4	-2.4	1380.6	18.6	-1.2	-5.25833	0
2022-02-20	2022		2	20	7	7	-3.1	-3.3	-2.1	1436.6	18.6	-1.1	-4.98333	0
2022-02-20	2022		2	20	8	7	-2.9	-3.6	-1.5	1512.3	18.6	-1.2	-4.60833	0
2022-02-20	2022		2	20	9	7	-2.7	-4.5	-1.2	1607.3	18.6	-1.3	-4.16667	0
2022-02-20	2022		2	20	10	7	-2.6	-4.7	-1.3	1648.7	18.6	-1.6	-3.60833	0
2022-02-20	2022		2	20	11	7	-2.5	-5.1	-0.2	1638.7	18.6	-1.9	-3.11667	0
2022-02-20	2022		2	20	12	7	-2.4	-5	0.3	1621.5	18.6	-2.2	-2.70833	0
2022-02-20	2022		2	20	13	7	-2.4	-4.6	0.6	1595.2	18.6	-2.6	-2.3	0
2022-02-20	2022		2	20	14	7	-2.4	-4.7	1.4	1542.2	18.6	-3.0	-1.90833	0
2022-02-20	2022		2	20	15	7	-2.5	-4.3	-2.4	1501.7	18.6	-3.4	-1.53333	0
2022-02-20	2022		2	20	16	7	-2.6	-3.6	-2.2	1502.5	18.6	-3.9	-1.24167	0
2022-02-20	2022		2	20	17	7	-2.6	-3.5	-2.4	1564.7	18.6	-4.0	-1.20833	0
2022-02-20	2022		2	20	18	7	-2.6	-4	-3.3	1657.3	18.6	-4.1	-1.15833	0
2022-02-20	2022		2	20	19	7	-2.7	-5.1	-3.6	1719.5	18.6	-4.2	-1.11667	0
2022-02-20	2022		2	20	20	7	-2.8	-5.3	-4.5	1706.1	18.6	-4.4	-1.19167	0
2022-02-20	2022		2	20	21	7	-2.9	-5.7	-4.7	1674.9	18.6	-4.5	-1.31667	0
2022-02-20	2022		2	20	22	7	-3.1	-5.7	-5.1	1618.0	18.6	-4.6	-1.56667	0
2022-02-20	2022		2	20	23	7	-3.3	-5.2	-5	1547.8	18.6	-4.7	-1.85833	0
2022-02-20	2022		2	20	24	7	-3.5	-4.2	-4.6	1481.2	18.6	-4.7	-2.175	0
2022-02-21	2022		2	21	1	1	-3.6	-2.8	-4.7	1420.5	16.0	-4.7	-2.575	0
2022-02-21	2022		2	21	2	1	-3.7	-0.8	-4.3	1374.6	16.0	-4.5	-2.98333	0
2022-02-21	2022		2	21	3	1	-3.8	0.3	-3.6	1350.2	16.0	-4.2	-3.425	0
2022-02-21	2022		2	21	4	1	-3.9	1.2	-3.5	1328.9	16.0	-3.8	-3.9	0
2022-02-21	2022		2	21	5	1	-3.7	1.9	-4	1327.6	16.0	-3.4	-4	0
2022-02-21	2022		2	21	6	1	-3.5	2.2	-5.1	1340.9	16.0	-3.0	-4.10833	0
2022-02-21	2022		2	21	7	1	-3.3	2.3	-5.3	1379.8	16.0	-2.4	-4.24167	0
2022-02-21	2022		2	21	8	1	-3.1	2.7	-5.7	1410.7	16.0	-1.8	-4.39167	0
2022-02-21	2022		2	21	9	1	-2.8	3	-5.7	1435.7	16.0	-1.2	-4.53333	0
2022-02-21	2022		2	21	10	1	-2.5	3.8	-5.2	1434.8	16.0	-0.4	-4.63333	0
2022-02-21	2022		2	21	11	1	-2.2	4.9	-4.2	1411.8	16.0	0.4	-4.71667	0
2022-02-21	2022		2	21	12	1	-1.8	5.7	-2.8	1390.7	16.0	1.2	-4.725	0
2022-02-21	2022		2	21	13	1	-1.3	7.4	-0.8	1361.2	16.0	2.0	-4.65833	0
2022-02-21	2022		2	21	14	1	-0.8	8.2	0.3	1313.8	16.0	2.9	-4.50833	0
2022-02-21	2022		2	21	15	1	-0.3	7.8	1.2	1283.5	16.0	3.6	-4.18333	0
2022-02-21	2022		2	21	16	1	0.2	8.4	1.9	1287.8	16.0	4.3	-3.8	0
2022-02-21	2022		2	21	17	1	0.7	7.5	2.2	1360.0	16.0	4.9	-3.4	0
2022-02-21	2022		2	21	18	1	1.2	6.6	2.3	1431.8	16.0	5.3	-2.95	0
2022-02-21	2022		2	21	19	1	1.6	4.8	2.7	1473.8	16.0	5.7	-2.43333	0
2022-02-21	2022		2	21	20	1	2.0	3.5	3	1467.4	16.0	5.9	-1.81667	0
2022-02-21	2022		2	21	21	1	2.4	3	3.8	1438.4	16.0	6.0	-1.15	0
2022-02-21	2022		2	21	22	1	2.8	1.3	4.9	1375.8	16.0	6.0	-0.425	0
2022-02-21	2022		2	21	23	1	3.1	1.8	5.7	1300.6	16.0	5.8	0.366667	0
2022-02-21	2022		2	21	24	1	3.4	0.5	7.4	1256.5	16.0	5.5	1.208333	0
2022-02-22	2022		2	22	1	2	3.6	0.7	8.2	1216.9	16.8	5.1	2.033333	1
2022-02-22	2022		2	22	2	2	3.7	2.7	7.8	1195.1	16.8	4.5	2.883333	1
2022-02-22	2022		2	22	3	2	3.8	1.9	8.4	1194.4	16.8	4.1	3.633333	1
2022-02-22	2022		2	22	4	2	3.9	0.5	7.5	1204.8	16.8	3.6	4.258333	1
2022-02-22	2022		2	22	5	2	3.9	-0.2	6.6	1228.1	16.8	2.9	4.858333	1
2022-02-22	2022		2	22	6	2	3.8	-0.5	4.8	1299.4	16.8	2.3	5.325	1
2022-02-22	2022		2	22	7	2	3.7	-0.8	3.5	1449.7	16.8	1.7	5.691667	1
2022-02-22	2022		2	22	8	2	3.6	-1.1	3	1573.7	16.8	1.2	5.9	1
2022-02-22	2022		2	22	9	2	3.4	-0.9	1.3	1602.4	16.8	0.8	5.966667	1
2022-02-22	2022		2	22	10	2	3.2	-0.2	1.8	1570.8	16.8	0.5	5.966667	1
2022-02-22	2022		2	22	11	2	3.1	0.7	0.5	1540.7	16.8	0.4	5.758333	1
2022-02-22	2022		2	22	12	2	2.9	0.4	0.7	1548.9	16.8	0.3	5.5	1
2022-02-22	2022		2	22	13	2	2.7	0.1	2.7	1573.3	16.8	0.3	5.066667	1
2022-02-22	2022		2	22	14	2	2.4	0.7	1.9	1562.1	16.8	0.2	4.508333	1
2022-02-22	2022		2	22	15	2	2.1	0.7	0.5	1550.8	16.8	0.1	4.05	1
2022-02-22	2022		2	22	16	2	1.8	0.7	-0.2	1577.5	16.8	-0.1	3.558333	1
2022-02-22	2022		2	22	17	2	1.4	0.3	-0.5	1636.7	16.8	0.0	2.9	1
2022-02-22	2022		2	22	18	2	1.1	0.4	-0.8	1687.6	16.8	0.0	2.258333	1
2022-02-22	2022		2	22	19	2	0.9	0.6	-1.1	1682.3	16.8	0.1	1.666667	1
2022-02-22	2022		2	22	20	2	0.7	0.7	-0.9	1638.7	16.8	0.2	1.2	1
2022-02-22	2022		2	22	21	2	0.6	0.9	-0.2	1578.5	16.8	0.4	0.816667	1
2022-02-22	2022		2	22	22	2	0.5	1.1	0.7	1492.8	16.8	0.5	0.491667	1
2022-02-22	2022		2	22	23	2	0.5	1.4	0.4	1401.8	16.8	0.6	0.366667	1
2022-02-22	2022		2	22	24	2	0.5	2.2	0.1	1365.7	16.8	0.7	0.275	1
2022-02-23	2022		2	23	1	3	0.5	2.7	0.7	1315.3	22.4	0.8	0.266667	1
2022-02-23	2022		2	23	2	3	0.6	4.2	0.7	1257.6	22.4	1.0	0.216667	1
2022-02-23	2022		2	23	3	3	0.7	5.6	0.7	1207.0	22.4	1.3	0.05	1
2022-02-23	2022		2	23	4	3	0.8	7.6	0.3	1170.7	22.4	1.7	-0.05	1
2022-02-23	2022		2	23	5	3	1.1	7.6	0.4	1160.2	22.4	2.3	-0.03333	1
2022-02-23	2022		2	23	6	3	1.5	7.4	0.6	1194.1	22.4	2.9	0.008333	1
2022-02-23	2022		2	23	7	3	1.8	7.2	0.7	1306.8	22.4	3.5	0.083333	1
2022-02-23	2022		2	23	8	3	2.1	7.6	0.9	1403.2	22.4	4.1	0.2	1
2022-02-23	2022		2	23	9	3	2.5	7.3	1.1	1428.6	22.4	4.6	0.35	1
2022-02-23	2022		2	23	10	3	2.8	8.2	1.4	1422.6	22.4	5.2	0.5	1
20														

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLag	Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLag	Weekdays	
2022-02-23	2022		2	23	24	3	7.0	5.9	8.1	1220.4	22.4	7.6	6.316667	1
2022-02-24	2022		2	24	1	4	7.1	2.1	8.2	1235.7	21.1	7.4	6.825	1
2022-02-24	2022		2	24	2	4	7.1	0.5	8.5	1261.2	21.1	6.9	7.275	1
2022-02-24	2022		2	24	3	4	7.0	-1.8	8.2	1292.8	21.1	6.3	7.608333	1
2022-02-24	2022		2	24	4	4	6.6	-3.9	7.6	1331.1	21.1	5.4	7.85	1
2022-02-24	2022		2	24	5	4	6.2	-5.7	7.4	1383.8	21.1	4.4	7.9	1
2022-02-24	2022		2	24	6	4	5.6	-6.7	7	1471.3	21.1	3.3	7.9	1
2022-02-24	2022		2	24	7	4	5.0	-7.2	6.9	1630.5	21.1	2.1	7.9	1
2022-02-24	2022		2	24	8	4	4.4	-7.3	7.1	1739.6	21.1	1.0	7.883333	1
2022-02-24	2022		2	24	9	4	3.8	-7.4	7	1742.1	21.1	-0.2	7.825	1
2022-02-24	2022		2	24	10	4	3.2	-6.6	7.3	1708.7	21.1	-1.4	7.808333	1
2022-02-24	2022		2	24	11	4	2.6	-6.1	5.9	1671.0	21.1	-2.6	7.708333	1
2022-02-24	2022		2	24	12	4	2.0	-5.4	2.1	1642.0	21.1	-3.7	7.633333	1
2022-02-24	2022		2	24	13	4	1.4	-4.6	0.5	1627.2	21.1	-4.6	7.433333	1
2022-02-24	2022		2	24	14	4	0.9	-3.9	-1.8	1586.1	21.1	-5.2	6.933333	1
2022-02-24	2022		2	24	15	4	0.4	-3.7	-3.9	1545.3	21.1	-5.6	6.291667	1
2022-02-24	2022		2	24	16	4	-0.1	-3.1	-5.7	1548.2	21.1	-5.7	5.433333	1
2022-02-24	2022		2	24	17	4	-0.6	-3	-6.7	1595.0	21.1	-5.6	4.425	1
2022-02-24	2022		2	24	18	4	-1.1	-3.7	-7.2	1690.1	21.1	-5.4	3.316667	1
2022-02-24	2022		2	24	19	4	-1.5	-4.7	-7.3	1773.7	21.1	-5.2	2.141667	1
2022-02-24	2022		2	24	20	4	-2.0	-5.4	-7.4	1780.3	21.1	-5.0	0.958333	1
2022-02-24	2022		2	24	21	4	-2.5	-5.8	-6.6	1750.8	21.1	-4.8	-0.225	1
2022-02-24	2022		2	24	22	4	-3.1	-6.3	-6.1	1691.8	21.1	-4.7	-1.43333	1
2022-02-24	2022		2	24	23	4	-3.6	-6.5	-5.4	1611.8	21.1	-4.6	-2.56667	1
2022-02-24	2022		2	24	24	4	-4.2	-6.9	-4.6	1603.4	21.1	-4.7	-3.68333	1
2022-02-25	2022		2	25	1	5	-4.7	-7.5	-3.9	1584.9	12.4	-4.8	-4.625	1
2022-02-25	2022		2	25	2	5	-5.1	-7.9	-3.7	1571.3	12.4	-5.0	-5.18333	1
2022-02-25	2022		2	25	3	5	-5.5	-8.7	-3.1	1560.4	12.4	-5.4	-5.55	1
2022-02-25	2022		2	25	4	5	-5.8	-8.9	-3	1562.4	12.4	-5.8	-5.70833	1
2022-02-25	2022		2	25	5	5	-6.0	-9.4	-3.7	1579.9	12.4	-6.3	-5.64167	1
2022-02-25	2022		2	25	6	5	-6.1	-9.7	-4.7	1628.8	12.4	-6.8	-5.41667	1
2022-02-25	2022		2	25	7	5	-6.2	-9.9	-5.4	1749.5	12.4	-7.3	-5.16667	1
2022-02-25	2022		2	25	8	5	-6.4	-9.9	-5.8	1846.5	12.4	-7.7	-4.95833	1
2022-02-25	2022		2	25	9	5	-6.5	-9.8	-6.3	1890.8	12.4	-8.1	-4.8	1
2022-02-25	2022		2	25	10	5	-6.6	-9.1	-6.5	1901.9	12.4	-8.5	-4.66667	1
2022-02-25	2022		2	25	11	5	-6.7	-8.7	-6.9	1908.2	12.4	-8.7	-4.64167	1
2022-02-25	2022		2	25	12	5	-6.8	-8.6	-7.5	1917.3	12.4	-8.9	-4.675	1
2022-02-25	2022		2	25	13	5	-6.9	-9.3	-7.9	1951.1	12.4	-9.0	-4.8	1
2022-02-25	2022		2	25	14	5	-7.1	-9.2	-8.7	1929.3	12.4	-9.2	-5.04167	1
2022-02-25	2022		2	25	15	5	-7.3	-9.5	-8.9	1911.1	12.4	-9.3	-5.375	1
2022-02-25	2022		2	25	16	5	-7.6	-9.2	-9.4	1905.6	12.4	-9.3	-5.79167	1
2022-02-25	2022		2	25	17	5	-7.8	-9	-9.7	1913.5	12.4	-9.4	-6.275	1
2022-02-25	2022		2	25	18	5	-8.1	-9.1	-9.9	1954.3	12.4	-9.3	-6.80833	1
2022-02-25	2022		2	25	19	5	-8.3	-9.3	-9.9	1956.3	12.4	-9.3	-7.30833	1
2022-02-25	2022		2	25	20	5	-8.5	-9.6	-9.8	1908.4	12.4	-9.2	-7.74167	1
2022-02-25	2022		2	25	21	5	-8.7	-10.2	-9.1	1848.9	12.4	-9.2	-8.11667	1
2022-02-25	2022		2	25	22	5	-8.8	-10.4	-8.7	1780.2	12.4	-9.2	-8.45	1
2022-02-25	2022		2	25	23	5	-9.0	-10.8	-8.6	1705.6	12.4	-9.3	-8.68333	1
2022-02-25	2022		2	25	24	5	-9.2	-10.5	-9.3	1699.3	12.4	-9.5	-8.86667	1
2022-02-26	2022		2	26	1	6	-9.3	-10.9	-9.2	1684.2	13.4	-9.7	-9.00833	0
2022-02-26	2022		2	26	2	6	-9.5	-11.3	-9.5	1643.1	13.4	-9.8	-9.15833	0
2022-02-26	2022		2	26	3	6	-9.6	-11.9	-9.2	1643.3	13.4	-10.0	-9.26667	0
2022-02-26	2022		2	26	4	6	-9.8	-12.4	-9	1633.6	13.4	-10.2	-9.33333	0
2022-02-26	2022		2	26	5	6	-9.9	-13.1	-9.1	1644.2	13.4	-10.5	-9.35833	0
2022-02-26	2022		2	26	6	6	-10.1	-13.5	-9.3	1677.0	13.4	-10.8	-9.325	0
2022-02-26	2022		2	26	7	6	-10.2	-13.3	-9.6	1741.1	13.4	-11.2	-9.275	0
2022-02-26	2022		2	26	8	6	-10.4	-13.7	-10.2	1797.2	13.4	-11.5	-9.225	0
2022-02-26	2022		2	26	9	6	-10.5	-13.2	-10.4	1823.4	13.4	-11.8	-9.2	0
2022-02-26	2022		2	26	10	6	-10.7	-12	-10.8	1808.0	13.4	-12.1	-9.23333	0
2022-02-26	2022		2	26	11	6	-10.8	-10.8	-10.5	1775.4	13.4	-12.2	-9.34167	0
2022-02-26	2022		2	26	12	6	-10.9	-9.3	-10.9	1737.8	13.4	-12.2	-9.51667	0
2022-02-26	2022		2	26	13	6	-10.9	-8.2	-11.3	1689.2	13.4	-12.1	-9.675	0
2022-02-26	2022		2	26	14	6	-10.9	-7.1	-11.9	1616.1	13.4	-11.9	-9.80833	0
2022-02-26	2022		2	26	15	6	-10.8	-5.3	-12.4	1571.0	13.4	-11.5	-9.98333	0
2022-02-26	2022		2	26	16	6	-10.6	-4.8	-13.1	1556.2	13.4	-11.0	-10.1833	0
2022-02-26	2022		2	26	17	6	-10.4	-4.5	-13.5	1598.4	13.4	-10.4	-10.45	0
2022-02-26	2022		2	26	18	6	-10.2	-5	-13.3	1689.1	13.4	-9.6	-10.7917	0
2022-02-26	2022		2	26	19	6	-10.0	-6.1	-13.7	1778.5	13.4	-8.9	-11.1583	0
2022-02-26	2022		2	26	20	6	-9.9	-6.9	-13.2	1780.9	13.4	-8.3	-11.4917	0
2022-02-26	2022		2	26	21	6	-9.8	-7.5	-12	1758.0	13.4	-7.8	-11.8333	0
2022-02-26	2022		2	26	22	6	-9.7	-8.5	-10.8	1720.8	13.4	-7.3	-12.0833	0
2022-02-26	2022		2	26	23	6	-9.6	-8.9	-9.3	1672.1	13.4	-7.0	-12.2167	0
2022-02-26	2022		2	26	24	6	-9.5	-9.2	-8.2	1621.5	13.4	-6.8	-12.2167	0
2022-02-27	2022		2	27	1	7	-9.5	-8.8	-7.1	1580.9	11.1	-6.8	-12.1167	0
2022-02-27	2022		2	27	2	7	-9.4	-8.8	-5.3	1558.9	11.1	-6.9	-11.8917	0
2022-02-27	2022		2	27	3	7	-9.3	-8.9	-4.8	1559.3	11.1	-7.0	-11.5417	0
2022-02-27	2022		2	27	4	7	-9.2	-8.9	-4.5	1566.0	11.1	-7.3	-10.9917	0
2022-02-27	2022		2	27	5	7	-9.0	-8.9	-5	1575.5	11.1	-7.7	-10.3583	0
2022-02-27	2022		2	27	6	7	-8.8	-8.8	-6.1	1601.0	11.1	-8.0	-9.64167	0
2022-02-27	2022		2	27	7	7	-8.6	-6.5	-6.9	1649.1	11.1	-8.4	-8.93333	0
2022-02-27	2022		2	27	8	7	-8.4	-6.2	-7.5	1699.3	11.1	-8.4	-8.33333	0
2022-02-27	2022		2	27	9	7	-8.0	-4.6	-8.5	1738.1	11.1	-8.3	-7.76667	0
2022-02-27	2022		2	27	10	7	-7.7	-3.8	-8.9	1753.3	11.1	-8.1	-7.29167	0
2022-02-27	2022		2	27	11	7	-7.3	-2.9	-9.2	1731.0	11.1	-7.7	-7	0
2022-02-27	2022		2	27	12	7	-7.0	-1.1	-8.8	1697.9	11.1	-7.2	-6.84167	0
2022-02-27	2022		2	27	13	7	-6.7	0.3	-8.8	1641.7	11.1	-6.5	-6.83333	0
2022-02-27	2022		2	27	14	7	-6.3	0.2	-8.9	1611.3	11.1	-5.8	-6.88333	0
2022-02-27	2022		2	27	15	7	-6.0	-0.3	-8.9	1597.6	11.1	-5.0	-7.025	0
2022-02-27	2022		2	27	16	7	-5.8	-0.6	-8.9	1601.8	11.1	-4.3	-7.325	0
2022-02-27	2022		2	27	17	7	-5.6	-0.1	-8.8	1666.9	11.1	-3.6	-7.66667	0
2022-02-27	2022		2	27	18	7	-5.5	-0.7	-6.5	1718.8	11.1	-2.9	-8.03333	0
2022-02-27	2022		2	27	19	7	-5.3	-0.8	-6.2	1737.2	11.1	-2.2	-8.35	0
2022-02-27	2022		2	27	20	7	-5.1	-1.4	-4.6	1702.1	11.1	-1.7	-8.38333	0
2022-02-27	2022		2	27	21	7	-4.8	-1.4	-3.8	1646.8	11.1	-1.3	-8.325	0
2022-02-27	2022		2	27	22	7	-4.6	-1.8</						

DATE	Year	Month	Day	HOUR	DOW	24hrAvgLag	Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLag	Weekdays
2022-02-28	2022	2	28	12	1	-3.6	-9.7	-2.2	1796.9	20.1	-6.3	-0.79167	1
2022-02-28	2022	2	28	13	1	-3.9	-8.9	-2.9	1793.7	20.1	-7.0	-0.85833	1
2022-02-28	2022	2	28	14	1	-4.3	-8.2	-1.9	1750.5	20.1	-7.5	-1.06667	1
2022-02-28	2022	2	28	15	1	-4.6	-8.5	-2.9	1722.2	20.1	-8.0	-1.325	1
2022-02-28	2022	2	28	16	1	-5.0	-7.2	-6.3	1737.0	20.1	-8.5	-1.45833	1
2022-02-28	2022	2	28	17	1	-5.3	-8.3	-8	1792.3	20.1	-8.9	-1.65	1
2022-02-28	2022	2	28	18	1	-5.6	-9	-9	1869.9	20.1	-9.0	-2.16667	1
2022-02-28	2022	2	28	19	1	-5.9	-9.6	-9.7	1946.0	20.1	-9.1	-2.775	1
2022-02-28	2022	2	28	20	1	-6.3	-9.8	-10.4	1946.5	20.1	-9.2	-3.45833	1
2022-02-28	2022	2	28	21	1	-6.7	-9.8	-10.1	1900.5	20.1	-9.2	-4.15	1
2022-02-28	2022	2	28	22	1	-7.0	-10.2	-10.4	1835.2	20.1	-9.1	-4.9	1
2022-02-28	2022	2	28	23	1	-7.4	-10.1	-9.7	1742.0	20.1	-9.1	-5.59167	1
2022-02-28	2022	2	28	24	1	-7.7	-10.2	-8.9	1726.9	20.1	-9.1	-6.30833	1
2022-03-01	2022	3	1	1	2	-8.1	-10.3	-8.2	1712.9	9.3	-9.2	-6.95833	1
2022-03-01	2022	3	1	2	2	-8.4	-10.8	-8.5	1693.4	9.3	-9.3	-7.51667	1
2022-03-01	2022	3	1	3	2	-8.7	-11.4	-7.2	1688.4	9.3	-9.5	-7.95833	1
2022-03-01	2022	3	1	4	2	-9.1	-12.2	-8.3	1698.1	9.3	-9.7	-8.50833	1
2022-03-01	2022	3	1	5	2	-9.5	-12.7	-9	1724.3	9.3	-10.1	-8.86667	1
2022-03-01	2022	3	1	6	2	-9.8	-13.9	-9.6	1789.2	9.3	-10.5	-9.03333	1
2022-03-01	2022	3	1	7	2	-10.0	-13	-9.8	1925.5	9.3	-10.9	-9.11667	1
2022-03-01	2022	3	1	8	2	-10.2	-13.2	-9.8	2010.5	9.3	-11.2	-9.16667	1
2022-03-01	2022	3	1	9	2	-10.3	-12.5	-10.2	1994.8	9.3	-11.5	-9.175	1
2022-03-01	2022	3	1	10	2	-10.4	-10.9	-10.1	1920.4	9.3	-11.7	-9.125	1
2022-03-01	2022	3	1	11	2	-10.5	-9.8	-10.2	1828.3	9.3	-11.8	-9.13333	1
2022-03-01	2022	3	1	12	2	-10.4	-8.5	-10.3	1745.7	9.3	-11.7	-9.10833	1
2022-03-01	2022	3	1	13	2	-10.4	-6.3	-10.8	1703.0	9.3	-11.6	-9.15	1
2022-03-01	2022	3	1	14	2	-10.3	-5.9	-11.4	1631.1	9.3	-11.3	-9.26667	1
2022-03-01	2022	3	1	15	2	-10.2	-3.5	-12.2	1565.2	9.3	-10.9	-9.48333	1
2022-03-01	2022	3	1	16	2	-10.0	-3.1	-12.7	1550.9	9.3	-10.2	-9.725	1
2022-03-01	2022	3	1	17	2	-9.8	-2.8	-13.9	1589.6	9.3	-9.4	-10.1417	1
2022-03-01	2022	3	1	18	2	-9.6	-3.4	-13	1683.3	9.3	-8.6	-10.5083	1
2022-03-01	2022	3	1	19	2	-9.3	-4.6	-13.2	1776.5	9.3	-7.7	-10.9167	1
2022-03-01	2022	3	1	20	2	-9.1	-5.1	-12.5	1784.0	9.3	-7.0	-11.2	1
2022-03-01	2022	3	1	21	2	-8.9	-5	-10.9	1749.3	9.3	-6.4	-11.4833	1
2022-03-01	2022	3	1	22	2	-8.7	-3.8	-9.8	1674.4	9.3	-5.7	-11.7083	1
2022-03-01	2022	3	1	23	2	-8.5	-3.1	-8.5	1582.7	9.3	-5.2	-11.7667	1
2022-03-01	2022	3	1	24	2	-8.2	-2.8	-6.3	1540.3	9.3	-4.6	-11.7417	1
2022-03-02	2022	3	2	1	3	-7.9	-2.3	-5.9	1508.9	19.8	-4.1	-11.6	1
2022-03-02	2022	3	2	2	3	-7.5	-1.4	-3.5	1474.1	19.8	-3.8	-11.2667	1
2022-03-02	2022	3	2	3	3	-7.1	-0.4	-3.1	1437.7	19.8	-3.4	-10.8583	1
2022-03-02	2022	3	2	4	3	-6.7	0.5	-2.8	1412.5	19.8	-3.2	-10.2	1
2022-03-02	2022	3	2	5	3	-6.1	-0.7	-3.4	1417.7	19.8	-2.9	-9.44167	1
2022-03-02	2022	3	2	6	3	-5.6	0.4	-4.6	1458.8	19.8	-2.7	-8.61667	1
2022-03-02	2022	3	2	7	3	-5.1	0.8	-5.1	1568.9	19.8	-2.4	-7.74167	1
2022-03-02	2022	3	2	8	3	-4.5	0.7	-5	1647.9	19.8	-1.9	-7.04167	1
2022-03-02	2022	3	2	9	3	-3.9	0.5	-3.8	1686.4	19.8	-1.4	-6.36667	1
2022-03-02	2022	3	2	10	3	-3.4	1.2	-3.1	1677.4	19.8	-1.0	-5.74167	1
2022-03-02	2022	3	2	11	3	-2.9	2.9	-2.8	1654.7	19.8	-0.6	-5.15	1
2022-03-02	2022	3	2	12	3	-2.3	3.9	-2.3	1631.6	19.8	-0.1	-4.59167	1
2022-03-02	2022	3	2	13	3	-1.8	4.2	-1.4	1607.5	19.8	0.5	-4.11667	1
2022-03-02	2022	3	2	14	3	-1.4	4.5	-0.4	1534.1	19.8	1.1	-3.78333	1
2022-03-02	2022	3	2	15	3	-0.9	4.6	0.5	1479.4	19.8	1.5	-3.40833	1
2022-03-02	2022	3	2	16	3	-0.6	4.4	-0.7	1479.2	19.8	2.0	-3.15	1
2022-03-02	2022	3	2	17	3	-0.3	3.4	0.4	1549.3	19.8	2.3	-2.85	1
2022-03-02	2022	3	2	18	3	0.0	2	0.8	1607.0	19.8	2.6	-2.675	1
2022-03-02	2022	3	2	19	3	0.2	0.9	0.7	1646.6	19.8	2.8	-2.35833	1
2022-03-02	2022	3	2	20	3	0.4	0.2	0.5	1637.9	19.8	2.8	-1.90833	1
2022-03-02	2022	3	2	21	3	0.7	-0.4	1.2	1597.5	19.8	2.7	-1.425	1
2022-03-02	2022	3	2	22	3	0.8	-1	2.9	1534.8	19.8	2.7	-0.96667	1
2022-03-02	2022	3	2	23	3	1.0	-1.1	3.9	1457.2	19.8	2.5	-0.55	1
2022-03-02	2022	3	2	24	3	1.0	-2	4.2	1448.9	19.8	2.1	-0.05	1
2022-03-03	2022	3	3	1	4	1.1	-2.9	4.5	1445.7	11.7	1.6	0.508333	1
2022-03-03	2022	3	3	2	4	1.1	-3.8	4.6	1425.0	11.7	1.1	1.05	1
2022-03-03	2022	3	3	3	4	1.0	-3.8	4.4	1410.0	11.7	0.4	1.541667	1
2022-03-03	2022	3	3	4	4	0.8	-4.6	3.4	1402.7	11.7	-0.3	1.958333	1
2022-03-03	2022	3	3	5	4	0.6	-4.4	2	1414.8	11.7	-1.1	2.283333	1
2022-03-03	2022	3	3	6	4	0.4	-4.2	0.9	1474.5	11.7	-1.7	2.625	1
2022-03-03	2022	3	3	7	4	0.3	-5	0.2	1596.1	11.7	-2.3	2.758333	1
2022-03-03	2022	3	3	8	4	0.0	-5	-0.4	1680.8	11.7	-2.8	2.766667	1
2022-03-03	2022	3	3	9	4	-0.2	-3.5	-1	1723.7	11.7	-3.2	2.725	1
2022-03-03	2022	3	3	10	4	-0.4	-3.3	-1.1	1730.3	11.7	-3.4	2.65	1
2022-03-03	2022	3	3	11	4	-0.6	-3.2	-2	1720.8	11.7	-3.6	2.466667	1
2022-03-03	2022	3	3	12	4	-0.8	-3.1	-2.9	1727.5	11.7	-3.8	2.133333	1
2022-03-03	2022	3	3	13	4	-1.1	-3.2	-3.8	1749.7	11.7	-3.9	1.641667	1
2022-03-03	2022	3	3	14	4	-1.4	-3.4	-3.8	1734.3	11.7	-3.9	1.05	1
2022-03-03	2022	3	3	15	4	-1.8	-3.7	-4.6	1720.9	11.7	-3.9	0.358333	1
2022-03-03	2022	3	3	16	4	-2.1	-3.9	-4.4	1715.1	11.7	-3.9	-0.34167	1
2022-03-03	2022	3	3	17	4	-2.5	-4	-4.2	1728.3	11.7	-3.8	-1.09167	1
2022-03-03	2022	3	3	18	4	-2.8	-3.8	-5	1761.3	11.7	-3.8	-1.74167	1
2022-03-03	2022	3	3	19	4	-3.0	-4.1	-5	1796.4	11.7	-3.8	-2.25833	1
2022-03-03	2022	3	3	20	4	-3.2	-5.1	-3.5	1787.3	11.7	-3.7	-2.75	1
2022-03-03	2022	3	3	21	4	-3.4	-6.1	-3.3	1750.9	11.7	-3.7	-3.18333	1
2022-03-03	2022	3	3	22	4	-3.7	-7.6	-3.2	1690.2	11.7	-3.9	-3.44167	1
2022-03-03	2022	3	3	23	4	-4.0	-8.4	-3.1	1611.1	11.7	-4.3	-3.63333	1
2022-03-03	2022	3	3	24	4	-4.3	-8	-3.2	1605.9	11.7	-4.7	-3.80833	1
2022-03-04	2022	3	4	1	5	-4.5	-8.6	-3.4	1596.2	14.5	-5.1	-3.9	1
2022-03-04	2022	3	4	2	5	-4.7	-9.8	-3.7	1595.1	14.5	-5.6	-3.925	1
2022-03-04	2022	3	4	3	5	-5.0	-10.8	-3.9	1597.3	14.5	-6.1	-3.89167	1
2022-03-04	2022	3	4	4	5	-5.3	-11.7	-4	1621.6	14.5	-6.7	-3.88333	1
2022-03-04	2022	3	4	5	5	-5.6	-12.8	-3.8	1663.0	14.5	-7.3	-3.825	1
2022-03-04	2022	3	4	6	5	-5.9	-13.6	-4.1	1738.2	14.5	-8.1	-3.79167	1
2022-03-04	2022	3	4	7	5	-6.3	-14.1	-5.1	1879.3	14.5	-8.9	-3.75833	1
2022-03-04	2022	3	4	8	5	-6.7	-14.5	-6.1	1943.4	14.5	-9.7	-3.68333	1
2022-03-04	2022	3	4	9	5	-7.1	-14.4	-7.6	1890.7	14.5	-10.5	-3.69167	1
2022-03-04	2022	3	4	10	5	-7.6	-14.2	-8.4	1885.0	14.5	-11.2	-3.90833	1
2022-03-04	2022	3	4	11	5	-8.0	-13.3	-8	1847.3	14.5	-11.7	-4.26667	1
2022-03-04	2022	3	4	12	5	-8.4	-11.8	-8.6	1796.0	14.5	-12.2	-4.7	1
2022-03-04	2022	3	4	13	5	-8.8	-10.3	-9.8	1767.7	14.5	-12.5	-5.10833	1
2022-03-04	2022	3	4	14	5	-9.1	-8.9	-10.8					

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLag	Temp	LagTemp	12hrLoad	Wind	12hrAvg	12hrAvgLag	Weekdays	
2022-03-04	2022		3	4	24	5	-10.2	-8.7	-10.3	1716.4	14.5	-8.3	-12.15	1
2022-03-05	2022		3	5	1	6	-10.2	-8.3	-8.9	1687.8	10.7	-8.0	-12.4667	0
2022-03-05	2022		3	5	2	6	-10.2	-8.9	-7.6	1662.6	10.7	-7.8	-12.6083	0
2022-03-05	2022		3	5	3	6	-10.2	-9.2	-6.8	1641.4	10.7	-7.8	-12.5333	0
2022-03-05	2022		3	5	4	6	-10.1	-7.6	-6.4	1632.9	10.7	-8.0	-12.2667	0
2022-03-05	2022		3	5	5	6	-9.9	-7.2	-6.1	1631.4	10.7	-8.0	-11.8583	0
2022-03-05	2022		3	5	6	6	-9.7	-7.9	-6.9	1659.7	10.7	-8.1	-11.325	0
2022-03-05	2022		3	5	7	6	-9.5	-8.2	-7.6	1715.5	10.7	-8.2	-10.7	0
2022-03-05	2022		3	5	8	6	-9.2	-9.2	-8.4	1766.7	10.7	-8.4	-10.1	0
2022-03-05	2022		3	5	9	6	-9.0	-7.2	-9.1	1758.7	10.7	-8.5	-9.525	0
2022-03-05	2022		3	5	10	6	-8.7	-5.8	-9.1	1717.5	10.7	-8.4	-9.025	0
2022-03-05	2022		3	5	11	6	-8.4	-4.3	-8.7	1680.3	10.7	-8.1	-8.6	0
2022-03-05	2022		3	5	12	6	-8.0	-3.5	-8.3	1634.4	10.7	-7.7	-8.25	0
2022-03-05	2022		3	5	13	6	-7.6	-1.9	-8.9	1581.6	10.7	-7.3	-7.99167	0
2022-03-05	2022		3	5	14	6	-7.3	-0.8	-9.2	1514.9	10.7	-6.7	-7.825	0
2022-03-05	2022		3	5	15	6	-6.9	-0.5	-7.6	1465.6	10.7	-6.1	-7.825	0
2022-03-05	2022		3	5	16	6	-6.7	-0.3	-7.2	1443.0	10.7	-5.3	-7.95833	0
2022-03-05	2022		3	5	17	6	-6.4	0.1	-7.9	1479.7	10.7	-4.7	-8.025	0
2022-03-05	2022		3	5	18	6	-6.1	0.2	-8.2	1556.6	10.7	-4.1	-8.09167	0
2022-03-05	2022		3	5	19	6	-5.8	-0.6	-9.2	1639.5	10.7	-3.5	-8.24167	0
2022-03-05	2022		3	5	20	6	-5.6	-1.2	-7.2	1640.6	10.7	-2.8	-8.35	0
2022-03-05	2022		3	5	21	6	-5.3	-1.8	-5.8	1605.1	10.7	-2.2	-8.48333	0
2022-03-05	2022		3	5	22	6	-5.0	-2.3	-4.3	1553.3	10.7	-1.7	-8.38333	0
2022-03-05	2022		3	5	23	6	-4.8	-2.4	-3.5	1495.1	10.7	-1.4	-8.10833	0
2022-03-05	2022		3	5	24	6	-4.5	-2.6	-1.9	1457.4	10.7	-1.3	-7.70833	0
2022-03-06	2022		3	6	1	7	-4.2	-2.4	-0.8	1412.7	11.3	-1.2	-7.275	0
2022-03-06	2022		3	6	2	7	-4.0	-2.3	-0.5	1390.8	11.3	-1.2	-6.74167	0
2022-03-06	2022		3	6	3	7	-3.7	-2.1	-0.3	1387.4	11.3	-1.3	-6.06667	0
2022-03-06	2022		3	6	4	7	-3.4	-2.5	0.1	1394.0	11.3	-1.5	-5.34167	0
2022-03-06	2022		3	6	5	7	-3.2	-2.3	0.2	1401.0	11.3	-1.7	-4.73333	0
2022-03-06	2022		3	6	6	7	-3.0	-1.9	-0.6	1416.4	11.3	-1.9	-4.125	0
2022-03-06	2022		3	6	7	7	-2.7	-1.9	-1.2	1453.4	11.3	-2.0	-3.45	0
2022-03-06	2022		3	6	8	7	-2.5	-1.1	-1.8	1512.3	11.3	-2.1	-2.81667	0
2022-03-06	2022		3	6	9	7	-2.1	-0.5	-2.3	1573.8	11.3	-2.1	-2.15	0
2022-03-06	2022		3	6	10	7	-1.9	1	-2.4	1633.9	11.3	-2.0	-1.7	0
2022-03-06	2022		3	6	11	7	-1.6	0.1	-2.6	1664.3	11.3	-1.8	-1.40833	0
2022-03-06	2022		3	6	12	7	-1.4	0.4	-2.4	1686.8	11.3	-1.5	-1.25	0
2022-03-06	2022		3	6	13	7	-1.2	0.6	-2.3	1696.6	11.3	-1.3	-1.175	0
2022-03-06	2022		3	6	14	7	-1.1	1	-2.1	1675.5	11.3	-1.0	-1.21667	0
2022-03-06	2022		3	6	15	7	-1.1	1.3	-2.5	1663.3	11.3	-0.8	-1.34167	0
2022-03-06	2022		3	6	16	7	-1.0	1.5	-2.3	1666.8	11.3	-0.5	-1.475	0
2022-03-06	2022		3	6	17	7	-0.9	1.9	-1.9	1701.5	11.3	-0.2	-1.65833	0
2022-03-06	2022		3	6	18	7	-0.8	3	-1.9	1690.1	11.3	0.2	-1.85833	0
2022-03-06	2022		3	6	19	7	-0.7	4.4	-1.1	1657.5	11.3	0.6	-2.03333	0
2022-03-06	2022		3	6	20	7	-0.5	4.7	-0.5	1608.6	11.3	1.1	-2.14167	0
2022-03-06	2022		3	6	21	7	-0.3	4.3	1	1518.5	11.3	1.6	-2.13333	0
2022-03-06	2022		3	6	22	7	0.0	5	0.1	1425.3	11.3	2.0	-2.025	0
2022-03-06	2022		3	6	23	7	0.3	6.1	0.4	1322.5	11.3	2.4	-1.75	0
2022-03-06	2022		3	6	24	7	0.7	6.1	0.6	1238.1	11.3	2.9	-1.54167	0
2022-03-07	2022		3	7	1	1	1.0	6	1	1184.6	9.5	3.3	-1.29167	1
2022-03-07	2022		3	7	2	1	1.4	5.6	1.3	1161.3	9.5	3.8	-1.04167	1
2022-03-07	2022		3	7	3	1	1.7	5.5	1.5	1141.9	9.5	4.2	-0.76667	1
2022-03-07	2022		3	7	4	1	2.0	5.4	1.9	1132.1	9.5	4.5	-0.48333	1
2022-03-07	2022		3	7	5	1	2.3	5.8	3	1144.6	9.5	4.8	-0.15	1
2022-03-07	2022		3	7	6	1	2.7	6	4.4	1199.5	9.5	5.2	0.2	1
2022-03-07	2022		3	7	7	1	3.0	5.4	4.7	1309.1	9.5	5.4	0.608333	1
2022-03-07	2022		3	7	8	1	3.3	6.1	4.3	1409.9	9.5	5.5	1.133333	1
2022-03-07	2022		3	7	9	1	3.6	6.7	5	1435.8	9.5	5.6	1.616667	1
2022-03-07	2022		3	7	10	1	3.9	7.7	6.1	1405.6	9.5	5.8	2.016667	1
2022-03-07	2022		3	7	11	1	4.2	8.4	6.1	1382.4	9.5	6.0	2.35	1
2022-03-07	2022		3	7	12	1	4.5	8.6	6	1382.9	9.5	6.2	2.85	1
2022-03-07	2022		3	7	13	1	4.9	7.5	5.6	1378.5	9.5	6.4	3.325	1
2022-03-07	2022		3	7	14	1	5.2	7.6	5.5	1336.4	9.5	6.6	3.775	1
2022-03-07	2022		3	7	15	1	5.4	7.2	5.4	1318.2	9.5	6.7	4.158333	1
2022-03-07	2022		3	7	16	1	5.7	8	5.8	1317.1	9.5	6.9	4.508333	1
2022-03-07	2022		3	7	17	1	6.0	8.3	6	1383.6	9.5	7.1	4.833333	1
2022-03-07	2022		3	7	18	1	6.2	6.1	5.4	1445.7	9.5	7.3	5.158333	1
2022-03-07	2022		3	7	19	1	6.4	4.7	6.1	1471.7	9.5	7.3	5.408333	1
2022-03-07	2022		3	7	20	1	6.4	4.2	6.7	1452.2	9.5	7.2	5.491667	1
2022-03-07	2022		3	7	21	1	6.3	3	7.7	1405.9	9.5	7.1	5.608333	1
2022-03-07	2022		3	7	22	1	6.3	3.1	8.4	1346.4	9.5	6.8	5.808333	1
2022-03-07	2022		3	7	23	1	6.2	2.8	8.6	1270.5	9.5	6.4	6.033333	1
2022-03-07	2022		3	7	24	1	6.1	2.6	7.5	1240.6	9.5	5.9	6.225	1
2022-03-08	2022		3	8	1	2	5.9	2.7	7.6	1208.1	25.5	5.4	6.433333	1
2022-03-08	2022		3	8	2	2	5.8	3.3	7.2	1171.5	25.5	5.0	6.558333	1
2022-03-08	2022		3	8	3	2	5.7	6.1	8	1132.7	25.5	4.7	6.725	1
2022-03-08	2022		3	8	4	2	5.7	8.2	8.3	1100.1	25.5	4.6	6.866667	1
2022-03-08	2022		3	8	5	2	5.8	8.2	6.1	1088.6	25.5	4.6	7.083333	1
2022-03-08	2022		3	8	6	2	5.9	8.1	4.7	1128.6	25.5	4.6	7.291667	1
2022-03-08	2022		3	8	7	2	6.0	8.6	4.2	1261.3	25.5	4.8	7.3	1
2022-03-08	2022		3	8	8	2	6.2	7.2	3	1378.7	25.5	5.1	7.241667	1
2022-03-08	2022		3	8	9	2	6.2	5.1	3.1	1412.1	25.5	5.3	7.083333	1
2022-03-08	2022		3	8	10	2	6.1	4.1	2.8	1417.2	25.5	5.5	6.775	1
2022-03-08	2022		3	8	11	2	6.0	4.1	2.6	1416.3	25.5	5.6	6.391667	1
2022-03-08	2022		3	8	12	2	5.8	4.3	2.7	1440.5	25.5	5.7	5.925	1
2022-03-08	2022		3	8	13	2	5.6	3.5	3.3	1462.3	25.5	5.8	5.425	1
2022-03-08	2022		3	8	14	2	5.5	3.1	6.1	1468.1	25.5	5.9	5.025	1
2022-03-08	2022		3	8	15	2	5.3	2.5	8.2	1477.7	25.5	5.9	4.666667	1
2022-03-08	2022		3	8	16	2	5.1	2.5	8.2	1498.5	25.5	5.6	4.575	1
2022-03-08	2022		3	8	17	2	4.9	2.4	8.1	1545.4	25.5	5.1	4.591667	1
2022-03-08	2022		3	8	18	2	4.6	1.8	8.6	1611.9	25.5	4.6	4.583333	1
2022-03-08	2022		3	8	19	2	4.4	1.1	7.2	1636.6	25.5	4.1	4.75	1
2022-03-08	2022		3	8	20	2	4.3	0.3	5.1	1632.8	25.5	3.5	5.075	1
2022-03-08	2022		3	8	21	2	4.1	-0.3	4.1	1620.3	25.5	2.9	5.325	1
2022-03-08	2022		3	8	22	2	4.0	-0.7	4.1	1576.4	25.5	2.5	5.5	1
2022-03-08	2022		3	8	23	2	3.8	-1.2	4.3	1495.8	25.5	2.1	5.583333	1
2022-														

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLag	Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLag	Weekdays
2022-03-09	2022	3	9	12	3	-1.0	-1.6	-2.1	1541.5	13.4	-3.6	1.608333	1
2022-03-09	2022	3	9	13	3	-1.3	-0.9	-2.8	1530.3	13.4	-3.6	1.125	1
2022-03-09	2022	3	9	14	3	-1.4	0.1	-3.3	1481.9	13.4	-3.5	0.658333	1
2022-03-09	2022	3	9	15	3	-1.6	0.7	-3.8	1444.5	13.4	-3.3	0.166667	1
2022-03-09	2022	3	9	16	3	-1.6	0.4	-4.2	1471.3	13.4	-3.0	-0.31667	1
2022-03-09	2022	3	9	17	3	-1.7	-0.1	-4.7	1545.3	13.4	-2.6	-0.84167	1
2022-03-09	2022	3	9	18	3	-1.8	0	-5.1	1616.0	13.4	-2.3	-1.39167	1
2022-03-09	2022	3	9	19	3	-1.9	0	-5.3	1639.3	13.4	-1.9	-1.93333	1
2022-03-09	2022	3	9	20	3	-1.9	0.5	-4.5	1619.1	13.4	-1.4	-2.45	1
2022-03-09	2022	3	9	21	3	-1.9	0.7	-3.7	1577.7	13.4	-1.0	-2.91667	1
2022-03-09	2022	3	9	22	3	-1.9	0.6	-2.4	1505.7	13.4	-0.5	-3.26667	1
2022-03-09	2022	3	9	23	3	-1.8	0.5	-1.6	1417.1	13.4	-0.2	-3.51667	1
2022-03-09	2022	3	9	24	3	-1.8	-0.6	-0.9	1384.2	13.4	0.1	-3.61667	1
2022-03-10	2022	3	10	1	4	-1.7	-1	0.1	1361.8	6.9	0.2	-3.625	1
2022-03-10	2022	3	10	2	4	-1.7	-1.1	0.7	1330.6	6.9	0.2	-3.525	1
2022-03-10	2022	3	10	3	4	-1.6	-1.3	0.4	1298.6	6.9	0.1	-3.28333	1
2022-03-10	2022	3	10	4	4	-1.5	-1.3	-0.1	1284.3	6.9	-0.1	-2.95	1
2022-03-10	2022	3	10	5	4	-1.4	-1.4	0	1296.7	6.9	-0.3	-2.6	1
2022-03-10	2022	3	10	6	4	-1.3	-1.2	0	1348.7	6.9	-0.4	-2.25833	1
2022-03-10	2022	3	10	7	4	-1.2	-1.1	0.5	1478.3	6.9	-0.5	-1.86667	1
2022-03-10	2022	3	10	8	4	-1.0	-2.2	0.7	1561.3	6.9	-0.6	-1.44167	1
2022-03-10	2022	3	10	9	4	-0.9	-0.4	0.6	1535.9	6.9	-0.8	-0.95833	1
2022-03-10	2022	3	10	10	4	-0.7	0.4	0.5	1469.6	6.9	-0.9	-0.525	1
2022-03-10	2022	3	10	11	4	-0.5	2.4	-0.6	1418.3	6.9	-0.9	-0.16667	1
2022-03-10	2022	3	10	12	4	-0.3	3	-1	1399.2	6.9	-0.7	0.075	1
2022-03-10	2022	3	10	13	4	-0.1	3.1	-1.1	1372.2	6.9	-0.4	0.158333	1
2022-03-10	2022	3	10	14	4	0.0	3.5	-1.3	1323.9	6.9	-0.1	0.15	1
2022-03-10	2022	3	10	15	4	0.2	4.7	-1.3	1288.5	6.9	0.3	0.05	1
2022-03-10	2022	3	10	16	4	0.3	4.8	-1.4	1288.6	6.9	0.8	-0.11667	1
2022-03-10	2022	3	10	17	4	0.5	5.2	-1.2	1322.6	6.9	1.3	-0.25833	1
2022-03-10	2022	3	10	18	4	0.7	4.7	-1.1	1379.7	6.9	1.9	-0.36667	1
2022-03-10	2022	3	10	19	4	0.9	2.9	-2.2	1443.3	6.9	2.3	-0.46667	1
2022-03-10	2022	3	10	20	4	1.1	1.8	-0.4	1468.0	6.9	2.7	-0.55833	1
2022-03-10	2022	3	10	21	4	1.1	1.1	0.4	1442.8	6.9	3.0	-0.78333	1
2022-03-10	2022	3	10	22	4	1.1	0.7	2.4	1394.4	6.9	3.1	-0.875	1
2022-03-10	2022	3	10	23	4	1.1	0.8	3	1312.1	6.9	3.2	-0.89167	1
2022-03-10	2022	3	10	24	4	1.1	1.7	3.1	1286.8	6.9	3.0	-0.73333	1
2022-03-11	2022	3	11	1	5	1.2	1.8	3.5	1258.3	8.7	2.9	-0.43333	1
2022-03-11	2022	3	11	2	5	1.4	1.7	4.7	1234.7	8.7	2.8	-0.09167	1
2022-03-11	2022	3	11	3	5	1.5	1.2	4.8	1218.4	8.7	2.7	0.291667	1
2022-03-11	2022	3	11	4	5	1.6	0.6	5.2	1215.7	8.7	2.4	0.791667	1
2022-03-11	2022	3	11	5	5	1.7	0.4	4.7	1240.7	8.7	2.0	1.3	1
2022-03-11	2022	3	11	6	5	1.7	-0.3	2.9	1307.0	8.7	1.6	1.85	1
2022-03-11	2022	3	11	7	5	1.8	-1.1	1.8	1433.6	8.7	1.2	2.341667	1
2022-03-11	2022	3	11	8	5	1.8	0	1.1	1522.5	8.7	0.9	2.675	1
2022-03-11	2022	3	11	9	5	1.9	1.3	0.7	1490.2	8.7	0.7	3.008333	1
2022-03-11	2022	3	11	10	5	1.9	2.8	0.8	1413.6	8.7	0.7	3.133333	1
2022-03-11	2022	3	11	11	5	2.0	3.8	1.7	1351.0	8.7	0.9	3.158333	1
2022-03-11	2022	3	11	12	5	2.1	4.6	1.8	1308.7	8.7	1.2	3.025	1
2022-03-11	2022	3	11	13	5	2.2	4.1	1.7	1276.4	8.7	1.4	2.916667	1
2022-03-11	2022	3	11	14	5	2.2	4.1	1.2	1234.5	8.7	1.6	2.808333	1
2022-03-11	2022	3	11	15	5	2.2	4.9	0.6	1217.6	8.7	1.8	2.658333	1
2022-03-11	2022	3	11	16	5	2.2	4.6	0.4	1215.4	8.7	2.1	2.366667	1
2022-03-11	2022	3	11	17	5	2.2	4.3	-0.3	1254.4	8.7	2.4	2.016667	1
2022-03-11	2022	3	11	18	5	2.2	4	-1.1	1312.1	8.7	2.8	1.616667	1
2022-03-11	2022	3	11	19	5	2.2	2.6	0	1377.2	8.7	3.1	1.2	1
2022-03-11	2022	3	11	20	5	2.1	1.9	1.3	1380.4	8.7	3.4	0.866667	1
2022-03-11	2022	3	11	21	5	2.2	1.6	2.8	1352.7	8.7	3.6	0.716667	1
2022-03-11	2022	3	11	22	5	2.2	1.1	3.8	1311.3	8.7	3.6	0.733333	1
2022-03-11	2022	3	11	23	5	2.2	1.3	4.6	1256.1	8.7	3.5	0.908333	1
2022-03-11	2022	3	11	24	5	2.2	0.7	4.1	1243.2	8.7	3.3	1.158333	1
2022-03-12	2022	3	12	1	6	2.2	0.4	4.1	1221.3	22.4	2.9	1.4	0
2022-03-12	2022	3	12	2	6	2.1	1.2	4.9	1189.5	22.4	2.6	1.591667	0
2022-03-12	2022	3	12	3	6	2.1	1.1	4.6	1163.9	22.4	2.4	1.791667	0
2022-03-12	2022	3	12	4	6	2.1	0.8	4.3	1154.0	22.4	2.1	2.1	0
2022-03-12	2022	3	12	5	6	2.1	0.5	4	1161.6	22.4	1.8	2.433333	0
2022-03-12	2022	3	12	6	6	2.1	0.9	2.6	1186.9	22.4	1.4	2.758333	0
2022-03-12	2022	3	12	7	6	2.1	1.1	1.9	1235.8	22.4	1.2	3.116667	0
2022-03-12	2022	3	12	8	6	2.2	1.6	1.6	1305.6	22.4	1.1	3.425	0
2022-03-12	2022	3	12	9	6	2.3	2.6	1.1	1398.0	22.4	1.0	3.583333	0
2022-03-12	2022	3	12	10	6	2.4	3.6	1.3	1458.8	22.4	1.1	3.608333	0
2022-03-12	2022	3	12	11	6	2.4	5.1	0.7	1448.2	22.4	1.3	3.466667	0
2022-03-12	2022	3	12	12	6	2.4	5	0.4	1462.9	22.4	1.6	3.258333	0
2022-03-12	2022	3	12	13	6	2.5	5.1	1.2	1457.3	22.4	2.0	2.933333	0
2022-03-12	2022	3	12	14	6	2.5	5.5	1.1	1425.4	22.4	2.4	2.625	0
2022-03-12	2022	3	12	15	6	2.6	7	0.8	1404.8	22.4	2.7	2.383333	0
2022-03-12	2022	3	12	16	6	2.7	7.7	0.5	1403.1	22.4	3.2	2.066667	0
2022-03-12	2022	3	12	17	6	2.8	9.2	0.9	1421.8	22.4	3.8	1.75	0
2022-03-12	2022	3	12	18	6	3.0	9	1.1	1423.9	22.4	4.5	1.433333	0
2022-03-12	2022	3	12	19	6	3.2	10.3	1.6	1383.2	22.4	5.2	1.175	0
2022-03-12	2022	3	12	20	6	3.5	10.6	2.6	1322.4	22.4	6.0	1.05	0
2022-03-12	2022	3	12	21	6	3.9	11.2	3.6	1247.1	22.4	6.7	1.025	0
2022-03-12	2022	3	12	22	6	4.3	11	5.1	1173.2	22.4	7.4	1.108333	0
2022-03-12	2022	3	12	23	6	4.7	10.8	5	1098.0	22.4	8.1	1.316667	0
2022-03-12	2022	3	12	24	6	5.1	9.8	5.1	1051.6	22.4	8.5	1.633333	0
2022-03-13	2022	3	13	1	7	5.5	9	5.5	1026.7	25.0	8.9	1.991667	0
2022-03-13	2022	3	13	2	7	5.8	7.3	7	1011.7	25.0	9.3	2.383333	0
2022-03-13	2022	3	13	3	7	6.1	5.7	7.7	1020.3	25.0	9.4	2.741667	0
2022-03-13	2022	3	13	4	7	6.3	3.2	9.2	1028.9	25.0	9.3	3.233333	0
2022-03-13	2022	3	13	5	7	6.4	2	9	1049.9	25.0	8.9	3.808333	0
2022-03-13	2022	3	13	6	7	6.4	0.7	10.3	1091.4	25.0	8.3	4.533333	0
2022-03-13	2022	3	13	7	7	6.4	0	10.6	1174.8	25.0	7.6	5.208333	0
2022-03-13	2022	3	13	8	7	6.4	-1.2	11.2	1261.1	25.0	6.8	5.975	0
2022-03-13	2022	3	13	9	7	6.3	-2.4	11	1380.0	25.0	5.8	6.725	0
2022-03-13	2022	3	13	10	7	6.1	-3.5	10.8	1489.8	25.0	4.7	7.441667	0
2022-03-13	2022	3	13	11	7	5.8	-2.5	9.8	1547.9	25.0	3.5	8.058333	0
2022-03-13	2022	3	13	12	7	5.4	-3.2	9	1588.3	25.0	2.3	8.533333	0
2022-03-13	2022	3	13	13	7	5.1	-2.4	7.3	1586.4	25.0	1.3	8.933333	0
2022-03-13	2022	3	13	1									

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLa	g Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLa	g Weekdays	
2022-03-13	2022	3	13	13	24	7	0.2	-2	-2.4	1443.0	25.0	-2.0	2.341667	0
2022-03-14	2022	3	14	14	1	1	-0.3	-2.2	-1.3	1396.2	11.2	-1.9	1.258333	1
2022-03-14	2022	3	14	14	2	1	-0.8	-2.5	-2.2	1376.5	11.2	-1.9	0.308333	1
2022-03-14	2022	3	14	14	3	1	-1.2	-3.1	-2.1	1360.9	11.2	-2.0	-0.40833	1
2022-03-14	2022	3	14	14	4	1	-1.5	-3.4	-1.5	1366.0	11.2	-2.0	-1.06667	1
2022-03-14	2022	3	14	14	5	1	-1.8	-3.6	-1.3	1385.5	11.2	-2.1	-1.50833	1
2022-03-14	2022	3	14	14	6	1	-2.1	-3.7	-1.8	1443.0	11.2	-2.3	-1.8	1
2022-03-14	2022	3	14	14	7	1	-2.2	-4.2	-2	1558.7	11.2	-2.5	-1.96667	1
2022-03-14	2022	3	14	14	8	1	-2.4	-4.6	-2	1660.6	11.2	-2.7	-2.11667	1
2022-03-14	2022	3	14	14	9	1	-2.6	-3.1	-1.9	1695.7	11.2	-2.9	-2.18333	1
2022-03-14	2022	3	14	14	10	1	-2.6	-2.2	-1.9	1686.7	11.2	-3.0	-2.15	1
2022-03-14	2022	3	14	14	11	1	-2.5	-1.2	-2	1629.0	11.2	-3.0	-2.01667	1
2022-03-14	2022	3	14	14	12	1	-2.5	-0.1	-2.2	1594.8	11.2	-3.0	-1.96667	1
2022-03-14	2022	3	14	14	13	1	-2.3	0.7	-2.5	1572.1	11.2	-2.8	-1.86667	1
2022-03-14	2022	3	14	14	14	1	-2.2	2.3	-3.1	1514.9	11.2	-2.6	-1.85	1
2022-03-14	2022	3	14	14	15	1	-2.1	2.7	-3.4	1451.9	11.2	-2.2	-1.95	1
2022-03-14	2022	3	14	14	16	1	-1.9	3.1	-3.6	1425.2	11.2	-1.7	-2.025	1
2022-03-14	2022	3	14	14	17	1	-1.6	2.7	-3.7	1436.0	11.2	-1.2	-2.13333	1
2022-03-14	2022	3	14	14	18	1	-1.5	1.5	-4.2	1458.7	11.2	-0.6	-2.30833	1
2022-03-14	2022	3	14	14	19	1	-1.4	1.9	-4.6	1455.5	11.2	-0.2	-2.50833	1
2022-03-14	2022	3	14	14	20	1	-1.2	1.5	-3.1	1495.6	11.2	0.3	-2.70833	1
2022-03-14	2022	3	14	14	21	1	-1.1	1.3	-2.2	1496.2	11.2	0.8	-2.925	1
2022-03-14	2022	3	14	14	22	1	-0.9	1.1	-1.2	1440.5	11.2	1.2	-3.01667	1
2022-03-14	2022	3	14	14	23	1	-0.8	1.4	-0.1	1360.0	11.2	1.5	-3.04167	1
2022-03-15	2022	3	15	24	2	2	-0.7	0.3	0.7	1267.1	9.5	1.7	-2.98333	1
2022-03-15	2022	3	15	1	2	2	-0.6	1.5	2.3	1308.6	9.5	1.7	-2.825	1
2022-03-15	2022	3	15	2	2	2	-0.4	1.3	2.7	1284.6	9.5	1.8	-2.58333	1
2022-03-15	2022	3	15	3	2	2	-0.2	0.8	3.1	1259.5	9.5	1.7	-2.18333	1
2022-03-15	2022	3	15	4	2	2	-0.1	0.6	2.7	1248.1	9.5	1.5	-1.7	1
2022-03-15	2022	3	15	5	2	2	0.1	0.5	1.5	1258.9	9.5	1.3	-1.15833	1
2022-03-15	2022	3	15	6	2	2	0.3	0.1	1.9	1297.4	9.5	1.1	-0.63333	1
2022-03-15	2022	3	15	7	2	2	0.4	2.2	1.5	1386.3	9.5	1.0	-0.2	1
2022-03-15	2022	3	15	8	2	2	0.7	3	1.3	1465.9	9.5	1.1	0.308333	1
2022-03-15	2022	3	15	9	2	2	1.0	3.4	1.1	1508.7	9.5	1.2	0.816667	1
2022-03-15	2022	3	15	10	2	2	1.3	3.4	1.4	1515.2	9.5	1.4	1.183333	1
2022-03-15	2022	3	15	11	2	2	1.5	3.6	0.3	1499.5	9.5	1.5	1.458333	1
2022-03-15	2022	3	15	12	2	2	1.7	4.1	1.5	1471.1	9.5	1.7	1.675	1
2022-03-15	2022	3	15	13	2	2	1.9	4.8	1.3	1430.8	9.5	2.0	1.708333	1
2022-03-15	2022	3	15	14	2	2	2.0	5.7	0.8	1377.1	9.5	2.3	1.775	1
2022-03-15	2022	3	15	15	2	2	2.2	6.8	0.6	1305.5	9.5	2.7	1.691667	1
2022-03-15	2022	3	15	16	2	2	2.4	7.7	0.5	1270.3	9.5	3.2	1.533333	1
2022-03-15	2022	3	15	17	2	2	2.6	8.3	0.1	1280.3	9.5	3.8	1.325	1
2022-03-15	2022	3	15	18	2	2	2.8	8.4	2.2	1312.1	9.5	4.4	1.141667	1
2022-03-15	2022	3	15	19	2	2	3.1	6.9	3	1324.3	9.5	5.1	1.025	1
2022-03-15	2022	3	15	20	2	2	3.3	5.4	3.4	1379.5	9.5	5.5	1.05	1
2022-03-15	2022	3	15	21	2	2	3.4	3.9	3.4	1398.6	9.5	5.7	1.175	1
2022-03-15	2022	3	15	22	2	2	3.6	2.6	3.6	1363.3	9.5	5.8	1.35	1
2022-03-15	2022	3	15	23	2	2	3.6	1.1	4.1	1298.1	9.5	5.7	1.541667	1
2022-03-16	2022	3	16	24	3	3	3.6	0.4	4.8	1272.0	10.2	5.5	1.725	1
2022-03-16	2022	3	16	1	3	3	3.6	0	5.7	1261.6	10.2	5.2	2.041667	1
2022-03-16	2022	3	16	2	3	3	3.5	-0.6	6.8	1245.8	10.2	4.8	2.316667	1
2022-03-16	2022	3	16	3	3	3	3.5	-0.8	7.7	1226.5	10.2	4.2	2.683333	1
2022-03-16	2022	3	16	4	3	3	3.4	-1	8.3	1222.5	10.2	3.6	3.183333	1
2022-03-16	2022	3	16	5	3	3	3.3	-1.2	8.4	1241.2	10.2	2.9	3.775	1
2022-03-16	2022	3	16	6	3	3	3.3	-1.3	6.9	1290.7	10.2	2.1	4.425	1
2022-03-16	2022	3	16	7	3	3	3.2	-1.5	5.4	1399.5	10.2	1.3	5.116667	1
2022-03-16	2022	3	16	8	3	3	3.0	-2.1	3.9	1507.5	10.2	0.6	5.508333	1
2022-03-16	2022	3	16	9	3	3	2.8	-2	2.6	1576.5	10.2	0.0	5.708333	1
2022-03-16	2022	3	16	10	3	3	2.6	-1.3	1.1	1587.8	10.2	-0.5	5.75	1
2022-03-16	2022	3	16	11	3	3	2.4	-1	0.4	1573.2	10.2	-0.9	5.683333	1
2022-03-16	2022	3	16	12	3	3	2.2	-0.4	0	1553.0	10.2	-1.0	5.475	1
2022-03-16	2022	3	16	13	3	3	2.0	0	-0.6	1516.6	10.2	-1.1	5.166667	1
2022-03-16	2022	3	16	14	3	3	1.8	0	-0.8	1468.7	10.2	-1.1	4.766667	1
2022-03-16	2022	3	16	15	3	3	1.6	0.6	-1	1413.5	10.2	-1.1	4.241667	1
2022-03-16	2022	3	16	16	3	3	1.3	0.8	-1.2	1387.1	10.2	-0.9	3.608333	1
2022-03-16	2022	3	16	17	3	3	1.1	0.3	-1.3	1393.4	10.2	-0.8	2.883333	1
2022-03-16	2022	3	16	18	3	3	0.7	0.3	-1.5	1421.0	10.2	-0.7	2.091667	1
2022-03-16	2022	3	16	19	3	3	0.4	0.2	-2.1	1419.3	10.2	-0.5	1.283333	1
2022-03-16	2022	3	16	20	3	3	0.1	0.1	-2	1457.9	10.2	-0.4	0.583333	1
2022-03-16	2022	3	16	21	3	3	-0.1	0.3	-1.3	1456.6	10.2	-0.2	-0.04167	1
2022-03-16	2022	3	16	22	3	3	-0.3	0.3	-1	1404.7	10.2	0.0	-0.53333	1
2022-03-16	2022	3	16	23	3	3	-0.4	0.3	-0.4	1317.1	10.2	0.1	-0.85833	1
2022-03-17	2022	3	17	24	4	4	-0.4	2.3	0	1163.6	11.1	0.2	-1.03333	1
2022-03-17	2022	3	17	1	4	4	-0.3	0.6	0	1250.1	11.1	0.5	-1.1	1
2022-03-17	2022	3	17	2	4	4	-0.3	1	0.6	1219.3	11.1	0.5	-1.1	1
2022-03-17	2022	3	17	3	4	4	-0.2	1.4	0.8	1184.5	11.1	0.6	-1.05	1
2022-03-17	2022	3	17	4	4	4	-0.1	1.4	0.3	1173.9	11.1	0.7	-0.93333	1
2022-03-17	2022	3	17	5	4	4	0.0	1.6	0.3	1181.7	11.1	0.7	-0.78333	1
2022-03-17	2022	3	17	6	4	4	0.1	1.5	0.2	1218.9	11.1	0.8	-0.65833	1
2022-03-17	2022	3	17	7	4	4	0.2	1.6	0.1	1316.8	11.1	0.9	-0.525	1
2022-03-17	2022	3	17	8	4	4	0.3	1.6	0.3	1408.4	11.1	1.0	-0.38333	1
2022-03-17	2022	3	17	9	4	4	0.5	1.9	0.3	1466.2	11.1	1.2	-0.2	1
2022-03-17	2022	3	17	10	4	4	0.6	1.9	0.3	1483.3	11.1	1.3	-0.00833	1
2022-03-17	2022	3	17	11	4	4	0.8	2	2.3	1474.2	11.1	1.4	0.125	1
2022-03-17	2022	3	17	12	4	4	0.9	2	0.6	1454.7	11.1	1.6	0.233333	1
2022-03-17	2022	3	17	13	4	4	1.0	3.1	1	1412.8	11.1	1.5	0.458333	1
2022-03-17	2022	3	17	14	4	4	1.1	4.8	1.4	1350.3	11.1	1.8	0.508333	1
2022-03-17	2022	3	17	15	4	4	1.3	5.9	1.4	1283.9	11.1	2.1	0.591667	1
2022-03-17	2022	3	17	16	4	4	1.6	6.6	1.6	1266.0	11.1	2.4	0.658333	1
2022-03-17	2022	3	17	17	4	4	1.8	6.3	1.5	1286.5	11.1	2.9	0.708333	1
2022-03-17	2022	3	17	18	4	4	2.0	5.5	1.6	1313.9	11.1	3.3	0.816667	1
2022-03-17	2022	3	17	19	4	4	2.3	4.7	1.6	1328.5	11.1	3.6	0.916667	1
2022-03-17	2022	3	17	20	4	4	2.4	3.8	1.9	1352.3	11.1	3.9	1.033333	1
2022-03-17	2022	3	17	21	4	4	2.6	3						

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLag	Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLag	Weekdays	
2022-03-18	2022		3	18	12	5	4.3	9.6	3.1	1289.7	8.0	4.3	4.283333	1
2022-03-18	2022		3	18	13	5	4.6	11.4	3.2	1249.9	8.0	4.5	4.708333	1
2022-03-18	2022		3	18	14	5	5.0	13.6	3.4	1184.5	8.0	5.2	4.708333	1
2022-03-18	2022		3	18	15	5	5.3	14.2	3.6	1127.1	8.0	6.1	4.575	1
2022-03-18	2022		3	18	16	5	5.7	15.5	3.5	1101.9	8.0	7.0	4.366667	1
2022-03-18	2022		3	18	17	5	6.0	16.1	3.7	1111.2	8.0	8.0	4.116667	1
2022-03-18	2022		3	18	18	5	6.5	15.4	3.5	1117.0	8.0	9.0	3.883333	1
2022-03-18	2022		3	18	19	5	6.9	13.9	4	1118.4	8.0	10.0	3.733333	1
2022-03-18	2022		3	18	20	5	7.2	11.8	4.6	1150.7	8.0	10.9	3.633333	1
2022-03-18	2022		3	18	21	5	7.6	10	5.6	1163.4	8.0	11.5	3.65	1
2022-03-18	2022		3	18	22	5	7.9	8.4	6.4	1130.2	8.0	12.0	3.758333	1
2022-03-18	2022		3	18	23	5	8.1	7	9.6	1084.3	8.0	12.2	3.991667	1
2022-03-19	2022		3	19	24	6	8.3	1.5	11.4	1224.2	12.6	12.2	4.308333	0
2022-03-19	2022		3	19	1	6	8.0	6.4	13.6	1039.5	12.6	11.6	4.516667	0
2022-03-19	2022		3	19	2	6	8.2	5.4	14.2	1019.0	12.6	11.2	5.208333	0
2022-03-19	2022		3	19	3	6	8.3	4.4	15.5	1002.7	12.6	10.5	6.075	0
2022-03-19	2022		3	19	4	6	8.3	3.4	16.1	998.2	12.6	9.7	6.975	0
2022-03-19	2022		3	19	5	6	8.3	2.5	15.4	1018.2	12.6	8.6	7.966667	0
2022-03-19	2022		3	19	6	6	8.3	1.9	13.9	1055.6	12.6	7.5	9.016667	0
2022-03-19	2022		3	19	7	6	8.2	1.7	11.8	1109.6	12.6	6.4	9.991667	0
2022-03-19	2022		3	19	8	6	8.1	1.9	10	1185.2	12.6	5.4	10.85833	0
2022-03-19	2022		3	19	9	6	8.0	2.2	8.4	1270.0	12.6	4.5	11.50833	0
2022-03-19	2022		3	19	10	6	7.9	2.7	7	1326.9	12.6	3.9	11.95833	0
2022-03-19	2022		3	19	11	6	7.8	3.2	1.5	1348.7	12.6	3.4	12.19167	0
2022-03-19	2022		3	19	12	6	7.7	3.2	6.4	1367.0	12.6	3.1	12.24167	0
2022-03-19	2022		3	19	13	6	7.4	2.9	5.4	1368.1	12.6	3.2	11.56667	0
2022-03-19	2022		3	19	14	6	7.1	2.1	4.4	1355.6	12.6	3.0	11.15	0
2022-03-19	2022		3	19	15	6	6.6	2.2	3.4	1346.2	12.6	2.7	10.46667	0
2022-03-19	2022		3	19	16	6	6.1	2.7	2.5	1351.3	12.6	2.5	9.65	0
2022-03-19	2022		3	19	17	6	5.5	2.6	1.9	1386.2	12.6	2.4	8.641667	0
2022-03-19	2022		3	19	18	6	5.0	2.6	1.7	1420.4	12.6	2.4	7.508333	0
2022-03-19	2022		3	19	19	6	4.4	2.4	1.9	1401.1	12.6	2.5	6.383333	0
2022-03-19	2022		3	19	20	6	4.0	2.3	2.2	1409.1	12.6	2.6	5.366667	0
2022-03-19	2022		3	19	21	6	3.6	2.1	2.7	1387.5	12.6	2.6	4.541667	0
2022-03-19	2022		3	19	22	6	3.2	1.4	3.2	1339.9	12.6	2.6	3.891667	0
2022-03-19	2022		3	19	23	6	2.9	1.4	3.2	1280.6	12.6	2.5	3.416667	0
2022-03-20	2022		3	20	24	7	2.7	6.7	2.9	1055.5	13.3	2.3	3.1	0
2022-03-20	2022		3	20	1	7	2.9	1.6	2.1	1184.4	13.3	2.6	3.241667	0
2022-03-20	2022		3	20	2	7	2.7	1.9	2.2	1159.9	13.3	2.5	2.95	0
2022-03-20	2022		3	20	3	7	2.6	2.2	2.7	1160.9	13.3	2.5	2.675	0
2022-03-20	2022		3	20	4	7	2.5	2.6	2.6	1166.1	13.3	2.5	2.491667	0
2022-03-20	2022		3	20	5	7	2.5	3.1	2.6	1170.8	13.3	2.5	2.433333	0
2022-03-20	2022		3	20	6	7	2.5	3.7	2.4	1185.7	13.3	2.5	2.441667	0
2022-03-20	2022		3	20	7	7	2.6	4.2	2.3	1214.0	13.3	2.6	2.5	0
2022-03-20	2022		3	20	8	7	2.7	4.4	2.1	1251.2	13.3	2.8	2.558333	0
2022-03-20	2022		3	20	9	7	2.8	4.7	1.4	1307.9	13.3	2.9	2.591667	0
2022-03-20	2022		3	20	10	7	2.9	5	1.4	1362.9	13.3	3.2	2.583333	0
2022-03-20	2022		3	20	11	7	3.0	6.9	6.7	1385.2	13.3	3.5	2.475	0
2022-03-20	2022		3	20	12	7	3.1	8.7	1.6	1373.8	13.3	3.9	2.325	0
2022-03-20	2022		3	20	13	7	3.4	9.7	1.9	1333.9	13.3	4.1	2.616667	0
2022-03-20	2022		3	20	14	7	3.6	11.7	2.2	1253.0	13.3	4.8	2.508333	0
2022-03-20	2022		3	20	15	7	4.0	11.7	2.6	1198.2	13.3	5.6	2.491667	0
2022-03-20	2022		3	20	16	7	4.4	11.4	3.1	1167.4	13.3	6.4	2.491667	0
2022-03-20	2022		3	20	17	7	4.8	10.6	3.7	1197.0	13.3	7.1	2.483333	0
2022-03-20	2022		3	20	18	7	5.1	9.4	4.2	1237.1	13.3	7.7	2.525	0
2022-03-20	2022		3	20	19	7	5.4	9.3	4.4	1243.9	13.3	8.2	2.616667	0
2022-03-20	2022		3	20	20	7	5.7	10.8	4.7	1277.1	13.3	8.6	2.766667	0
2022-03-20	2022		3	20	21	7	6.1	5.4	5	1279.7	13.3	9.2	2.941667	0
2022-03-20	2022		3	20	22	7	6.2	5.4	6.9	1218.9	13.3	9.2	3.158333	0
2022-03-20	2022		3	20	23	7	6.4	5.8	8.7	1129.4	13.3	9.3	3.458333	0
2022-03-21	2022		3	21	24	1	6.5	1.7	9.7	1245.5	13.2	9.2	3.916667	1
2022-03-21	2022		3	21	1	1	6.3	6.3	11.7	998.9	13.2	8.6	4.083333	1
2022-03-21	2022		3	21	2	1	6.5	5.9	11.7	967.6	13.2	8.3	4.758333	1
2022-03-21	2022		3	21	3	1	6.7	4.7	11.4	967.7	13.2	7.8	5.575	1
2022-03-21	2022		3	21	4	1	6.8	3.9	10.6	983.4	13.2	7.2	6.366667	1
2022-03-21	2022		3	21	5	1	6.9	4.1	9.4	1004.4	13.2	6.6	7.1	1
2022-03-21	2022		3	21	6	1	6.9	4.3	9.3	1062.8	13.2	6.1	7.725	1
2022-03-21	2022		3	21	7	1	6.9	4.2	10.8	1199.2	13.2	5.6	8.2	1
2022-03-21	2022		3	21	8	1	6.9	3.9	5.4	1323.3	13.2	5.2	8.625	1
2022-03-21	2022		3	21	9	1	6.9	4.1	5.4	1378.7	13.2	4.6	9.158333	1
2022-03-21	2022		3	21	10	1	6.9	3.1	5.8	1401.6	13.2	4.5	9.216667	1
2022-03-21	2022		3	21	11	1	6.8	3	1.7	1404.5	13.2	4.3	9.25	1
2022-03-21	2022		3	21	12	1	6.6	3.9	6.3	1387.4	13.2	4.1	9.158333	1
2022-03-21	2022		3	21	13	1	6.4	3.4	5.9	1377.8	13.2	4.3	8.575	1
2022-03-21	2022		3	21	14	1	6.2	3.3	4.7	1353.0	13.2	4.0	8.291667	1
2022-03-21	2022		3	21	15	1	5.8	4.6	3.9	1331.3	13.2	3.8	7.808333	1
2022-03-21	2022		3	21	16	1	5.5	3.6	4.1	1354.1	13.2	3.8	7.225	1
2022-03-21	2022		3	21	17	1	5.2	4	4.3	1401.2	13.2	3.8	6.6	1
2022-03-21	2022		3	21	18	1	4.9	3.5	4.2	1427.4	13.2	3.8	6.058333	1
2022-03-21	2022		3	21	19	1	4.7	3.7	3.9	1407.5	13.2	3.7	5.633333	1
2022-03-21	2022		3	21	20	1	4.4	3.6	4.1	1425.7	13.2	3.7	5.208333	1
2022-03-21	2022		3	21	21	1	4.1	2.9	3.1	1420.8	13.2	3.7	4.633333	1
2022-03-21	2022		3	21	22	1	4.0	2.5	3	1364.5	13.2	3.6	4.525	1
2022-03-21	2022		3	21	23	1	3.9	1.8	3.9	1288.1	13.2	3.5	4.333333	1
2022-03-22	2022		3	22	24	2	3.8	0.9	3.4	1319.5	21.5	3.4	4.1	1
2022-03-22	2022		3	22	1	2	3.7	1.8	3.3	1227.9	21.5	3.2	4.283333	1
2022-03-22	2022		3	22	2	2	3.5	1.2	4.6	1205.9	21.5	3.0	4.041667	1
2022-03-22	2022		3	22	3	2	3.3	1.1	3.6	1182.0	21.5	2.8	3.825	1
2022-03-22	2022		3	22	4	2	3.2	0.8	4	1176.8	21.5	2.6	3.816667	1
2022-03-22	2022		3	22	5	2	3.1	0.4	3.5	1190.8	21.5	2.3	3.791667	1
2022-03-22	2022		3	22	6	2	2.9	0.1	3.7	1245.9	21.5	2.0	3.783333	1
2022-03-22	2022		3	22	7	2	2.7	-0.2	3.6	1372.1	21.5	1.7	3.716667	1
2022-03-22	2022		3	22	8	2	2.5	-0.6	2.9	1493.2	21.5	1.4	3.675	1
2022-03-22	2022		3	22	9	2	2.4	-0.6	2.5	1524.2	21.5	1.1	3.65	1
2022-03-22	2022		3	22	10									

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLa	gTemp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLa	gWeekdays	
2022-03-23	2022		3	23	24	3	0.9	-0.9	0.7	1289.1	20.7	1.3	0.541667	1
2022-03-23	2022		3	23	1	3	0.9	0.8	1.6	1291.7	20.7	1.2	0.516667	1
2022-03-23	2022		3	23	2	3	0.8	0.8	2.3	1268.1	20.7	1.2	0.425	1
2022-03-23	2022		3	23	3	3	0.8	1.1	3.2	1238.2	20.7	1.1	0.458333	1
2022-03-23	2022		3	23	4	3	0.8	1.1	2.2	1217.2	20.7	1.0	0.558333	1
2022-03-23	2022		3	23	5	3	0.8	1.1	1.6	1225.3	20.7	0.9	0.758333	1
2022-03-23	2022		3	23	6	3	0.8	1.3	1.1	1266.8	20.7	0.8	0.908333	1
2022-03-23	2022		3	23	7	3	0.9	1.4	0.9	1385.1	20.7	0.7	1.033333	1
2022-03-23	2022		3	23	8	3	1.0	1.4	0.7	1492.2	20.7	0.8	1.141667	1
2022-03-23	2022		3	23	9	3	1.0	1.7	0.5	1522.3	20.7	0.8	1.266667	1
2022-03-23	2022		3	23	10	3	1.1	2.3	0.4	1492.5	20.7	0.9	1.375	1
2022-03-23	2022		3	23	11	3	1.2	3.2	-0.9	1463.7	20.7	1.0	1.358333	1
2022-03-23	2022		3	23	12	3	1.3	3.9	0.8	1439.0	20.7	1.3	1.316667	1
2022-03-23	2022		3	23	13	3	1.4	4.5	0.8	1423.1	20.7	1.7	1.191667	1
2022-03-23	2022		3	23	14	3	1.6	4	1.1	1386.6	20.7	2.0	1.2	1
2022-03-23	2022		3	23	15	3	1.7	3.9	1.1	1353.8	20.7	2.3	1.133333	1
2022-03-23	2022		3	23	16	3	1.8	3.8	1.1	1340.9	20.7	2.5	1.033333	1
2022-03-23	2022		3	23	17	3	1.8	4.2	1.3	1363.8	20.7	2.7	0.858333	1
2022-03-23	2022		3	23	18	3	1.9	3.4	1.4	1394.1	20.7	3.0	0.766667	1
2022-03-23	2022		3	23	19	3	1.9	2.1	1.4	1390.1	20.7	3.1	0.741667	1
2022-03-23	2022		3	23	20	3	2.0	1.2	1.7	1423.5	20.7	3.2	0.766667	1
2022-03-23	2022		3	23	21	3	2.0	0.5	2.3	1452.6	20.7	3.2	0.808333	1
2022-03-23	2022		3	23	22	3	2.0	-0.1	3.2	1409.7	20.7	3.1	0.891667	1
2022-03-23	2022		3	23	23	3	2.0	-0.6	3.9	1323.0	20.7	2.9	1.041667	1
2022-03-24	2022		3	24	24	4	1.9	1	4.5	1240.2	11.6	2.6	1.275	1
2022-03-24	2022		3	24	1	4	2.0	-1.5	4	1273.4	11.6	2.3	1.675	1
2022-03-24	2022		3	24	2	4	1.9	-1.7	3.9	1258.1	11.6	1.8	1.983333	1
2022-03-24	2022		3	24	3	4	1.8	-2.1	3.8	1247.8	11.6	1.4	2.25	1
2022-03-24	2022		3	24	4	4	1.7	-2	4.2	1246.7	11.6	0.9	2.483333	1
2022-03-24	2022		3	24	5	4	1.5	-2.1	3.4	1267.0	11.6	0.4	2.708333	1
2022-03-24	2022		3	24	6	4	1.4	-2.3	2.1	1318.7	11.6	-0.2	2.966667	1
2022-03-24	2022		3	24	7	4	1.3	-2.5	1.2	1452.5	11.6	-0.6	3.141667	1
2022-03-24	2022		3	24	8	4	1.1	-1.3	0.5	1561.4	11.6	-1.0	3.2	1
2022-03-24	2022		3	24	9	4	1.0	0.3	-0.1	1553.4	11.6	-1.2	3.183333	1
2022-03-24	2022		3	24	10	4	0.9	2.1	-0.6	1492.2	11.6	-1.2	3.083333	1
2022-03-24	2022		3	24	11	4	0.9	2.8	1	1426.0	11.6	-1.1	2.883333	1
2022-03-24	2022		3	24	12	4	0.9	3.4	-1.5	1375.8	11.6	-0.8	2.566667	1
2022-03-24	2022		3	24	13	4	0.9	4.4	-1.7	1337.2	11.6	-0.6	2.325	1
2022-03-24	2022		3	24	14	4	0.9	3.9	-2.1	1297.0	11.6	-0.1	1.825	1
2022-03-24	2022		3	24	15	4	0.9	2.9	-2	1264.3	11.6	0.4	1.35	1
2022-03-24	2022		3	24	16	4	0.8	2.6	-2.1	1284.5	11.6	0.8	0.85	1
2022-03-24	2022		3	24	17	4	0.8	2.4	-2.3	1329.4	11.6	1.2	0.366667	1
2022-03-24	2022		3	24	18	4	0.7	1.8	-2.5	1376.6	11.6	1.6	-0.15833	1
2022-03-24	2022		3	24	19	4	0.6	1.5	-1.3	1385.5	11.6	1.9	-0.63333	1
2022-03-24	2022		3	24	20	4	0.6	1.1	0.3	1412.2	11.6	2.2	-1.01667	1
2022-03-24	2022		3	24	21	4	0.6	1	2.1	1413.0	11.6	2.4	-1.225	1
2022-03-24	2022		3	24	22	4	0.6	1.1	2.8	1357.8	11.6	2.5	-1.24167	1
2022-03-24	2022		3	24	23	4	0.7	0.9	3.4	1284.4	11.6	2.4	-1.05833	1
2022-03-25	2022		3	25	24	5	0.7	4.7	4.4	1213.5	18.6	2.3	-0.775	1
2022-03-25	2022		3	25	1	5	0.9	1.2	3.9	1221.9	18.6	2.4	-0.575	1
2022-03-25	2022		3	25	2	5	1.0	1.2	2.9	1200.2	18.6	2.1	-0.08333	1
2022-03-25	2022		3	25	3	5	1.1	1.1	2.6	1176.1	18.6	1.9	0.383333	1
2022-03-25	2022		3	25	4	5	1.3	1.2	2.4	1169.2	18.6	1.7	0.8	1
2022-03-25	2022		3	25	5	5	1.4	1.2	1.8	1186.2	18.6	1.6	1.183333	1
2022-03-25	2022		3	25	6	5	1.5	1.2	1.5	1242.4	18.6	1.5	1.558333	1
2022-03-25	2022		3	25	7	5	1.7	1.3	1.1	1372.4	18.6	1.5	1.9	1
2022-03-25	2022		3	25	8	5	1.8	1.3	1	1498.7	18.6	1.4	2.233333	1
2022-03-25	2022		3	25	9	5	1.9	1.4	1.1	1551.8	18.6	1.5	2.433333	1
2022-03-25	2022		3	25	10	5	2.0	1.7	0.9	1586.6	18.6	1.5	2.491667	1
2022-03-25	2022		3	25	11	5	2.0	2	4.7	1596.0	18.6	1.5	2.408333	1
2022-03-25	2022		3	25	12	5	1.9	2.4	1.2	1591.8	18.6	1.6	2.25	1
2022-03-25	2022		3	25	13	5	1.9	2.5	1.2	1594.5	18.6	1.4	2.358333	1
2022-03-25	2022		3	25	14	5	1.8	2.9	1.1	1573.7	18.6	1.5	2.091667	1
2022-03-25	2022		3	25	15	5	1.8	3.7	1.2	1536.0	18.6	1.7	1.866667	1
2022-03-25	2022		3	25	16	5	1.8	4.1	1.2	1504.2	18.6	1.9	1.716667	1
2022-03-25	2022		3	25	17	5	1.9	3.4	1.2	1494.6	18.6	2.1	1.6	1
2022-03-25	2022		3	25	18	5	1.9	3.9	1.3	1490.7	18.6	2.3	1.5	1
2022-03-25	2022		3	25	19	5	2.0	3.8	1.3	1448.6	18.6	2.6	1.45	1
2022-03-25	2022		3	25	20	5	2.1	3.7	1.4	1429.2	18.6	2.8	1.433333	1
2022-03-25	2022		3	25	21	5	2.2	3.7	1.7	1389.9	18.6	3.0	1.45	1
2022-03-25	2022		3	25	22	5	2.3	4	2	1338.2	18.6	3.2	1.483333	1
2022-03-25	2022		3	25	23	5	2.4	4.2	2.4	1259.7	18.6	3.3	1.533333	1
2022-03-26	2022		3	26	24	6	2.6	3.1	2.5	1081.6	9.8	3.5	1.625	0
2022-03-26	2022		3	26	1	6	2.5	4.4	2.9	1187.2	9.8	3.6	1.433333	0
2022-03-26	2022		3	26	2	6	2.6	4	3.7	1152.9	9.8	3.7	1.541667	0
2022-03-26	2022		3	26	3	6	2.8	2.7	4.1	1131.1	9.8	3.8	1.683333	0
2022-03-26	2022		3	26	4	6	2.8	2.3	3.4	1119.3	9.8	3.8	1.9	0
2022-03-26	2022		3	26	5	6	2.9	2.1	3.9	1118.3	9.8	3.6	2.141667	0
2022-03-26	2022		3	26	6	6	2.9	2.5	3.8	1147.3	9.8	3.5	2.325	0
2022-03-26	2022		3	26	7	6	3.0	2.7	3.7	1190.0	9.8	3.4	2.55	0
2022-03-26	2022		3	26	8	6	3.0	3.2	3.7	1244.0	9.8	3.3	2.758333	0
2022-03-26	2022		3	26	9	6	3.1	3.5	4	1305.5	9.8	3.2	2.958333	0
2022-03-26	2022		3	26	10	6	3.2	4.1	4.2	1345.4	9.8	3.2	3.15	0
2022-03-26	2022		3	26	11	6	3.3	6.3	3.1	1329.2	9.8	3.2	3.341667	0
2022-03-26	2022		3	26	12	6	3.5	5.7	4.4	1301.2	9.8	3.4	3.525	0
2022-03-26	2022		3	26	13	6	3.6	5.3	4	1281.8	9.8	3.6	3.583333	0
2022-03-26	2022		3	26	14	6	3.7	6.7	2.7	1217.7	9.8	3.7	3.741667	0
2022-03-26	2022		3	26	15	6	3.9	7.9	2.3	1150.0	9.8	3.9	3.833333	0
2022-03-26	2022		3	26	16	6	4.1	8.1	2.1	1124.2	9.8	4.4	3.75	0
2022-03-26	2022		3	26	17	6	4.2	6.7	2.5	1138.2	9.8	4.8	3.6	0
2022-03-26	2022		3	26	18	6	4.4	6.2	2.7	1159.4	9.8	5.2	3.491667	0
2022-03-26	2022		3	26	19	6	4.5	6.8	3.2	1163.5	9.8	5.5	3.375	0
2022-03-26	2022		3	26	20	6	4.6	5.6	3.5	1206.3	9.8	5.9	3.283333	0
2022-03-26	2022		3	26	21	6	4.7	4.7	4.1	1236.5	9.8	6.1	3.241667	0
2022-03-26	2022		3	26	22	6	4.7	5.1	6.3	1191.1	9.8	6.2	3.225	0

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLa	g Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLa	g Weekdays	
2022-03-27	2022		3	27	12	7	5.1	6.6	2.9	1283.1	13.1	4.2	6.05	0
2022-03-27	2022		3	27	13	7	5.1	7	3	1254.7	13.1	4.4	5.858333	0
2022-03-27	2022		3	27	14	7	5.2	6.2	3.6	1227.3	13.1	4.8	5.658333	0
2022-03-27	2022		3	27	15	7	5.2	6.1	4	1211.9	13.1	5.0	5.35	0
2022-03-27	2022		3	27	16	7	5.1	4.5	4.8	1218.8	13.1	5.2	4.991667	0
2022-03-27	2022		3	27	17	7	5.0	5.4	4.5	1244.9	13.1	5.3	4.65	0
2022-03-27	2022		3	27	18	7	4.9	6.7	4	1248.4	13.1	5.3	4.491667	0
2022-03-27	2022		3	27	19	7	4.9	6.9	4.3	1228.2	13.1	5.5	4.35	0
2022-03-27	2022		3	27	20	7	4.9	4	4.7	1267.3	13.1	5.8	4.116667	0
2022-03-27	2022		3	27	21	7	4.9	3.5	4.9	1293.9	13.1	5.7	4.008333	0
2022-03-27	2022		3	27	22	7	4.8	4.1	5.8	1245.2	13.1	5.6	4.008333	0
2022-03-27	2022		3	27	23	7	4.8	4.3	6.6	1167.0	13.1	5.6	3.991667	0
2022-03-28	2022		3	28	24	1	4.8	0.5	7	1206.3	12.9	5.4	4.158333	1
2022-03-28	2022		3	28	1	1	4.7	2.9	6.2	1061.5	12.9	4.9	4.425	1
2022-03-28	2022		3	28	2	1	4.7	2.5	6.1	1051.7	12.9	4.6	4.766667	1
2022-03-28	2022		3	28	3	1	4.7	3	4.5	1051.1	12.9	4.3	5.033333	1
2022-03-28	2022		3	28	4	1	4.6	3.1	5.4	1054.4	12.9	4.0	5.241667	1
2022-03-28	2022		3	28	5	1	4.6	2.7	6.7	1074.0	12.9	3.9	5.283333	1
2022-03-28	2022		3	28	6	1	4.5	2.7	6.9	1125.0	12.9	3.7	5.333333	1
2022-03-28	2022		3	28	7	1	4.4	2.8	4	1252.5	12.9	3.4	5.516667	1
2022-03-28	2022		3	28	8	1	4.4	2.8	3.5	1360.8	12.9	3.0	5.758333	1
2022-03-28	2022		3	28	9	1	4.3	3.8	4.1	1382.3	12.9	2.9	5.733333	1
2022-03-28	2022		3	28	10	1	4.3	3.9	4.3	1358.6	12.9	2.9	5.633333	1
2022-03-28	2022		3	28	11	1	4.2	3.7	0.5	1341.1	12.9	2.9	5.566667	1
2022-03-28	2022		3	28	12	1	4.2	3.8	2.9	1326.8	12.9	2.9	5.441667	1
2022-03-28	2022		3	28	13	1	4.0	4.4	2.5	1312.0	12.9	3.1	4.933333	1
2022-03-28	2022		3	28	14	1	3.9	5.8	3	1279.6	12.9	3.3	4.591667	1
2022-03-28	2022		3	28	15	1	3.9	6.4	3.1	1246.9	12.9	3.5	4.283333	1
2022-03-28	2022		3	28	16	1	3.9	7.1	2.7	1251.9	12.9	3.8	4.025	1
2022-03-28	2022		3	28	17	1	4.0	6.3	2.7	1287.3	12.9	4.2	3.908333	1
2022-03-28	2022		3	28	18	1	4.1	4.5	2.8	1327.1	12.9	4.5	3.683333	1
2022-03-28	2022		3	28	19	1	4.0	4.1	2.8	1340.2	12.9	4.6	3.35	1
2022-03-28	2022		3	28	20	1	3.9	3	3.8	1368.0	12.9	4.7	3.008333	1
2022-03-28	2022		3	28	21	1	3.8	1.9	3.9	1378.0	12.9	4.7	2.908333	1
2022-03-28	2022		3	28	22	1	3.8	1.3	3.7	1326.9	12.9	4.6	2.933333	1
2022-03-28	2022		3	28	23	1	3.6	0.6	3.8	1241.8	12.9	4.4	2.916667	1
2022-03-29	2022		3	29	24	2	3.5	-0.7	4.4	1319.4	15.3	4.1	2.866667	1
2022-03-29	2022		3	29	1	2	3.4	0.2	5.8	1190.1	15.3	3.7	3.141667	1
2022-03-29	2022		3	29	2	2	3.3	0.3	6.4	1170.1	15.3	3.4	3.266667	1
2022-03-29	2022		3	29	3	2	3.2	0.1	7.1	1152.5	15.3	2.9	3.541667	1
2022-03-29	2022		3	29	4	2	3.1	-0.2	6.3	1145.9	15.3	2.4	3.825	1
2022-03-29	2022		3	29	5	2	3.0	-0.5	4.5	1164.0	15.3	1.8	4.158333	1
2022-03-29	2022		3	29	6	2	2.8	-0.9	4.1	1211.6	15.3	1.2	4.458333	1
2022-03-29	2022		3	29	7	2	2.7	-1.5	3	1346.4	15.3	0.8	4.608333	1
2022-03-29	2022		3	29	8	2	2.5	-1.7	1.9	1472.1	15.3	0.3	4.716667	1
2022-03-29	2022		3	29	9	2	2.3	-1.6	1.3	1509.2	15.3	-0.1	4.733333	1
2022-03-29	2022		3	29	10	2	2.1	-1.7	0.6	1501.8	15.3	-0.4	4.575	1
2022-03-29	2022		3	29	11	2	1.9	-1.4	-0.7	1484.0	15.3	-0.6	4.358333	1
2022-03-29	2022		3	29	12	2	1.7	-0.9	0.2	1484.3	15.3	-0.8	4.1	1
2022-03-29	2022		3	29	13	2	1.5	0.1	0.3	1473.4	15.3	-0.8	3.725	1
2022-03-29	2022		3	29	14	2	1.3	0.3	0.1	1451.4	15.3	-0.8	3.375	1
2022-03-29	2022		3	29	15	2	1.0	1.4	-0.2	1418.4	15.3	-0.8	2.916667	1
2022-03-29	2022		3	29	16	2	0.8	2.3	-0.5	1409.4	15.3	-0.7	2.391667	1
2022-03-29	2022		3	29	17	2	0.6	2.5	-0.9	1427.8	15.3	-0.5	1.783333	1
2022-03-29	2022		3	29	18	2	0.5	1.2	-1.5	1455.6	15.3	-0.3	1.216667	1
2022-03-29	2022		3	29	19	2	0.3	1.2	-1.7	1447.0	15.3	-0.1	0.766667	1
2022-03-29	2022		3	29	20	2	0.2	0.6	-1.6	1475.6	15.3	0.1	0.3	1
2022-03-29	2022		3	29	21	2	0.1	0.2	-1.7	1498.9	15.3	0.3	-0.09167	1
2022-03-29	2022		3	29	22	2	0.1	-0.3	-1.4	1447.9	15.3	0.5	-0.38333	1
2022-03-29	2022		3	29	23	2	0.0	-0.5	-0.9	1360.0	15.3	0.6	-0.63333	1
2022-03-30	2022		3	30	24	3	-0.1	1.8	0.1	1221.9	16.4	0.7	-0.8	1
2022-03-30	2022		3	30	1	3	0.0	-1.1	0.3	1311.3	16.4	0.9	-0.81667	1
2022-03-30	2022		3	30	2	3	0.0	-1.7	1.4	1293.3	16.4	0.8	-0.825	1
2022-03-30	2022		3	30	3	3	-0.1	-2.2	2.3	1277.2	16.4	0.6	-0.825	1
2022-03-30	2022		3	30	4	3	-0.2	-2.9	2.5	1277.2	16.4	0.3	-0.71667	1
2022-03-30	2022		3	30	5	3	-0.3	-3.1	1.2	1295.1	16.4	-0.1	-0.50833	1
2022-03-30	2022		3	30	6	3	-0.4	-3.2	1.2	1349.8	16.4	-0.6	-0.25833	1
2022-03-30	2022		3	30	7	3	-0.5	-3.5	0.6	1482.9	16.4	-0.9	-0.08333	1
2022-03-30	2022		3	30	8	3	-0.6	-3.5	0.2	1598.8	16.4	-1.3	0.141667	1
2022-03-30	2022		3	30	9	3	-0.7	-3.1	-0.3	1627.7	16.4	-1.7	0.333333	1
2022-03-30	2022		3	30	10	3	-0.7	-1.8	-0.5	1594.8	16.4	-1.9	0.483333	1
2022-03-30	2022		3	30	11	3	-0.7	-0.6	1.8	1540.6	16.4	-2.1	0.6	1
2022-03-30	2022		3	30	12	3	-0.7	0.3	-1.1	1471.9	16.4	-2.1	0.675	1
2022-03-30	2022		3	30	13	3	-0.7	2.6	-1.7	1419.5	16.4	-2.2	0.9	1
2022-03-30	2022		3	30	14	3	-0.5	4.3	-2.2	1366.0	16.4	-1.9	0.8	1
2022-03-30	2022		3	30	15	3	-0.4	5.6	-2.9	1316.6	16.4	-1.4	0.633333	1
2022-03-30	2022		3	30	16	3	-0.2	6.2	-3.1	1297.7	16.4	-0.7	0.333333	1
2022-03-30	2022		3	30	17	3	0.0	7.3	-3.2	1307.0	16.4	0.0	-0.1	1
2022-03-30	2022		3	30	18	3	0.2	6	-3.5	1316.4	16.4	0.9	-0.56667	1
2022-03-30	2022		3	30	19	3	0.4	5	-3.5	1309.0	16.4	1.7	-0.93333	1
2022-03-30	2022		3	30	20	3	0.5	4.2	-3.1	1343.1	16.4	2.4	-1.325	1
2022-03-30	2022		3	30	21	3	0.7	3.3	-1.8	1382.3	16.4	3.0	-1.66667	1
2022-03-30	2022		3	30	22	3	0.8	2.9	-0.6	1345.9	16.4	3.5	-1.94167	1
2022-03-30	2022		3	30	23	3	0.9	2.1	0.3	1263.5	16.4	3.9	-2.06667	1
2022-03-31	2022		3	31	24	4	1.0	2.8	2.6	1171.4	10.3	4.2	-2.075	1
2022-03-31	2022		3	31	1	4	1.1	1.5	4.3	1196.8	10.3	4.4	-2.2	1
2022-03-31	2022		3	31	2	4	1.2	1.4	5.6	1176.4	10.3	4.3	-1.89167	1
2022-03-31	2022		3	31	3	4	1.3	1.4	6.2	1157.7	10.3	4.0	-1.39167	1
2022-03-31	2022		3	31	4	4	1.5	1	7.3	1148.2	10.3	3.7	-0.74167	1
2022-03-31	2022		3	31	5	4	1.6	0.5	6	1158.2	10.3	3.2	0.016667	1
2022-03-31	2022		3	31	6	4	1.8	0.9	5	1200.6	10.3	2.7	0.883333	1
2022-03-31	2022		3	31	7	4	2.0	0.9	4.2	1320.7	10.3	2.3	1.65	1
2022-03-31	2022		3	31	8	4	2.1	1.9	3.3	1434.1	10.3	1.9	2.358333	1
2022-03-31	2022		3	31	9	4	2.4	3.3	2.9	1455.4	10.3	1.7	3	1
2022-03-31	2022		3	31	10	4	2.6	3.9	2.1	1441.3	10.3	1.		

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLa	gTemp	LagTemp	12Load	Wind	12hrAvg	12hrAvgLa	gWeekdays	
2022-11-01	2022	11	1	1	24	2	10.7	14.1	16.8	882.6	7.7	14.1	7.241667	1
2022-11-01	2022	11	1	1	1	2	10.8	10.9	16.5	873.6	7.7	14.1	7.591667	1
2022-11-01	2022	11	1	2	2	2	11.0	11.1	18.1	838.4	7.7	13.6	8.433333	1
2022-11-01	2022	11	1	3	2	2	11.2	10.9	17.9	818.9	7.7	13.2	9.316667	1
2022-11-01	2022	11	1	4	2	2	11.5	11.6	16.7	811.9	7.7	12.6	10.36667	1
2022-11-01	2022	11	1	5	2	2	11.8	11.6	13.6	812.6	7.7	12.0	11.50833	1
2022-11-01	2022	11	1	6	2	2	12.1	11.4	11.8	856.9	7.7	11.6	12.55833	1
2022-11-01	2022	11	1	7	2	2	12.4	11.6	11.5	970.6	7.7	11.4	13.36667	1
2022-11-01	2022	11	1	8	2	2	12.7	12.6	11.6	1084.2	7.7	11.4	13.98333	1
2022-11-01	2022	11	1	9	2	2	12.9	13.2	10.1	1113.4	7.7	11.5	14.35833	1
2022-11-01	2022	11	1	10	2	2	13.1	13.9	10.4	1120.0	7.7	11.6	14.49167	1
2022-11-01	2022	11	1	11	2	2	13.1	14	14.1	1126.7	7.7	11.9	14.35	1
2022-11-01	2022	11	1	12	2	2	13.2	14.3	10.9	1133.9	7.7	12.2	14.11667	1
2022-11-01	2022	11	1	13	2	2	13.2	14.5	11.1	1128.4	7.7	12.3	14.09167	1
2022-11-01	2022	11	1	14	2	2	13.1	14.7	10.9	1117.5	7.7	12.6	13.6	1
2022-11-01	2022	11	1	15	2	2	13.0	15	11.6	1103.7	7.7	12.9	13.15	1
2022-11-01	2022	11	1	16	2	2	12.9	15.1	11.6	1112.6	7.7	13.2	12.55	1
2022-11-01	2022	11	1	17	2	2	12.8	14.9	11.4	1150.3	7.7	13.5	12.025	1
2022-11-01	2022	11	1	18	2	2	12.7	14.4	11.6	1183.9	7.7	13.8	11.6	1
2022-11-01	2022	11	1	19	2	2	12.7	14.2	12.6	1197.3	7.7	14.0	11.41667	1
2022-11-01	2022	11	1	20	2	2	12.8	14.3	13.2	1169.2	7.7	14.2	11.4	1
2022-11-01	2022	11	1	21	2	2	12.9	14.4	13.9	1115.0	7.7	14.4	11.49167	1
2022-11-01	2022	11	1	22	2	2	13.1	14.6	14	1040.7	7.7	14.5	11.625	1
2022-11-01	2022	11	1	23	2	2	13.2	14.5	14.3	953.3	7.7	14.5	11.94167	1
2022-11-02	2022	11	2	24	3	3	13.4	7.4	14.5	967.1	13.9	14.6	12.24167	1
2022-11-02	2022	11	2	1	3	3	13.1	14	14.7	821.8	13.9	14.0	12.25833	1
2022-11-02	2022	11	2	2	3	3	13.3	13.5	15	788.6	13.9	14.0	12.55833	1
2022-11-02	2022	11	2	3	3	3	13.4	12.8	15.1	775.3	13.9	13.9	12.85833	1
2022-11-02	2022	11	2	4	3	3	13.4	12.3	14.9	767.3	13.9	13.7	13.2	1
2022-11-02	2022	11	2	5	3	3	13.5	11.7	14.4	779.7	13.9	13.4	13.49167	1
2022-11-02	2022	11	2	6	3	3	13.5	11.5	14.2	819.8	13.9	13.2	13.76667	1
2022-11-02	2022	11	2	7	3	3	13.5	11.1	14.3	955.5	13.9	12.9	14.01667	1
2022-11-02	2022	11	2	8	3	3	13.5	10.6	14.4	1077.6	13.9	12.7	14.23333	1
2022-11-02	2022	11	2	9	3	3	13.4	12.2	14.6	1096.8	13.9	12.4	14.375	1
2022-11-02	2022	11	2	10	3	3	13.3	13.8	14.5	1085.3	13.9	12.2	14.475	1
2022-11-02	2022	11	2	11	3	3	13.3	14.2	7.4	1076.0	13.9	12.1	14.53333	1
2022-11-02	2022	11	2	12	3	3	13.3	14.7	14	1063.6	13.9	12.1	14.575	1
2022-11-02	2022	11	2	13	3	3	13.4	15	13.5	1053.1	13.9	12.7	14	1
2022-11-02	2022	11	2	14	3	3	13.4	15.5	12.8	1037.2	13.9	12.8	13.95833	1
2022-11-02	2022	11	2	15	3	3	13.4	15.6	12.3	1018.5	13.9	13.0	13.85833	1
2022-11-02	2022	11	2	16	3	3	13.4	15.4	11.7	1032.0	13.9	13.2	13.675	1
2022-11-02	2022	11	2	17	3	3	13.4	14.6	11.5	1082.0	13.9	13.4	13.44167	1
2022-11-02	2022	11	2	18	3	3	13.4	13.1	11.1	1133.8	13.9	13.7	13.175	1
2022-11-02	2022	11	2	19	3	3	13.4	11.3	10.6	1172.6	13.9	13.8	12.93333	1
2022-11-02	2022	11	2	20	3	3	13.3	10.3	12.2	1174.1	13.9	13.8	12.675	1
2022-11-02	2022	11	2	21	3	3	13.1	9.4	13.8	1142.5	13.9	13.8	12.36667	1
2022-11-02	2022	11	2	22	3	3	12.9	9	14.2	1092.8	13.9	13.6	12.18333	1
2022-11-02	2022	11	2	23	3	3	12.6	8.4	14.7	1014.4	13.9	13.2	12.11667	1
2022-11-03	2022	11	3	24	4	4	12.4	7.8	15	983.8	10.8	12.7	12.09167	1
2022-11-03	2022	11	3	1	4	4	12.4	6.5	15.5	933.5	10.8	12.1	12.7	1
2022-11-03	2022	11	3	2	4	4	12.1	5.8	15.6	916.3	10.8	11.4	12.78333	1
2022-11-03	2022	11	3	3	4	4	11.8	4.5	15.4	903.4	10.8	10.6	12.95	1
2022-11-03	2022	11	3	4	4	4	11.4	4	14.6	900.7	10.8	9.7	13.18333	1
2022-11-03	2022	11	3	5	4	4	11.1	3.4	13.1	912.7	10.8	8.7	13.44167	1
2022-11-03	2022	11	3	6	4	4	10.7	3.6	11.3	967.9	10.8	7.8	13.68333	1
2022-11-03	2022	11	3	7	4	4	10.4	3.1	10.3	1111.3	10.8	7.0	13.81667	1
2022-11-03	2022	11	3	8	4	4	10.1	2.9	9.4	1251.4	10.8	6.3	13.83333	1
2022-11-03	2022	11	3	9	4	4	9.8	5	9	1274.1	10.8	5.7	13.80833	1
2022-11-03	2022	11	3	10	4	4	9.5	6.2	8.4	1241.4	10.8	5.3	13.575	1
2022-11-03	2022	11	3	11	4	4	9.1	8	7.8	1188.4	10.8	5.1	13.175	1
2022-11-03	2022	11	3	12	4	4	8.9	10	6.5	1146.2	10.8	5.1	12.69167	1
2022-11-03	2022	11	3	13	4	4	8.7	10.7	5.8	1132.2	10.8	5.3	12.11667	1
2022-11-03	2022	11	3	14	4	4	8.5	12.5	4.5	1102.1	10.8	5.6	11.40833	1
2022-11-03	2022	11	3	15	4	4	8.4	13.6	4	1068.1	10.8	6.2	10.6	1
2022-11-03	2022	11	3	16	4	4	8.3	13.5	3.4	1073.8	10.8	6.9	9.675	1
2022-11-03	2022	11	3	17	4	4	8.2	12.2	3.6	1112.6	10.8	7.7	8.725	1
2022-11-03	2022	11	3	18	4	4	8.1	10.4	3.1	1166.4	10.8	8.4	7.791667	1
2022-11-03	2022	11	3	19	4	4	8.0	10.1	2.9	1217.8	10.8	9.0	7	1
2022-11-03	2022	11	3	20	4	4	8.0	8.8	5	1211.8	10.8	9.6	6.316667	1
2022-11-03	2022	11	3	21	4	4	7.9	8.7	6.2	1178.3	10.8	10.1	5.7	1
2022-11-03	2022	11	3	22	4	4	7.9	8.7	8	1119.1	10.8	10.4	5.333333	1
2022-11-03	2022	11	3	23	4	4	7.9	8.4	10	1031.2	10.8	10.6	5.1	1
2022-11-04	2022	11	4	24	5	5	7.9	13.2	10.7	874.6	8.7	10.6	5.066667	1
2022-11-04	2022	11	4	1	5	5	8.1	8.4	12.5	931.9	8.7	10.9	5.25	1
2022-11-04	2022	11	4	2	5	5	8.2	8.9	13.6	901.2	8.7	10.7	5.6	1
2022-11-04	2022	11	4	3	5	5	8.3	8.6	13.5	879.1	8.7	10.4	6.158333	1
2022-11-04	2022	11	4	4	5	5	8.5	8.4	12.2	871.6	8.7	10.0	6.916667	1
2022-11-04	2022	11	4	5	5	5	8.6	8.8	10.4	885.6	8.7	9.6	7.708333	1
2022-11-04	2022	11	4	6	5	5	8.9	8.8	10.1	931.8	8.7	9.3	8.441667	1
2022-11-04	2022	11	4	7	5	5	9.1	9.3	8.8	1052.2	8.7	9.2	9.008333	1
2022-11-04	2022	11	4	8	5	5	9.3	9.9	8.7	1164.3	8.7	9.1	9.591667	1
2022-11-04	2022	11	4	9	5	5	9.6	11.1	8.7	1187.9	8.7	9.2	10.08333	1
2022-11-04	2022	11	4	10	5	5	9.9	12.9	8.4	1156.3	8.7	9.4	10.39167	1
2022-11-04	2022	11	4	11	5	5	10.2	14.6	13.2	1111.9	8.7	9.7	10.6	1
2022-11-04	2022	11	4	12	5	5	10.4	16.9	8.4	1079.4	8.7	10.2	10.63333	1
2022-11-04	2022	11	4	13	5	5	10.7	18	8.9	1055.5	8.7	10.6	10.9	1
2022-11-04	2022	11	4	14	5	5	11.0	18.5	8.6	1025.7	8.7	11.4	10.70833	1
2022-11-04	2022	11	4	15	5	5	11.3	18.5	8.4	1010.8	8.7	12.2	10.40833	1
2022-11-04	2022	11	4	16	5	5	11.5	18.5	8.8	1020.9	8.7	13.0	9.991667	1
2022-11-04	2022	11	4	17	5	5	11.7	17.4	8.8	1047.3	8.7	13.8	9.566667	1
2022-11-04	2022	11	4	18	5	5	11.9	15	9.3	1073.5	8.7	14.5	9.283333	1
2022-11-04	2022	11	4	19	5	5	12.1	13.9	9.9	1097.5	8.7	15.1	9.1	

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLa	gTemp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLa	Weekdays	
2022-11-05	2022	11	11	5	12	6	14.8	18.1	12.5	1017.4	13.3	13.9	15.78333	0
2022-11-05	2022	11	11	5	13	6	14.9	19.1	12.2	1010.0	13.3	14.1	15.65	0
2022-11-05	2022	11	11	5	14	6	14.9	19.1	13.1	987.2	13.3	14.7	15.19167	0
2022-11-05	2022	11	11	5	15	6	14.9	19.7	13.5	971.0	13.3	15.2	14.66667	0
2022-11-05	2022	11	11	5	16	6	15.0	20.1	13.5	972.0	13.3	15.8	14.21667	0
2022-11-05	2022	11	11	5	17	6	15.1	19.1	13.6	1004.0	13.3	16.3	13.8	0
2022-11-05	2022	11	11	5	18	6	15.1	17.3	13.3	1035.8	13.3	16.8	13.475	0
2022-11-05	2022	11	11	5	19	6	15.2	17	13	1065.3	13.3	17.1	13.35833	0
2022-11-05	2022	11	11	5	20	6	15.4	17.5	14.2	1037.1	13.3	17.4	13.30833	0
2022-11-05	2022	11	11	5	21	6	15.5	15.8	15.9	990.6	13.3	17.8	13.29167	0
2022-11-05	2022	11	11	5	22	6	15.6	16.5	16.3	938.6	13.3	17.9	13.325	0
2022-11-05	2022	11	11	5	23	6	15.8	16.4	18.1	887.7	13.3	18.0	13.55833	0
2022-11-06	2022	11	11	6	24	7	15.9	16.3	19.1	781.0	14.0	18.0	13.86667	0
2022-11-06	2022	11	11	6	1	7	16.0	14.7	19.1	758.7	14.0	17.8	14.1	0
2022-11-06	2022	11	11	6	2	7	16.1	14.5	19.7	720.4	14.0	17.5	14.65	0
2022-11-06	2022	11	11	6	3	7	16.2	15.4	20.1	715.8	14.0	17.1	15.225	0
2022-11-06	2022	11	11	6	4	7	16.2	14.9	19.1	717.2	14.0	16.7	15.775	0
2022-11-06	2022	11	11	6	5	7	16.3	14.4	17.3	716.6	14.0	16.3	16.325	0
2022-11-06	2022	11	11	6	6	7	16.3	14.1	17	738.4	14.0	15.9	16.79167	0
2022-11-06	2022	11	11	6	7	7	16.4	13.6	17.5	787.3	14.0	15.6	17.1	0
2022-11-06	2022	11	11	6	8	7	16.4	13.8	15.8	861.8	14.0	15.3	17.40833	0
2022-11-06	2022	11	11	6	9	7	16.4	14.7	16.5	934.0	14.0	15.0	17.78333	0
2022-11-06	2022	11	11	6	10	7	16.4	17	16.4	983.4	14.0	14.9	17.91667	0
2022-11-06	2022	11	11	6	11	7	16.5	18.5	16.3	999.9	14.0	15.0	17.96667	0
2022-11-06	2022	11	11	6	12	7	16.6	19.5	14.7	1005.3	14.0	15.2	17.975	0
2022-11-06	2022	11	11	6	13	7	16.6	20.4	14.5	997.5	14.0	15.4	17.825	0
2022-11-06	2022	11	11	6	14	7	16.7	20.2	15.4	984.8	14.0	15.9	17.45833	0
2022-11-06	2022	11	11	6	15	7	16.7	20.6	14.9	975.0	14.0	16.4	17.075	0
2022-11-06	2022	11	11	6	16	7	16.8	19.3	14.4	995.9	14.0	16.8	16.71667	0
2022-11-06	2022	11	11	6	17	7	16.7	18.2	14.1	1062.0	14.0	17.2	16.28333	0
2022-11-06	2022	11	11	6	18	7	16.7	16.9	13.6	1135.7	14.0	17.5	15.89167	0
2022-11-06	2022	11	11	6	19	7	16.7	16.4	13.8	1100.6	14.0	17.7	15.625	0
2022-11-06	2022	11	11	6	20	7	16.7	16.2	14.7	1054.9	14.0	18.0	15.34167	0
2022-11-06	2022	11	11	6	21	7	16.6	16	17	999.0	14.0	18.2	15.03333	0
2022-11-06	2022	11	11	6	22	7	16.6	16.1	18.5	928.5	14.0	18.3	14.94167	0
2022-11-06	2022	11	11	6	23	7	16.6	16.2	19.5	849.9	14.0	18.2	14.98333	0
2022-11-07	2022	11	11	7	24	1	16.6	13.2	20.4	859.7	19.0	18.0	15.15833	1
2022-11-07	2022	11	11	7	1	1	16.5	16.4	20.2	735.8	19.0	17.5	15.425	1
2022-11-07	2022	11	11	7	2	1	16.5	16	20.6	716.4	19.0	17.1	15.9	1
2022-11-07	2022	11	11	7	3	1	16.6	16.2	19.3	702.4	19.0	16.8	16.375	1
2022-11-07	2022	11	11	7	4	1	16.6	16	18.2	708.5	19.0	16.4	16.80833	1
2022-11-07	2022	11	11	7	5	1	16.7	15.8	16.9	724.3	19.0	16.2	17.175	1
2022-11-07	2022	11	11	7	6	1	16.7	15.7	16.4	774.4	19.0	16.0	17.49167	1
2022-11-07	2022	11	11	7	7	1	16.8	15.6	16.2	895.6	19.0	15.9	17.725	1
2022-11-07	2022	11	11	7	8	1	16.9	15.4	16	1002.8	19.0	15.8	17.95833	1
2022-11-07	2022	11	11	7	9	1	16.9	16.5	16.1	1039.6	19.0	15.7	18.15833	1
2022-11-07	2022	11	11	7	10	1	17.0	17.4	16.2	1055.8	19.0	15.8	18.26667	1
2022-11-07	2022	11	11	7	11	1	17.0	18.3	13.2	1069.7	19.0	15.9	18.19167	1
2022-11-07	2022	11	11	7	12	1	17.0	16.4	16.4	1073.5	19.0	16.0	18	1
2022-11-07	2022	11	11	7	13	1	16.9	17.1	16	1076.6	19.0	16.3	17.475	1
2022-11-07	2022	11	11	7	14	1	16.8	17.1	16.2	1064.5	19.0	16.4	17.14167	1
2022-11-07	2022	11	11	7	15	1	16.6	17.1	16	1060.4	19.0	16.5	16.79167	1
2022-11-07	2022	11	11	7	16	1	16.5	16.9	15.8	1075.2	19.0	16.5	16.425	1
2022-11-07	2022	11	11	7	17	1	16.4	15.9	15.7	1123.5	19.0	16.6	16.15	1
2022-11-07	2022	11	11	7	18	1	16.3	15.9	15.6	1179.1	19.0	16.6	15.95	1
2022-11-07	2022	11	11	7	19	1	16.2	15.8	15.4	1140.5	19.0	16.6	15.85	1
2022-11-07	2022	11	11	7	20	1	16.2	15.2	16.5	1099.2	19.0	16.7	15.78333	1
2022-11-07	2022	11	11	7	21	1	16.2	15.1	17.4	1051.3	19.0	16.6	15.71667	1
2022-11-07	2022	11	11	7	22	1	16.1	15	18.3	980.7	19.0	16.5	15.75833	1
2022-11-07	2022	11	11	7	23	1	16.1	14.2	16.4	905.4	19.0	16.3	15.86667	1
2022-11-07	2022	11	11	7	24	1	16.0	13.2	17.1	859.7	19.0	16.0	16.04167	1
2022-11-08	2022	11	11	8	1	2	16.0	11.7	17.1	823.5	24.6	15.7	16.30833	1
2022-11-08	2022	11	11	8	2	2	15.8	11.2	17.1	804.5	24.6	15.3	16.36667	1
2022-11-08	2022	11	11	8	3	2	15.6	9.9	16.9	799.3	24.6	14.8	16.45833	1
2022-11-08	2022	11	11	8	4	2	15.4	9.4	15.9	797.8	24.6	14.2	16.53333	1
2022-11-08	2022	11	11	8	5	2	15.1	9	15.9	809.5	24.6	13.5	16.60833	1
2022-11-08	2022	11	11	8	6	2	14.8	8.2	15.8	872.9	24.6	13.0	16.61667	1
2022-11-08	2022	11	11	8	7	2	14.5	7.7	15.2	1008.8	24.6	12.3	16.63333	1
2022-11-08	2022	11	11	8	8	2	14.2	7.4	15.1	1123.1	24.6	11.7	16.65	1
2022-11-08	2022	11	11	8	9	2	13.8	7.4	15	1144.5	24.6	11.0	16.63333	1
2022-11-08	2022	11	11	8	10	2	13.4	6.9	14.2	1145.5	24.6	10.4	16.51667	1
2022-11-08	2022	11	11	8	11	2	13.0	7	13.2	1144.2	24.6	9.7	16.31667	1
2022-11-08	2022	11	11	8	12	2	12.5	7.1	11.7	1158.5	24.6	9.1	15.975	1
2022-11-08	2022	11	11	8	13	2	12.1	8.1	11.2	1164.7	24.6	8.6	15.70833	1
2022-11-08	2022	11	11	8	14	2	11.8	7.7	9.9	1159.0	24.6	8.3	15.25833	1
2022-11-08	2022	11	11	8	15	2	11.4	7.8	9.4	1165.2	24.6	8.0	14.76667	1
2022-11-08	2022	11	11	8	16	2	11.0	6.9	9	1201.0	24.6	7.8	14.16667	1
2022-11-08	2022	11	11	8	17	2	10.6	6.5	8.2	1296.4	24.6	7.6	13.54167	1
2022-11-08	2022	11	11	8	18	2	10.2	6.2	7.7	1392.1	24.6	7.4	12.96667	1
2022-11-08	2022	11	11	8	19	2	9.8	6.1	7.4	1369.8	24.6	7.2	12.325	1
2022-11-08	2022	11	11	8	20	2	9.4	6	7.4	1338.5	24.6	7.1	11.65	1
2022-11-08	2022	11	11	8	21	2	9.0	5.8	6.9	1287.0	24.6	7.0	11	1
2022-11-08	2022	11	11	8	22	2	8.6	5.4	7	1211.9	24.6	6.8	10.35833	1
2022-11-08	2022	11	11	8	23	2	8.2	4.8	7.1	1135.6	24.6	6.7	9.683333	1
2022-11-08	2022	11	11	8	24	2	7.8	4.4	8.1	1090.0	24.6	6.5	9.083333	1
2022-11-09	2022	11	11	9	1	3	7.4	4.1	7.7	1056.0	15.6	6.3	8.575	1
2022-11-09	2022	11	11	9	2	3	7.1	3.8	7.8	1026.3	15.6	6.0	8.275	1
2022-11-09	2022	11	11	9	3	3	6.8	3.3	6.9	1001.1	15.6	5.7	7.983333	1
2022-11-09	2022	11	11	9	4	3	6.5	3.1	6.5	998.3	15.6	5.3	7.808333	1
2022-11-09	2022	11	11	9	5	3	6.3	3	6.2	1013.8	15.6	5.0	7.6	1
2022-11-09	2022	11	11	9	6	3	6.0	2.7	6.1	107				

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLag	Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLag	Weekdays
2022-11-09	2022	11	11	9	24	3	4.4	4.5	6.5	1107.7	15.6	5.4 3.366667	1
2022-11-10	2022	11	11	10	1	4	4.4	4	6.8	1049.0	15.8	5.2 3.5	1
2022-11-10	2022	11	11	10	2	4	4.4	3.4	7.4	1016.9	15.8	5.0 3.7	1
2022-11-10	2022	11	11	10	3	4	4.3	4	7.3	983.1	15.8	4.7 3.95	1
2022-11-10	2022	11	11	10	4	4	4.4	4.4	6.6	974.4	15.8	4.5 4.291667	1
2022-11-10	2022	11	11	10	5	4	4.4	4.4	4.7	986.9	15.8	4.2 4.641667	1
2022-11-10	2022	11	11	10	6	4	4.5	5.5	3.7	1037.5	15.8	4.0 4.941667	1
2022-11-10	2022	11	11	10	7	4	4.6	6.4	3.3	1152.9	15.8	4.1 5.108333	1
2022-11-10	2022	11	11	10	8	4	4.8	8.2	3.7	1250.8	15.8	4.3 5.216667	1
2022-11-10	2022	11	11	10	9	4	5.0	9.2	4	1274.8	15.8	4.7 5.308333	1
2022-11-10	2022	11	11	10	10	4	5.3	9.8	4.3	1260.4	15.8	5.2 5.391667	1
2022-11-10	2022	11	11	10	11	4	5.5	10.1	4.5	1238.5	15.8	5.7 5.408333	1
2022-11-10	2022	11	11	10	12	4	5.8	11.1	4	1219.9	15.8	6.2 5.358333	1
2022-11-10	2022	11	11	10	13	4	6.0	12.1	3.4	1192.3	15.8	6.7 5.233333	1
2022-11-10	2022	11	11	10	14	4	6.2	14.3	4	1153.5	15.8	7.4 5.025	1
2022-11-10	2022	11	11	10	15	4	6.5	15.3	4.4	1136.2	15.8	8.3 4.741667	1
2022-11-10	2022	11	11	10	16	4	6.8	15.5	4.4	1137.2	15.8	9.2 4.458333	1
2022-11-10	2022	11	11	10	17	4	7.2	14.7	5.5	1178.7	15.8	10.2 4.216667	1
2022-11-10	2022	11	11	10	18	4	7.5	13.1	6.4	1242.6	15.8	11.0 4.033333	1
2022-11-10	2022	11	11	10	19	4	7.9	12.6	8.2	1216.8	15.8	11.7 4.1	1
2022-11-10	2022	11	11	10	20	4	8.2	12.3	9.2	1176.7	15.8	12.2 4.325	1
2022-11-10	2022	11	11	10	21	4	8.6	12.2	9.8	1125.9	15.8	12.5 4.733333	1
2022-11-10	2022	11	11	10	22	4	9.0	11.8	10.1	1061.4	15.8	12.8 5.191667	1
2022-11-10	2022	11	11	10	23	4	9.3	11.6	11.1	994.3	15.8	12.9 5.675	1
2022-11-10	2022	11	11	10	24	4	9.6	11.7	12.1	934.5	15.8	13.1 6.158333	1
2022-11-11	2022	11	11	11	1	5	9.9	12	14.3	864.4	6.2	13.1 6.708333	0
2022-11-11	2022	11	11	11	2	5	10.2	12	15.3	823.3	6.2	13.1 7.383333	0
2022-11-11	2022	11	11	11	3	5	10.6	12.2	15.5	818.2	6.2	12.9 8.291667	0
2022-11-11	2022	11	11	11	4	5	10.9	12.1	14.7	811.3	6.2	12.6 9.233333	0
2022-11-11	2022	11	11	11	5	5	11.3	12.2	13.1	819.7	6.2	12.4 10.15833	0
2022-11-11	2022	11	11	11	6	5	11.6	11.5	12.6	856.3	6.2	12.2 11.01667	0
2022-11-11	2022	11	11	11	7	5	11.8	11	12.3	906.0	6.2	12.0 11.65	0
2022-11-11	2022	11	11	11	8	5	12.0	10.7	12.2	963.2	6.2	11.9 12.16667	0
2022-11-11	2022	11	11	11	9	5	12.1	11.3	11.8	1023.4	6.2	11.8 12.50833	0
2022-11-11	2022	11	11	11	10	5	12.2	14.3	11.6	1057.0	6.2	11.7 12.75833	0
2022-11-11	2022	11	11	11	11	5	12.4	15.9	11.7	1049.5	6.2	11.9 12.925	0
2022-11-11	2022	11	11	11	12	5	12.6	17.1	12	1037.4	6.2	12.2 13.05	0
2022-11-11	2022	11	11	11	13	5	12.9	17.8	12	1038.2	6.2	12.7 13.1	0
2022-11-11	2022	11	11	11	14	5	13.1	17.8	12.2	1015.3	6.2	13.2 13.09167	0
2022-11-11	2022	11	11	11	15	5	13.3	17.6	12.1	1003.4	6.2	13.7 12.9	0
2022-11-11	2022	11	11	11	16	5	13.4	15.5	12.2	1019.6	6.2	14.1 12.64167	0
2022-11-11	2022	11	11	11	17	5	13.4	15	11.5	1089.5	6.2	14.4 12.35833	0
2022-11-11	2022	11	11	11	18	5	13.4	12.6	11	1167.8	6.2	14.6 12.15	0
2022-11-11	2022	11	11	11	19	5	13.4	11.5	10.7	1125.1	6.2	14.7 12.01667	0
2022-11-11	2022	11	11	11	20	5	13.3	10.7	11.3	1078.0	6.2	14.8 11.88333	0
2022-11-11	2022	11	11	11	21	5	13.3	11.1	14.3	1026.3	6.2	14.8 11.75	0
2022-11-11	2022	11	11	11	22	5	13.2	11.6	15.9	977.6	6.2	14.7 11.675	0
2022-11-11	2022	11	11	11	23	5	13.2	13.3	17.1	922.1	6.2	14.5 11.88333	0
2022-11-11	2022	11	11	11	24	5	13.3	13.7	17.8	876.1	6.2	14.3 12.24167	0
2022-11-12	2022	11	12	12	1	6	13.4	13.6	17.8	823.4	26.5	14.0 12.69167	0
2022-11-12	2022	11	12	12	2	6	13.4	13.7	17.6	789.7	26.5	13.7 13.175	0
2022-11-12	2022	11	12	12	3	6	13.5	15.1	15.5	773.2	26.5	13.3 13.65833	0
2022-11-12	2022	11	12	12	4	6	13.6	14.8	15	770.3	26.5	13.1 14.10833	0
2022-11-12	2022	11	12	12	5	6	13.7	14.3	12.6	770.1	26.5	13.1 14.39167	0
2022-11-12	2022	11	12	12	6	6	13.8	13.9	11.5	790.1	26.5	13.0 14.625	0
2022-11-12	2022	11	12	12	7	6	13.9	14.3	10.7	831.7	26.5	13.1 14.71667	0
2022-11-12	2022	11	12	12	8	6	14.1	15.6	11.1	895.7	26.5	13.3 14.75833	0
2022-11-12	2022	11	12	12	9	6	14.3	15.3	11.6	982.0	26.5	13.8 14.75833	0
2022-11-12	2022	11	12	12	10	6	14.4	15.3	13.3	1048.7	26.5	14.1 14.74167	0
2022-11-12	2022	11	12	12	11	6	14.5	16.9	13.7	1074.4	26.5	14.4 14.51667	0
2022-11-12	2022	11	12	12	12	6	14.5	16.3	13.6	1104.9	26.5	14.7 14.3	0
2022-11-12	2022	11	12	12	13	6	14.5	17.3	13.7	1100.7	26.5	14.9 14.01667	0
2022-11-12	2022	11	12	12	14	6	14.5	17.3	15.1	1080.1	26.5	15.2 13.66667	0
2022-11-12	2022	11	12	12	15	6	14.4	17.2	14.8	1067.4	26.5	15.5 13.325	0
2022-11-12	2022	11	12	12	16	6	14.4	17.1	14.3	1074.1	26.5	15.7 13.11667	0
2022-11-12	2022	11	12	12	17	6	14.5	16.8	13.9	1116.4	26.5	15.9 13.05833	0
2022-11-12	2022	11	12	12	18	6	14.6	17.3	14.3	1163.9	26.5	16.1 13	0
2022-11-12	2022	11	12	12	19	6	14.8	16.7	15.6	1113.3	26.5	16.4 13.10833	0
2022-11-12	2022	11	12	12	20	6	15.0	15.8	15.3	1058.0	26.5	16.6 13.34167	0
2022-11-12	2022	11	12	12	21	6	15.2	15.6	15.3	1011.5	26.5	16.6 13.75	0
2022-11-12	2022	11	12	12	22	6	15.4	16.3	16.9	968.5	26.5	16.6 14.1	0
2022-11-12	2022	11	12	12	23	6	15.6	12.2	16.3	927.2	26.5	16.7 14.40833	0
2022-11-12	2022	11	12	12	24	6	15.5	8.9	17.3	881.7	26.5	16.3 14.70833	0
2022-11-13	2022	11	13	13	1	7	15.3	7.4	17.3	838.8	12.7	15.7 14.925	0
2022-11-13	2022	11	13	13	2	7	15.1	6.7	17.2	818.8	12.7	14.9 15.23333	0
2022-11-13	2022	11	13	13	3	7	14.8	6.4	17.1	811.7	12.7	14.0 15.53333	0
2022-11-13	2022	11	13	13	4	7	14.4	6.1	16.8	810.8	12.7	13.1 15.70833	0
2022-11-13	2022	11	13	13	5	7	14.0	5.8	17.3	819.0	12.7	12.2 15.9	0
2022-11-13	2022	11	13	13	6	7	13.7	5.5	16.7	844.9	12.7	11.3 16.10833	0
2022-11-13	2022	11	13	13	7	7	13.3	5.4	15.8	889.6	12.7	10.3 16.39167	0
2022-11-13	2022	11	13	13	8	7	13.0	5	15.6	956.7	12.7	9.3 16.59167	0
2022-11-13	2022	11	13	13	9	7	12.5	5.2	16.3	1036.9	12.7	8.4 16.60833	0
2022-11-13	2022	11	13	13	10	7	12.1	6.4	12.2	1094.1	12.7	7.6 16.63333	0
2022-11-13	2022	11	13	13	11	7	11.7	6.8	8.9	1110.0	12.7	6.8 16.71667	0
2022-11-13	2022	11	13	13	12	7	11.3	7.7	7.4	1124.5	12.7	6.3 16.325	0
2022-11-13	2022	11	13	13	13	7	11.0	8.2	6.7	1134.5	12.7	6.2 15.70833	0
2022-11-13	2022	11	13	13	14	7	10.6	8.4	6.4	1126.0	12.7	6.3 14.88333	0
2022-11-13	2022	11	13	13	15	7	10.2	8.4	6.1	1134.6	12.7	6.4 14	0
2022-11-13	2022	11	13	13	16	7	9.8	8.6	5.8	1161.6	12.7	6.6 13.1	0
2022-11-13	2022	11	13	13	17	7	9.5	8.4	5.5	1251.5	12.7	6.8 12.18333	0
2022-11-13	2022	11	13	13	18	7	9.1	8.3	5.4	1309.0	12.7	7.0 11.26667	0
2022-11-13	2022	11	13	13	19	7	8.8	8.3	5	1271.7	12.7	7.2 10.28333	0
2022-11-13	2022	11	13	13	20	7	8.4	8.8	5.2	1235.0	12.7	7.5 9.341667	0
2022-11-13													

DATE	Year	Month	Day	HOUR	DOW	24hrAvgLa	g Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLa	g Weekdays	
2022-11-14	2022	11	14	14	12	1	8.9	6.4	10.2	1242.8	21.3	9.3	8.5	1
2022-11-14	2022	11	14	14	13	1	8.9	6.5	10.7	1241.4	21.3	9.1	8.666667	1
2022-11-14	2022	11	14	14	14	1	8.8	6.1	11.6	1228.9	21.3	8.8	8.833333	1
2022-11-14	2022	11	14	15	15	1	8.7	5.6	13.3	1234.7	21.3	8.4	9.025	1
2022-11-14	2022	11	14	16	16	1	8.6	5.4	12	1270.2	21.3	7.9	9.291667	1
2022-11-14	2022	11	14	17	17	1	8.4	4.7	11	1356.2	21.3	7.2	9.683333	1
2022-11-14	2022	11	14	18	18	1	8.3	3.8	8.3	1457.3	21.3	6.6	9.983333	1
2022-11-14	2022	11	14	19	19	1	8.1	3.4	6.5	1425.8	21.3	6.0	10.20833	1
2022-11-14	2022	11	14	20	20	1	7.9	3.4	6.1	1391.1	21.3	5.6	10.20833	1
2022-11-14	2022	11	14	21	21	1	7.7	3.4	6.2	1343.0	21.3	5.3	10.01667	1
2022-11-14	2022	11	14	22	22	1	7.5	3.1	6.4	1272.9	21.3	5.1	9.8	1
2022-11-14	2022	11	14	23	23	1	7.2	2.7	6.4	1187.1	21.3	4.9	9.575	1
2022-11-14	2022	11	14	24	24	1	6.9	2.8	6.5	1145.8	21.3	4.5	9.333333	1
2022-11-15	2022	11	15	1	2	2	6.7	2.5	6.1	1106.6	12.8	4.2	9.058333	1
2022-11-15	2022	11	15	2	2	2	6.3	2.4	5.6	1071.1	12.8	3.9	8.75	1
2022-11-15	2022	11	15	3	2	2	6.0	2.4	5.4	1047.1	12.8	3.6	8.366667	1
2022-11-15	2022	11	15	4	2	2	5.6	2.3	4.7	1037.6	12.8	3.3	7.866667	1
2022-11-15	2022	11	15	5	2	2	5.1	2.3	3.8	1050.8	12.8	3.1	7.208333	1
2022-11-15	2022	11	15	6	2	2	4.7	2.3	3.4	1106.8	12.8	2.9	6.6	1
2022-11-15	2022	11	15	7	2	2	4.4	2.2	3.4	1237.1	12.8	2.8	6	1
2022-11-15	2022	11	15	8	2	2	4.1	1.9	3.4	1349.4	12.8	2.7	5.591667	1
2022-11-15	2022	11	15	9	2	2	3.9	2	3.1	1379.5	12.8	2.5	5.333333	1
2022-11-15	2022	11	15	10	2	2	3.8	2	2.7	1345.5	12.8	2.4	5.108333	1
2022-11-15	2022	11	15	11	2	2	3.6	3.3	2.8	1297.1	12.8	2.3	4.85	1
2022-11-15	2022	11	15	12	2	2	3.5	4	2.5	1276.1	12.8	2.4	4.541667	1
2022-11-15	2022	11	15	13	2	2	3.4	3.7	2.4	1262.8	12.8	2.5	4.241667	1
2022-11-15	2022	11	15	14	2	2	3.2	4	2.4	1231.2	12.8	2.6	3.908333	1
2022-11-15	2022	11	15	15	2	2	3.2	5	2.3	1226.2	12.8	2.7	3.6	1
2022-11-15	2022	11	15	16	2	2	3.1	5.2	2.3	1268.3	12.8	2.9	3.333333	1
2022-11-15	2022	11	15	17	2	2	3.1	4.3	2.3	1366.8	12.8	3.2	3.075	1
2022-11-15	2022	11	15	18	2	2	3.1	2.7	2.2	1470.9	12.8	3.3	2.875	1
2022-11-15	2022	11	15	19	2	2	3.1	2.3	1.9	1447.8	12.8	3.4	2.75	1
2022-11-15	2022	11	15	20	2	2	3.0	1.5	2	1388.0	12.8	3.4	2.65	1
2022-11-15	2022	11	15	21	2	2	2.9	1.1	2	1358.3	12.8	3.3	2.525	1
2022-11-15	2022	11	15	22	2	2	2.8	1.9	3.3	1295.3	12.8	3.3	2.408333	1
2022-11-15	2022	11	15	23	2	2	2.8	1.8	4	1214.4	12.8	3.3	2.316667	1
2022-11-15	2022	11	15	24	2	2	2.7	1.6	3.7	1165.5	12.8	3.1	2.366667	1
2022-11-16	2022	11	16	1	3	3	2.7	1.2	4	1120.8	15.9	2.9	2.466667	1
2022-11-16	2022	11	16	2	3	3	2.6	0.9	5	1086.2	15.9	2.7	2.566667	1
2022-11-16	2022	11	16	3	3	3	2.6	1.1	5.2	1059.4	15.9	2.5	2.7	1
2022-11-16	2022	11	16	4	3	3	2.5	1.1	4.3	1055.1	15.9	2.1	2.916667	1
2022-11-16	2022	11	16	5	3	3	2.5	-0.2	2.7	1070.4	15.9	1.8	3.158333	1
2022-11-16	2022	11	16	6	3	3	2.4	0.3	2.3	1125.6	15.9	1.4	3.325	1
2022-11-16	2022	11	16	7	3	3	2.3	0.6	1.5	1262.6	15.9	1.2	3.358333	1
2022-11-16	2022	11	16	8	3	3	2.2	0.4	1.1	1373.0	15.9	1.1	3.366667	1
2022-11-16	2022	11	16	9	3	3	2.2	1	1.9	1401.9	15.9	1.0	3.333333	1
2022-11-16	2022	11	16	10	3	3	2.1	1.5	1.8	1378.4	15.9	1.0	3.258333	1
2022-11-16	2022	11	16	11	3	3	2.1	3	1.6	1336.6	15.9	0.9	3.25	1
2022-11-16	2022	11	16	12	3	3	2.1	6.1	1.2	1327.8	15.9	1.0	3.125	1
2022-11-16	2022	11	16	13	3	3	2.2	6.9	0.9	1333.0	15.9	1.4	2.925	1
2022-11-16	2022	11	16	14	3	3	2.3	7.9	1.1	1325.9	15.9	1.9	2.716667	1
2022-11-16	2022	11	16	15	3	3	2.5	8.2	1.1	1321.7	15.9	2.5	2.458333	1
2022-11-16	2022	11	16	16	3	3	2.6	8.2	-0.2	1346.2	15.9	3.1	2.133333	1
2022-11-16	2022	11	16	17	3	3	2.7	7.9	0.3	1414.8	15.9	3.7	1.791667	1
2022-11-16	2022	11	16	18	3	3	2.9	8.6	0.6	1466.4	15.9	4.3	1.416667	1
2022-11-16	2022	11	16	19	3	3	3.1	9.3	0.4	1419.2	15.9	5.0	1.216667	1
2022-11-16	2022	11	16	20	3	3	3.4	9.8	1	1372.1	15.9	5.8	1.075	1
2022-11-16	2022	11	16	21	3	3	3.8	10.9	1.5	1306.9	15.9	6.5	0.983333	1
2022-11-16	2022	11	16	22	3	3	4.2	12	3	1217.7	15.9	7.4	0.975	1
2022-11-16	2022	11	16	23	3	3	4.6	14.3	6.1	1114.2	15.9	8.2	0.941667	1
2022-11-16	2022	11	16	24	3	3	5.1	13.9	6.9	1032.2	15.9	9.2	1.041667	1
2022-11-17	2022	11	17	1	4	4	5.6	12.4	7.9	966.9	17.0	9.8	1.416667	1
2022-11-17	2022	11	17	2	4	4	6.1	11.8	8.2	927.6	17.0	10.3	1.891667	1
2022-11-17	2022	11	17	3	4	4	6.5	11.3	8.2	910.2	17.0	10.6	2.475	1
2022-11-17	2022	11	17	4	4	4	7.0	10.3	7.9	917.6	17.0	10.9	3.066667	1
2022-11-17	2022	11	17	5	4	4	7.4	7.9	8.6	938.6	17.0	11.0	3.658333	1
2022-11-17	2022	11	17	6	4	4	7.7	6.2	9.3	994.9	17.0	11.0	4.333333	1
2022-11-17	2022	11	17	7	4	4	7.9	5.5	9.8	1127.4	17.0	10.8	5.025	1
2022-11-17	2022	11	17	8	4	4	8.1	4.8	10.9	1245.0	17.0	10.5	5.75	1
2022-11-17	2022	11	17	9	4	4	8.3	4.2	12	1278.4	17.0	10.1	6.533333	1
2022-11-17	2022	11	17	10	4	4	8.5	4.1	14.3	1267.8	17.0	9.6	7.358333	1
2022-11-17	2022	11	17	11	4	4	8.6	5.8	13.9	1248.0	17.0	8.9	8.233333	1
2022-11-17	2022	11	17	12	4	4	8.7	6	12.4	1245.1	17.0	8.2	9.175	1
2022-11-17	2022	11	17	13	4	4	8.7	5.7	11.8	1253.1	17.0	7.5	9.825	1
2022-11-17	2022	11	17	14	4	4	8.6	7	11.3	1259.3	17.0	7.0	10.28333	1
2022-11-17	2022	11	17	15	4	4	8.6	6.6	10.3	1248.0	17.0	6.6	10.60833	1
2022-11-17	2022	11	17	16	4	4	8.5	6.3	7.9	1277.8	17.0	6.2	10.86667	1
2022-11-17	2022	11	17	17	4	4	8.4	5.5	6.2	1362.9	17.0	5.8	11.04167	1
2022-11-17	2022	11	17	18	4	4	8.3	4.6	5.5	1464.0	17.0	5.6	11.04167	1
2022-11-17	2022	11	17	19	4	4	8.2	3.8	4.8	1444.2	17.0	5.5	10.84167	1
2022-11-17	2022	11	17	20	4	4	7.9	3	4.2	1421.9	17.0	5.4	10.525	1
2022-11-17	2022	11	17	21	4	4	7.7	2.5	4.1	1384.3	17.0	5.2	10.10833	1
2022-11-17	2022	11	17	22	4	4	7.3	2.2	5.8	1332.8	17.0	5.1	9.55	1
2022-11-17	2022	11	17	23	4	4	6.9	1.7	6	1254.3	17.0	4.9	8.891667	1
2022-11-17	2022	11	17	24	4	4	6.4	1.6	5.7	1213.6	17.0	4.6	8.183333	1
2022-11-18	2022	11	18	1	5	5	5.9	0.9	7	1177.7	12.0	4.2	7.525	1
2022-11-18	2022	11	18	2	5	5	5.4	0.8	6.6	1146.3	12.0	3.8	6.966667	1
2022-11-18	2022	11	18	3	5	5	4.9	0.8	6.3	1121.0	12.0	3.3	6.566667	1
2022-11-18	2022	11	18	4	5	5	4.5	0.8	5.5	1119.6	12.0	2.8	6.175	1
2022-11-18	2022	11	18	5	5	5	4.1	0.4	4.6	1128.8	12.0	2.4	5.841667	1
2022-11-18	2022	11	18	6	5	5	3.8	0.4	3.8	1194.2	12.0	1.9	5.641667	1
2022-11-18	2022	11	18	7	5	5	3.5	0.1	3	1315.9	12.0	1.6	5.508333	1
2022-11-18	2022	11	18	8	5	5</								

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLa	g Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLa	g Weekdays	
2022-11-18	2022	11	18	18	24	5	1.6	2.9	2.7	1248.4	12.0	2.2	0.958333	1
2022-11-19	2022	11	19	19	1	6	1.6	2.2	2.8	1212.4	8.0	2.2	1.016667	0
2022-11-19	2022	11	19	2	6	6	1.7	1.3	4.3	1180.9	8.0	2.2	1.166667	0
2022-11-19	2022	11	19	3	6	6	1.7	0.7	4.1	1157.9	8.0	2.0	1.333333	0
2022-11-19	2022	11	19	4	6	6	1.7	0.3	3.8	1150.2	8.0	1.7	1.625	0
2022-11-19	2022	11	19	5	6	6	1.7	-0.8	2.5	1160.8	8.0	1.4	1.9	0
2022-11-19	2022	11	19	6	6	6	1.6	-2	1.6	1195.7	8.0	1.0	2.183333	0
2022-11-19	2022	11	19	7	6	6	1.5	-1.3	0.2	1267.8	8.0	0.7	2.358333	0
2022-11-19	2022	11	19	8	6	6	1.5	-2.6	0.4	1351.9	8.0	0.4	2.483333	0
2022-11-19	2022	11	19	9	6	6	1.3	-1	0.6	1391.8	8.0	0.2	2.483333	0
2022-11-19	2022	11	19	10	6	6	1.3	2.8	0.6	1358.7	8.0	0.1	2.425	0
2022-11-19	2022	11	19	11	6	6	1.3	4.6	2.9	1306.0	8.0	0.3	2.333333	0
2022-11-19	2022	11	19	12	6	6	1.4	5.7	2.2	1275.6	8.0	0.6	2.158333	0
2022-11-19	2022	11	19	13	6	6	1.5	7.1	1.3	1251.5	8.0	0.8	2.208333	0
2022-11-19	2022	11	19	14	6	6	1.7	6.6	0.7	1209.2	8.0	1.2	2.166667	0
2022-11-19	2022	11	19	15	6	6	1.9	7.5	0.3	1201.6	8.0	1.7	2.041667	0
2022-11-19	2022	11	19	16	6	6	2.0	6.1	-0.8	1232.3	8.0	2.2	1.741667	0
2022-11-19	2022	11	19	17	6	6	2.1	5.2	-2	1327.1	8.0	2.7	1.425	0
2022-11-19	2022	11	19	18	6	6	2.1	4.8	-1.3	1416.6	8.0	3.2	1.041667	0
2022-11-19	2022	11	19	19	6	6	2.2	4.9	-2.6	1386.3	8.0	3.8	0.666667	0
2022-11-19	2022	11	19	20	6	6	2.4	3.5	-1	1360.1	8.0	4.3	0.425	0
2022-11-19	2022	11	19	21	6	6	2.5	2.9	2.8	1334.4	8.0	4.8	0.191667	0
2022-11-19	2022	11	19	22	6	6	2.6	1.8	4.6	1295.0	8.0	5.1	0.075	0
2022-11-19	2022	11	19	23	6	6	2.7	2	5.7	1232.7	8.0	5.1	0.258333	0
2022-11-19	2022	11	19	24	6	6	2.7	2.4	7.1	1177.2	8.0	4.8	0.591667	0
2022-11-20	2022	11	20	1	7	7	2.7	2.5	6.6	1124.5	16.3	4.6	0.825	0
2022-11-20	2022	11	20	2	7	7	2.7	3.6	7.5	1087.7	16.3	4.2	1.233333	0
2022-11-20	2022	11	20	3	7	7	2.8	3.3	6.1	1069.2	16.3	3.9	1.675	0
2022-11-20	2022	11	20	4	7	7	2.9	3.4	5.2	1058.4	16.3	3.6	2.241667	0
2022-11-20	2022	11	20	5	7	7	3.0	2.1	4.8	1059.8	16.3	3.4	2.725	0
2022-11-20	2022	11	20	6	7	7	3.2	1.9	4.9	1081.1	16.3	3.1	3.225	0
2022-11-20	2022	11	20	7	7	7	3.3	1.9	3.5	1130.1	16.3	2.9	3.791667	0
2022-11-20	2022	11	20	8	7	7	3.5	3.1	2.9	1188.1	16.3	2.6	4.308333	0
2022-11-20	2022	11	20	9	7	7	3.7	7.1	1.8	1265.1	16.3	2.6	4.816667	0
2022-11-20	2022	11	20	10	7	7	4.0	5.6	2	1312.9	16.3	2.9	5.141667	0
2022-11-20	2022	11	20	11	7	7	4.2	6.1	2.4	1318.6	16.3	3.2	5.058333	0
2022-11-20	2022	11	20	12	7	7	4.2	7.2	2.5	1292.7	16.3	3.6	4.841667	0
2022-11-20	2022	11	20	13	7	7	4.3	7.3	3.6	1269.1	16.3	4.0	4.566667	0
2022-11-20	2022	11	20	14	7	7	4.3	8.2	3.3	1251.6	16.3	4.4	4.183333	0
2022-11-20	2022	11	20	15	7	7	4.4	7.6	3.4	1262.3	16.3	4.8	3.933333	0
2022-11-20	2022	11	20	16	7	7	4.4	6.5	2.1	1328.3	16.3	5.1	3.583333	0
2022-11-20	2022	11	20	17	7	7	4.4	5.5	1.9	1442.1	16.3	5.4	3.358333	0
2022-11-20	2022	11	20	18	7	7	4.4	2.9	1.9	1509.7	16.3	5.7	3.1	0
2022-11-20	2022	11	20	19	7	7	4.3	1.8	3.1	1488.8	16.3	5.8	2.858333	0
2022-11-20	2022	11	20	20	7	7	4.2	1	7.1	1477.4	16.3	5.7	2.608333	0
2022-11-20	2022	11	20	21	7	7	4.1	0.2	5.6	1445.7	16.3	5.6	2.575	0
2022-11-20	2022	11	20	22	7	7	4.0	-0.3	6.1	1389.5	16.3	5.0	2.925	0
2022-11-20	2022	11	20	23	7	7	3.9	-0.8	7.2	1310.7	16.3	4.5	3.241667	0
2022-11-20	2022	11	20	24	7	7	3.8	-1.2	7.3	1250.1	16.3	3.9	3.583333	0
2022-11-21	2022	11	21	1	1	1	3.6	-1.1	8.2	1210.5	17.0	3.2	3.983333	1
2022-11-21	2022	11	21	2	1	1	3.5	-1.3	7.6	1206.8	17.0	2.5	4.383333	1
2022-11-21	2022	11	21	3	1	1	3.3	-2	6.5	1209.9	17.0	1.7	4.766667	1
2022-11-21	2022	11	21	4	1	1	3.0	-2.3	5.5	1221.1	17.0	0.9	5.125	1
2022-11-21	2022	11	21	5	1	1	2.8	-2.9	2.9	1246.3	17.0	0.2	5.383333	1
2022-11-21	2022	11	21	6	1	1	2.6	-3.1	1.8	1320.1	17.0	-0.5	5.666667	1
2022-11-21	2022	11	21	7	1	1	2.4	-3.1	1	1466.5	17.0	-1.0	5.75	1
2022-11-21	2022	11	21	8	1	1	2.2	-3.3	0.2	1585.8	17.0	-1.4	5.741667	1
2022-11-21	2022	11	21	9	1	1	1.9	-3.1	-0.3	1606.9	17.0	-1.8	5.566667	1
2022-11-21	2022	11	21	10	1	1	1.5	-2.6	-0.8	1572.4	17.0	-2.0	4.991667	1
2022-11-21	2022	11	21	11	1	1	1.1	-1.5	-1.2	1537.7	17.0	-2.2	4.5	1
2022-11-21	2022	11	21	12	1	1	0.8	-0.9	-1.1	1512.2	17.0	-2.3	3.925	1
2022-11-21	2022	11	21	13	1	1	0.5	-0.3	-1.3	1474.3	17.0	-2.3	3.225	1
2022-11-21	2022	11	21	14	1	1	0.2	0.7	-2	1438.0	17.0	-2.2	2.525	1
2022-11-21	2022	11	21	15	1	1	-0.2	1.2	-2.3	1418.9	17.0	-2.0	1.733333	1
2022-11-21	2022	11	21	16	1	1	-0.4	0.8	-2.9	1446.7	17.0	-1.8	0.933333	1
2022-11-21	2022	11	21	17	1	1	-0.7	0.4	-3.1	1553.5	17.0	-1.5	0.2	1
2022-11-21	2022	11	21	18	1	1	-0.9	-0.8	-3.1	1662.5	17.0	-1.2	-0.5	1
2022-11-21	2022	11	21	19	1	1	-1.0	-1.4	-3.3	1639.3	17.0	-1.0	-1	1
2022-11-21	2022	11	21	20	1	1	-1.2	-1.4	-3.1	1598.8	17.0	-0.9	-1.40833	1
2022-11-21	2022	11	21	21	1	1	-1.3	-1.5	-2.6	1548.1	17.0	-0.7	-1.76667	1
2022-11-21	2022	11	21	22	1	1	-1.3	-0.7	-1.5	1469.4	17.0	-0.6	-2.04167	1
2022-11-21	2022	11	21	23	1	1	-1.3	0.4	-0.9	1367.6	17.0	-0.5	-2.23333	1
2022-11-21	2022	11	21	24	1	1	-1.3	2.7	-0.3	1309.9	17.0	-0.3	-2.29167	1
2022-11-22	2022	11	22	1	2	2	-1.1	3.7	0.7	1251.5	16.6	0.0	-2.26667	1
2022-11-22	2022	11	22	2	2	2	-0.9	4.9	1.2	1204.1	16.6	0.3	-2.2	1
2022-11-22	2022	11	22	3	2	2	-0.7	5.7	0.8	1167.6	16.6	0.7	-2.03333	1
2022-11-22	2022	11	22	4	2	2	-0.4	6.4	0.4	1145.7	16.6	1.1	-1.76667	1
2022-11-22	2022	11	22	5	2	2	0.0	5.9	-0.8	1154.7	16.6	1.5	-1.50833	1
2022-11-22	2022	11	22	6	2	2	0.4	5.4	-1.4	1207.7	16.6	2.0	-1.23333	1
2022-11-22	2022	11	22	7	2	2	0.7	5.2	-1.4	1335.2	16.6	2.5	-1.04167	1
2022-11-22	2022	11	22	8	2	2	1.1	3.5	-1.5	1431.5	16.6	3.1	-0.9	1
2022-11-22	2022	11	22	9	2	2	1.4	3.8	-0.7	1439.5	16.6	3.5	-0.74167	1
2022-11-22	2022	11	22	10	2	2	1.7	4.3	0.4	1410.3	16.6	3.9	-0.60833	1
2022-11-22	2022	11	22	11	2	2	1.9	3.6	2.7	1384.2	16.6	4.3	-0.45	1
2022-11-22	2022	11	22	12	2	2	2.2	4.7	3.7	1361.7	16.6	4.6	-0.29167	1
2022-11-22	2022	11	22	13	2	2	2.4	5.2	4.9	1340.7	16.6	4.8	0.008333	1
2022-11-22	2022	11	22	14	2	2	2.6	4.2	5.7	1310.9	16.6	4.9	0.341667	1
2022-11-22	2022	11	22	15	2	2	2.8	4.9	6.4	1302.0	16.6	4.8	0.691667	1
2022-11-22	2022	11	22	16	2	2	2.9	4.4	5.9	1342.3	16.6	4.8	1.066667	1
2022-11-22	2022	11	22	17	2	2	3.1	4.1	5.4	1446.0	16.6	4.6	1.533333	1
2022-11-22	2022	11	22	18	2	2	3.2	2.6	5.2	1566.5	16.6	4.4	1.991667	1
2022-11-22	2022	11	22	19	2	2	3.4	1.4	3.5	1558.1	16.6	4.2	2.508333	1
2022-11-22	2022	11	22	20	2	2	3.5	1	3.8	1536				

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLa	g Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLa	g Weekdays	
2022-11-23	2022	11	23	23	12	3	2.4	4.4	-0.6	1362.5	14.1	2.4	2.366667	1
2022-11-23	2022	11	23	23	13	3	2.4	4.5	1.9	1337.3	14.1	2.9	1.9	1
2022-11-23	2022	11	23	23	14	3	2.4	4.6	2.5	1317.0	14.1	3.3	1.416667	1
2022-11-23	2022	11	23	23	15	3	2.4	5.3	3.3	1314.0	14.1	3.5	1.225	1
2022-11-23	2022	11	23	23	16	3	2.4	5.2	3	1366.1	14.1	3.8	1.025	1
2022-11-23	2022	11	23	23	17	3	2.4	3.9	2.8	1477.9	14.1	3.9	0.933333	1
2022-11-23	2022	11	23	23	18	3	2.4	3.6	3.3	1564.6	14.1	4.0	0.841667	1
2022-11-23	2022	11	23	23	19	3	2.5	3.1	3.7	1543.4	14.1	4.1	0.858333	1
2022-11-23	2022	11	23	23	20	3	2.5	2.2	4	1525.2	14.1	4.1	1.016667	1
2022-11-23	2022	11	23	23	21	3	2.6	1	3.2	1499.7	14.1	3.9	1.241667	1
2022-11-23	2022	11	23	23	22	3	2.7	-0.5	3.1	1444.2	14.1	3.7	1.708333	1
2022-11-23	2022	11	23	23	23	3	2.7	-1	4.4	1376.3	14.1	3.4	2.1	1
2022-11-23	2022	11	23	24	3	3	2.7	-2.2	4.5	1353.3	14.1	3.0	2.441667	1
2022-11-24	2022	11	24	1	4	4	2.7	-3.2	4.6	1339.4	16.7	2.5	2.883333	1
2022-11-24	2022	11	24	2	4	4	2.6	-4	5.3	1324.0	16.7	1.8	3.308333	1
2022-11-24	2022	11	24	3	4	4	2.3	-4.7	5.2	1312.5	16.7	1.1	3.533333	1
2022-11-24	2022	11	24	4	4	4	2.0	-5.1	3.9	1310.4	16.7	0.3	3.766667	1
2022-11-24	2022	11	24	5	4	4	1.7	-5.5	3.6	1328.5	16.7	-0.6	3.925	1
2022-11-24	2022	11	24	6	4	4	1.3	-5.8	3.1	1395.8	16.7	-1.4	4	1
2022-11-24	2022	11	24	7	4	4	1.0	-5.4	2.2	1536.9	16.7	-2.1	4.066667	1
2022-11-24	2022	11	24	8	4	4	0.6	-5.8	1	1646.8	16.7	-2.9	4.05	1
2022-11-24	2022	11	24	9	4	4	0.2	-4.8	-0.5	1649.9	16.7	-3.5	3.925	1
2022-11-24	2022	11	24	10	4	4	-0.2	-3.4	-1	1577.3	16.7	-4.0	3.675	1
2022-11-24	2022	11	24	11	4	4	-0.4	-1.7	-2.2	1492.2	16.7	-4.2	3.366667	1
2022-11-24	2022	11	24	12	4	4	-0.6	-0.1	-3.2	1455.7	16.7	-4.3	3.025	1
2022-11-24	2022	11	24	13	4	4	-0.8	0.7	-4	1440.4	16.7	-4.1	2.475	1
2022-11-24	2022	11	24	14	4	4	-1.0	1.6	-4.7	1408.9	16.7	-3.8	1.833333	1
2022-11-24	2022	11	24	15	4	4	-1.1	2.2	-5.1	1394.6	16.7	-3.3	1.116667	1
2022-11-24	2022	11	24	16	4	4	-1.2	1.7	-5.5	1431.7	16.7	-2.8	0.283333	1
2022-11-24	2022	11	24	17	4	4	-1.4	1.1	-5.8	1544.2	16.7	-2.2	-0.575	1
2022-11-24	2022	11	24	18	4	4	-1.5	-0.1	-5.4	1657.8	16.7	-1.6	-1.35833	1
2022-11-24	2022	11	24	19	4	4	-1.7	-0.6	-5.8	1638.0	16.7	-1.2	-2.14167	1
2022-11-24	2022	11	24	20	4	4	-1.8	-0.9	-4.8	1609.8	16.7	-0.8	-2.85	1
2022-11-24	2022	11	24	21	4	4	-1.9	-1	-3.4	1574.5	16.7	-0.4	-3.51667	1
2022-11-24	2022	11	24	22	4	4	-2.0	-1	-1.7	1509.5	16.7	0.0	-4	1
2022-11-24	2022	11	24	23	4	4	-2.0	-1.6	-0.1	1429.3	16.7	0.2	-4.24167	1
2022-11-24	2022	11	24	24	4	4	-2.1	-1.7	0.7	1388.8	16.7	0.2	-4.3	1
2022-11-25	2022	11	25	1	5	5	-2.0	-2.2	1.6	1347.4	14.8	0.0	-4.125	1
2022-11-25	2022	11	25	2	5	5	-2.0	-2.4	2.2	1317.9	14.8	-0.2	-3.8	1
2022-11-25	2022	11	25	3	5	5	-1.9	-2.8	1.7	1299.0	14.8	-0.5	-3.33333	1
2022-11-25	2022	11	25	4	5	5	-1.9	-3.2	1.1	1293.7	14.8	-1.0	-2.75833	1
2022-11-25	2022	11	25	5	5	5	-1.8	-4.9	-0.1	1308.7	14.8	-1.4	-2.19167	1
2022-11-25	2022	11	25	6	5	5	-1.8	-5.4	-0.6	1377.0	14.8	-1.9	-1.64167	1
2022-11-25	2022	11	25	7	5	5	-1.7	-5.1	-0.9	1507.7	14.8	-2.3	-1.16667	1
2022-11-25	2022	11	25	8	5	5	-1.7	-4.5	-1	1603.8	14.8	-2.7	-0.76667	1
2022-11-25	2022	11	25	9	5	5	-1.7	-3.8	-1	1629.7	14.8	-3.0	-0.35833	1
2022-11-25	2022	11	25	10	5	5	-1.6	-2.3	-1.6	1596.0	14.8	-3.2	-0.04167	1
2022-11-25	2022	11	25	11	5	5	-1.6	0.8	-1.7	1550.1	14.8	-3.3	0.158333	1
2022-11-25	2022	11	25	12	5	5	-1.5	4.2	-2.2	1520.1	14.8	-3.1	0.166667	1
2022-11-25	2022	11	25	13	5	5	-1.3	5.1	-2.4	1497.5	14.8	-2.6	0.033333	1
2022-11-25	2022	11	25	14	5	5	-1.1	5.8	-2.8	1465.2	14.8	-2.0	-0.20833	1
2022-11-25	2022	11	25	15	5	5	-0.9	6.6	-3.2	1441.6	14.8	-1.3	-0.54167	1
2022-11-25	2022	11	25	16	5	5	-0.8	7.5	-4.9	1438.2	14.8	-0.6	-0.95833	1
2022-11-25	2022	11	25	17	5	5	-0.5	7.8	-5.4	1473.5	14.8	0.3	-1.36667	1
2022-11-25	2022	11	25	18	5	5	-0.2	7.9	-5.1	1504.9	14.8	1.4	-1.86667	1
2022-11-25	2022	11	25	19	5	5	0.1	8	-4.5	1447.3	14.8	2.5	-2.30833	1
2022-11-25	2022	11	25	20	5	5	0.5	8.5	-3.8	1390.9	14.8	3.6	-2.68333	1
2022-11-25	2022	11	25	21	5	5	0.8	8.5	-2.3	1336.6	14.8	4.7	-2.98333	1
2022-11-25	2022	11	25	22	5	5	1.2	8.7	0.8	1273.0	14.8	5.7	-3.21667	1
2022-11-25	2022	11	25	23	5	5	1.6	8.8	4.2	1195.4	14.8	6.6	-3.325	1
2022-11-25	2022	11	25	24	5	5	2.1	8.6	5.1	1148.5	14.8	7.3	-3.125	1
2022-11-26	2022	11	26	1	6	6	2.5	8.1	5.8	1108.6	28.1	7.7	-2.63333	0
2022-11-26	2022	11	26	2	6	6	2.9	7.9	6.6	1062.9	28.1	7.9	-2.025	0
2022-11-26	2022	11	26	3	6	6	3.4	7.4	7.5	1026.9	28.1	8.1	-1.34167	0
2022-11-26	2022	11	26	4	6	6	3.8	7.7	7.8	1007.0	28.1	8.1	-0.55833	0
2022-11-26	2022	11	26	5	6	6	4.2	6.9	7.9	1014.0	28.1	8.2	0.333333	0
2022-11-26	2022	11	26	6	6	6	4.7	5.7	8	1049.1	28.1	8.1	1.391667	0
2022-11-26	2022	11	26	7	6	6	5.2	5.3	8.5	1103.9	28.1	7.9	2.5	0
2022-11-26	2022	11	26	8	6	6	5.6	5.2	8.5	1179.8	28.1	7.7	3.591667	0
2022-11-26	2022	11	26	9	6	6	6.0	4.9	8.7	1265.1	28.1	7.4	4.675	0
2022-11-26	2022	11	26	10	6	6	6.4	4.4	8.8	1341.0	28.1	7.1	5.7	0
2022-11-26	2022	11	26	11	6	6	6.7	4	8.6	1387.5	28.1	6.7	6.616667	0
2022-11-26	2022	11	26	12	6	6	6.8	3.7	8.1	1414.4	28.1	6.3	7.283333	0
2022-11-26	2022	11	26	13	6	6	6.8	3.8	7.9	1418.4	28.1	5.9	7.65	0
2022-11-26	2022	11	26	14	6	6	6.7	4.5	7.4	1413.3	28.1	5.6	7.9	0
2022-11-26	2022	11	26	15	6	6	6.7	4.4	7.7	1399.7	28.1	5.3	8.075	0
2022-11-26	2022	11	26	16	6	6	6.6	4.3	6.9	1394.4	28.1	5.0	8.141667	0
2022-11-26	2022	11	26	17	6	6	6.5	4	5.7	1464.8	28.1	4.8	8.158333	0
2022-11-26	2022	11	26	18	6	6	6.3	3.5	5.3	1520.4	28.1	4.5	8.083333	0
2022-11-26	2022	11	26	19	6	6	6.1	3.4	5.2	1465.5	28.1	4.3	7.9	0
2022-11-26	2022	11	26	20	6	6	5.9	3.6	4.9	1422.2	28.1	4.2	7.675	0
2022-11-26	2022	11	26	21	6	6	5.7	3.3	4.4	1385.5	28.1	4.0	7.4	0
2022-11-26	2022	11	26	22	6	6	5.5	3.2	4	1347.2	28.1	3.9	7.1	0
2022-11-26	2022	11	26	23	6	6	5.3	3.4	3.7	1268.4	28.1	3.8	6.741667	0
2022-11-26	2022	11	26	24	6	6	5.1	3.2	3.8	1200.7	28.1	3.8	6.341667	0
2022-11-27	2022	11	27	1	7	7	4.8	2.7	4.5	1150.4	11.2	3.7	5.933333	0
2022-11-27	2022	11	27	2	7	7	4.6	2.4	4.4	1117.7	11.2	3.6	5.575	0
2022-11-27	2022	11	27	3	7	7	4.4	1.9	4.3	1097.3	11.2	3.5	5.291667	0
2022-11-27	2022	11	27	4	7	7	4.1	1.8	4	1094.5	11.2	3.2	5.041667	0
2022-11-27	2022	11	27	5	7	7	3.9	1.4	3.5	1106.1	11.2	3.0	4.758333	0
2022-11-27	2022	11	27	6	7	7	3.7	0.5	3.4	1134.8	11.2	2.8	4.516667	0
2022-11-27	2022	11	27	7	7	7	3.5	-0.2	3.6	1191.2	11.2	2.6	4.333333	0
2022-11-27	2022	11	27	8	7	7	3.2	-0.2	3.3	1268.9	11.2	2.		

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLag	Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLag	Weekdays	
2022-11-27	2022	11	27	24	24	7	4.6	8.7	7.1	1054.4	11.2	7.5	1.7	0
2022-11-28	2022	11	28	1	1	1	4.8	9	7.8	992.9	18.9	7.7	1.908333	1
2022-11-28	2022	11	28	2	1	1	5.1	8.9	8.3	956.8	18.9	7.9	2.275	1
2022-11-28	2022	11	28	3	1	1	5.4	9.1	9.8	945.5	18.9	8.0	2.725	1
2022-11-28	2022	11	28	4	1	1	5.7	8.5	8	944.3	18.9	8.1	3.258333	1
2022-11-28	2022	11	28	5	1	1	5.9	8.4	6.2	957.0	18.9	7.9	3.925	1
2022-11-28	2022	11	28	6	1	1	6.2	8.2	5.3	1009.0	18.9	8.0	4.475	1
2022-11-28	2022	11	28	7	1	1	6.5	9.4	6.9	1133.4	18.9	8.1	4.95	1
2022-11-28	2022	11	28	8	1	1	6.9	10.4	7.8	1234.3	18.9	8.5	5.408333	1
2022-11-28	2022	11	28	9	1	1	7.4	12.6	8.4	1254.6	18.9	8.8	6	1
2022-11-28	2022	11	28	10	1	1	7.9	12.6	8.5	1244.9	18.9	9.2	6.566667	1
2022-11-28	2022	11	28	11	1	1	8.3	12	8.7	1240.6	18.9	9.5	7.091667	1
2022-11-28	2022	11	28	12	1	1	8.7	11.8	9	1237.7	18.9	9.8	7.483333	1
2022-11-28	2022	11	28	13	1	1	8.9	10.9	8.9	1243.8	18.9	10.1	7.733333	1
2022-11-28	2022	11	28	14	1	1	9.1	10.1	9.1	1233.7	18.9	10.2	7.891667	1
2022-11-28	2022	11	28	15	1	1	9.2	8.3	8.5	1256.9	18.9	10.3	7.983333	1
2022-11-28	2022	11	28	16	1	1	9.2	7.4	8.4	1301.4	18.9	10.3	8.05	1
2022-11-28	2022	11	28	17	1	1	9.1	6.4	8.2	1397.3	18.9	10.2	7.941667	1
2022-11-28	2022	11	28	18	1	1	9.0	5.5	9.4	1463.8	18.9	10.0	7.975	1
2022-11-28	2022	11	28	19	1	1	9.0	4.9	10.4	1423.6	18.9	9.8	8.141667	1
2022-11-28	2022	11	28	20	1	1	8.9	4.6	12.6	1389.9	18.9	9.4	8.483333	1
2022-11-28	2022	11	28	21	1	1	8.9	4.2	12.6	1350.2	18.9	8.9	8.775	1
2022-11-28	2022	11	28	22	1	1	8.7	3.4	12	1285.1	18.9	8.2	9.175	1
2022-11-28	2022	11	28	23	1	1	8.5	3	11.8	1202.9	18.9	7.5	9.525	1
2022-11-28	2022	11	28	24	1	1	8.3	2.6	10.9	1174.0	18.9	6.7	9.816667	1
2022-11-29	2022	11	29	1	2	2	8.0	2.9	10.1	1140.3	13.9	5.9	10.075	1
2022-11-29	2022	11	29	2	2	2	7.8	2.6	8.3	1117.1	13.9	5.3	10.23333	1
2022-11-29	2022	11	29	3	2	2	7.5	1.6	7.4	1102.6	13.9	4.7	10.33333	1
2022-11-29	2022	11	29	4	2	2	7.2	0.9	6.4	1108.6	13.9	4.1	10.26667	1
2022-11-29	2022	11	29	5	2	2	6.9	0.5	5.5	1132.5	13.9	3.6	10.175	1
2022-11-29	2022	11	29	6	2	2	6.5	0.2	4.9	1196.4	13.9	3.1	10.00833	1
2022-11-29	2022	11	29	7	2	2	6.2	0.2	4.6	1339.6	13.9	2.6	9.783333	1
2022-11-29	2022	11	29	8	2	2	5.8	-1.1	4.2	1463.7	13.9	2.2	9.408333	1
2022-11-29	2022	11	29	9	2	2	5.3	-1.5	3.4	1490.1	13.9	1.8	8.925	1
2022-11-29	2022	11	29	10	2	2	4.8	-1	3	1460.4	13.9	1.3	8.225	1
2022-11-29	2022	11	29	11	2	2	4.2	-1	2.6	1415.8	13.9	0.9	7.458333	1
2022-11-29	2022	11	29	12	2	2	3.6	-0.3	2.9	1384.3	13.9	0.6	6.708333	1
2022-11-29	2022	11	29	13	2	2	3.1	1	2.6	1367.5	13.9	0.3	5.941667	1
2022-11-29	2022	11	29	14	2	2	2.7	1.7	1.6	1341.2	13.9	0.2	5.275	1
2022-11-29	2022	11	29	15	2	2	2.4	1.7	0.9	1341.2	13.9	0.1	4.65	1
2022-11-29	2022	11	29	16	2	2	2.1	1.9	0.5	1385.7	13.9	0.1	4.091667	1
2022-11-29	2022	11	29	17	2	2	1.9	1.3	0.2	1501.4	13.9	0.2	3.55	1
2022-11-29	2022	11	29	18	2	2	1.7	-0.1	0.2	1619.5	13.9	0.3	3.058333	1
2022-11-29	2022	11	29	19	2	2	1.4	-0.9	-1.1	1598.7	13.9	0.2	2.616667	1
2022-11-29	2022	11	29	20	2	2	1.2	-1.2	-1.5	1579.9	13.9	0.1	2.225	1
2022-11-29	2022	11	29	21	2	2	0.9	-1.5	-1	1554.1	13.9	0.1	1.75	1
2022-11-29	2022	11	29	22	2	2	0.7	-2.2	-1	1488.9	13.9	0.1	1.275	1
2022-11-29	2022	11	29	23	2	2	0.5	-2.9	-0.3	1414.9	13.9	0.0	0.908333	1
2022-11-29	2022	11	29	24	2	2	0.2	-4.2	1	1388.7	13.9	-0.1	0.575	1
2022-11-30	2022	11	30	1	3	3	-0.1	-3.9	1.7	1357.0	15.8	-0.5	0.333333	1
2022-11-30	2022	11	30	2	3	3	-0.3	-4	1.7	1330.5	15.8	-0.9	0.175	1
2022-11-30	2022	11	30	3	3	3	-0.6	-4.5	1.9	1307.1	15.8	-1.3	0.1	1
2022-11-30	2022	11	30	4	3	3	-0.9	-4.6	1.3	1305.2	15.8	-1.9	0.108333	1
2022-11-30	2022	11	30	5	3	3	-1.1	-5	-0.1	1332.0	15.8	-2.4	0.191667	1
2022-11-30	2022	11	30	6	3	3	-1.3	-4.1	-0.9	1396.6	15.8	-2.9	0.258333	1
2022-11-30	2022	11	30	7	3	3	-1.5	-4.1	-1.2	1532.0	15.8	-3.3	0.233333	1
2022-11-30	2022	11	30	8	3	3	-1.7	-4.1	-1.5	1642.0	15.8	-3.5	0.141667	1
2022-11-30	2022	11	30	9	3	3	-1.8	-3.8	-2.2	1635.3	15.8	-3.8	0.133333	1
2022-11-30	2022	11	30	10	3	3	-1.9	-2.2	-2.9	1546.1	15.8	-4.0	0.133333	1
2022-11-30	2022	11	30	11	3	3	-2.0	1.4	-4.2	1462.2	15.8	-4.0	0.033333	1
2022-11-30	2022	11	30	12	3	3	-1.9	3.9	-3.9	1429.9	15.8	-3.6	-0.125	1
2022-11-30	2022	11	30	13	3	3	-1.7	3.7	-4	1417.9	15.8	-2.9	-0.45	1
2022-11-30	2022	11	30	14	3	3	-1.6	5.3	-4.5	1383.0	15.8	-2.3	-0.85833	1
2022-11-30	2022	11	30	15	3	3	-1.4	5.5	-4.6	1395.9	15.8	-1.5	-1.33333	1
2022-11-30	2022	11	30	16	3	3	-1.3	5.7	-5	1435.2	15.8	-0.7	-1.85	1
2022-11-30	2022	11	30	17	3	3	-1.1	5.9	-4.1	1520.1	15.8	0.2	-2.39167	1
2022-11-30	2022	11	30	18	3	3	-0.9	6.5	-4.1	1581.8	15.8	1.1	-2.91667	1
2022-11-30	2022	11	30	19	3	3	-0.6	7.2	-4.1	1538.5	15.8	2.0	-3.25	1
2022-11-30	2022	11	30	20	3	3	-0.3	7.7	-3.8	1489.3	15.8	2.9	-3.51667	1
2022-11-30	2022	11	30	21	3	3	0.1	8.5	-2.2	1429.8	15.8	3.9	-3.75833	1
2022-11-30	2022	11	30	22	3	3	0.5	9.2	1.4	1347.4	15.8	4.9	-3.95	1
2022-11-30	2022	11	30	23	3	3	1.0	9.4	3.9	1254.2	15.8	5.9	-3.95	1
2022-11-30	2022	11	30	24	3	3	1.5	9.6	3.7	1187.9	15.8	6.5	-3.59167	1
2022-12-01	2022	12	1	1	4	4	2.1	10	5.3	1121.0	25.2	7.0	-2.91667	1
2022-12-01	2022	12	1	2	4	4	2.6	10.5	5.5	1065.5	25.2	7.5	-2.28333	1
2022-12-01	2022	12	1	3	4	4	3.2	11	5.7	1024.7	25.2	8.0	-1.50833	1
2022-12-01	2022	12	1	4	4	4	3.9	11.3	5.9	970.1	25.2	8.4	-0.675	1
2022-12-01	2022	12	1	5	4	4	4.5	11.7	6.5	952.5	25.2	8.9	0.183333	1
2022-12-01	2022	12	1	6	4	4	5.2	11.6	7.2	985.2	25.2	9.4	1.091667	1
2022-12-01	2022	12	1	7	4	4	5.9	11.6	7.7	1074.7	25.2	9.8	1.975	1
2022-12-01	2022	12	1	8	4	4	6.5	11.3	8.5	1146.0	25.2	10.2	2.916667	1
2022-12-01	2022	12	1	9	4	4	7.2	11.3	9.2	1195.9	25.2	10.5	3.9	1
2022-12-01	2022	12	1	10	4	4	7.8	9	9.4	1249.6	25.2	10.7	4.925	1
2022-12-01	2022	12	1	11	4	4	8.3	6.2	9.6	1271.7	25.2	10.7	5.875	1
2022-12-01	2022	12	1	12	4	4	8.5	6.7	10	1280.3	25.2	10.4	6.541667	1
2022-12-01	2022	12	1	13	4	4	8.6	7	10.5	1296.3	25.2	10.2	7.016667	1
2022-12-01	2022	12	1	14	4	4	8.7	5.9	11	1308.6	25.2	9.9	7.541667	1
2022-12-01	2022	12	1	15	4	4	8.8	5.5	11.3	1324.6	25.2	9.6	7.975	1
2022-12-01	2022	12	1	16	4	4	8.8	4.8	11.7	1371.0	25.2	9.1	8.433333	1
2022-12-01	2022	12	1	17	4	4	8.7	3.3	11.6	1470.2	25.2	8.6	8.9	1
2022-12-01	2022	12	1	18	4	4	8.6	2.3	11.6	1553.8	25.2	7.9	9.383333	1
2022-12-01	2022	12	1	19	4	4	8.4	2.2	11.3	1520.4	25.2	7.1	9.808333	1
2022-12-01	2022	12	1	20	4	4	8.2	1.5	11.3	1493.4	25.2	6.3</		

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLa	g Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLa	g Weekdays	
2022-12-02	2022	12	12	2	12	5	1.9	1.8	0.9	1428.1	11.1	0.2	3.616667	1
2022-12-02	2022	12	12	2	13	5	1.7	2.4	0.5	1405.3	11.1	0.2	3.166667	1
2022-12-02	2022	12	12	2	14	5	1.5	3.3	0.4	1369.9	11.1	0.4	2.658333	1
2022-12-02	2022	12	12	2	15	5	1.4	3.8	0.4	1359.5	11.1	0.6	2.208333	1
2022-12-02	2022	12	12	2	16	5	1.3	3.8	-0.1	1378.9	11.1	0.9	1.783333	1
2022-12-02	2022	12	12	2	17	5	1.3	3.4	-0.3	1458.2	11.1	1.2	1.416667	1
2022-12-02	2022	12	12	2	18	5	1.3	2.4	-0.4	1567.4	11.1	1.5	1.133333	1
2022-12-02	2022	12	12	2	19	5	1.3	1.7	-0.9	1491.2	11.1	1.7	0.916667	1
2022-12-02	2022	12	12	2	20	5	1.3	0.2	-0.4	1451.4	11.1	1.9	0.7	1
2022-12-02	2022	12	12	2	21	5	1.2	0.2	0.3	1439.7	11.1	1.9	0.5	1
2022-12-02	2022	12	12	2	22	5	1.2	-1.3	0.6	1395.4	11.1	2.0	0.358333	1
2022-12-02	2022	12	12	2	23	5	1.1	-2.7	1.8	1343.2	11.1	1.9	0.258333	1
2022-12-02	2022	12	12	2	24	5	0.9	-2.3	2.4	1327.7	11.1	1.6	0.191667	1
2022-12-03	2022	12	12	3	1	6	0.7	-3.1	3.3	1310.3	19.3	1.2	0.233333	0
2022-12-03	2022	12	12	3	2	6	0.6	-2.9	3.8	1291.3	19.3	0.8	0.358333	0
2022-12-03	2022	12	12	3	3	6	0.4	-2.6	3.8	1268.3	19.3	0.3	0.591667	0
2022-12-03	2022	12	12	3	4	6	0.3	-2.4	3.4	1260.8	19.3	-0.3	0.875	0
2022-12-03	2022	12	12	3	5	6	0.2	-1.7	2.4	1263.6	19.3	-0.8	1.158333	0
2022-12-03	2022	12	12	3	6	6	0.1	-2	1.7	1280.5	19.3	-1.2	1.45	0
2022-12-03	2022	12	12	3	7	6	0.0	-1.7	0.2	1324.5	19.3	-1.6	1.675	0
2022-12-03	2022	12	12	3	8	6	0.0	4.3	0.2	1379.6	19.3	-1.9	1.85	0
2022-12-03	2022	12	12	3	9	6	0.2	5.3	-1.3	1417.2	19.3	-1.5	1.941667	0
2022-12-03	2022	12	12	3	10	6	0.5	6.2	-2.7	1405.2	19.3	-1.1	1.991667	0
2022-12-03	2022	12	12	3	11	6	0.7	7.5	-2.3	1363.6	19.3	-0.5	1.858333	0
2022-12-03	2022	12	12	3	12	6	1.0	8.5	-3.1	1333.5	19.3	0.4	1.583333	0
2022-12-03	2022	12	12	3	13	6	1.3	9.2	-2.9	1320.9	19.3	1.3	1.241667	0
2022-12-03	2022	12	12	3	14	6	1.5	9.2	-2.6	1302.1	19.3	2.3	0.783333	0
2022-12-03	2022	12	12	3	15	6	1.8	9.6	-2.4	1275.9	19.3	3.3	0.266667	0
2022-12-03	2022	12	12	3	16	6	2.0	9.5	-1.7	1283.8	19.3	4.3	-0.26667	0
2022-12-03	2022	12	12	3	17	6	2.3	9.3	-2	1369.3	19.3	5.3	-0.78333	0
2022-12-03	2022	12	12	3	18	6	2.5	9.2	-1.7	1417.9	19.3	6.2	-1.20833	0
2022-12-03	2022	12	12	3	19	6	2.8	9.7	4.3	1375.1	19.3	7.2	-1.575	0
2022-12-03	2022	12	12	3	20	6	3.1	9.9	5.3	1331.4	19.3	8.1	-1.85833	0
2022-12-03	2022	12	12	3	21	6	3.5	10	6.2	1278.9	19.3	8.6	-1.51667	0
2022-12-03	2022	12	12	3	22	6	3.9	10.1	7.5	1224.8	19.3	9.0	-1.09167	0
2022-12-03	2022	12	12	3	23	6	4.4	10.3	8.5	1156.9	19.3	9.3	-0.46667	0
2022-12-03	2022	12	12	3	24	6	5.0	10	9.2	1086.2	19.3	9.5	0.383333	0
2022-12-04	2022	12	12	4	1	7	5.5	10.1	9.2	1027.6	18.0	9.7	1.283333	0
2022-12-04	2022	12	12	4	2	7	6.0	10.2	9.6	986.5	18.0	9.7	2.308333	0
2022-12-04	2022	12	12	4	3	7	6.6	10.1	9.5	964.2	18.0	9.8	3.316667	0
2022-12-04	2022	12	12	4	4	7	7.1	10.3	9.3	954.8	18.0	9.9	4.333333	0
2022-12-04	2022	12	12	4	5	7	7.6	11.3	9.2	952.9	18.0	9.9	5.325	0
2022-12-04	2022	12	12	4	6	7	8.2	10.9	9.7	968.4	18.0	10.1	6.241667	0
2022-12-04	2022	12	12	4	7	7	8.7	10.5	9.9	1011.7	18.0	10.2	7.175	0
2022-12-04	2022	12	12	4	8	7	9.2	9.7	10	1099.2	18.0	10.3	8.125	0
2022-12-04	2022	12	12	4	9	7	9.4	7.5	10.1	1177.1	18.0	10.3	8.591667	0
2022-12-04	2022	12	12	4	10	7	9.5	6.2	10.3	1221.4	18.0	10.1	8.983333	0
2022-12-04	2022	12	12	4	11	7	9.5	7.1	10	1247.5	18.0	9.8	9.308333	0
2022-12-04	2022	12	12	4	12	7	9.5	7.3	10.1	1281.2	18.0	9.5	9.541667	0
2022-12-04	2022	12	12	4	13	7	9.5	6.5	10.2	1306.8	18.0	9.3	9.666667	0
2022-12-04	2022	12	12	4	14	7	9.4	6.1	10.1	1297.4	18.0	9.0	9.741667	0
2022-12-04	2022	12	12	4	15	7	9.2	4.8	10.3	1304.0	18.0	8.6	9.825	0
2022-12-04	2022	12	12	4	16	7	9.0	4.6	11.3	1345.5	18.0	8.2	9.866667	0
2022-12-04	2022	12	12	4	17	7	8.8	3.9	10.9	1440.2	18.0	7.7	9.933333	0
2022-12-04	2022	12	12	4	18	7	8.6	3.3	10.5	1514.7	18.0	7.1	10.1	0
2022-12-04	2022	12	12	4	19	7	8.4	2.8	9.7	1486.6	18.0	6.5	10.24167	0
2022-12-04	2022	12	12	4	20	7	8.1	1.7	7.5	1469.5	18.0	5.8	10.30833	0
2022-12-04	2022	12	12	4	21	7	7.7	1.4	6.2	1439.4	18.0	5.2	10.29167	0
2022-12-04	2022	12	12	4	22	7	7.4	1.6	7.1	1372.5	18.0	4.6	10.08333	0
2022-12-04	2022	12	12	4	23	7	7.0	1.5	7.3	1275.8	18.0	4.3	9.758333	0
2022-12-04	2022	12	12	4	24	7	6.6	1.2	6.5	1199.5	18.0	3.8	9.491667	0
2022-12-05	2022	12	12	5	1	1	6.3	0.4	6.1	1157.3	6.9	3.3	9.266667	1
2022-12-05	2022	12	12	5	2	1	5.9	0.3	4.8	1148.8	6.9	2.8	8.966667	1
2022-12-05	2022	12	12	5	3	1	5.5	-1.9	4.6	1158.6	6.9	2.3	8.625	1
2022-12-05	2022	12	12	5	4	1	5.0	-1.2	3.9	1174.5	6.9	1.7	8.183333	1
2022-12-05	2022	12	12	5	5	1	4.5	-3	3.3	1210.3	6.9	1.3	7.708333	1
2022-12-05	2022	12	12	5	6	1	3.9	-3.3	2.8	1289.0	6.9	0.7	7.091667	1
2022-12-05	2022	12	12	5	7	1	3.3	-2.6	1.7	1441.5	6.9	0.1	6.458333	1
2022-12-05	2022	12	12	5	8	1	2.7	-2.4	1.4	1576.8	6.9	-0.3	5.816667	1
2022-12-05	2022	12	12	5	9	1	2.2	-2	1.6	1581.9	6.9	-0.7	5.15	1
2022-12-05	2022	12	12	5	10	1	1.8	-0.5	1.5	1505.4	6.9	-1.0	4.641667	1
2022-12-05	2022	12	12	5	11	1	1.6	1.1	1.2	1443.5	6.9	-1.1	4.258333	1
2022-12-05	2022	12	12	5	12	1	1.3	2.7	0.4	1392.2	6.9	-1.2	3.791667	1
2022-12-05	2022	12	12	5	13	1	1.1	3.2	0.3	1359.8	6.9	-1.0	3.283333	1
2022-12-05	2022	12	12	5	14	1	1.0	3.7	-1.9	1323.7	6.9	-0.8	2.775	1
2022-12-05	2022	12	12	5	15	1	0.9	3.7	-1.2	1309.1	6.9	-0.5	2.291667	1
2022-12-05	2022	12	12	5	16	1	0.8	3.7	-3	1339.1	6.9	0.0	1.733333	1
2022-12-05	2022	12	12	5	17	1	0.8	3.2	-3.3	1468.8	6.9	0.4	1.25	1
2022-12-05	2022	12	12	5	18	1	0.8	0.9	-2.6	1599.4	6.9	0.9	0.675	1
2022-12-05	2022	12	12	5	19	1	0.7	0.1	-2.4	1584.9	6.9	1.2	0.125	1
2022-12-05	2022	12	12	5	20	1	0.6	-1.1	-2	1571.4	6.9	1.5	-0.325	1
2022-12-05	2022	12	12	5	21	1	0.4	-0.7	-0.5	1551.0	6.9	1.6	-0.66667	1
2022-12-05	2022	12	12	5	22	1	0.4	-0.1	1.1	1486.6	6.9	1.7	-0.95	1
2022-12-05	2022	12	12	5	23	1	0.3	-0.3	2.7	1401.6	6.9	1.7	-1.125	1
2022-12-05	2022	12	12	5	24	1	0.2	-0.2	3.2	1370.6	6.9	1.6	-1.15833	1
2022-12-06	2022	12	12	6	1	2	0.2	0	3.7	1340.2	11.8	1.3	-1.03333	1
2022-12-06	2022	12	12	6	2	2	0.1	-0.7	3.7	1309.1	11.8	1.1	-0.8	1
2022-12-06	2022	12	12	6	3	2	0.1	-0.9	3.7	1279.1	11.8	0.7	-0.51667	1
2022-12-06	2022	12	12	6	4	2	0.1	-1.1	3.2	1279.1	11.8	0.3	-0.05	1
2022-12-06	2022	12	12	6	5	2	0.1	-0.8	0.9	1302.2	11.8	-0.1	0.358333	1
2022-12-06	2022	12	12	6	6	2	0.2	-0.6	0.1	1359.3	11.8	-0.4	0.875	1
2022-12-06	2022	12	12	6	7	2	0.3	-0.4	-1.1	1491.6	11.8	-0.5	1.225	1
2022-12-06	2022	12	12	6	8	2								

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLag	Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLag	Weekdays
2022-12-06	2022	12	12	6	24	2	2.6	6.6	5.6	1209.8	11.8	5.2 -0.01667	1
2022-12-07	2022	12	7	7	1	3	2.9	7.1	6.6	1154.5	16.8	5.3 0.425	1
2022-12-07	2022	12	7	7	2	3	3.2	7.3	6.2	1107.2	16.8	5.4 0.891667	1
2022-12-07	2022	12	7	7	3	3	3.5	7.1	6	1070.8	16.8	5.5 1.5	1
2022-12-07	2022	12	7	7	4	3	3.8	7	5.5	1053.1	16.8	5.6 2.091667	1
2022-12-07	2022	12	7	7	5	3	4.2	7.1	5	1055.6	16.8	5.7 2.683333	1
2022-12-07	2022	12	7	7	6	3	4.5	7.2	4.8	1109.2	16.8	5.8 3.208333	1
2022-12-07	2022	12	7	7	7	3	4.8	7.5	4.1	1226.5	16.8	6.0 3.675	1
2022-12-07	2022	12	7	7	8	3	5.2	7.5	4.1	1328.4	16.8	6.2 4.108333	1
2022-12-07	2022	12	7	7	9	3	5.5	7.6	4.4	1359.8	16.8	6.5 4.516667	1
2022-12-07	2022	12	7	7	10	3	5.8	7.7	4.9	1357.8	16.8	6.8 4.833333	1
2022-12-07	2022	12	7	7	11	3	6.1	7.8	6.6	1355.1	16.8	7.1 5.05	1
2022-12-07	2022	12	7	7	12	3	6.2	8	7.1	1347.9	16.8	7.3 5.191667	1
2022-12-07	2022	12	7	7	13	3	6.4	8.4	7.3	1347.5	16.8	7.4 5.316667	1
2022-12-07	2022	12	7	7	14	3	6.5	8.2	7.1	1342.2	16.8	7.5 5.441667	1
2022-12-07	2022	12	7	7	15	3	6.5	8	7	1341.2	16.8	7.6 5.5	1
2022-12-07	2022	12	7	7	16	3	6.6	7.6	7.1	1372.0	16.8	7.7 5.575	1
2022-12-07	2022	12	7	7	17	3	6.7	7.5	7.2	1457.3	16.8	7.7 5.658333	1
2022-12-07	2022	12	7	7	18	3	6.8	7.4	7.5	1511.8	16.8	7.8 5.791667	1
2022-12-07	2022	12	7	7	19	3	6.9	7.3	7.5	1466.9	16.8	7.8 5.975	1
2022-12-07	2022	12	7	7	20	3	7.0	7.5	7.6	1424.7	16.8	7.8 6.2	1
2022-12-07	2022	12	7	7	21	3	7.1	7.5	7.7	1381.9	16.8	7.8 6.483333	1
2022-12-07	2022	12	7	7	22	3	7.3	7.8	7.8	1296.6	16.8	7.7 6.775	1
2022-12-07	2022	12	7	7	23	3	7.4	8	8	1199.5	16.8	7.8 7.05	1
2022-12-07	2022	12	7	7	24	3	7.5	8.2	8.4	1145.2	16.8	7.8 7.291667	1
2022-12-08	2022	12	8	8	1	4	7.6	8.2	8.2	1096.6	19.1	7.8 7.408333	1
2022-12-08	2022	12	8	8	2	4	7.6	8.4	8	1056.2	19.1	7.8 7.516667	1
2022-12-08	2022	12	8	8	3	4	7.7	8.3	7.6	1023.4	19.1	7.8 7.591667	1
2022-12-08	2022	12	8	8	4	4	7.7	8.5	7.5	1008.0	19.1	7.8 7.666667	1
2022-12-08	2022	12	8	8	5	4	7.8	8.7	7.4	1011.4	19.1	7.9 7.716667	1
2022-12-08	2022	12	8	8	6	4	7.9	8.9	7.3	1052.3	19.1	8.0 7.75	1
2022-12-08	2022	12	8	8	7	4	7.9	8.9	7.5	1161.6	19.1	8.1 7.766667	1
2022-12-08	2022	12	8	8	8	4	8.0	9.1	7.5	1272.9	19.1	8.2 7.75	1
2022-12-08	2022	12	8	8	9	4	8.1	8.9	7.8	1322.5	19.1	8.4 7.75	1
2022-12-08	2022	12	8	8	10	4	8.1	9	8	1324.1	19.1	8.5 7.741667	1
2022-12-08	2022	12	8	8	11	4	8.2	9.4	8.2	1331.0	19.1	8.6 7.75	1
2022-12-08	2022	12	8	8	12	4	8.2	9.4	8.2	1337.2	19.1	8.7 7.766667	1
2022-12-08	2022	12	8	8	13	4	8.3	9.2	8.4	1342.7	19.1	8.8 7.783333	1
2022-12-08	2022	12	8	8	14	4	8.3	9.1	8.3	1334.7	19.1	8.9 7.766667	1
2022-12-08	2022	12	8	8	15	4	8.4	9.3	8.5	1320.5	19.1	9.0 7.783333	1
2022-12-08	2022	12	8	8	16	4	8.4	9.6	8.7	1334.5	19.1	9.0 7.808333	1
2022-12-08	2022	12	8	8	17	4	8.5	9.3	8.9	1388.4	19.1	9.1 7.883333	1
2022-12-08	2022	12	8	8	18	4	8.6	9.1	8.9	1435.7	19.1	9.2 7.983333	1
2022-12-08	2022	12	8	8	19	4	8.7	9.1	9.1	1389.7	19.1	9.2 8.108333	1
2022-12-08	2022	12	8	8	20	4	8.7	9.6	8.9	1358.6	19.1	9.2 8.241667	1
2022-12-08	2022	12	8	8	21	4	8.8	9.6	9	1337.5	19.1	9.3 8.375	1
2022-12-08	2022	12	8	8	22	4	8.9	9.4	9.4	1280.4	19.1	9.3 8.491667	1
2022-12-08	2022	12	8	8	23	4	9.0	5.6	9.4	1202.3	19.1	9.3 8.591667	1
2022-12-08	2022	12	8	8	24	4	8.9	4.9	9.2	1163.2	19.1	9.0 8.708333	1
2022-12-09	2022	12	9	9	1	5	8.7	4.5	9.1	1135.6	23.6	8.7 8.808333	1
2022-12-09	2022	12	9	9	2	5	8.6	4.3	9.3	1113.9	23.6	8.3 8.891667	1
2022-12-09	2022	12	9	9	3	5	8.4	4	9.6	1088.6	23.6	7.9 8.95	1
2022-12-09	2022	12	9	9	4	5	8.2	3.7	9.3	1080.7	23.6	7.4 9.033333	1
2022-12-09	2022	12	9	9	5	5	8.0	3.6	9.1	1092.0	23.6	6.9 9.125	1
2022-12-09	2022	12	9	9	6	5	7.8	3.5	9.1	1143.0	23.6	6.5 9.175	1
2022-12-09	2022	12	9	9	7	5	7.6	3.4	9.6	1270.4	23.6	6.0 9.191667	1
2022-12-09	2022	12	9	9	8	5	7.4	3.4	9.6	1388.3	23.6	5.5 9.208333	1
2022-12-09	2022	12	9	9	9	5	7.1	3.4	9.4	1435.6	23.6	5.0 9.25	1
2022-12-09	2022	12	9	9	10	5	6.9	3.9	5.6	1440.9	23.6	4.5 9.308333	1
2022-12-09	2022	12	9	9	11	5	6.7	4.6	4.9	1442.5	23.6	4.0 9.341667	1
2022-12-09	2022	12	9	9	12	5	6.5	5.2	4.5	1443.4	23.6	3.9 9.025	1
2022-12-09	2022	12	9	9	13	5	6.3	6.2	4.3	1436.5	23.6	4.0 8.65	1
2022-12-09	2022	12	9	9	14	5	6.2	6.5	4	1418.9	23.6	4.1 8.258333	1
2022-12-09	2022	12	9	9	15	5	6.1	6.5	3.7	1405.3	23.6	4.3 7.858333	1
2022-12-09	2022	12	9	9	16	5	6.0	6.4	3.6	1411.9	23.6	4.5 7.416667	1
2022-12-09	2022	12	9	9	17	5	5.8	6.6	3.5	1468.5	23.6	4.7 6.925	1
2022-12-09	2022	12	9	9	18	5	5.7	5.9	3.4	1519.4	23.6	5.0 6.45	1
2022-12-09	2022	12	9	9	19	5	5.6	5.1	3.4	1478.3	23.6	5.2 5.983333	1
2022-12-09	2022	12	9	9	20	5	5.4	4.5	3.4	1437.2	23.6	5.3 5.508333	1
2022-12-09	2022	12	9	9	21	5	5.2	4.2	3.9	1404.4	23.6	5.4 4.991667	1
2022-12-09	2022	12	9	9	22	5	5.0	3.9	4.6	1342.4	23.6	5.5 4.475	1
2022-12-09	2022	12	9	9	23	5	4.7	3.7	5.2	1281.1	23.6	5.5 4.016667	1
2022-12-09	2022	12	9	9	24	5	4.7	3.7	6.2	1254.2	23.6	5.4 3.933333	1
2022-12-10	2022	12	10	10	1	6	4.6	3.5	6.5	1219.5	26.0	5.3 3.958333	0
2022-12-10	2022	12	10	10	2	6	4.6	3	6.5	1179.4	26.0	5.0 4.1	0
2022-12-10	2022	12	10	10	3	6	4.5	3.1	6.4	1145.0	26.0	4.8 4.283333	0
2022-12-10	2022	12	10	10	4	6	4.5	3.1	6.6	1137.5	26.0	4.5 4.491667	0
2022-12-10	2022	12	10	10	5	6	4.5	3	5.9	1141.7	26.0	4.2 4.716667	0
2022-12-10	2022	12	10	10	6	6	4.4	2.8	5.1	1175.0	26.0	3.9 4.966667	0
2022-12-10	2022	12	10	10	7	6	4.4	2.5	4.5	1247.7	26.0	3.6 5.166667	0
2022-12-10	2022	12	10	10	8	6	4.4	2.1	4.2	1333.3	26.0	3.4 5.308333	0
2022-12-10	2022	12	10	10	9	6	4.3	1.6	3.9	1420.7	26.0	3.2 5.4	0
2022-12-10	2022	12	10	10	10	6	4.2	1.3	3.7	1496.6	26.0	3.0 5.466667	0
2022-12-10	2022	12	10	10	11	6	4.1	0.9	3.7	1539.5	26.0	2.8 5.466667	0
2022-12-10	2022	12	10	10	12	6	4.0	0.5	3.5	1575.9	26.0	2.6 5.391667	0
2022-12-10	2022	12	10	10	13	6	3.8	0.3	3	1596.3	26.0	2.3 5.266667	0
2022-12-10	2022	12	10	10	14	6	3.5	-0.1	3.1	1606.8	26.0	2.0 5.041667	0
2022-12-10	2022	12	10	10	15	6	3.3	-1	3.1	1615.4	26.0	1.8 4.75	0
2022-12-10	2022	12	10	10	16	6	2.9	-2.1	3	1644.5	26.0	1.4 4.466667	0
2022-12-10	2022	12	10	10	17	6	2.6	-2.8	2.8	1728.1	26.0	1.0 4.191667	0
2022-12-10	2022	12	10	10	18	6	2.2	-3	2.5	1785.7	26.0	0.5 3.891667	0
2022-12-10	2022	12	10	10	19	6	1.8	-3.2	2.1	1740.8	26.0	0.0 3.633333	0
2022-12-10	2022	12	10	10	20	6	1.5	-3.2	1.6	1694.2	26.0	-0.5 3.416667	0
2022-12-10	2022	12	10	10	21	6	1.2	-3.2	1.3	1650.9	26.0	-0.9 3.216667	0
2022-12-10	2022	12	10	10	22	6	0.9	-3.2	0.9	1577.8	26.0	-1.3 3	0
2022-12-10	2022	12	10	10	23	6	0.6	-3.1	0.5	1502.2	26.0	-1.7 2.78333	

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLa	g Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLa	g Weekdays	
2022-12-11	2022	12	11	11	12	7	-2.8	-3	-3.3	1687.3	14.8	-3.5	-2.00833	0
2022-12-11	2022	12	11	11	13	7	-2.9	-2.6	-3.4	1682.6	14.8	-3.5	-2.31667	0
2022-12-11	2022	12	11	11	14	7	-3.0	-2.7	-3.5	1659.0	14.8	-3.5	-2.61667	0
2022-12-11	2022	12	11	11	15	7	-3.1	-2.6	-3.7	1640.9	14.8	-3.4	-2.89167	0
2022-12-11	2022	12	11	11	16	7	-3.2	-2.9	-3.7	1669.3	14.8	-3.3	-3.1	0
2022-12-11	2022	12	11	11	17	7	-3.2	-3.1	-3.8	1761.5	14.8	-3.3	-3.23333	0
2022-12-11	2022	12	11	11	18	7	-3.3	-3.3	-3.7	1800.6	14.8	-3.2	-3.30833	0
2022-12-11	2022	12	11	11	19	7	-3.3	-3.6	-3.8	1742.6	14.8	-3.2	-3.375	0
2022-12-11	2022	12	11	11	20	7	-3.3	-3.8	-3.6	1712.9	14.8	-3.2	-3.41667	0
2022-12-11	2022	12	11	11	21	7	-3.3	-3.8	-3.4	1665.4	14.8	-3.2	-3.46667	0
2022-12-11	2022	12	11	11	22	7	-3.3	-4	-3.2	1605.7	14.8	-3.2	-3.5	0
2022-12-11	2022	12	11	11	23	7	-3.4	-4	-3	1499.8	14.8	-3.2	-3.51667	0
2022-12-11	2022	12	11	11	24	7	-3.4	-4.2	-2.6	1388.8	14.8	-3.3	-3.525	0
2022-12-12	2022	12	12	12	1	1	-3.4	-4.3	-2.7	1316.1	17.2	-3.4	-3.50833	1
2022-12-12	2022	12	12	12	2	1	-3.5	-4.3	-2.6	1297.5	17.2	-3.5	-3.45	1
2022-12-12	2022	12	12	12	3	1	-3.5	-4.3	-2.9	1292.5	17.2	-3.7	-3.39167	1
2022-12-12	2022	12	12	12	4	1	-3.6	-4.4	-3.1	1294.5	17.2	-3.8	-3.31667	1
2022-12-12	2022	12	12	12	5	1	-3.6	-4.5	-3.3	1340.4	17.2	-3.9	-3.25	1
2022-12-12	2022	12	12	12	6	1	-3.6	-4.6	-3.6	1411.8	17.2	-4.0	-3.2	1
2022-12-12	2022	12	12	12	7	1	-3.7	-4.6	-3.8	1538.8	17.2	-4.2	-3.15833	1
2022-12-12	2022	12	12	12	8	1	-3.7	-4.9	-3.8	1656.3	17.2	-4.2	-3.15	1
2022-12-12	2022	12	12	12	9	1	-3.7	-5	-4	1704.3	17.2	-4.3	-3.15	1
2022-12-12	2022	12	12	12	10	1	-3.8	-4.7	-4	1715.3	17.2	-4.4	-3.16667	1
2022-12-12	2022	12	12	12	11	1	-3.9	-4.3	-4.2	1726.0	17.2	-4.5	-3.21667	1
2022-12-12	2022	12	12	12	12	1	-3.9	-3.4	-4.3	1729.5	17.2	-4.5	-3.28333	1
2022-12-12	2022	12	12	12	13	1	-3.9	-3.2	-4.3	1735.4	17.2	-4.4	-3.38333	1
2022-12-12	2022	12	12	12	14	1	-3.9	-2.7	-4.3	1718.6	17.2	-4.4	-3.525	1
2022-12-12	2022	12	12	12	15	1	-3.9	-2.6	-4.4	1693.1	17.2	-4.2	-3.65833	1
2022-12-12	2022	12	12	12	16	1	-3.9	-2.7	-4.5	1710.4	17.2	-4.1	-3.8	1
2022-12-12	2022	12	12	12	17	1	-3.9	-3	-4.6	1780.8	17.2	-3.9	-3.925	1
2022-12-12	2022	12	12	12	18	1	-3.9	-3.3	-4.6	1847.0	17.2	-3.8	-4.04167	1
2022-12-12	2022	12	12	12	19	1	-3.9	-3.4	-4.9	1825.9	17.2	-3.7	-4.15	1
2022-12-12	2022	12	12	12	20	1	-3.9	-3.7	-5	1790.9	17.2	-3.6	-4.23333	1
2022-12-12	2022	12	12	12	21	1	-3.9	-3.6	-4.7	1747.3	17.2	-3.5	-4.325	1
2022-12-12	2022	12	12	12	22	1	-3.9	-3.4	-4.3	1664.9	17.2	-3.4	-4.425	1
2022-12-12	2022	12	12	12	23	1	-3.9	-3.3	-3.4	1559.3	17.2	-3.3	-4.48333	1
2022-12-12	2022	12	12	12	24	1	-3.9	-3.3	-3.2	1509.9	17.2	-3.2	-4.50833	1
2022-12-13	2022	12	13	13	1	2	-3.8	-3.4	-2.7	1474.7	30.5	-3.2	-4.44167	1
2022-12-13	2022	12	13	13	2	2	-3.8	-3.7	-2.6	1445.4	30.5	-3.2	-4.35	1
2022-12-13	2022	12	13	13	3	2	-3.8	-3.6	-2.7	1424.7	30.5	-3.3	-4.21667	1
2022-12-13	2022	12	13	13	4	2	-3.7	-3.3	-3	1410.5	30.5	-3.4	-4.075	1
2022-12-13	2022	12	13	13	5	2	-3.7	-2.9	-3.3	1416.1	30.5	-3.4	-3.93333	1
2022-12-13	2022	12	13	13	6	2	-3.6	-2.1	-3.4	1465.6	30.5	-3.4	-3.80833	1
2022-12-13	2022	12	13	13	7	2	-3.5	-1.9	-3.7	1589.8	30.5	-3.3	-3.7	1
2022-12-13	2022	12	13	13	8	2	-3.4	-2	-3.6	1682.6	30.5	-3.2	-3.6	1
2022-12-13	2022	12	13	13	9	2	-3.3	-2.6	-3.4	1732.1	30.5	-3.0	-3.5	1
2022-12-13	2022	12	13	13	10	2	-3.2	-2.9	-3.3	1735.8	30.5	-3.0	-3.38333	1
2022-12-13	2022	12	13	13	11	2	-3.1	-2.4	-3.3	1714.5	30.5	-2.9	-3.275	1
2022-12-13	2022	12	13	13	12	2	-3.0	-1.9	-3.4	1689.8	30.5	-2.8	-3.19167	1
2022-12-13	2022	12	13	13	13	2	-3.0	-1.1	-3.7	1689.5	30.5	-2.7	-3.18333	1
2022-12-13	2022	12	13	13	14	2	-2.9	-0.8	-3.6	1657.9	30.5	-2.5	-3.2	1
2022-12-13	2022	12	13	13	15	2	-2.8	-1.2	-3.3	1639.0	30.5	-2.3	-3.28333	1
2022-12-13	2022	12	13	13	16	2	-2.7	-1.2	-2.9	1674.1	30.5	-2.1	-3.36667	1
2022-12-13	2022	12	13	13	17	2	-2.7	-1.6	-2.1	1771.6	30.5	-1.9	-3.41667	1
2022-12-13	2022	12	13	13	18	2	-2.6	-2.1	-1.9	1862.2	30.5	-1.8	-3.40833	1
2022-12-13	2022	12	13	13	19	2	-2.6	-2.6	-2	1823.5	30.5	-1.8	-3.30833	1
2022-12-13	2022	12	13	13	20	2	-2.5	-3.2	-2.6	1784.6	30.5	-1.9	-3.18333	1
2022-12-13	2022	12	13	13	21	2	-2.5	-3.7	-2.9	1743.4	30.5	-2.0	-3.04167	1
2022-12-13	2022	12	13	13	22	2	-2.5	-4	-2.4	1673.9	30.5	-2.1	-2.95833	1
2022-12-13	2022	12	13	13	23	2	-2.5	-4.3	-1.9	1586.2	30.5	-2.2	-2.91667	1
2022-12-13	2022	12	13	13	24	2	-2.6	-4.5	-1.1	1545.3	30.5	-2.3	-2.84167	1
2022-12-14	2022	12	14	14	1	3	-2.6	-4.9	-0.8	1508.4	15.5	-2.5	-2.725	1
2022-12-14	2022	12	14	14	2	3	-2.7	-5.1	-1.2	1479.1	15.5	-2.8	-2.53333	1
2022-12-14	2022	12	14	14	3	3	-2.7	-5.3	-1.2	1461.7	15.5	-3.2	-2.29167	1
2022-12-14	2022	12	14	14	4	3	-2.8	-5.5	-1.6	1455.7	15.5	-3.5	-2.09167	1
2022-12-14	2022	12	14	14	5	3	-2.9	-5.4	-2.1	1467.5	15.5	-3.9	-1.91667	1
2022-12-14	2022	12	14	14	6	3	-3.0	-5.6	-2.6	1514.6	15.5	-4.2	-1.80833	1
2022-12-14	2022	12	14	14	7	3	-3.2	-5.8	-3.2	1638.4	15.5	-4.5	-1.80833	1
2022-12-14	2022	12	14	14	8	3	-3.3	-5.5	-3.7	1735.5	15.5	-4.8	-1.86667	1
2022-12-14	2022	12	14	14	9	3	-3.5	-5.1	-4	1750.9	15.5	-5.0	-1.96667	1
2022-12-14	2022	12	14	14	10	3	-3.6	-4.1	-4.3	1705.9	15.5	-5.1	-2.05833	1
2022-12-14	2022	12	14	14	11	3	-3.6	-2.8	-4.5	1645.9	15.5	-5.1	-2.15	1
2022-12-14	2022	12	14	14	12	3	-3.6	-2.7	-4.9	1600.5	15.5	-5.0	-2.30833	1
2022-12-14	2022	12	14	14	13	3	-3.7	-0.7	-5.1	1569.9	15.5	-4.8	-2.525	1
2022-12-14	2022	12	14	14	14	3	-3.7	-0.1	-5.3	1517.1	15.5	-4.5	-2.84167	1
2022-12-14	2022	12	14	14	15	3	-3.6	0.7	-5.5	1493.2	15.5	-4.1	-3.2	1
2022-12-14	2022	12	14	14	16	3	-3.5	0.1	-5.4	1524.7	15.5	-3.6	-3.54167	1
2022-12-14	2022	12	14	14	17	3	-3.5	-0.2	-5.6	1639.2	15.5	-3.1	-3.9	1
2022-12-14	2022	12	14	14	18	3	-3.4	-0.8	-5.8	1760.5	15.5	-2.7	-4.21667	1
2022-12-14	2022	12	14	14	19	3	-3.4	-1.2	-5.5	1744.9	15.5	-2.3	-4.50833	1
2022-12-14	2022	12	14	14	20	3	-3.3	-1.9	-5.1	1728.5	15.5	-1.9	-4.775	1
2022-12-14	2022	12	14	14	21	3	-3.3	-2.5	-4.1	1702.1	15.5	-1.6	-4.96667	1
2022-12-14	2022	12	14	14	22	3	-3.2	-2.8	-2.8	1642.9	15.5	-1.4	-5.08333	1
2022-12-14	2022	12	14	14	23	3	-3.2	-2.8	-2.7	1528.5	15.5	-1.2	-5.09167	1
2022-12-14	2022	12	14	14	24	3	-3.1	-2	-0.7	1468.3	15.5	-1.2	-4.96667	1
2022-12-15	2022	12	15	15	1	4	-3.0	-1.1	-0.1	1402.3	23.0	-1.2	-4.81667	1
2022-12-15	2022	12	15	15	2	4	-2.8	0.3	0.7	1345.6	23.0	-1.2	-4.46667	1
2022-12-15	2022	12	15	15	3	4	-2.6	1	0.1	1303.4	23.0	-1.2	-4.05	1
2022-12-15	2022	12	15	15	4	4	-2.4	1.6	-0.2	1276.5	23.0	-1.2	-3.55	1
2022-12-15	2022	12	15	15	5	4	-2.1	2	-0.8	1272.7	23.0	-1.0	-3.08333	1
2022-12-15	2022	12	15	15	6	4	-1.8	2.6	-1.2	1315.8	23.0	-0.9	-2.65	1
2022-12-15	2022	12	15	15	7	4	-1.4	2.8	-1.9	1430.7	23.0	-0.6	-2.25	1
2022-12-15	2022	12	15	15	8	4	-1.							

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLag	Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLag	Weekdays	
2022-12-15	2022	12	15	15	24	4	2.5	1.7	4.6	1358.3	23.0	3.2	1.875	1
2022-12-16	2022	12	16	16	1	5	2.7	2	4.7	1311.9	17.3	2.9	2.433333	1
2022-12-16	2022	12	16	16	2	5	2.8	2.2	4.5	1273.9	17.3	2.7	2.908333	1
2022-12-16	2022	12	16	16	3	5	2.9	2.6	3.9	1243.0	17.3	2.5	3.275	1
2022-12-16	2022	12	16	16	4	5	3.0	2.7	3.4	1222.0	17.3	2.3	3.566667	1
2022-12-16	2022	12	16	16	5	5	3.0	2.6	2.8	1225.7	17.3	2.2	3.758333	1
2022-12-16	2022	12	16	16	6	5	3.0	2.5	2.2	1273.9	17.3	2.2	3.875	1
2022-12-16	2022	12	16	16	7	5	3.0	2.5	2.1	1382.5	17.3	2.2	3.891667	1
2022-12-16	2022	12	16	16	8	5	3.0	2.7	1.7	1492.7	17.3	2.2	3.841667	1
2022-12-16	2022	12	16	16	9	5	3.0	2.8	1.8	1531.9	17.3	2.2	3.75	1
2022-12-16	2022	12	16	16	10	5	3.0	3.1	1.7	1535.1	17.3	2.3	3.6	1
2022-12-16	2022	12	16	16	11	5	2.9	3.3	1.7	1528.0	17.3	2.4	3.416667	1
2022-12-16	2022	12	16	16	12	5	2.9	3.5	2	1533.5	17.3	2.6	3.175	1
2022-12-16	2022	12	16	16	13	5	2.8	3.5	2.2	1528.3	17.3	2.7	2.925	1
2022-12-16	2022	12	16	16	14	5	2.8	3.4	2.6	1512.1	17.3	2.8	2.708333	1
2022-12-16	2022	12	16	16	15	5	2.7	3.8	2.7	1506.3	17.3	2.9	2.5	1
2022-12-16	2022	12	16	16	16	5	2.7	3.8	2.6	1523.2	17.3	3.0	2.341667	1
2022-12-16	2022	12	16	16	17	5	2.7	3.6	2.5	1565.4	17.3	3.1	2.241667	1
2022-12-16	2022	12	16	16	18	5	2.7	3.5	2.5	1616.2	17.3	3.2	2.175	1
2022-12-16	2022	12	16	16	19	5	2.7	3	2.7	1570.3	17.3	3.3	2.15	1
2022-12-16	2022	12	16	16	20	5	2.8	2.6	2.8	1531.4	17.3	3.3	2.175	1
2022-12-16	2022	12	16	16	21	5	2.8	2.5	3.1	1499.3	17.3	3.3	2.225	1
2022-12-16	2022	12	16	16	22	5	2.8	2.5	3.3	1447.4	17.3	3.3	2.316667	1
2022-12-16	2022	12	16	16	23	5	2.8	2.7	3.5	1374.3	17.3	3.3	2.425	1
2022-12-16	2022	12	16	16	24	5	2.9	3.4	3.5	1330.8	17.3	3.2	2.558333	1
2022-12-17	2022	12	17	17	1	6	3.0	3.9	3.4	1285.7	27.4	3.2	2.708333	0
2022-12-17	2022	12	17	17	2	6	3.0	4	3.8	1245.0	27.4	3.2	2.833333	0
2022-12-17	2022	12	17	17	3	6	3.1	4.1	3.8	1204.7	27.4	3.3	2.933333	0
2022-12-17	2022	12	17	17	4	6	3.2	4.3	3.6	1179.7	27.4	3.3	3.033333	0
2022-12-17	2022	12	17	17	5	6	3.2	4.3	3.5	1178.4	27.4	3.3	3.125	0
2022-12-17	2022	12	17	17	6	6	3.3	4.5	3	1203.9	27.4	3.4	3.208333	0
2022-12-17	2022	12	17	17	7	6	3.4	4.6	2.6	1252.0	27.4	3.5	3.291667	0
2022-12-17	2022	12	17	17	8	6	3.5	4.4	2.5	1318.1	27.4	3.6	3.333333	0
2022-12-17	2022	12	17	17	9	6	3.5	4.4	2.5	1391.2	27.4	3.8	3.325	0
2022-12-17	2022	12	17	17	10	6	3.6	4.4	2.7	1460.7	27.4	3.9	3.3	0
2022-12-17	2022	12	17	17	11	6	3.7	4.7	3.4	1496.9	27.4	4.1	3.25	0
2022-12-17	2022	12	17	17	12	6	3.7	5.2	3.9	1512.5	27.4	4.3	3.2	0
2022-12-17	2022	12	17	17	13	6	3.8	5.3	4	1512.1	27.4	4.4	3.191667	0
2022-12-17	2022	12	17	17	14	6	3.9	5.6	4.1	1490.2	27.4	4.5	3.225	0
2022-12-17	2022	12	17	17	15	6	4.0	5.6	4.3	1472.9	27.4	4.7	3.275	0
2022-12-17	2022	12	17	17	16	6	4.0	5.3	4.3	1484.8	27.4	4.8	3.3	0
2022-12-17	2022	12	17	17	17	6	4.1	5	4.5	1547.3	27.4	4.9	3.341667	0
2022-12-17	2022	12	17	17	18	6	4.2	4.9	4.6	1589.7	27.4	4.9	3.4	0
2022-12-17	2022	12	17	17	19	6	4.2	4.8	4.4	1536.4	27.4	5.0	3.483333	0
2022-12-17	2022	12	17	17	20	6	4.3	4.5	4.4	1483.1	27.4	5.0	3.616667	0
2022-12-17	2022	12	17	17	21	6	4.4	4.2	4.4	1444.3	27.4	5.0	3.766667	0
2022-12-17	2022	12	17	17	22	6	4.4	3.4	4.7	1394.2	27.4	5.0	3.925	0
2022-12-17	2022	12	17	17	23	6	4.5	3.1	5.2	1324.6	27.4	4.9	4.083333	0
2022-12-17	2022	12	17	17	24	6	4.5	2.4	5.3	1260.8	27.4	4.7	4.25	0
2022-12-18	2022	12	18	18	1	7	4.5	2.6	5.6	1206.9	9.5	4.5	4.4	0
2022-12-18	2022	12	18	18	2	7	4.4	3	5.6	1175.0	9.5	4.3	4.516667	0
2022-12-18	2022	12	18	18	3	7	4.4	2.8	5.3	1150.3	9.5	4.1	4.65	0
2022-12-18	2022	12	18	18	4	7	4.3	2.7	5	1140.4	9.5	3.8	4.775	0
2022-12-18	2022	12	18	18	5	7	4.2	2.6	4.9	1133.1	9.5	3.6	4.858333	0
2022-12-18	2022	12	18	18	6	7	4.2	2.5	4.8	1150.5	9.5	3.4	4.916667	0
2022-12-18	2022	12	18	18	7	7	4.1	2.5	4.5	1196.7	9.5	3.2	4.95	0
2022-12-18	2022	12	18	18	8	7	4.0	2.5	4.2	1263.3	9.5	3.0	4.966667	0
2022-12-18	2022	12	18	18	9	7	3.9	2.4	3.4	1349.4	9.5	2.9	4.975	0
2022-12-18	2022	12	18	18	10	7	3.8	2.8	3.1	1415.5	9.5	2.7	4.958333	0
2022-12-18	2022	12	18	18	11	7	3.8	4.3	2.4	1437.1	9.5	2.7	4.875	0
2022-12-18	2022	12	18	18	12	7	3.8	4.5	2.6	1442.9	9.5	2.8	4.741667	0
2022-12-18	2022	12	18	18	13	7	3.7	5.1	3	1440.6	9.5	2.9	4.508333	0
2022-12-18	2022	12	18	18	14	7	3.7	4.6	2.8	1417.6	9.5	3.1	4.283333	0
2022-12-18	2022	12	18	18	15	7	3.7	4.9	2.7	1415.0	9.5	3.3	4.066667	0
2022-12-18	2022	12	18	18	16	7	3.6	4.6	2.6	1439.1	9.5	3.5	3.833333	0
2022-12-18	2022	12	18	18	17	7	3.6	4.3	2.5	1520.5	9.5	3.6	3.616667	0
2022-12-18	2022	12	18	18	18	7	3.6	3.9	2.5	1573.9	9.5	3.8	3.416667	0
2022-12-18	2022	12	18	18	19	7	3.5	3.7	2.5	1530.3	9.5	3.9	3.216667	0
2022-12-18	2022	12	18	18	20	7	3.5	3.3	2.4	1500.0	9.5	4.0	3.025	0
2022-12-18	2022	12	18	18	21	7	3.4	3.2	2.8	1456.2	9.5	4.0	2.858333	0
2022-12-18	2022	12	18	18	22	7	3.4	2.9	4.3	1402.8	9.5	4.1	2.708333	0
2022-12-18	2022	12	18	18	23	7	3.4	2.8	4.5	1305.5	9.5	4.1	2.658333	0
2022-12-18	2022	12	18	18	24	7	3.4	2.5	5.1	1230.5	9.5	4.0	2.758333	0
2022-12-19	2022	12	19	19	1	1	3.4	2.3	4.6	1180.1	14.4	3.8	2.933333	1
2022-12-19	2022	12	19	19	2	1	3.4	1.9	4.9	1151.7	14.4	3.6	3.141667	1
2022-12-19	2022	12	19	19	3	1	3.3	1.6	4.6	1140.8	14.4	3.4	3.275	1
2022-12-19	2022	12	19	19	4	1	3.3	1.2	4.3	1145.4	14.4	3.1	3.45	1
2022-12-19	2022	12	19	19	5	1	3.2	1.1	3.9	1164.0	14.4	2.8	3.608333	1
2022-12-19	2022	12	19	19	6	1	3.1	1.1	3.7	1218.7	14.4	2.5	3.75	1
2022-12-19	2022	12	19	19	7	1	3.1	1.2	3.3	1340.0	14.4	2.3	3.866667	1
2022-12-19	2022	12	19	19	8	1	3.0	1.3	3.2	1451.2	14.4	2.1	3.966667	1
2022-12-19	2022	12	19	19	9	1	3.0	1.7	2.9	1491.8	14.4	1.9	4.033333	1
2022-12-19	2022	12	19	19	10	1	3.0	2	2.8	1503.7	14.4	1.8	4.1	1
2022-12-19	2022	12	19	19	11	1	2.9	2.4	2.5	1497.6	14.4	1.7	4.108333	1
2022-12-19	2022	12	19	19	12	1	2.8	2.9	2.3	1500.6	14.4	1.7	3.983333	1
2022-12-19	2022	12	19	19	13	1	2.8	2.6	1.9	1500.2	14.4	1.7	3.816667	1
2022-12-19	2022	12	19	19	14	1	2.7	3.1	1.6	1491.2	14.4	1.8	3.583333	1
2022-12-19	2022	12	19	19	15	1	2.6	2.8	1.2	1483.3	14.4	1.9	3.358333	1
2022-12-19	2022	12	19	19	16	1	2.5	2.8	1.1	1503.8	14.4	2.0	3.083333	1
2022-12-19	2022	12	19	19	17	1	2.4	2.6	1.1	1576.8	14.4	2.1	2.8	1
2022-12-19	2022	12	19	19	18	1	2.4	2.4	1.2	1643.8	14.4	2.2	2.533333	1
2022-12-19	2022	12	19	19	19	1	2.3	2	1.3	1607.0	14.4	2.3	2.3	1
2022-12-19	2022	12</												

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLag	Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLag	Weekdays	
2022-12-20	2022	12	20	20	12	2	2.2	4.2	1.8	1473.1	20.5	2.0	2.308333	1
2022-12-20	2022	12	20	20	13	2	2.2	4.7	1.4	1476.5	20.5	2.2	2.2	1
2022-12-20	2022	12	20	20	14	2	2.3	4.4	1	1460.3	20.5	2.5	2.133333	1
2022-12-20	2022	12	20	20	15	2	2.3	4.3	1.6	1454.6	20.5	2.7	1.991667	1
2022-12-20	2022	12	20	20	16	2	2.4	4.5	1.6	1469.5	20.5	3.0	1.841667	1
2022-12-20	2022	12	20	20	17	2	2.5	4.2	1.9	1537.8	20.5	3.2	1.741667	1
2022-12-20	2022	12	20	20	18	2	2.5	3.9	2.1	1607.0	20.5	3.4	1.658333	1
2022-12-20	2022	12	20	20	19	2	2.6	3.7	2.8	1570.1	20.5	3.6	1.616667	1
2022-12-20	2022	12	20	20	20	2	2.7	3.5	2.7	1535.9	20.5	3.7	1.625	1
2022-12-20	2022	12	20	20	21	2	2.8	3.3	2.3	1494.2	20.5	3.8	1.708333	1
2022-12-20	2022	12	20	20	22	2	2.8	3	3.1	1436.8	20.5	3.8	1.791667	1
2022-12-20	2022	12	20	20	23	2	2.9	3.1	4.2	1343.4	20.5	3.9	1.858333	1
2022-12-20	2022	12	20	20	24	2	2.9	3.1	4.7	1289.6	20.5	3.9	1.991667	1
2022-12-21	2022	12	21	21	1	3	3.0	3.1	4.4	1245.3	7.3	3.8	2.208333	1
2022-12-21	2022	12	21	21	2	3	3.1	3.2	4.3	1202.0	7.3	3.7	2.45	1
2022-12-21	2022	12	21	21	3	3	3.1	2.9	4.5	1172.7	7.3	3.6	2.7	1
2022-12-21	2022	12	21	21	4	3	3.2	2.8	4.2	1159.9	7.3	3.5	2.975	1
2022-12-21	2022	12	21	21	5	3	3.3	2.6	3.9	1157.3	7.3	3.3	3.216667	1
2022-12-21	2022	12	21	21	6	3	3.3	2.6	3.7	1197.6	7.3	3.2	3.433333	1
2022-12-21	2022	12	21	21	7	3	3.3	2	3.5	1312.8	7.3	3.1	3.6	1
2022-12-21	2022	12	21	21	8	3	3.3	2	3.3	1408.6	7.3	2.9	3.733333	1
2022-12-21	2022	12	21	21	9	3	3.3	1.7	3	1476.2	7.3	2.8	3.791667	1
2022-12-21	2022	12	21	21	10	3	3.3	2.4	3.1	1495.3	7.3	2.7	3.841667	1
2022-12-21	2022	12	21	21	11	3	3.3	2.7	3.1	1474.4	7.3	2.6	3.9	1
2022-12-21	2022	12	21	21	12	3	3.2	3.5	3.1	1450.8	7.3	2.6	3.9	1
2022-12-21	2022	12	21	21	13	3	3.2	3.6	3.2	1461.5	7.3	2.6	3.808333	1
2022-12-21	2022	12	21	21	14	3	3.2	3.8	2.9	1458.1	7.3	2.7	3.675	1
2022-12-21	2022	12	21	21	15	3	3.1	3.6	2.8	1440.8	7.3	2.7	3.575	1
2022-12-21	2022	12	21	21	16	3	3.1	3.2	2.6	1457.7	7.3	2.8	3.458333	1
2022-12-21	2022	12	21	21	17	3	3.1	2.9	2.6	1524.0	7.3	2.8	3.316667	1
2022-12-21	2022	12	21	21	18	3	3.0	2.6	2	1610.6	7.3	2.8	3.183333	1
2022-12-21	2022	12	21	21	19	3	3.0	2.3	2	1580.1	7.3	2.8	3.075	1
2022-12-21	2022	12	21	21	20	3	2.9	2.1	1.7	1551.2	7.3	2.9	2.933333	1
2022-12-21	2022	12	21	21	21	3	2.8	2.3	2.4	1517.6	7.3	2.9	2.808333	1
2022-12-21	2022	12	21	21	22	3	2.8	2	2.7	1460.9	7.3	2.9	2.675	1
2022-12-21	2022	12	21	21	23	3	2.8	2.2	3.5	1378.3	7.3	2.9	2.625	1
2022-12-21	2022	12	21	21	24	3	2.7	2.1	3.6	1328.5	7.3	2.8	2.591667	1
2022-12-22	2022	12	22	22	1	4	2.7	1.8	3.8	1294.9	8.6	2.7	2.625	1
2022-12-22	2022	12	22	22	2	4	2.6	0.9	3.6	1251.7	8.6	2.6	2.666667	1
2022-12-22	2022	12	22	22	3	4	2.5	1.1	3.2	1218.7	8.6	2.3	2.716667	1
2022-12-22	2022	12	22	22	4	4	2.5	0.4	2.9	1215.5	8.6	2.1	2.775	1
2022-12-22	2022	12	22	22	5	4	2.4	-0.1	2.6	1228.4	8.6	1.9	2.808333	1
2022-12-22	2022	12	22	22	6	4	2.2	0.4	2.3	1282.5	8.6	1.6	2.833333	1
2022-12-22	2022	12	22	22	7	4	2.1	-0.1	2.1	1392.6	8.6	1.5	2.833333	1
2022-12-22	2022	12	22	22	8	4	2.1	-0.3	2.3	1498.9	8.6	1.3	2.858333	1
2022-12-22	2022	12	22	22	9	4	2.0	-1	2	1554.1	8.6	1.1	2.866667	1
2022-12-22	2022	12	22	22	10	4	1.9	0.1	2.2	1537.6	8.6	0.8	2.916667	1
2022-12-22	2022	12	22	22	11	4	1.8	1.2	2.1	1504.3	8.6	0.6	2.883333	1
2022-12-22	2022	12	22	22	12	4	1.7	1.8	1.8	1480.6	8.6	0.5	2.841667	1
2022-12-22	2022	12	22	22	13	4	1.6	2.2	0.9	1451.2	8.6	0.5	2.725	1
2022-12-22	2022	12	22	22	14	4	1.6	2.4	1.1	1424.3	8.6	0.6	2.575	1
2022-12-22	2022	12	22	22	15	4	1.5	2.8	0.4	1426.1	8.6	0.7	2.333333	1
2022-12-22	2022	12	22	22	16	4	1.5	2.7	-0.1	1462.0	8.6	0.8	2.125	1
2022-12-22	2022	12	22	22	17	4	1.5	1.9	0.4	1540.6	8.6	1.0	1.891667	1
2022-12-22	2022	12	22	22	18	4	1.4	1.3	-0.1	1626.6	8.6	1.2	1.641667	1
2022-12-22	2022	12	22	22	19	4	1.4	0.5	-0.3	1610.8	8.6	1.3	1.458333	1
2022-12-22	2022	12	22	22	20	4	1.3	0	-1	1589.6	8.6	1.3	1.258333	1
2022-12-22	2022	12	22	22	21	4	1.2	-1	0.1	1573.4	8.6	1.3	1.058333	1
2022-12-22	2022	12	22	22	22	4	1.1	-0.9	1.2	1531.2	8.6	1.3	0.783333	1
2022-12-22	2022	12	22	22	23	4	0.9	-1.2	1.8	1461.5	8.6	1.2	0.625	1
2022-12-22	2022	12	22	22	24	4	0.8	-1.8	2.2	1422.0	8.6	1.0	0.541667	1
2022-12-23	2022	12	23	23	1	5	0.6	-2.7	2.4	1385.8	27.3	0.7	0.516667	1
2022-12-23	2022	12	23	23	2	5	0.4	-2.1	2.8	1352.2	27.3	0.3	0.55	1
2022-12-23	2022	12	23	23	3	5	0.3	-2.5	2.7	1318.8	27.3	0.0	0.675	1
2022-12-23	2022	12	23	23	4	5	0.2	-2.4	1.9	1302.9	27.3	-0.5	0.816667	1
2022-12-23	2022	12	23	23	5	5	0.1	-2.1	1.3	1313.0	27.3	-0.9	1.008333	1
2022-12-23	2022	12	23	23	6	5	0.0	-1.7	0.5	1356.2	27.3	-1.2	1.175	1
2022-12-23	2022	12	23	23	7	5	-0.1	-1.3	0	1443.1	27.3	-1.5	1.25	1
2022-12-23	2022	12	23	23	8	5	-0.2	2.3	-1	1521.6	27.3	-1.6	1.3	1
2022-12-23	2022	12	23	23	9	5	-0.1	3.3	-0.9	1586.2	27.3	-1.5	1.325	1
2022-12-23	2022	12	23	23	10	5	0.1	3.7	-1.2	1634.4	27.3	-1.1	1.325	1
2022-12-23	2022	12	23	23	11	5	0.3	3.1	-1.8	1646.6	27.3	-0.7	1.241667	1
2022-12-23	2022	12	23	23	12	5	0.3	3.8	-2.7	1640.6	27.3	-0.4	1.041667	1
2022-12-23	2022	12	23	23	13	5	0.4	4.1	-2.1	1637.0	27.3	0.1	0.741667	1
2022-12-23	2022	12	23	23	14	5	0.5	4.3	-2.5	1622.4	27.3	0.7	0.333333	1
2022-12-23	2022	12	23	23	15	5	0.6	5.3	-2.4	1598.0	27.3	1.2	-0.04167	1
2022-12-23	2022	12	23	23	16	5	0.7	6.4	-2.1	1591.6	27.3	1.9	-0.48333	1
2022-12-23	2022	12	23	23	17	5	0.8	7.2	-1.7	1620.5	27.3	2.6	-0.90833	1
2022-12-23	2022	12	23	23	18	5	1.1	7.6	-1.3	1637.8	27.3	3.4	-1.24167	1
2022-12-23	2022	12	23	23	19	5	1.3	7.8	2.3	1571.7	27.3	4.2	-1.49167	1
2022-12-23	2022	12	23	23	20	5	1.6	8.9	3.3	1482.0	27.3	4.9	-1.64167	1
2022-12-23	2022	12	23	23	21	5	2.0	9.4	3.7	1406.8	27.3	5.5	-1.45	1
2022-12-23	2022	12	23	23	22	5	2.4	9.9	3.1	1297.7	27.3	6.0	-1.09167	1
2022-12-23	2022	12	23	23	23	5	2.9	10.3	3.8	1226.6	27.3	6.5	-0.70833	1
2022-12-23	2022	12	23	23	24	5	3.4	11	4.1	1163.3	27.3	7.1	-0.35	1
2022-12-24	2022	12	24	24	1	6	3.9	11.7	4.3	1083.6	26.6	7.7	0.116667	0
2022-12-24	2022	12	24	24	2	6	4.5	12.3	5.3	1009.7	26.6	8.3	0.683333	0
2022-12-24	2022	12	24	24	3	6	5.1	11.7	6.4	983.3	26.6	9.0	1.216667	0
2022-12-24	2022	12	24	24	4	6	5.7	9.7	7.2	974.8	26.6	9.5	1.866667	0
2022-12-24	2022	12	24	24	5	6	6.2	7.7	7.6	981.1	26.6	9.8	2.6	0
2022-12-24	2022	12	24	24	6	6	6.6	6.2	7.8	1016.4	26.6	9.8	3.375	0
2022-12-24	2022	12	24	24	7	6	6.9	5.4	8.9	1051.8	26.6	9.7	4.15	0
2022-12-24	2022	12	24											

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLag	Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLag	Weekdays
2022-12-24	2022	12	24	24	24	6	5.1	2	3.4	1229.6	26.6	2.5 7.683333	0
2022-12-25	2022	12	25	1	7	7	4.7	2.2	3.1	1175.1	21.8	2.4 7.025	0
2022-12-25	2022	12	25	2	7	7	4.3	1.7	3.3	1141.0	21.8	2.3 6.333333	0
2022-12-25	2022	12	25	3	7	7	3.9	1.5	2.4	1130.6	21.8	2.2 5.566667	0
2022-12-25	2022	12	25	4	7	7	3.4	1.5	2.2	1129.9	21.8	2.0 4.866667	0
2022-12-25	2022	12	25	5	7	7	3.1	1.2	2.1	1149.9	21.8	1.9 4.258333	0
2022-12-25	2022	12	25	6	7	7	2.8	0.6	2.1	1177.8	21.8	1.8 3.8	0
2022-12-25	2022	12	25	7	7	7	2.6	0.1	1.9	1233.7	21.8	1.7 3.458333	0
2022-12-25	2022	12	25	8	7	7	2.4	-0.2	2	1314.6	21.8	1.6 3.183333	0
2022-12-25	2022	12	25	9	7	7	2.2	-0.2	2	1412.1	21.8	1.4 2.925	0
2022-12-25	2022	12	25	10	7	7	2.0	0.1	1.9	1482.4	21.8	1.2 2.741667	0
2022-12-25	2022	12	25	11	7	7	1.8	0.5	2	1516.9	21.8	1.0 2.6	0
2022-12-25	2022	12	25	12	7	7	1.7	0.9	2.2	1543.1	21.8	0.9 2.458333	0
2022-12-25	2022	12	25	13	7	7	1.6	0.8	1.7	1552.7	21.8	0.8 2.366667	0
2022-12-25	2022	12	25	14	7	7	1.5	1	1.5	1540.0	21.8	0.7 2.266667	0
2022-12-25	2022	12	25	15	7	7	1.4	1.1	1.5	1531.2	21.8	0.7 2.15	0
2022-12-25	2022	12	25	16	7	7	1.3	0.9	1.2	1539.0	21.8	0.6 2	0
2022-12-25	2022	12	25	17	7	7	1.2	0.9	0.6	1552.7	21.8	0.6 1.925	0
2022-12-25	2022	12	25	18	7	7	1.2	0.9	0.1	1536.7	21.8	0.5 1.841667	0
2022-12-25	2022	12	25	19	7	7	1.1	0.8	-0.2	1491.4	21.8	0.6 1.716667	0
2022-12-25	2022	12	25	20	7	7	1.1	0.7	-0.2	1475.3	21.8	0.6 1.55	0
2022-12-25	2022	12	25	21	7	7	1.0	0.3	0.1	1455.1	21.8	0.7 1.375	0
2022-12-25	2022	12	25	22	7	7	1.0	0	0.5	1427.6	21.8	0.7 1.191667	0
2022-12-25	2022	12	25	23	7	7	0.9	-0.4	0.9	1368.2	21.8	0.7 1.033333	0
2022-12-25	2022	12	25	24	7	7	0.8	-0.4	0.8	1302.2	21.8	0.7 0.916667	0
2022-12-26	2022	12	26	1	1	1	0.7	-0.4	1	1252.6	11.8	0.6 0.825	0
2022-12-26	2022	12	26	2	1	1	0.6	-0.6	1.1	1230.5	11.8	0.5 0.708333	0
2022-12-26	2022	12	26	3	1	1	0.5	-0.8	0.9	1211.4	11.8	0.3 0.65	0
2022-12-26	2022	12	26	4	1	1	0.4	-0.4	0.9	1190.8	11.8	0.2 0.616667	0
2022-12-26	2022	12	26	5	1	1	0.3	-0.5	0.9	1203.5	11.8	0.1 0.566667	0
2022-12-26	2022	12	26	6	1	1	0.2	-0.9	0.8	1234.3	11.8	-0.1 0.541667	0
2022-12-26	2022	12	26	7	1	1	0.2	-1	0.7	1279.2	11.8	-0.2 0.566667	0
2022-12-26	2022	12	26	8	1	1	0.1	-0.8	0.3	1323.6	11.8	-0.4 0.625	0
2022-12-26	2022	12	26	9	1	1	0.1	-0.6	0	1393.7	11.8	-0.5 0.7	0
2022-12-26	2022	12	26	10	1	1	0.1	-0.3	-0.4	1470.0	11.8	-0.6 0.741667	0
2022-12-26	2022	12	26	11	1	1	0.1	0	-0.4	1512.7	11.8	-0.6 0.733333	0
2022-12-26	2022	12	26	12	1	1	0.1	0	-0.4	1515.9	11.8	-0.6 0.658333	0
2022-12-26	2022	12	26	13	1	1	0.0	0.3	-0.6	1488.8	11.8	-0.5 0.55	0
2022-12-26	2022	12	26	14	1	1	0.0	1.1	-0.8	1429.6	11.8	-0.5 0.45	0
2022-12-26	2022	12	26	15	1	1	0.0	2.3	-0.4	1394.2	11.8	-0.3 0.316667	0
2022-12-26	2022	12	26	16	1	1	0.0	1.1	-0.5	1402.6	11.8	-0.1 0.158333	0
2022-12-26	2022	12	26	17	1	1	0.1	1.2	-0.9	1485.9	11.8	0.1 0.05	0
2022-12-26	2022	12	26	18	1	1	0.1	0.2	-1	1578.3	11.8	0.2 -0.06667	0
2022-12-26	2022	12	26	19	1	1	0.0	-0.1	-0.8	1551.0	11.8	0.3 -0.21667	0
2022-12-26	2022	12	26	20	1	1	0.0	-0.4	-0.6	1527.9	11.8	0.4 -0.36667	0
2022-12-26	2022	12	26	21	1	1	0.0	-0.5	-0.3	1490.3	11.8	0.4 -0.49167	0
2022-12-26	2022	12	26	22	1	1	-0.1	-0.1	0	1438.7	11.8	0.4 -0.56667	0
2022-12-26	2022	12	26	23	1	1	-0.1	0	0	1373.1	11.8	0.4 -0.59167	0
2022-12-26	2022	12	26	24	1	1	-0.1	0	0.3	1336.4	11.8	0.4 -0.55833	0
2022-12-27	2022	12	27	1	2	2	-0.1	-0.1	1.1	1296.0	11.3	0.4 -0.525	0
2022-12-27	2022	12	27	2	2	2	0.0	-0.3	2.3	1253.8	11.3	0.4 -0.46667	0
2022-12-27	2022	12	27	3	2	2	0.0	-0.4	1.1	1219.4	11.3	0.3 -0.325	0
2022-12-27	2022	12	27	4	2	2	0.0	-0.3	1.2	1206.5	11.3	0.1 -0.06667	0
2022-12-27	2022	12	27	5	2	2	0.0	-0.1	0.2	1215.5	11.3	-0.1 0.058333	0
2022-12-27	2022	12	27	6	2	2	0.0	-0.2	-0.1	1243.8	11.3	-0.2 0.2	0
2022-12-27	2022	12	27	7	2	2	0.0	-0.2	-0.4	1301.3	11.3	-0.2 0.291667	0
2022-12-27	2022	12	27	8	2	2	0.1	-0.3	-0.5	1362.3	11.3	-0.2 0.366667	0
2022-12-27	2022	12	27	9	2	2	0.1	-1	-0.1	1431.5	11.3	-0.2 0.4	0
2022-12-27	2022	12	27	10	2	2	0.1	-0.7	0	1501.1	11.3	-0.3 0.408333	0
2022-12-27	2022	12	27	11	2	2	0.1	0.7	0	1538.3	11.3	-0.3 0.425	0
2022-12-27	2022	12	27	12	2	2	0.1	2.4	-0.1	1558.9	11.3	-0.2 0.425	0
2022-12-27	2022	12	27	13	2	2	0.2	3.1	-0.3	1553.2	11.3	0.0 0.425	0
2022-12-27	2022	12	27	14	2	2	0.3	4.1	-0.4	1532.1	11.3	0.2 0.391667	0
2022-12-27	2022	12	27	15	2	2	0.4	3.9	-0.3	1511.0	11.3	0.6 0.275	0
2022-12-27	2022	12	27	16	2	2	0.5	2.3	-0.1	1517.0	11.3	1.0 0.05	0
2022-12-27	2022	12	27	17	2	2	0.6	2.2	-0.2	1580.2	11.3	1.2 -0.06667	0
2022-12-27	2022	12	27	18	2	2	0.6	2.1	-0.2	1636.7	11.3	1.4 -0.175	0
2022-12-27	2022	12	27	19	2	2	0.7	1.8	-0.3	1591.1	11.3	1.6 -0.20833	0
2022-12-27	2022	12	27	20	2	2	0.8	0.5	-1	1567.0	11.3	1.7 -0.21667	0
2022-12-27	2022	12	27	21	2	2	0.8	-0.1	-0.7	1527.0	11.3	1.8 -0.20833	0
2022-12-27	2022	12	27	22	2	2	0.8	-0.3	0.7	1467.1	11.3	1.9 -0.25	0
2022-12-27	2022	12	27	23	2	2	0.8	-0.5	2.4	1401.6	11.3	1.9 -0.3	0
2022-12-27	2022	12	27	24	2	2	0.8	-0.7	3.1	1375.8	11.3	1.8 -0.24167	0
2022-12-28	2022	12	28	1	3	3	0.7	-1	4.1	1341.5	10.7	1.5 -0.04167	1
2022-12-28	2022	12	28	2	3	3	0.7	-1.6	3.9	1319.4	10.7	1.2 0.225	1
2022-12-28	2022	12	28	3	3	3	0.7	-2.6	2.3	1319.8	10.7	0.7 0.591667	1
2022-12-28	2022	12	28	4	3	3	0.6	-4	2.2	1325.7	10.7	0.2 0.95	1
2022-12-28	2022	12	28	5	3	3	0.4	-4.7	2.1	1349.3	10.7	-0.4 1.166667	1
2022-12-28	2022	12	28	6	3	3	0.2	-5.6	1.8	1395.4	10.7	-0.9 1.358333	1
2022-12-28	2022	12	28	7	3	3	0.0	-5.9	0.5	1494.4	10.7	-1.6 1.55	1
2022-12-28	2022	12	28	8	3	3	-0.2	-6.2	-0.1	1580.6	10.7	-2.2 1.716667	1
2022-12-28	2022	12	28	9	3	3	-0.5	-6.4	-0.3	1637.1	10.7	-2.8 1.783333	1
2022-12-28	2022	12	28	10	3	3	-0.7	-5.1	-0.5	1674.4	10.7	-3.3 1.858333	1
2022-12-28	2022	12	28	11	3	3	-0.9	-5.1	-0.7	1678.1	10.7	-3.7 1.891667	1
2022-12-28	2022	12	28	12	3	3	-1.1	-3	-1	1698.9	10.7	-4.1 1.791667	1
2022-12-28	2022	12	28	13	3	3	-1.4	-4	-1.6	1744.9	10.7	-4.3 1.533333	1
2022-12-28	2022	12	28	14	3	3	-1.7	-3.5	-2.6	1734.5	10.7	-4.5 1.191667	1
2022-12-28	2022	12	28	15	3	3	-2.0	-3.6	-4	1708.6	10.7	-4.7 0.716667	1
2022-12-28	2022	12	28	16	3	3	-2.3	-3.9	-4.7	1688.5	10.7	-4.8 0.175	1
2022-12-28	2022	12	28	17	3	3	-2.6	-3.4	-5.6	1747.7	10.7	-4.8 -0.35	1
2022-12-28	2022	12	28	18	3	3	-2.8	-3.3	-5.9	1810.8	10.7	-4.6 -0.925	1
2022-12-28	2022	12	28	19	3	3	-3.0	-2.8	-6.2	1753.6	10.7	-4.5 -1.56667	1
2022-12-28	2022	12	28	20	3	3	-3.2	-2.1	-6.4	1698.5	10.7	-4.2 -2.20833	1
2022-12-28	2022	12	28	21	3	3	-3.3	-1.4	-5.1	1627.1	10.7	-3.9 -2.76667	1
2022-12-28	2022	12	28	22	3	3	-3.4	-0.1	-5.1	1543.9	10.7	-3.4 -3.29167	1
2022-12-28	2022	12	28	23	3	3	-3.4	0.7	-3	1456.0	10.7	-3.0 -3.69167	

DATE	Year	Month	Day	HOUR	DOW	24hrAvgLa	g Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLa	g Weekdays	
2022-12-29	2022	12	29	29	12	4	-1.6	-1	0.4	1568.3	6.6	-0.6	-2.53333	1
2022-12-29	2022	12	29	29	13	4	-1.5	-0.2	-0.2	1576.6	6.6	-0.8	-2.15833	1
2022-12-29	2022	12	29	29	14	4	-1.3	0	0.5	1544.9	6.6	-0.8	-1.79167	1
2022-12-29	2022	12	29	29	15	4	-1.2	0.3	0.8	1527.1	6.6	-0.8	-1.51667	1
2022-12-29	2022	12	29	29	16	4	-1.0	0.3	0.1	1541.2	6.6	-0.8	-1.175	1
2022-12-29	2022	12	29	29	17	4	-0.8	0.2	-0.6	1601.1	6.6	-0.9	-0.78333	1
2022-12-29	2022	12	29	29	18	4	-0.7	-0.4	-1.6	1678.6	6.6	-0.9	-0.49167	1
2022-12-29	2022	12	29	29	19	4	-0.6	-0.7	-2	1639.3	6.6	-0.8	-0.26667	1
2022-12-29	2022	12	29	29	20	4	-0.5	-0.7	-2	1599.6	6.6	-0.8	-0.16667	1
2022-12-29	2022	12	29	29	21	4	-0.4	-0.6	-2	1553.3	6.6	-0.7	-0.15833	1
2022-12-29	2022	12	29	29	22	4	-0.4	-1.2	-1.7	1490.6	6.6	-0.5	-0.20833	1
2022-12-29	2022	12	29	29	23	4	-0.4	-1.2	-1	1411.2	6.6	-0.5	-0.36667	1
2022-12-29	2022	12	29	29	24	4	-0.5	-1.1	-0.2	1373.7	6.6	-0.4	-0.56667	1
2022-12-30	2022	12	30	1	5	5	-0.6	-0.9	0	1333.8	5.8	-0.4	-0.775	1
2022-12-30	2022	12	30	2	5	5	-0.7	0.9	0.3	1284.6	5.8	-0.5	-0.825	1
2022-12-30	2022	12	30	3	5	5	-0.6	1.5	0.3	1241.1	5.8	-0.4	-0.80833	1
2022-12-30	2022	12	30	4	5	5	-0.6	1.2	0.2	1220.3	5.8	-0.3	-0.825	1
2022-12-30	2022	12	30	5	5	5	-0.6	1.8	-0.4	1212.6	5.8	-0.3	-0.86667	1
2022-12-30	2022	12	30	6	5	5	-0.5	2.6	-0.7	1242.2	5.8	-0.1	-0.85833	1
2022-12-30	2022	12	30	7	5	5	-0.4	2.1	-0.7	1311.8	5.8	0.1	-0.84167	1
2022-12-30	2022	12	30	8	5	5	-0.2	2.2	-0.6	1371.7	5.8	0.4	-0.76667	1
2022-12-30	2022	12	30	9	5	5	0.0	1.7	-1.2	1437.2	5.8	0.6	-0.65833	1
2022-12-30	2022	12	30	10	5	5	0.1	2.1	-1.2	1469.1	5.8	0.8	-0.54167	1
2022-12-30	2022	12	30	11	5	5	0.3	5.5	-1.1	1449.9	5.8	1.1	-0.475	1
2022-12-30	2022	12	30	12	5	5	0.6	5.5	-0.9	1421.3	5.8	1.6	-0.43333	1
2022-12-30	2022	12	30	13	5	5	0.9	6.6	0.9	1393.4	5.8	2.2	-0.44167	1
2022-12-30	2022	12	30	14	5	5	1.2	7	1.5	1347.0	5.8	2.8	-0.5	1
2022-12-30	2022	12	30	15	5	5	1.4	5.9	1.2	1334.7	5.8	3.3	-0.425	1
2022-12-30	2022	12	30	16	5	5	1.7	5.6	1.8	1345.7	5.8	3.7	-0.325	1
2022-12-30	2022	12	30	17	5	5	1.9	5.1	2.6	1411.7	5.8	4.1	-0.25	1
2022-12-30	2022	12	30	18	5	5	2.1	4.6	2.1	1479.2	5.8	4.3	-0.11667	1
2022-12-30	2022	12	30	19	5	5	2.3	4.3	2.2	1442.3	5.8	4.5	0.133333	1
2022-12-30	2022	12	30	20	5	5	2.5	4.1	1.7	1394.9	5.8	4.7	0.366667	1
2022-12-30	2022	12	30	21	5	5	2.7	4	2.1	1346.2	5.8	4.8	0.608333	1
2022-12-30	2022	12	30	22	5	5	2.9	4.1	5.5	1295.3	5.8	5.0	0.8	1
2022-12-30	2022	12	30	23	5	5	3.1	4.5	5.5	1229.5	5.8	5.2	1.075	1
2022-12-30	2022	12	30	24	5	5	3.4	5.6	6.6	1195.6	5.8	5.1	1.633333	1
2022-12-31	2022	12	31	1	6	6	3.7	6.2	7	1151.1	10.8	5.1	2.183333	0
2022-12-31	2022	12	31	2	6	6	3.9	6.1	5.9	1099.9	10.8	5.1	2.808333	0
2022-12-31	2022	12	31	3	6	6	4.2	5.7	5.6	1062.2	10.8	5.0	3.316667	0
2022-12-31	2022	12	31	4	6	6	4.3	5.3	5.1	1043.6	10.8	5.0	3.683333	0
2022-12-31	2022	12	31	5	6	6	4.5	5.7	4.6	1031.1	10.8	5.0	4.05	0
2022-12-31	2022	12	31	6	6	6	4.7	5.8	4.3	1049.4	10.8	5.0	4.325	0
2022-12-31	2022	12	31	7	6	6	4.8	6.5	4.1	1093.3	10.8	5.1	4.491667	0
2022-12-31	2022	12	31	8	6	6	5.0	6.8	4	1151.7	10.8	5.3	4.675	0
2022-12-31	2022	12	31	9	6	6	5.2	6.9	4.1	1214.2	10.8	5.5	4.833333	0
2022-12-31	2022	12	31	10	6	6	5.4	7.8	4.5	1256.5	10.8	5.8	5.025	0
2022-12-31	2022	12	31	11	6	6	5.6	9.1	5.6	1258.3	10.8	6.1	5.191667	0
2022-12-31	2022	12	31	12	6	6	5.8	10.1	6.2	1235.9	10.8	6.5	5.108333	0
2022-12-31	2022	12	31	13	6	6	6.0	10.6	6.1	1212.1	10.8	6.8	5.116667	0
2022-12-31	2022	12	31	14	6	6	6.1	11.6	5.7	1195.5	10.8	7.2	5.083333	0
2022-12-31	2022	12	31	15	6	6	6.3	12.1	5.3	1174.2	10.8	7.7	5.008333	0
2022-12-31	2022	12	31	16	6	6	6.6	11.4	5.7	1201.6	10.8	8.2	4.991667	0
2022-12-31	2022	12	31	17	6	6	6.8	10.1	5.8	1291.2	10.8	8.7	4.966667	0
2022-12-31	2022	12	31	18	6	6	7.0	10	6.5	1345.8	10.8	9.1	5.016667	0
2022-12-31	2022	12	31	19	6	6	7.3	9.3	6.8	1299.8	10.8	9.4	5.116667	0
2022-12-31	2022	12	31	20	6	6	7.5	9.6	6.9	1236.2	10.8	9.7	5.3	0
2022-12-31	2022	12	31	21	6	6	7.7	9.8	7.8	1171.1	10.8	9.9	5.525	0
2022-12-31	2022	12	31	22	6	6	7.9	9.4	9.1	1113.1	10.8	10.1	5.766667	0
2022-12-31	2022	12	31	23	6	6	8.2	10.2	10.1	1062.0	10.8	10.3	6.075	0
2022-12-31	2022	12	31	24	6	6	8.4	10	10.6	1022.7	10.8	10.4	6.458333	0
2023-01-01	2023	1	1	1	7	7	8.6	9.8	11.6	979.6	12.5	10.3	6.833333	0
2023-01-01	2023	1	1	2	7	7	8.7	9.4	12.1	937.9	12.5	10.3	7.2	0
2023-01-01	2023	1	1	3	7	7	8.9	10.3	11.4	907.5	12.5	10.1	7.658333	0
2023-01-01	2023	1	1	4	7	7	9.1	10.6	10.1	890.7	12.5	9.9	8.191667	0
2023-01-01	2023	1	1	5	7	7	9.3	9.6	10	887.0	12.5	9.9	8.7	0
2023-01-01	2023	1	1	6	7	7	9.5	9.3	9.3	898.9	12.5	9.8	9.066667	0
2023-01-01	2023	1	1	7	7	7	9.6	9.6	9.6	923.9	12.5	9.8	9.416667	0
2023-01-01	2023	1	1	8	7	7	9.7	9.6	9.8	963.7	12.5	9.8	9.65	0
2023-01-01	2023	1	1	9	7	7	9.8	9.1	9.4	1020.3	12.5	9.8	9.883333	0
2023-01-01	2023	1	1	10	7	7	9.9	8.7	10.2	1077.2	12.5	9.7	10.125	0
2023-01-01	2023	1	1	11	7	7	10.0	9.1	10	1127.6	12.5	9.7	10.25833	0
2023-01-01	2023	1	1	12	7	7	10.0	9	9.8	1163.9	12.5	9.6	10.35	0
2023-01-01	2023	1	1	13	7	7	9.9	9.8	9.4	1182.8	12.5	9.5	10.34167	0
2023-01-01	2023	1	1	14	7	7	9.9	10.3	10.3	1179.7	12.5	9.5	10.275	0
2023-01-01	2023	1	1	15	7	7	9.8	11.5	10.6	1168.6	12.5	9.6	10.09167	0
2023-01-01	2023	1	1	16	7	7	9.8	12	9.6	1195.8	12.5	9.7	9.941667	0
2023-01-01	2023	1	1	17	7	7	9.8	11.4	9.3	1275.1	12.5	9.8	9.875	0
2023-01-01	2023	1	1	18	7	7	9.9	10.3	9.6	1340.6	12.5	10.0	9.833333	0
2023-01-01	2023	1	1	19	7	7	9.9	6.4	9.6	1333.2	12.5	10.0	9.775	0
2023-01-01	2023	1	1	20	7	7	9.8	4.5	9.1	1315.1	12.5	9.8	9.8	0
2023-01-01	2023	1	1	21	7	7	9.6	2.9	8.7	1277.5	12.5	9.3	9.8	0
2023-01-01	2023	1	1	22	7	7	9.3	3.1	9.1	1231.4	12.5	8.8	9.741667	0
2023-01-01	2023	1	1	23	7	7	9.0	2.9	9	1181.7	12.5	8.4	9.683333	0
2023-01-01	2023	1	1	24	7	7	8.7	2.5	9.8	1128.9	12.5	7.8	9.591667	0
2023-01-02	2023	1	2	1	1	1	8.4	2.3	10.3	1097.4	10.4	7.3	9.508333	0
2023-01-02	2023	1	2	2	1	1	8.1	2.1	11.5	1073.1	10.4	6.7	9.508333	0
2023-01-02	2023	1	2	3	1	1	7.8	1.7	12	1064.1	10.4	6.0	9.583333	0
2023-01-02	2023	1	2	4	1	1	7.4	1	11.4	1061.6	10.4	5.2	9.683333	0
2023-01-02	2023	1	2	5	1	1	7.0	2.1	10.3	1062.3	10.4	4.3	9.8	0
2023-01-02	2023	1	2	6	1	1	6.7	2.2	6.4	1095.1	10.4	3.5	9.95	0
2023-01-02	2023	1	2	7	1	1	6.4	1.5	4.5	1159.6	10.4	2.8	10.03333	0
2023-01-02	2023	1	2	8	1	1	6.1	1.5	2.9	1225.8	10.4	2.4	9.766667	0
2023-01-02	2023													

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLag	Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLag	Weekdays	
2023-01-02	2023		1	2	24	1	1.9	0.1	2.1	1316.0	10.4	2.0	1.9	0
2023-01-03	2023		1	3	1	2	1.8	0	3.5	1273.9	11.8	1.7	1.966667	1
2023-01-03	2023		1	3	2	2	1.7	0.2	2.9	1234.1	11.8	1.5	1.95	1
2023-01-03	2023		1	3	3	2	1.7	0.5	3.3	1202.4	11.8	1.3	2.066667	1
2023-01-03	2023		1	3	4	2	1.6	0.9	2.8	1190.7	11.8	1.1	2.166667	1
2023-01-03	2023		1	3	5	2	1.6	1	1.9	1206.0	11.8	0.9	2.358333	1
2023-01-03	2023		1	3	6	2	1.6	1	1.5	1249.2	11.8	0.7	2.416667	1
2023-01-03	2023		1	3	7	2	1.5	1	1.1	1373.2	11.8	0.6	2.391667	1
2023-01-03	2023		1	3	8	2	1.5	1	0.7	1481.3	11.8	0.6	2.391667	1
2023-01-03	2023		1	3	9	2	1.5	1.3	0.5	1508.3	11.8	0.6	2.358333	1
2023-01-03	2023		1	3	10	2	1.5	1.7	0.2	1494.0	11.8	0.6	2.291667	1
2023-01-03	2023		1	3	11	2	1.5	3.5	0.1	1478.4	11.8	0.7	2.175	1
2023-01-03	2023		1	3	12	2	1.5	3.8	0	1485.0	11.8	1.0	1.983333	1
2023-01-03	2023		1	3	13	2	1.5	4.5	0.2	1499.7	11.8	1.3	1.716667	1
2023-01-03	2023		1	3	14	2	1.6	5	0.5	1484.9	11.8	1.7	1.541667	1
2023-01-03	2023		1	3	15	2	1.7	5.5	0.9	1463.8	11.8	2.1	1.266667	1
2023-01-03	2023		1	3	16	2	1.8	6.1	1	1470.1	11.8	2.5	1.066667	1
2023-01-03	2023		1	3	17	2	1.9	5.8	1	1527.3	11.8	3.0	0.866667	1
2023-01-03	2023		1	3	18	2	2.0	5.8	1	1584.1	11.8	3.4	0.716667	1
2023-01-03	2023		1	3	19	2	2.2	6.2	1	1536.4	11.8	3.8	0.641667	1
2023-01-03	2023		1	3	20	2	2.4	6.4	1.3	1503.3	11.8	4.2	0.6	1
2023-01-03	2023		1	3	21	2	2.6	6.6	1.7	1448.7	11.8	4.6	0.591667	1
2023-01-03	2023		1	3	22	2	2.9	6.5	3.5	1366.7	11.8	5.1	0.641667	1
2023-01-03	2023		1	3	23	2	3.1	5.9	3.8	1272.1	11.8	5.5	0.741667	1
2023-01-03	2023		1	3	24	2	3.3	5.7	4.5	1210.1	11.8	5.7	1.016667	1
2023-01-04	2023		1	4	1	3	3.6	5.7	5	1157.0	10.9	5.8	1.325	1
2023-01-04	2023		1	4	2	3	3.8	6.1	5.5	1119.4	10.9	5.9	1.7	1
2023-01-04	2023		1	4	3	3	4.1	6.2	6.1	1082.3	10.9	6.0	2.1	1
2023-01-04	2023		1	4	4	3	4.3	6.6	5.8	1068.0	10.9	6.1	2.516667	1
2023-01-04	2023		1	4	5	3	4.5	6.6	5.8	1076.0	10.9	6.1	2.95	1
2023-01-04	2023		1	4	6	3	4.8	6.4	6.2	1121.0	10.9	6.2	3.35	1
2023-01-04	2023		1	4	7	3	5.0	6.4	6.4	1223.4	10.9	6.2	3.75	1
2023-01-04	2023		1	4	8	3	5.2	6.2	6.6	1339.7	10.9	6.3	4.183333	1
2023-01-04	2023		1	4	9	3	5.4	6.2	6.5	1370.5	10.9	6.2	4.633333	1
2023-01-04	2023		1	4	10	3	5.6	6.1	5.9	1379.0	10.9	6.2	5.075	1
2023-01-04	2023		1	4	11	3	5.8	6.3	5.7	1370.9	10.9	6.2	5.475	1
2023-01-04	2023		1	4	12	3	5.9	6.6	5.7	1373.2	10.9	6.2	5.675	1
2023-01-04	2023		1	4	13	3	6.1	7	6.1	1377.4	10.9	6.3	5.833333	1
2023-01-04	2023		1	4	14	3	6.2	7.3	6.2	1365.1	10.9	6.4	5.933333	1
2023-01-04	2023		1	4	15	3	6.3	7.5	6.6	1352.6	10.9	6.5	6.025	1
2023-01-04	2023		1	4	16	3	6.3	7.7	6.6	1376.2	10.9	6.6	6.083333	1
2023-01-04	2023		1	4	17	3	6.4	7.8	6.4	1452.1	10.9	6.7	6.125	1
2023-01-04	2023		1	4	18	3	6.5	6.9	6.4	1527.3	10.9	6.8	6.191667	1
2023-01-04	2023		1	4	19	3	6.5	4.9	6.2	1497.8	10.9	6.8	6.241667	1
2023-01-04	2023		1	4	20	3	6.5	4.1	6.2	1470.3	10.9	6.7	6.258333	1
2023-01-04	2023		1	4	21	3	6.4	3.2	6.1	1429.6	10.9	6.5	6.241667	1
2023-01-04	2023		1	4	22	3	6.2	2.4	6.3	1379.0	10.9	6.3	6.208333	1
2023-01-04	2023		1	4	23	3	6.1	1.5	6.6	1314.0	10.9	6.0	6.175	1
2023-01-04	2023		1	4	24	3	5.9	1	7	1302.6	10.9	5.6	6.208333	1
2023-01-05	2023		1	5	1	4	5.7	1	7.3	1268.1	16.3	5.1	6.283333	1
2023-01-05	2023		1	5	2	4	5.5	0.6	7.5	1237.9	16.3	4.6	6.391667	1
2023-01-05	2023		1	5	3	4	5.3	0.3	7.7	1219.5	16.3	4.1	6.491667	1
2023-01-05	2023		1	5	4	4	5.0	0	7.8	1218.3	16.3	3.5	6.6	1
2023-01-05	2023		1	5	5	4	4.8	-0.3	6.9	1239.6	16.3	2.8	6.691667	1
2023-01-05	2023		1	5	6	4	4.5	-1	4.9	1291.8	16.3	2.1	6.791667	1
2023-01-05	2023		1	5	7	4	4.2	-1.5	4.1	1426.0	16.3	1.5	6.833333	1
2023-01-05	2023		1	5	8	4	3.8	-2	3.2	1562.8	16.3	0.9	6.708333	1
2023-01-05	2023		1	5	9	4	3.5	-1.8	2.4	1612.3	16.3	0.4	6.533333	1
2023-01-05	2023		1	5	10	4	3.2	-1.5	1.5	1630.4	16.3	0.0	6.283333	1
2023-01-05	2023		1	5	11	4	2.8	-1.4	1	1644.2	16.3	-0.3	5.975	1
2023-01-05	2023		1	5	12	4	2.5	-1.2	1	1655.4	16.3	-0.6	5.575	1
2023-01-05	2023		1	5	13	4	2.2	-1	0.6	1669.6	16.3	-0.7	5.108333	1
2023-01-05	2023		1	5	14	4	1.9	-1.1	0.3	1645.4	16.3	-0.9	4.608333	1
2023-01-05	2023		1	5	15	4	1.5	-1.2	0	1638.4	16.3	-1.0	4.05	1
2023-01-05	2023		1	5	16	4	1.1	-1	-0.3	1654.7	16.3	-1.2	3.45	1
2023-01-05	2023		1	5	17	4	0.8	-0.9	-1	1718.6	16.3	-1.3	2.808333	1
2023-01-05	2023		1	5	18	4	0.4	-1.4	-1.5	1777.4	16.3	-1.3	2.133333	1
2023-01-05	2023		1	5	19	4	0.1	-1.9	-2	1733.7	16.3	-1.3	1.475	1
2023-01-05	2023		1	5	20	4	-0.2	-1.9	-1.8	1701.7	16.3	-1.4	0.941667	1
2023-01-05	2023		1	5	21	4	-0.5	-1.6	-1.5	1628.3	16.3	-1.4	0.433333	1
2023-01-05	2023		1	5	22	4	-0.7	-1.5	-1.4	1545.8	16.3	-1.3	0.016667	1
2023-01-05	2023		1	5	23	4	-0.8	-1.5	-1.2	1460.8	16.3	-1.3	-0.30833	1
2023-01-05	2023		1	5	24	4	-1.0	-1.3	-1	1443.3	16.3	-1.4	-0.55	1
2023-01-06	2023		1	6	1	5	-1.0	-1.2	-1.1	1396.0	11.6	-1.4	-0.73333	1
2023-01-06	2023		1	6	2	5	-1.1	-1.1	-1.2	1350.1	11.6	-1.4	-0.9	1
2023-01-06	2023		1	6	3	5	-1.2	-0.8	-1	1313.9	11.6	-1.4	-1.04167	1
2023-01-06	2023		1	6	4	5	-1.3	-0.4	-0.9	1289.1	11.6	-1.3	-1.16667	1
2023-01-06	2023		1	6	5	5	-1.3	-0.1	-1.4	1285.2	11.6	-1.3	-1.25	1
2023-01-06	2023		1	6	6	5	-1.3	0.2	-1.9	1336.6	11.6	-1.2	-1.3	1
2023-01-06	2023		1	6	7	5	-1.2	-0.2	-1.9	1467.8	11.6	-1.1	-1.33333	1
2023-01-06	2023		1	6	8	5	-1.2	-0.6	-1.6	1564.0	11.6	-1.0	-1.36667	1
2023-01-06	2023		1	6	9	5	-1.1	-0.6	-1.5	1609.6	11.6	-0.8	-1.35833	1
2023-01-06	2023		1	6	10	5	-1.1	-0.6	-1.5	1619.6	11.6	-0.8	-1.34167	1
2023-01-06	2023		1	6	11	5	-1.0	-0.1	-1.3	1618.0	11.6	-0.7	-1.34167	1
2023-01-06	2023		1	6	12	5	-1.0	0.2	-1.2	1620.0	11.6	-0.6	-1.35	1
2023-01-06	2023		1	6	13	5	-0.9	0.5	-1.1	1614.8	11.6	-0.4	-1.35833	1
2023-01-06	2023		1	6	14	5	-0.8	0.7	-0.8	1592.8	11.6	-0.3	-1.375	1
2023-01-06	2023		1	6	15	5	-0.8	0.7	-0.4	1577.0	11.6	-0.2	-1.375	1
2023-01-06	2023		1	6	16	5	-0.7	0.8	-0.1	1591.9	11.6	0.0	-1.34167	1
2023-01-06	2023		1	6	17	5	-0.6	0.5	0.2	1639.3	11.6	0.1	-1.29167	1
2023-01-06	2023		1	6	18	5	-0.6	0.4	-0.2	1686.5	11.6	0.1	-1.225	1
2023-01-06	2023		1	6	19	5	-0.5	0.3	-0.6	1632.9	11.6	0.1	-1.09167	1
2023-01-06	2023		1	6	20	5	-0.4	0.4	-0.6	1586.1	11.6	0.2	-0.95	1
2023-01-06	2023		1	6	21	5	-0.3	0.4	-0.6	1537.9	11.6	0.3	-0.84167	1
2023-01-06	2023		1	6	22	5	-0.2	0.3	-0.1	1466.4	11.6	0.4	-0.75833	1
2023-01-06	2023		1	6	23	5	-0.1	0	0.2	1397.1	11.6	0.4		

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLa	g Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLa	g Weekdays	
2023-01-07	2023		1	7	12	6	-0.2	0.2	-0.2	1488.0	7.8	-0.9	0.433333	0
2023-01-07	2023		1	7	13	6	-0.2	1.7	-0.3	1456.5	7.8	-0.8	0.4	0
2023-01-07	2023		1	7	14	6	-0.2	1.7	-0.6	1415.0	7.8	-0.7	0.341667	0
2023-01-07	2023		1	7	15	6	-0.1	2.3	-0.9	1400.7	7.8	-0.5	0.258333	0
2023-01-07	2023		1	7	16	6	-0.1	2.3	-0.9	1424.9	7.8	-0.3	0.15	0
2023-01-07	2023		1	7	17	6	0.0	1.3	-1	1515.1	7.8	0.0	0.008333	0
2023-01-07	2023		1	7	18	6	0.0	0.9	-1.2	1611.3	7.8	0.2	-0.10833	0
2023-01-07	2023		1	7	19	6	0.1	0.7	-1.3	1573.5	7.8	0.4	-0.225	0
2023-01-07	2023		1	7	20	6	0.1	0.5	-1.6	1529.0	7.8	0.5	-0.35	0
2023-01-07	2023		1	7	21	6	0.1	0.8	-1.1	1483.9	7.8	0.7	-0.49167	0
2023-01-07	2023		1	7	22	6	0.1	1	-0.9	1422.6	7.8	0.9	-0.65833	0
2023-01-07	2023		1	7	23	6	0.1	1.1	0.2	1359.5	7.8	1.0	-0.775	0
2023-01-07	2023		1	7	24	6	0.2	1.5	1.7	1300.8	7.8	1.2	-0.85	0
2023-01-08	2023		1	8	1	7	0.3	1.5	1.7	1249.0	17.1	1.3	-0.81667	0
2023-01-08	2023		1	8	2	7	0.3	1.5	2.3	1228.5	17.1	1.3	-0.65833	0
2023-01-08	2023		1	8	3	7	0.4	1.7	2.3	1224.4	17.1	1.3	-0.49167	0
2023-01-08	2023		1	8	4	7	0.5	1.3	1.3	1239.6	17.1	1.2	-0.25	0
2023-01-08	2023		1	8	5	7	0.6	-0.9	0.9	1264.0	17.1	1.2	0.016667	0
2023-01-08	2023		1	8	6	7	0.6	-1.7	0.7	1309.3	17.1	1.0	0.2	0
2023-01-08	2023		1	8	7	7	0.6	-3.2	0.5	1371.7	17.1	0.8	0.358333	0
2023-01-08	2023		1	8	8	7	0.5	-5.2	0.8	1450.3	17.1	0.4	0.516667	0
2023-01-08	2023		1	8	9	7	0.3	-6.5	1	1557.2	17.1	-0.1	0.666667	0
2023-01-08	2023		1	8	10	7	0.1	-6.9	1.1	1651.4	17.1	-0.7	0.866667	0
2023-01-08	2023		1	8	11	7	-0.1	-6.9	1.5	1687.2	17.1	-1.3	1.041667	0
2023-01-08	2023		1	8	12	7	-0.4	-6.4	1.5	1707.5	17.1	-2.0	1.208333	0
2023-01-08	2023		1	8	13	7	-0.7	-6.3	1.5	1701.0	17.1	-2.6	1.316667	0
2023-01-08	2023		1	8	14	7	-1.0	-6.5	1.7	1660.9	17.1	-3.3	1.3	0
2023-01-08	2023		1	8	15	7	-1.3	-6.5	1.3	1631.9	17.1	-4.0	1.283333	0
2023-01-08	2023		1	8	16	7	-1.7	-5.5	-0.9	1645.1	17.1	-4.6	1.233333	0
2023-01-08	2023		1	8	17	7	-2.0	-5.8	-1.7	1757.7	17.1	-5.2	1.15	0
2023-01-08	2023		1	8	18	7	-2.3	-6.7	-3.2	1876.9	17.1	-5.6	0.966667	0
2023-01-08	2023		1	8	19	7	-2.6	-7	-5.2	1859.9	17.1	-6.0	0.75	0
2023-01-08	2023		1	8	20	7	-3.0	-6.3	-6.5	1847.5	17.1	-6.4	0.425	0
2023-01-08	2023		1	8	21	7	-3.2	-6.2	-6.9	1798.2	17.1	-6.4	-0.05	0
2023-01-08	2023		1	8	22	7	-3.5	-6.5	-6.9	1705.0	17.1	-6.4	-0.65833	0
2023-01-08	2023		1	8	23	7	-3.9	-6.1	-6.4	1608.9	17.1	-6.4	-1.31667	0
2023-01-08	2023		1	8	24	7	-4.2	-5.6	-6.3	1538.8	17.1	-6.3	-1.98333	0
2023-01-09	2023		1	9	1	1	-4.4	-5.1	-6.5	1488.8	11.9	-6.3	-2.64167	1
2023-01-09	2023		1	9	2	1	-4.7	-4.9	-6.5	1462.3	11.9	-6.2	-3.29167	1
2023-01-09	2023		1	9	3	1	-5.0	-3.4	-5.5	1441.0	11.9	-6.0	-3.95833	1
2023-01-09	2023		1	9	4	1	-5.2	-2.5	-5.8	1433.0	11.9	-5.8	-4.64167	1
2023-01-09	2023		1	9	5	1	-5.4	-1.6	-6.7	1436.6	11.9	-5.5	-5.20833	1
2023-01-09	2023		1	9	6	1	-5.4	-0.5	-7	1459.7	11.9	-5.2	-5.61667	1
2023-01-09	2023		1	9	7	1	-5.3	0.3	-6.3	1581.4	11.9	-4.6	-6.03333	1
2023-01-09	2023		1	9	8	1	-5.2	1.3	-6.2	1687.1	11.9	-4.0	-6.35	1
2023-01-09	2023		1	9	9	1	-4.9	1.2	-6.5	1705.4	11.9	-3.4	-6.44167	1
2023-01-09	2023		1	9	10	1	-4.6	2.5	-6.1	1650.2	11.9	-2.8	-6.41667	1
2023-01-09	2023		1	9	11	1	-4.2	3.9	-5.6	1590.3	11.9	-2.0	-6.38333	1
2023-01-09	2023		1	9	12	1	-3.8	3.7	-5.1	1558.9	11.9	-1.2	-6.31667	1
2023-01-09	2023		1	9	13	1	-3.3	4.5	-4.9	1566.6	11.9	-0.4	-6.25	1
2023-01-09	2023		1	9	14	1	-2.9	4.4	-3.4	1546.9	11.9	0.4	-6.15	1
2023-01-09	2023		1	9	15	1	-2.4	4.7	-2.5	1528.8	11.9	1.2	-6.01667	1
2023-01-09	2023		1	9	16	1	-2.0	4.5	-1.6	1551.9	11.9	1.8	-5.75833	1
2023-01-09	2023		1	9	17	1	-1.6	4.5	-0.5	1605.5	11.9	2.4	-5.50833	1
2023-01-09	2023		1	9	18	1	-1.1	4.2	0.3	1677.5	11.9	2.9	-5.15833	1
2023-01-09	2023		1	9	19	1	-0.7	3.9	1.3	1637.5	11.9	3.3	-4.64167	1
2023-01-09	2023		1	9	20	1	-0.2	3.7	1.2	1589.8	11.9	3.6	-4.03333	1
2023-01-09	2023		1	9	21	1	0.2	4.5	2.5	1538.6	11.9	3.8	-3.4	1
2023-01-09	2023		1	9	22	1	0.7	4.4	3.9	1465.3	11.9	4.1	-2.78333	1
2023-01-09	2023		1	9	23	1	1.1	4.2	3.7	1370.9	11.9	4.2	-2.03333	1
2023-01-09	2023		1	9	24	1	1.5	3.8	4.5	1327.6	11.9	4.3	-1.2	1
2023-01-10	2023		1	10	1	2	1.9	3.4	4.4	1286.0	13.9	4.3	-0.425	1
2023-01-10	2023		1	10	2	2	2.3	3.3	4.7	1253.3	13.9	4.2	0.375	1
2023-01-10	2023		1	10	3	2	2.6	3	4.5	1225.5	13.9	4.1	1.15	1
2023-01-10	2023		1	10	4	2	2.9	2.7	4.5	1212.4	13.9	4.0	1.825	1
2023-01-10	2023		1	10	5	2	3.1	2.4	4.2	1226.3	13.9	3.8	2.408333	1
2023-01-10	2023		1	10	6	2	3.3	2.2	3.9	1279.2	13.9	3.6	2.916667	1
2023-01-10	2023		1	10	7	2	3.4	2.3	3.7	1419.2	13.9	3.5	3.308333	1
2023-01-10	2023		1	10	8	2	3.5	2.1	4.5	1556.1	13.9	3.3	3.608333	1
2023-01-10	2023		1	10	9	2	3.5	0.6	4.4	1599.3	13.9	3.2	3.808333	1
2023-01-10	2023		1	10	10	2	3.5	0.4	4.2	1606.8	13.9	2.9	4.083333	1
2023-01-10	2023		1	10	11	2	3.4	0.4	3.8	1602.9	13.9	2.5	4.241667	1
2023-01-10	2023		1	10	12	2	3.2	-0.5	3.4	1603.2	13.9	2.2	4.266667	1
2023-01-10	2023		1	10	13	2	3.1	-0.8	3.3	1607.7	13.9	1.9	4.275	1
2023-01-10	2023		1	10	14	2	2.8	-0.9	3	1569.7	13.9	1.5	4.183333	1
2023-01-10	2023		1	10	15	2	2.6	-0.2	2.7	1553.7	13.9	1.2	4.091667	1
2023-01-10	2023		1	10	16	2	2.4	0.3	2.4	1576.4	13.9	0.9	3.95	1
2023-01-10	2023		1	10	17	2	2.2	-0.4	2.2	1656.8	13.9	0.7	3.8	1
2023-01-10	2023		1	10	18	2	2.0	-1.7	2.3	1741.0	13.9	0.5	3.625	1
2023-01-10	2023		1	10	19	2	1.8	-1.8	2.1	1723.7	13.9	0.1	3.458333	1
2023-01-10	2023		1	10	20	2	1.6	-2.6	0.6	1705.1	13.9	-0.2	3.325	1
2023-01-10	2023		1	10	21	2	1.3	-2.8	0.4	1667.1	13.9	-0.6	3.191667	1
2023-01-10	2023		1	10	22	2	1.0	-3.2	0.4	1594.2	13.9	-0.9	2.866667	1
2023-01-10	2023		1	10	23	2	0.7	-3.8	-0.5	1504.6	13.9	-1.2	2.533333	1
2023-01-10	2023		1	10	24	2	0.3	-4.5	-0.8	1480.4	13.9	-1.5	2.216667	1
2023-01-11	2023		1	11	1	3	0.0	-5	-0.9	1470.3	9.8	-1.9	1.858333	1
2023-01-11	2023		1	11	2	3	-0.4	-5.5	-0.2	1448.1	9.8	-2.2	1.508333	1
2023-01-11	2023		1	11	3	3	-0.7	-6.1	0.3	1429.6	9.8	-2.6	1.158333	1
2023-01-11	2023		1	11	4	3	-1.1	-6.5	-0.4	1427.2	9.8	-3.1	0.891667	1
2023-01-11	2023		1	11	5	3	-1.5	-6.7	-1.7	1445.3	9.8	-3.7	0.691667	1
2023-01-11	2023		1	11	6	3	-1.9	-7.5	-1.8	1511.5	9.8	-4.2	0.458333	1
2023-01-11	2023		1	11	7	3	-2.3	-7.5	-2.6	1659.5	9.8	-4.7	0.133333	1
2023-01-11	2023		1	11	8	3	-2.7	-7.8	-2.8	1782.4	9.8	-5.1	-0.20833	1
2023-01-11	2023		1	11	9	3	-3.1	-7.5	-3.2	1812.3	9.8	-5.6	-0.6	1
2023-01-11	2023		1	11	10	3	-3.4	-6	-3.8	1762.4	9.8	-6.0	-0.88333	1
2023-01-11	2023		1	11	11	3	-3.7							

DATE	Year	Month	Day	HOUR	DOW	24hrAvgLa	g Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLa	g Weekdays	
2023-01-11	2023		1	11	24	3	-5.4	-7.9	-3.6	1641.8	9.8	-4.5	-6.31667	1
2023-01-12	2023		1	12	1	4	-5.5	-9	-2.7	1620.7	5.4	-4.8	-6.3	1
2023-01-12	2023		1	12	2	4	-5.7	-8.3	-2.6	1604.2	5.4	-5.2	-6.18333	1
2023-01-12	2023		1	12	3	4	-5.8	-9.8	-2	1588.6	5.4	-5.7	-5.95	1
2023-01-12	2023		1	12	4	4	-6.0	-8.7	-2.8	1589.2	5.4	-6.3	-5.65833	1
2023-01-12	2023		1	12	5	4	-6.1	-8.8	-4.4	1601.0	5.4	-6.8	-5.28333	1
2023-01-12	2023		1	12	6	4	-6.1	-9	-5.4	1655.7	5.4	-7.3	-4.95833	1
2023-01-12	2023		1	12	7	4	-6.2	-8.9	-6.2	1789.5	5.4	-7.7	-4.7	1
2023-01-12	2023		1	12	8	4	-6.3	-9.3	-6.4	1902.4	5.4	-8.0	-4.525	1
2023-01-12	2023		1	12	9	4	-6.3	-8.9	-6.6	1904.6	5.4	-8.3	-4.39167	1
2023-01-12	2023		1	12	10	4	-6.4	-7	-6.4	1813.3	5.4	-8.5	-4.3	1
2023-01-12	2023		1	12	11	4	-6.4	-4.3	-7.9	1732.4	5.4	-8.5	-4.35	1
2023-01-12	2023		1	12	12	4	-6.4	-2.8	-9	1690.1	5.4	-8.3	-4.45	1
2023-01-12	2023		1	12	13	4	-6.3	-2.6	-8.3	1667.8	5.4	-7.9	-4.75	1
2023-01-12	2023		1	12	14	4	-6.3	-1.4	-9.8	1600.6	5.4	-7.4	-5.2	1
2023-01-12	2023		1	12	15	4	-6.2	-0.3	-8.7	1554.7	5.4	-6.8	-5.66667	1
2023-01-12	2023		1	12	16	4	-6.1	-1.6	-8.8	1569.0	5.4	-6.0	-6.26667	1
2023-01-12	2023		1	12	17	4	-6.1	-1.8	-9	1659.5	5.4	-5.4	-6.825	1
2023-01-12	2023		1	12	18	4	-6.1	-2.8	-8.9	1781.2	5.4	-4.8	-7.325	1
2023-01-12	2023		1	12	19	4	-6.0	-4.1	-9.3	1783.3	5.4	-4.3	-7.70833	1
2023-01-12	2023		1	12	20	4	-6.0	-4.2	-8.9	1771.9	5.4	-3.9	-8	1
2023-01-12	2023		1	12	21	4	-5.9	-4.8	-7	1733.6	5.4	-3.5	-8.25833	1
2023-01-12	2023		1	12	22	4	-5.8	-5	-4.3	1659.0	5.4	-3.1	-8.46667	1
2023-01-12	2023		1	12	23	4	-5.7	-3.4	-2.8	1573.4	5.4	-3.0	-8.5	1
2023-01-12	2023		1	12	24	4	-5.6	-1.9	-2.6	1538.5	5.4	-2.9	-8.325	1
2023-01-13	2023		1	13	1	5	-5.4	-0.8	-1.4	1498.4	26.5	-2.8	-7.9	1
2023-01-13	2023		1	13	2	5	-5.0	0.3	-0.3	1451.9	26.5	-2.7	-7.36667	1
2023-01-13	2023		1	13	3	5	-4.7	1.2	-1.6	1403.1	26.5	-2.5	-6.79167	1
2023-01-13	2023		1	13	4	5	-4.2	2	-1.8	1368.2	26.5	-2.4	-6	1
2023-01-13	2023		1	13	5	5	-3.8	2.5	-2.8	1361.2	26.5	-2.1	-5.40833	1
2023-01-13	2023		1	13	6	5	-3.3	2.8	-4.1	1394.9	26.5	-1.8	-4.825	1
2023-01-13	2023		1	13	7	5	-2.8	3.5	-4.2	1501.9	26.5	-1.3	-4.30833	1
2023-01-13	2023		1	13	8	5	-2.3	4	-4.8	1601.2	26.5	-0.7	-3.90833	1
2023-01-13	2023		1	13	9	5	-1.7	4.2	-5	1639.4	26.5	0.0	-3.48333	1
2023-01-13	2023		1	13	10	5	-1.2	4.2	-3.4	1636.0	26.5	0.8	-3.14167	1
2023-01-13	2023		1	13	11	5	-0.7	5.1	-1.9	1626.7	26.5	1.6	-2.975	1
2023-01-13	2023		1	13	12	5	-0.3	7.3	-0.8	1621.6	26.5	2.3	-2.9	1
2023-01-13	2023		1	13	13	5	0.1	7.9	0.3	1612.5	26.5	3.0	-2.825	1
2023-01-13	2023		1	13	14	5	0.5	8.4	1.2	1564.2	26.5	3.8	-2.675	1
2023-01-13	2023		1	13	15	5	0.9	8.9	2	1509.5	26.5	4.4	-2.53333	1
2023-01-13	2023		1	13	16	5	1.3	9	2.5	1482.9	26.5	5.1	-2.40833	1
2023-01-13	2023		1	13	17	5	1.8	9.6	2.8	1488.8	26.5	5.7	-2.10833	1
2023-01-13	2023		1	13	18	5	2.2	9.9	3.5	1510.2	26.5	6.2	-1.75	1
2023-01-13	2023		1	13	19	5	2.8	9.7	4	1453.0	26.5	6.8	-1.28333	1
2023-01-13	2023		1	13	20	5	3.4	10.1	4.2	1396.2	26.5	7.4	-0.65	1
2023-01-13	2023		1	13	21	5	3.9	10.4	4.2	1328.8	26.5	7.9	0.033333	1
2023-01-13	2023		1	13	22	5	4.6	10.9	5.1	1254.4	26.5	8.4	0.783333	1
2023-01-13	2023		1	13	23	5	5.2	11.1	7.3	1181.4	26.5	8.9	1.55	1
2023-01-13	2023		1	13	24	5	5.8	10.3	7.9	1132.7	26.5	9.4	2.258333	1
2023-01-14	2023		1	14	1	6	6.4	10.6	8.4	1078.2	18.8	9.7	3.025	0
2023-01-14	2023		1	14	2	6	6.8	10.2	8.9	1033.4	18.8	9.9	3.75	0
2023-01-14	2023		1	14	3	6	7.2	10	9	1003.4	18.8	10.1	4.425	0
2023-01-14	2023		1	14	4	6	7.6	9.6	9.6	988.2	18.8	10.2	5.066667	0
2023-01-14	2023		1	14	5	6	7.9	9	9.9	991.0	18.8	10.2	5.65	0
2023-01-14	2023		1	14	6	6	8.2	8.9	9.7	1027.4	18.8	10.2	6.241667	0
2023-01-14	2023		1	14	7	6	8.5	9	10.1	1078.6	18.8	10.1	6.833333	0
2023-01-14	2023		1	14	8	6	8.7	9	10.4	1153.4	18.8	10.0	7.35	0
2023-01-14	2023		1	14	9	6	8.9	9.2	10.9	1235.7	18.8	9.9	7.858333	0
2023-01-14	2023		1	14	10	6	9.1	9.4	11.1	1310.5	18.8	9.8	8.375	0
2023-01-14	2023		1	14	11	6	9.3	10.3	10.3	1363.8	18.8	9.7	8.933333	0
2023-01-14	2023		1	14	12	6	9.5	11	10.6	1402.0	18.8	9.6	9.433333	0
2023-01-14	2023		1	14	13	6	9.7	11.3	10.2	1415.0	18.8	9.7	9.683333	0
2023-01-14	2023		1	14	14	6	9.8	9.9	10	1414.5	18.8	9.7	9.908333	0
2023-01-14	2023		1	14	15	6	9.9	10.1	9.6	1414.1	18.8	9.7	10.05833	0
2023-01-14	2023		1	14	16	6	9.9	8.8	9	1435.4	18.8	9.7	10.15	0
2023-01-14	2023		1	14	17	6	9.9	4.6	8.9	1501.4	18.8	9.7	10.2	0
2023-01-14	2023		1	14	18	6	9.7	2.9	9	1542.0	18.8	9.3	10.15	0
2023-01-14	2023		1	14	19	6	9.4	2.2	9	1500.1	18.8	8.8	10.06667	0
2023-01-14	2023		1	14	20	6	9.1	2	9.2	1459.9	18.8	8.2	10.00833	0
2023-01-14	2023		1	14	21	6	8.8	1.7	9.4	1429.6	18.8	7.6	9.916667	0
2023-01-14	2023		1	14	22	6	8.4	1.3	10.3	1383.5	18.8	7.0	9.816667	0
2023-01-14	2023		1	14	23	6	8.0	0.9	11	1342.7	18.8	6.3	9.691667	0
2023-01-14	2023		1	14	24	6	7.6	0.5	11.3	1309.5	18.8	5.6	9.625	0
2023-01-15	2023		1	15	1	7	7.2	0.3	9.9	1277.5	23.6	4.7	9.683333	0
2023-01-15	2023		1	15	2	7	6.8	-0.1	10.1	1255.2	23.6	3.8	9.741667	0
2023-01-15	2023		1	15	3	7	6.3	-0.1	8.8	1247.3	23.6	2.9	9.716667	0
2023-01-15	2023		1	15	4	7	5.9	-0.1	4.6	1264.9	23.6	2.1	9.725	0
2023-01-15	2023		1	15	5	7	5.5	-0.2	2.9	1273.0	23.6	1.3	9.658333	0
2023-01-15	2023		1	15	6	7	5.1	-0.4	2.2	1299.2	23.6	0.9	9.291667	0
2023-01-15	2023		1	15	7	7	4.7	-0.3	2	1334.5	23.6	0.7	8.791667	0
2023-01-15	2023		1	15	8	7	4.3	-0.3	1.7	1410.9	23.6	0.5	8.225	0
2023-01-15	2023		1	15	9	7	4.0	-0.2	1.3	1501.0	23.6	0.3	7.641667	0
2023-01-15	2023		1	15	10	7	3.6	0	0.9	1587.9	23.6	0.1	7.016667	0
2023-01-15	2023		1	15	11	7	3.2	0.3	0.5	1651.3	23.6	0.0	6.341667	0
2023-01-15	2023		1	15	12	7	2.8	0.4	0.3	1693.6	23.6	-0.1	5.558333	0
2023-01-15	2023		1	15	13	7	2.3	0.5	-0.1	1703.6	23.6	-0.1	4.683333	0
2023-01-15	2023		1	15	14	7	1.9	0.6	-0.1	1690.7	23.6	0.0	3.766667	0
2023-01-15	2023		1	15	15	7	1.5	0.6	-0.1	1676.6	23.6	0.0	2.933333	0
2023-01-15	2023		1	15	16	7	1.1	0.9	-0.2	1686.6	23.6	0.1	2.083333	0
2023-01-15	2023		1	15	17	7	0.8	0.8	-0.4	1740.8	23.6	0.2	1.341667	0
2023-01-15	2023		1	15	18	7	0.6	1	-0.3	1775.1	23.6	0.2	0.941667	0
2023-01-15	2023		1	15	19	7	0.5	1.1	-0.3	1723.2	23.6	0.4	0.666667	0
2023-01-15	2023		1	15	20	7	0.5	1.2	-0.2	1668.0	23.6	0.5	0.458333	0
2023-01-15	2023		1	15	21	7	0.4	1.4	0	1603.3	23.6	0.6	0.266667	0
2023-01-15	2023		1	15	22	7	0.4	1.6	0.3	1524.6	23.6	0.7	0.108333	0
2023-01-15	2023		1	15										

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLag	Temp	LagTemp12	Load	Wind	12hrAvg	12hrAvgLag	Weekdays	
2023-01-16	2023		1	16	12	1	2.1	5.5	1.9	1555.3	12.5	3.2	0.966667	1
2023-01-16	2023		1	16	13	1	2.3	6.4	2.1	1563.4	12.5	3.5	1.066667	1
2023-01-16	2023		1	16	14	1	2.5	7.2	2.6	1542.6	12.5	3.9	1.183333	1
2023-01-16	2023		1	16	15	1	2.8	8.1	3	1522.0	12.5	4.3	1.308333	1
2023-01-16	2023		1	16	16	1	3.1	8.3	3.5	1526.1	12.5	4.8	1.475	1
2023-01-16	2023		1	16	17	1	3.4	7.7	3.8	1555.1	12.5	5.2	1.65	1
2023-01-16	2023		1	16	18	1	3.7	7.9	3.9	1596.7	12.5	5.6	1.875	1
2023-01-16	2023		1	16	19	1	4.0	8.2	3.6	1540.3	12.5	5.9	2.108333	1
2023-01-16	2023		1	16	20	1	4.3	8.2	3.7	1479.2	12.5	6.3	2.341667	1
2023-01-16	2023		1	16	21	1	4.6	7.9	3.9	1420.4	12.5	6.7	2.541667	1
2023-01-16	2023		1	16	22	1	4.9	7.9	4.7	1340.6	12.5	7.0	2.733333	1
2023-01-16	2023		1	16	23	1	5.1	7.8	5.5	1247.9	12.5	7.3	2.925	1
2023-01-16	2023		1	16	24	1	5.4	7.3	6.4	1208.5	12.5	7.6	3.191667	1
2023-01-17	2023		1	17	1	2	5.6	7.2	7.2	1160.3	9.2	7.7	3.516667	1
2023-01-17	2023		1	17	2	2	5.9	7	8.1	1114.2	9.2	7.8	3.891667	1
2023-01-17	2023		1	17	3	2	6.1	6.9	8.3	1079.2	9.2	7.8	4.316667	1
2023-01-17	2023		1	17	4	2	6.2	7.1	7.7	1072.0	9.2	7.7	4.775	1
2023-01-17	2023		1	17	5	2	6.4	7	7.9	1081.5	9.2	7.6	5.216667	1
2023-01-17	2023		1	17	6	2	6.6	6.9	8.2	1120.5	9.2	7.5	5.566667	1
2023-01-17	2023		1	17	7	2	6.7	6.6	8.2	1234.3	9.2	7.5	5.908333	1
2023-01-17	2023		1	17	8	2	6.8	6.5	7.9	1357.5	9.2	7.3	6.266667	1
2023-01-17	2023		1	17	9	2	6.9	6.1	7.9	1386.2	9.2	7.2	6.65	1
2023-01-17	2023		1	17	10	2	7.0	6	7.8	1385.1	9.2	7.0	7	1
2023-01-17	2023		1	17	11	2	7.1	5.7	7.3	1373.8	9.2	6.9	7.333333	1
2023-01-17	2023		1	17	12	2	7.1	5.1	7.2	1385.7	9.2	6.7	7.591667	1
2023-01-17	2023		1	17	13	2	7.1	4.8	7	1389.7	9.2	6.5	7.741667	1
2023-01-17	2023		1	17	14	2	7.1	4.7	6.9	1373.3	9.2	6.3	7.808333	1
2023-01-17	2023		1	17	15	2	7.0	5.1	7.1	1366.3	9.2	6.1	7.791667	1
2023-01-17	2023		1	17	16	2	6.8	5	7	1392.6	9.2	6.0	7.691667	1
2023-01-17	2023		1	17	17	2	6.7	5	6.9	1460.9	9.2	5.8	7.591667	1
2023-01-17	2023		1	17	18	2	6.6	4.7	6.6	1538.5	9.2	5.6	7.533333	1
2023-01-17	2023		1	17	19	2	6.4	4.4	6.5	1509.0	9.2	5.4	7.45	1
2023-01-17	2023		1	17	20	2	6.3	3.7	6.1	1483.9	9.2	5.3	7.316667	1
2023-01-17	2023		1	17	21	2	6.1	3.1	6	1440.8	9.2	5.0	7.175	1
2023-01-17	2023		1	17	22	2	5.9	2.8	5.7	1385.0	9.2	4.8	7.025	1
2023-01-17	2023		1	17	23	2	5.7	2.5	5.1	1309.9	9.2	4.5	6.866667	1
2023-01-17	2023		1	17	24	2	5.5	2.5	4.8	1278.3	9.2	4.2	6.691667	1
2023-01-18	2023		1	18	1	3	5.3	2.2	4.7	1248.1	8.6	4.0	6.508333	1
2023-01-18	2023		1	18	2	3	5.1	2.1	5.1	1213.4	8.6	3.8	6.308333	1
2023-01-18	2023		1	18	3	3	4.9	1.8	5	1179.0	8.6	3.6	6.116667	1
2023-01-18	2023		1	18	4	3	4.6	1.6	5	1167.3	8.6	3.3	5.966667	1
2023-01-18	2023		1	18	5	3	4.4	1.8	4.7	1176.9	8.6	3.0	5.791667	1
2023-01-18	2023		1	18	6	3	4.2	1.7	4.4	1233.4	8.6	2.8	5.625	1
2023-01-18	2023		1	18	7	3	4.0	1.5	3.7	1349.4	8.6	2.5	5.441667	1
2023-01-18	2023		1	18	8	3	3.8	1.7	3.1	1471.9	8.6	2.3	5.258333	1
2023-01-18	2023		1	18	9	3	3.6	1.7	2.8	1491.3	8.6	2.1	5.025	1
2023-01-18	2023		1	18	10	3	3.4	2.9	2.5	1471.1	8.6	2.0	4.775	1
2023-01-18	2023		1	18	11	3	3.3	3.9	2.5	1448.7	8.6	2.0	4.508333	1
2023-01-18	2023		1	18	12	3	3.2	5	2.2	1429.8	8.6	2.1	4.241667	1
2023-01-18	2023		1	18	13	3	3.2	6.4	2.1	1413.1	8.6	2.3	4.025	1
2023-01-18	2023		1	18	14	3	3.2	6.9	1.8	1373.2	8.6	2.7	3.808333	1
2023-01-18	2023		1	18	15	3	3.3	7.7	1.6	1341.4	8.6	3.1	3.591667	1
2023-01-18	2023		1	18	16	3	3.4	8.2	1.8	1358.8	8.6	3.6	3.316667	1
2023-01-18	2023		1	18	17	3	3.6	8.1	1.7	1410.3	8.6	4.1	3.033333	1
2023-01-18	2023		1	18	18	3	3.7	6.5	1.5	1499.8	8.6	4.6	2.766667	1
2023-01-18	2023		1	18	19	3	3.8	4.7	1.7	1496.3	8.6	5.0	2.516667	1
2023-01-18	2023		1	18	20	3	3.8	4.1	1.7	1477.2	8.6	5.3	2.275	1
2023-01-18	2023		1	18	21	3	3.8	3.8	2.9	1447.7	8.6	5.5	2.108333	1
2023-01-18	2023		1	18	22	3	3.8	3.1	3.9	1395.6	8.6	5.7	1.991667	1
2023-01-18	2023		1	18	23	3	3.9	3	5	1331.6	8.6	5.7	2	1
2023-01-18	2023		1	18	24	3	3.9	1.8	6.4	1305.3	8.6	5.6	2.116667	1
2023-01-19	2023		1	19	1	4	3.8	1.3	6.9	1273.4	14.3	5.4	2.325	1
2023-01-19	2023		1	19	2	4	3.8	1	7.7	1247.8	14.3	4.9	2.675	1
2023-01-19	2023		1	19	3	4	3.8	0.9	8.2	1214.8	14.3	4.4	3.075	1
2023-01-19	2023		1	19	4	4	3.7	1	8.1	1207.0	14.3	3.9	3.566667	1
2023-01-19	2023		1	19	5	4	3.7	1	6.5	1221.3	14.3	3.3	4.116667	1
2023-01-19	2023		1	19	6	4	3.7	1.2	4.7	1272.3	14.3	2.7	4.641667	1
2023-01-19	2023		1	19	7	4	3.6	1.2	4.1	1392.2	14.3	2.2	5.041667	1
2023-01-19	2023		1	19	8	4	3.6	1.3	3.8	1507.6	14.3	2.0	5.308333	1
2023-01-19	2023		1	19	9	4	3.6	1.5	3.1	1548.1	14.3	1.7	5.508333	1
2023-01-19	2023		1	19	10	4	3.6	1.5	3	1535.0	14.3	1.5	5.683333	1
2023-01-19	2023		1	19	11	4	3.5	2	1.8	1529.7	14.3	1.4	5.7	1
2023-01-19	2023		1	19	12	4	3.5	2.5	1.3	1521.2	14.3	1.3	5.625	1
2023-01-19	2023		1	19	13	4	3.4	2.1	1	1522.2	14.3	1.4	5.358333	1
2023-01-19	2023		1	19	14	4	3.2	1.9	0.9	1505.5	14.3	1.4	4.933333	1
2023-01-19	2023		1	19	15	4	3.0	1.9	1	1500.4	14.3	1.5	4.441667	1
2023-01-19	2023		1	19	16	4	2.7	2	1	1527.5	14.3	1.6	3.875	1
2023-01-19	2023		1	19	17	4	2.5	1.8	1.2	1588.9	14.3	1.7	3.275	1
2023-01-19	2023		1	19	18	4	2.2	1	1.2	1654.0	14.3	1.7	2.683333	1
2023-01-19	2023		1	19	19	4	2.0	0.9	1.3	1629.4	14.3	1.7	2.241667	1
2023-01-19	2023		1	19	20	4	1.8	0.9	1.5	1599.6	14.3	1.7	1.95	1
2023-01-19	2023		1	19	21	4	1.7	0.9	1.5	1567.7	14.3	1.7	1.716667	1
2023-01-19	2023		1	19	22	4	1.6	0.8	2	1502.0	14.3	1.6	1.525	1
2023-01-19	2023		1	19	23	4	1.5	0.8	2.5	1415.5	14.3	1.6	1.391667	1
2023-01-19	2023		1	19	24	4	1.4	0.3	2.1	1382.2	14.3	1.5	1.308333	1
2023-01-20	2023		1	20	1	5	1.3	-0.2	1.9	1343.1	15.9	1.3	1.366667	1
2023-01-20	2023		1	20	2	5	1.3	-0.6	1.9	1314.8	15.9	1.1	1.433333	1
2023-01-20	2023		1	20	3	5	1.2	-0.9	2	1284.3	15.9	0.9	1.508333	1
2023-01-20	2023		1	20	4	5	1.1	-0.8	1.8	1269.8	15.9	0.6	1.591667	1
2023-01-20	2023		1	20	5	5	1.0	-0.9	1	1281.6	15.9	0.4	1.675	1
2023-01-20	2023		1	20	6	5	1.0	-0.9	0.9	1328.3	15.9	0.2	1.741667	1
2023-01-20	2023		1	20	7	5	0.9	-0.9	0.9	1435.2	15.9	0.0	1.725	1
2023-01-20	2023		1	20	8	5	0.8	-0.6	0.9	1537.5	15.9	-0.1	1.7	1
2023-01-20	2023		1	20	9	5	0.7	-0.6	0.8	1602.8	15.9	-0.3	1.666667	1
2023-01-20	2023		1	20	10	5	0.6	-1.2	0.8	1629.6	15.9	-0.4	1.616667	1
2023-01-20	2023</													

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLag	Temp	LagTemp12	Load	Wind	12hrAvg	12hrAvgLag	Weekdays	
2023-01-20	2023		1	20	24	5	-0.5	-0.4	-0.7	1426.3	15.9	-0.3	-0.7	1
2023-01-21	2023		1	21	1	6	-0.5	-0.5	-0.6	1395.2	19.8	-0.3	-0.79167	0
2023-01-21	2023		1	21	2	6	-0.5	-0.5	-0.3	1353.2	19.8	-0.3	-0.83333	0
2023-01-21	2023		1	21	3	6	-0.5	-0.6	-0.4	1312.9	19.8	-0.2	-0.83333	0
2023-01-21	2023		1	21	4	6	-0.5	-0.7	-0.2	1294.6	19.8	-0.3	-0.78333	0
2023-01-21	2023		1	21	5	6	-0.5	-0.8	-0.1	1298.9	19.8	-0.3	-0.75	0
2023-01-21	2023		1	21	6	6	-0.5	-0.9	0	1325.5	19.8	-0.3	-0.69167	0
2023-01-21	2023		1	21	7	6	-0.5	-0.7	0	1382.0	19.8	-0.4	-0.625	0
2023-01-21	2023		1	21	8	6	-0.5	-0.9	0	1449.9	19.8	-0.5	-0.55	0
2023-01-21	2023		1	21	9	6	-0.5	-0.9	-0.2	1521.5	19.8	-0.5	-0.5	0
2023-01-21	2023		1	21	10	6	-0.5	-0.5	-0.3	1571.4	19.8	-0.6	-0.45	0
2023-01-21	2023		1	21	11	6	-0.5	-0.2	-0.4	1592.1	19.8	-0.6	-0.36667	0
2023-01-21	2023		1	21	12	6	-0.5	0	-0.5	1603.1	19.8	-0.6	-0.3	0
2023-01-21	2023		1	21	13	6	-0.4	-0.2	-0.5	1592.5	19.8	-0.6	-0.26667	0
2023-01-21	2023		1	21	14	6	-0.4	-0.5	-0.6	1559.0	19.8	-0.6	-0.25	0
2023-01-21	2023		1	21	15	6	-0.4	-0.2	-0.7	1559.5	19.8	-0.6	-0.24167	0
2023-01-21	2023		1	21	16	6	-0.4	-0.9	-0.8	1593.0	19.8	-0.5	-0.26667	0
2023-01-21	2023		1	21	17	6	-0.4	-1.7	-0.9	1663.7	19.8	-0.6	-0.29167	0
2023-01-21	2023		1	21	18	6	-0.5	-2.5	-0.7	1737.8	19.8	-0.6	-0.34167	0
2023-01-21	2023		1	21	19	6	-0.6	-2.9	-0.9	1711.8	19.8	-0.8	-0.40833	0
2023-01-21	2023		1	21	20	6	-0.7	-3.3	-0.9	1664.3	19.8	-1.0	-0.46667	0
2023-01-21	2023		1	21	21	6	-0.8	-4	-0.5	1626.1	19.8	-1.2	-0.54167	0
2023-01-21	2023		1	21	22	6	-1.0	-4.9	-0.2	1588.3	19.8	-1.4	-0.61667	0
2023-01-21	2023		1	21	23	6	-1.2	-5.3	0	1532.4	19.8	-1.8	-0.64167	0
2023-01-21	2023		1	21	24	6	-1.4	-5.9	-0.2	1482.8	19.8	-2.2	-0.63333	0
2023-01-22	2023		1	22	1	7	-1.6	-6	-0.5	1436.4	9.5	-2.7	-0.6	0
2023-01-22	2023		1	22	2	7	-1.9	-6.3	-0.2	1410.0	9.5	-3.2	-0.575	0
2023-01-22	2023		1	22	3	7	-2.1	-6.1	-0.9	1403.4	9.5	-3.7	-0.575	0
2023-01-22	2023		1	22	4	7	-2.3	-6.2	-1.7	1405.2	9.5	-4.2	-0.54167	0
2023-01-22	2023		1	22	5	7	-2.6	-5.6	-2.5	1419.9	9.5	-4.6	-0.55833	0
2023-01-22	2023		1	22	6	7	-2.8	-6.1	-2.9	1451.4	9.5	-4.9	-0.63333	0
2023-01-22	2023		1	22	7	7	-3.0	-6.1	-3.3	1499.1	9.5	-5.2	-0.76667	0
2023-01-22	2023		1	22	8	7	-3.2	-5.7	-4	1562.4	9.5	-5.5	-0.95	0
2023-01-22	2023		1	22	9	7	-3.4	-6.5	-4.9	1632.9	9.5	-5.7	-1.15	0
2023-01-22	2023		1	22	10	7	-3.7	-4.3	-5.3	1639.1	9.5	-5.9	-1.40833	0
2023-01-22	2023		1	22	11	7	-3.8	-2.6	-5.9	1607.7	9.5	-5.8	-1.775	0
2023-01-22	2023		1	22	12	7	-3.9	-1.5	-6	1559.8	9.5	-5.6	-2.2	0
2023-01-22	2023		1	22	13	7	-4.0	-0.3	-6.3	1511.9	9.5	-5.3	-2.69167	0
2023-01-22	2023		1	22	14	7	-4.0	0.8	-6.1	1465.9	9.5	-4.8	-3.175	0
2023-01-22	2023		1	22	15	7	-3.9	1.3	-6.2	1442.9	9.5	-4.2	-3.65833	0
2023-01-22	2023		1	22	16	7	-3.9	1.3	-5.6	1470.6	9.5	-3.6	-4.15	0
2023-01-22	2023		1	22	17	7	-3.8	-0.1	-6.1	1562.9	9.5	-2.9	-4.59167	0
2023-01-22	2023		1	22	18	7	-3.7	-0.2	-6.1	1657.7	9.5	-2.5	-4.91667	0
2023-01-22	2023		1	22	19	7	-3.6	-0.3	-5.7	1650.8	9.5	-2.0	-5.21667	0
2023-01-22	2023		1	22	20	7	-3.5	-0.4	-6.5	1627.2	9.5	-1.5	-5.48333	0
2023-01-22	2023		1	22	21	7	-3.4	-0.3	-4.3	1582.0	9.5	-1.1	-5.68333	0
2023-01-22	2023		1	22	22	7	-3.2	-0.5	-2.6	1516.1	9.5	-0.6	-5.89167	0
2023-01-22	2023		1	22	23	7	-3.0	0.5	-1.5	1412.9	9.5	-0.2	-5.84167	0
2023-01-22	2023		1	22	24	7	-2.8	1.7	-0.3	1331.9	9.5	0.0	-5.61667	0
2023-01-23	2023		1	23	1	1	-2.5	2.5	0.8	1272.0	12.3	0.3	-5.25	1
2023-01-23	2023		1	23	2	1	-2.1	2.7	1.3	1239.0	12.3	0.5	-4.775	1
2023-01-23	2023		1	23	3	1	-1.8	2.1	1.3	1233.8	12.3	0.7	-4.18333	1
2023-01-23	2023		1	23	4	1	-1.4	1.9	-0.1	1235.3	12.3	0.8	-3.56667	1
2023-01-23	2023		1	23	5	1	-1.1	1.2	-0.2	1244.1	12.3	0.8	-2.94167	1
2023-01-23	2023		1	23	6	1	-0.8	2.1	-0.3	1287.9	12.3	0.9	-2.48333	1
2023-01-23	2023		1	23	7	1	-0.4	2.9	-0.4	1404.5	12.3	1.1	-1.99167	1
2023-01-23	2023		1	23	8	1	-0.1	4.4	-0.3	1495.5	12.3	1.4	-1.50833	1
2023-01-23	2023		1	23	9	1	0.4	4.8	-0.5	1530.4	12.3	1.8	-1.06667	1
2023-01-23	2023		1	23	10	1	0.8	5.6	0.5	1545.3	12.3	2.2	-0.55	1
2023-01-23	2023		1	23	11	1	1.2	6.5	1.7	1564.3	12.3	2.7	-0.23333	1
2023-01-23	2023		1	23	12	1	1.6	7	2.5	1586.3	12.3	3.2	0.025	1
2023-01-23	2023		1	23	13	1	2.0	7.4	2.7	1601.6	12.3	3.6	0.291667	1
2023-01-23	2023		1	23	14	1	2.3	7.8	2.1	1567.8	12.3	4.1	0.525	1
2023-01-23	2023		1	23	15	1	2.6	8.3	1.9	1510.0	12.3	4.5	0.683333	1
2023-01-23	2023		1	23	16	1	2.9	9.4	1.2	1493.0	12.3	5.0	0.75	1
2023-01-23	2023		1	23	17	1	3.2	9.4	2.1	1536.6	12.3	5.6	0.8	1
2023-01-23	2023		1	23	18	1	3.6	8.9	2.9	1596.8	12.3	6.3	0.908333	1
2023-01-23	2023		1	23	19	1	4.0	6.1	4.4	1561.7	12.3	6.9	1.1	1
2023-01-23	2023		1	23	20	1	4.3	4.7	4.8	1512.2	12.3	7.1	1.366667	1
2023-01-23	2023		1	23	21	1	4.5	3.7	5.6	1465.4	12.3	7.2	1.766667	1
2023-01-23	2023		1	23	22	1	4.6	2.8	6.5	1404.7	12.3	7.1	2.191667	1
2023-01-23	2023		1	23	23	1	4.8	2.2	7	1340.1	12.3	6.8	2.7	1
2023-01-23	2023		1	23	24	1	4.8	1.6	7.4	1318.0	12.3	6.5	3.2	1
2023-01-24	2023		1	24	1	2	4.8	1.3	7.8	1306.0	19.5	6.0	3.641667	1
2023-01-24	2023		1	24	2	2	4.8	0.5	8.3	1301.3	19.5	5.5	4.05	1
2023-01-24	2023		1	24	3	2	4.7	0.1	9.4	1273.9	19.5	4.9	4.475	1
2023-01-24	2023		1	24	4	2	4.6	-0.3	9.4	1270.9	19.5	4.2	4.991667	1
2023-01-24	2023		1	24	5	2	4.5	-1.2	8.9	1308.2	19.5	3.4	5.616667	1
2023-01-24	2023		1	24	6	2	4.4	-1.6	6.1	1373.0	19.5	2.5	6.3	1
2023-01-24	2023		1	24	7	2	4.3	-1.3	4.7	1483.0	19.5	1.7	6.866667	1
2023-01-24	2023		1	24	8	2	4.1	-1.3	3.7	1590.6	19.5	1.0	7.133333	1
2023-01-24	2023		1	24	9	2	3.9	-1.6	2.8	1625.5	19.5	0.5	7.158333	1
2023-01-24	2023		1	24	10	2	3.6	-1.9	2.2	1615.6	19.5	0.1	7.066667	1
2023-01-24	2023		1	24	11	2	3.3	-1	1.6	1597.0	19.5	-0.3	6.833333	1
2023-01-24	2023		1	24	12	2	3.0	-1.2	1.3	1587.8	19.5	-0.6	6.475	1
2023-01-24	2023		1	24	13	2	2.6	-0.8	0.5	1598.6	19.5	-0.8	6.025	1
2023-01-24	2023		1	24	14	2	2.3	-0.8	0.1	1581.3	19.5	-1.0	5.516667	1
2023-01-24	2023		1	24	15	2	1.9	-0.3	-0.3	1574.9	19.5	-1.1	4.908333	1
2023-01-24	2023		1	24	16	2	1.6	-0.1	-1.2	1585.4	19.5	-1.1	4.225	1
2023-01-24	2023		1	24	17	2	1.2	0	-1.6	1640.9	19.5	-1.1	3.416667	1
2023-01-24	2023		1	24	18	2	0.8	0.4	-1.3	1719.8	19.5	-1.0	2.533333	1
2023-01-24	2023		1	24	19	2	0.4	0.6	-1.3	1700.0	19.5	-0.8	1.658333	1
2023-01-24	2023		1	24	20	2	0.2	0.2	-1.6	1660.0	19.5	-0.7	1.041667	1
2023-01-24	2023		1	24	21	2	0.0	0.9	-1.9	1615.4	19.5	-0.5	0.541667	1
2023-01-24	2023		1	24	22	2	-0.1	1.2	-1	1533.2	19.5	-0.3	0.1	1
2023-01-24	2023		1	24	23									

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLa	gTemp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLa	gWeekdays	
2023-01-25	2023		1	25	12	3	-0.3	-1.9	1.1	1568.4	10.5	-0.8	0.1	1
2023-01-25	2023		1	25	13	3	-0.4	-1.4	0.6	1557.2	10.5	-1.0	0.316667	1
2023-01-25	2023		1	25	14	3	-0.4	-1.4	0	1525.6	10.5	-1.3	0.475	1
2023-01-25	2023		1	25	15	3	-0.4	-0.7	-0.2	1511.5	10.5	-1.4	0.591667	1
2023-01-25	2023		1	25	16	3	-0.4	-1.1	-0.5	1561.8	10.5	-1.5	0.616667	1
2023-01-25	2023		1	25	17	3	-0.5	-1.9	-0.4	1647.4	10.5	-1.6	0.608333	1
2023-01-25	2023		1	25	18	3	-0.6	-2.3	-0.7	1756.4	10.5	-1.7	0.566667	1
2023-01-25	2023		1	25	19	3	-0.7	-2.8	-2.1	1760.7	10.5	-1.8	0.5	1
2023-01-25	2023		1	25	20	3	-0.8	-3	-3.2	1730.1	10.5	-2.0	0.391667	1
2023-01-25	2023		1	25	21	3	-0.9	-3.6	-2.7	1690.2	10.5	-2.1	0.2	1
2023-01-25	2023		1	25	22	3	-1.1	-3.7	-2.5	1617.2	10.5	-2.1	-0.14167	1
2023-01-25	2023		1	25	23	3	-1.3	-3.8	-1.9	1531.1	10.5	-2.2	-0.46667	1
2023-01-25	2023		1	25	24	3	-1.5	-3.8	-1.4	1487.2	10.5	-2.3	-0.76667	1
2023-01-26	2023		1	26	1	4	-1.8	-2.6	-1.4	1447.3	30.7	-2.5	-1.04167	1
2023-01-26	2023		1	26	2	4	-1.9	-0.2	-0.7	1405.8	30.7	-2.6	-1.25	1
2023-01-26	2023		1	26	3	4	-1.9	0.5	-1.1	1366.8	30.7	-2.5	-1.41667	1
2023-01-26	2023		1	26	4	4	-1.9	2	-1.9	1342.8	30.7	-2.4	-1.475	1
2023-01-26	2023		1	26	5	4	-1.8	3	-2.3	1343.5	30.7	-2.1	-1.55	1
2023-01-26	2023		1	26	6	4	-1.7	3.7	-2.8	1376.6	30.7	-1.7	-1.66667	1
2023-01-26	2023		1	26	7	4	-1.5	4.4	-3	1476.1	30.7	-1.2	-1.825	1
2023-01-26	2023		1	26	8	4	-1.3	5.3	-3.6	1581.7	30.7	-0.6	-2	1
2023-01-26	2023		1	26	9	4	-1.0	6	-3.7	1616.4	30.7	0.1	-2.075	1
2023-01-26	2023		1	26	10	4	-0.6	6.4	-3.8	1616.0	30.7	0.9	-2.10833	1
2023-01-26	2023		1	26	11	4	-0.2	7	-3.8	1608.6	30.7	1.7	-2.19167	1
2023-01-26	2023		1	26	12	4	0.2	7.9	-2.6	1611.8	30.7	2.6	-2.3	1
2023-01-26	2023		1	26	13	4	0.6	8.2	-0.2	1610.4	30.7	3.6	-2.45833	1
2023-01-26	2023		1	26	14	4	1.0	9	0.5	1560.4	30.7	4.5	-2.55833	1
2023-01-26	2023		1	26	15	4	1.4	10.1	2	1457.1	30.7	5.3	-2.45833	1
2023-01-26	2023		1	26	16	4	1.9	11.1	3	1422.7	30.7	6.1	-2.35833	1
2023-01-26	2023		1	26	17	4	2.4	10.7	3.7	1439.7	30.7	6.8	-2.1	1
2023-01-26	2023		1	26	18	4	2.9	10.7	4.4	1485.7	30.7	7.5	-1.69167	1
2023-01-26	2023		1	26	19	4	3.4	9.4	5.3	1462.6	30.7	8.1	-1.19167	1
2023-01-26	2023		1	26	20	4	3.9	8	6	1416.0	30.7	8.5	-0.59167	1
2023-01-26	2023		1	26	21	4	4.4	7.4	6.4	1391.2	30.7	8.7	0.1	1
2023-01-26	2023		1	26	22	4	4.9	6.8	7	1331.7	30.7	8.8	0.9	1
2023-01-26	2023		1	26	23	4	5.3	6.3	7.9	1257.9	30.7	8.9	1.741667	1
2023-01-26	2023		1	26	24	4	5.7	6.1	8.2	1219.7	30.7	8.8	2.641667	1
2023-01-27	2023		1	27	1	5	6.1	5.4	9	1192.2	14.8	8.7	3.616667	1
2023-01-27	2023		1	27	2	5	6.5	5.2	10.1	1161.6	14.8	8.4	4.516667	1
2023-01-27	2023		1	27	3	5	6.7	5.1	11.1	1139.4	14.8	8.1	5.283333	1
2023-01-27	2023		1	27	4	5	6.9	4.7	10.7	1143.7	14.8	7.7	6.083333	1
2023-01-27	2023		1	27	5	5	7.0	3.5	10.7	1182.1	14.8	7.2	6.841667	1
2023-01-27	2023		1	27	6	5	7.0	2.5	9.4	1246.4	14.8	6.6	7.483333	1
2023-01-27	2023		1	27	7	5	7.0	1.7	8	1374.1	14.8	5.9	8.066667	1
2023-01-27	2023		1	27	8	5	6.9	0.7	7.4	1501.9	14.8	5.2	8.483333	1
2023-01-27	2023		1	27	9	5	6.7	0	6.8	1560.5	14.8	4.6	8.708333	1
2023-01-27	2023		1	27	10	5	6.4	0	6.3	1579.1	14.8	4.0	8.825	1
2023-01-27	2023		1	27	11	5	6.1	0.4	6.1	1555.9	14.8	3.4	8.858333	1
2023-01-27	2023		1	27	12	5	5.9	0.9	5.4	1499.4	14.8	2.9	8.8	1
2023-01-27	2023		1	27	13	5	5.6	1	5.2	1468.2	14.8	2.5	8.65	1
2023-01-27	2023		1	27	14	5	5.3	1.4	5.1	1427.3	14.8	2.1	8.416667	1
2023-01-27	2023		1	27	15	5	5.0	1.9	4.7	1401.3	14.8	1.8	8.1	1
2023-01-27	2023		1	27	16	5	4.6	2.2	3.5	1410.5	14.8	1.6	7.683333	1
2023-01-27	2023		1	27	17	5	4.3	2.2	2.5	1472.2	14.8	1.4	7.15	1
2023-01-27	2023		1	27	18	5	3.9	1.4	1.7	1591.6	14.8	1.2	6.55	1
2023-01-27	2023		1	27	19	5	3.5	0.3	0.7	1620.0	14.8	1.2	5.866667	1
2023-01-27	2023		1	27	20	5	3.1	-0.5	0	1602.4	14.8	1.0	5.225	1
2023-01-27	2023		1	27	21	5	2.8	-1.4	0	1576.2	14.8	0.9	4.616667	1
2023-01-27	2023		1	27	22	5	2.4	-2	0.4	1536.0	14.8	0.8	4	1
2023-01-27	2023		1	27	23	5	2.0	-2.5	0.9	1490.4	14.8	0.7	3.433333	1
2023-01-27	2023		1	27	24	5	1.7	-2.7	1	1490.0	14.8	0.4	2.941667	1
2023-01-28	2023		1	28	1	6	1.3	-4.2	1.4	1475.4	12.0	0.1	2.508333	0
2023-01-28	2023		1	28	2	6	0.9	-4.4	1.9	1451.1	12.0	-0.3	2.141667	0
2023-01-28	2023		1	28	3	6	0.5	-3	2.2	1423.4	12.0	-0.8	1.825	0
2023-01-28	2023		1	28	4	6	0.2	-3.6	2.2	1415.4	12.0	-1.2	1.558333	0
2023-01-28	2023		1	28	5	6	-0.2	-3.9	1.4	1420.3	12.0	-1.7	1.35	0
2023-01-28	2023		1	28	6	6	-0.5	-4.1	0.3	1448.4	12.0	-2.2	1.241667	0
2023-01-28	2023		1	28	7	6	-0.8	-4.4	-0.5	1502.9	12.0	-2.7	1.15	0
2023-01-28	2023		1	28	8	6	-1.0	-4.4	-1.4	1578.6	12.0	-3.1	1.033333	0
2023-01-28	2023		1	28	9	6	-1.2	-3.9	-2	1633.0	12.0	-3.4	0.933333	0
2023-01-28	2023		1	28	10	6	-1.4	-2.2	-2.5	1608.6	12.0	-3.6	0.816667	0
2023-01-28	2023		1	28	11	6	-1.5	-0.6	-2.7	1545.3	12.0	-3.6	0.65	0
2023-01-28	2023		1	28	12	6	-1.5	3.3	-4.2	1502.5	12.0	-3.5	0.408333	0
2023-01-28	2023		1	28	13	6	-1.4	4.1	-4.4	1484.5	12.0	-3.0	0.108333	0
2023-01-28	2023		1	28	14	6	-1.3	3	-3	1455.7	12.0	-2.3	-0.325	0
2023-01-28	2023		1	28	15	6	-1.2	3.7	-3.6	1444.3	12.0	-1.6	-0.80833	0
2023-01-28	2023		1	28	16	6	-1.2	4	-3.9	1460.8	12.0	-1.1	-1.21667	0
2023-01-28	2023		1	28	17	6	-1.1	3.4	-4.1	1517.8	12.0	-0.5	-1.7	0
2023-01-28	2023		1	28	18	6	-1.0	3.4	-4.4	1577.2	12.0	0.2	-2.20833	0
2023-01-28	2023		1	28	19	6	-0.9	3.6	-4.4	1545.7	12.0	0.8	-2.66667	0
2023-01-28	2023		1	28	20	6	-0.8	4.2	-3.9	1504.3	12.0	1.5	-3.05833	0
2023-01-28	2023		1	28	21	6	-0.6	4.2	-2.2	1458.5	12.0	2.2	-3.38333	0
2023-01-28	2023		1	28	22	6	-0.4	4.2	-0.6	1403.8	12.0	2.8	-3.59167	0
2023-01-28	2023		1	28	23	6	-0.1	4.6	3.3	1338.0	12.0	3.4	-3.60833	0
2023-01-28	2023		1	28	24	6	0.2	4	4.1	1292.3	12.0	3.8	-3.45	0
2023-01-29	2023		1	29	1	7	0.5	3	3	1251.6	10.6	3.9	-2.95	0
2023-01-29	2023		1	29	2	7	0.8	2.1	3.7	1228.4	10.6	3.8	-2.25833	0
2023-01-29	2023		1	29	3	7	1.0	1.4	4	1215.7	10.6	3.7	-1.64167	0
2023-01-29	2023		1	29	4	7	1.2	1.4	3.4	1213.9	10.6	3.5	-1.08333	0
2023-01-29	2023		1	29	5	7	1.4	2	3.4	1233.4	10.6	3.3	-0.45	0
2023-01-29	2023		1	29	6	7	1.7	0.8	3.6	1265.1	10.6	3.2	0.158333	0
2023-01-29	2023		1	29	7	7	1.9	0.4	4.2	1311.2	10.6	3.0	0.783333	0
2023-01-29	2023		1	29	8	7	2.1	0.2	4.2	1383.2	10.6	2.7	1.45	0
2023-01-29	2023		1	29	9	7	2.3	0	4.2	1449.5	10.6	2.4	2.166667	0
2023-01-29	2023		1	29	10	7	2.4	1.1	4.6	1457.9	10.6	2.0	2.841667	0
2023-01-29	2023		1	29										

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLag	Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLag	Weekdays	
2023-01-29	2023		1	29	24	7	2.3	5	2.3	1241.6	10.6	3.1	1.566667	0
2023-01-30	2023		1	30	1	1	2.4	5.4	3	1173.1	11.5	3.3	1.516667	1
2023-01-30	2023		1	30	2	1	2.5	6.8	2.9	1135.6	11.5	3.5	1.458333	1
2023-01-30	2023		1	30	3	1	2.7	7.4	2.6	1113.8	11.5	3.8	1.533333	1
2023-01-30	2023		1	30	4	1	2.9	7.4	2.1	1101.7	11.5	4.2	1.658333	1
2023-01-30	2023		1	30	5	1	3.2	7	1.9	1106.7	11.5	4.6	1.758333	1
2023-01-30	2023		1	30	6	1	3.4	7	2.1	1157.4	11.5	5.0	1.766667	1
2023-01-30	2023		1	30	7	1	3.7	6.6	2.8	1287.3	11.5	5.4	1.858333	1
2023-01-30	2023		1	30	8	1	3.9	5.7	4	1398.3	11.5	5.8	2	1
2023-01-30	2023		1	30	9	1	4.1	5.4	5	1415.8	11.5	6.1	2.216667	1
2023-01-30	2023		1	30	10	1	4.4	6.7	5.4	1386.6	11.5	6.2	2.55	1
2023-01-30	2023		1	30	11	1	4.6	7.4	5	1368.3	11.5	6.3	2.875	1
2023-01-30	2023		1	30	12	1	4.8	6.9	5.4	1349.2	11.5	6.5	3.125	1
2023-01-30	2023		1	30	13	1	5.0	8.3	6.8	1338.0	11.5	6.6	3.258333	1
2023-01-30	2023		1	30	14	1	5.2	8.9	7.4	1308.8	11.5	6.9	3.516667	1
2023-01-30	2023		1	30	15	1	5.4	9.1	7.4	1294.5	11.5	7.1	3.833333	1
2023-01-30	2023		1	30	16	1	5.7	7.7	7	1325.2	11.5	7.2	4.208333	1
2023-01-30	2023		1	30	17	1	5.9	8.1	7	1408.8	11.5	7.2	4.608333	1
2023-01-30	2023		1	30	18	1	6.2	6.9	6.6	1507.3	11.5	7.3	5.016667	1
2023-01-30	2023		1	30	19	1	6.4	5	5.7	1521.7	11.5	7.3	5.441667	1
2023-01-30	2023		1	30	20	1	6.5	3.7	5.4	1498.6	11.5	7.2	5.816667	1
2023-01-30	2023		1	30	21	1	6.5	3.3	6.7	1459.0	11.5	7.0	6.058333	1
2023-01-30	2023		1	30	22	1	6.5	3.9	7.4	1399.1	11.5	6.8	6.175	1
2023-01-30	2023		1	30	23	1	6.5	3.1	6.9	1321.2	11.5	6.6	6.316667	1
2023-01-30	2023		1	30	24	1	6.4	2.8	8.3	1307.3	11.5	6.2	6.483333	1
2023-01-31	2023		1	31	1	2	6.3	2.4	8.9	1296.9	10.5	5.9	6.641667	1
2023-01-31	2023		1	31	2	2	6.1	0.9	9.1	1274.3	10.5	5.4	6.883333	1
2023-01-31	2023		1	31	3	2	5.9	0.6	7.7	1244.5	10.5	4.7	7.058333	1
2023-01-31	2023		1	31	4	2	5.6	0	8.1	1253.0	10.5	4.0	7.2	1
2023-01-31	2023		1	31	5	2	5.3	-0.3	6.9	1243.3	10.5	3.4	7.225	1
2023-01-31	2023		1	31	6	2	5.0	-0.3	5	1286.6	10.5	2.7	7.316667	1
2023-01-31	2023		1	31	7	2	4.7	-0.5	3.7	1428.8	10.5	2.1	7.308333	1
2023-01-31	2023		1	31	8	2	4.4	-0.4	3.3	1565.2	10.5	1.6	7.175	1
2023-01-31	2023		1	31	9	2	4.2	-0.4	3.9	1627.4	10.5	1.3	7.008333	1
2023-01-31	2023		1	31	10	2	3.9	-0.3	3.1	1637.6	10.5	1.0	6.833333	1
2023-01-31	2023		1	31	11	2	3.6	-0.7	2.8	1657.4	10.5	0.6	6.6	1
2023-01-31	2023		1	31	12	2	3.3	-1.1	2.4	1679.1	10.5	0.3	6.241667	1
2023-01-31	2023		1	31	13	2	2.9	-2.1	0.9	1703.9	10.5	0.0	5.9	1
2023-01-31	2023		1	31	14	2	2.5	-2.5	0.6	1694.5	10.5	-0.4	5.408333	1
2023-01-31	2023		1	31	15	2	2.0	-2.5	0	1655.1	10.5	-0.7	4.741667	1
2023-01-31	2023		1	31	16	2	1.6	-2.3	-0.3	1645.5	10.5	-0.9	4.033333	1
2023-01-31	2023		1	31	17	2	1.1	-2.2	-0.3	1686.3	10.5	-1.1	3.391667	1
2023-01-31	2023		1	31	18	2	0.7	-2.3	-0.5	1782.9	10.5	-1.3	2.691667	1
2023-01-31	2023		1	31	19	2	0.3	-3	-0.4	1783.9	10.5	-1.4	2.091667	1
2023-01-31	2023		1	31	20	2	0.0	-3.8	-0.4	1762.5	10.5	-1.7	1.633333	1
2023-01-31	2023		1	31	21	2	-0.3	-4.8	-0.3	1712.9	10.5	-1.9	1.291667	1
2023-01-31	2023		1	31	22	2	-0.7	-5.1	-0.7	1651.9	10.5	-2.3	0.983333	1
2023-01-31	2023		1	31	23	2	-1.0	-5.9	-1.1	1580.9	10.5	-2.7	0.633333	1
2023-01-31	2023		1	31	24	2	-1.4	-6	-2.1	1560.7	10.5	-3.1	0.316667	1
2023-02-01	2023		2	1	1	3	-1.8	-6.7	-2.5	1546.3	12.8	-3.5	-0.00833	1
2023-02-01	2023		2	1	2	3	-2.2	-7.5	-2.5	1532.3	12.8	-3.9	-0.38333	1
2023-02-01	2023		2	1	3	3	-2.5	-8.2	-2.3	1521.7	12.8	-4.3	-0.66667	1
2023-02-01	2023		2	1	4	3	-2.9	-8.7	-2.2	1513.7	12.8	-4.8	-0.925	1
2023-02-01	2023		2	1	5	3	-3.2	-9.3	-2.3	1525.7	12.8	-5.4	-1.11667	1
2023-02-01	2023		2	1	6	3	-3.6	-9.8	-3	1596.7	12.8	-5.9	-1.275	1
2023-02-01	2023		2	1	7	3	-4.0	-10.6	-3.8	1764.7	12.8	-6.6	-1.44167	1
2023-02-01	2023		2	1	8	3	-4.4	-11.3	-4.8	1896.3	12.8	-7.2	-1.65	1
2023-02-01	2023		2	1	9	3	-4.9	-11.6	-5.1	1913.0	12.8	-7.8	-1.93333	1
2023-02-01	2023		2	1	10	3	-5.3	-10.8	-5.9	1841.4	12.8	-8.4	-2.3	1
2023-02-01	2023		2	1	11	3	-5.8	-10.1	-6	1774.8	12.8	-8.9	-2.7	1
2023-02-01	2023		2	1	12	3	-6.2	-8.6	-6.7	1729.3	12.8	-9.2	-3.13333	1
2023-02-01	2023		2	1	13	3	-6.5	-7.9	-7.5	1707.3	12.8	-9.4	-3.54167	1
2023-02-01	2023		2	1	14	3	-6.7	-6.9	-8.2	1663.3	12.8	-9.5	-3.925	1
2023-02-01	2023		2	1	15	3	-6.9	-6.3	-8.7	1631.1	12.8	-9.5	-4.34167	1
2023-02-01	2023		2	1	16	3	-7.1	-5.7	-9.3	1647.3	12.8	-9.3	-4.81667	1
2023-02-01	2023		2	1	17	3	-7.2	-6.2	-9.8	1722.1	12.8	-9.1	-5.35	1
2023-02-01	2023		2	1	18	3	-7.4	-7.1	-10.6	1852.7	12.8	-8.8	-5.94167	1
2023-02-01	2023		2	1	19	3	-7.6	-8.6	-11.3	1909.9	12.8	-8.6	-6.56667	1
2023-02-01	2023		2	1	20	3	-7.8	-9.5	-11.6	1908.3	12.8	-8.4	-7.2	1
2023-02-01	2023		2	1	21	3	-8.1	-10.3	-10.8	1886.9	12.8	-8.3	-7.825	1
2023-02-01	2023		2	1	22	3	-8.3	-10.5	-10.1	1835.4	12.8	-8.2	-8.39167	1
2023-02-01	2023		2	1	23	3	-8.5	-11.2	-8.6	1774.7	12.8	-8.1	-8.86667	1
2023-02-01	2023		2	1	24	3	-8.7	-11.1	-7.9	1769.6	12.8	-8.2	-9.21667	1
2023-02-02	2023		2	2	1	4	-8.9	-11.6	-6.9	1745.2	9.2	-8.4	-9.43333	1
2023-02-02	2023		2	2	2	4	-9.1	-13.2	-6.3	1712.3	9.2	-8.8	-9.53333	1
2023-02-02	2023		2	2	3	4	-9.4	-13	-5.7	1707.4	9.2	-9.3	-9.48333	1
2023-02-02	2023		2	2	4	4	-9.6	-12	-6.2	1710.8	9.2	-9.8	-9.325	1
2023-02-02	2023		2	2	5	4	-9.7	-12.8	-7.1	1720.5	9.2	-10.4	-9.075	1
2023-02-02	2023		2	2	6	4	-9.9	-13.5	-8.6	1787.0	9.2	-10.9	-8.81667	1
2023-02-02	2023		2	2	7	4	-10.0	-13.8	-9.5	1936.4	9.2	-11.4	-8.59167	1
2023-02-02	2023		2	2	8	4	-10.2	-13.1	-10.3	2038.3	9.2	-11.9	-8.425	1
2023-02-02	2023		2	2	9	4	-10.2	-11.1	-10.5	2028.7	9.2	-12.2	-8.275	1
2023-02-02	2023		2	2	10	4	-10.2	-6.7	-11.2	1940.1	9.2	-12.2	-8.16667	1
2023-02-02	2023		2	2	11	4	-10.0	-4.7	-11.1	1862.0	9.2	-11.9	-8.14167	1
2023-02-02	2023		2	2	12	4	-9.8	-3.5	-11.6	1797.0	9.2	-11.4	-8.23333	1
2023-02-02	2023		2	2	13	4	-9.6	-2.9	-13.2	1751.8	9.2	-10.8	-8.44167	1
2023-02-02	2023		2	2	14	4	-9.4	-2.5	-13	1697.5	9.2	-10.0	-8.75	1
2023-02-02	2023		2	2	15	4	-9.2	-1.6	-12	1669.1	9.2	-9.1	-9.275	1
2023-02-02	2023		2	2	16	4	-9.0	-2.2	-12.8	1681.2	9.2	-8.2	-9.83333	1
2023-02-02	2023		2	2	17	4	-8.9	-2.1	-13.5	1729.2	9.2	-7.4	-10.3583	1
2023-02-02	2023		2	2	18	4	-8.7	-2.8	-13.8	1823.9	9.2	-6.5	-10.9083	1
2023-02-02	2023		2	2	19	4	-8.5	-3	-13.1	1842.8	9.2	-5.6	-11.4417	1
2023-02-02	2023		2	2	20	4	-8.3	-2.6	-11.1	1807.7	9.2	-4.7	-11.875	1
2023-02-02	2023		2	2	21	4	-8.0	-2.2	-6.7	1748.1	9.2	-3.8	-12.175	1
2023-02-02	2023		2	2	22	4	-7.7	-1.7	-4.7	1673.3	9.2	-3.1	-12.2417	1
2023-02														

DATE	Year	Month	Day	HOUR	DOW	24hrAvgLa	g Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLa	g Weekdays	
2023-02-03	2023		2	3	12	5	-0.3	2.4	1.4	1705.7	24.4	1.7	-2.35833	1
2023-02-03	2023		2	3	13	5	-0.1	-1.1	1.7	1724.9	24.4	2.0	-2.09167	1
2023-02-03	2023		2	3	14	5	0.0	-2	1.8	1708.2	24.4	1.7	-1.73333	1
2023-02-03	2023		2	3	15	5	0.0	-3.7	2.2	1726.3	24.4	1.4	-1.38333	1
2023-02-03	2023		2	3	16	5	-0.1	-6	2.6	1793.3	24.4	1.0	-1.1	1
2023-02-03	2023		2	3	17	5	-0.2	-9	1.5	1916.4	24.4	0.3	-0.73333	1
2023-02-03	2023		2	3	18	5	-0.5	-12.2	1.1	2062.5	24.4	-0.7	-0.34167	1
2023-02-03	2023		2	3	19	5	-0.9	-13.9	1.3	2115.7	24.4	-1.8	0.016667	1
2023-02-03	2023		2	3	20	5	-1.4	-15.1	2.2	2117.6	24.4	-3.1	0.358333	1
2023-02-03	2023		2	3	21	5	-1.9	-16	2.6	2102.0	24.4	-4.4	0.683333	1
2023-02-03	2023		2	3	22	5	-2.5	-17.5	2.6	2090.5	24.4	-6.0	1.05	1
2023-02-03	2023		2	3	23	5	-3.1	-19.6	2.4	2062.8	24.4	-7.6	1.408333	1
2023-02-03	2023		2	3	24	5	-3.9	-20.8	-1.1	2067.8	24.4	-9.5	1.725	1
2023-02-04	2023		2	4	1	6	-4.7	-22	-2	2089.2	28.4	-11.4	1.95	0
2023-02-04	2023		2	4	2	6	-5.7	-22.9	-3.7	2092.5	28.4	-13.2	1.741667	0
2023-02-04	2023		2	4	3	6	-6.7	-23.2	-6	2094.6	28.4	-14.9	1.433333	0
2023-02-04	2023		2	4	4	6	-7.8	-23.7	-9	2105.9	28.4	-16.5	0.975	0
2023-02-04	2023		2	4	5	6	-8.9	-23.5	-12.2	2127.3	28.4	-18.0	0.291667	0
2023-02-04	2023		2	4	6	6	-9.9	-23.7	-13.9	2161.9	28.4	-19.2	-0.675	0
2023-02-04	2023		2	4	7	6	-11.0	-23.4	-15.1	2214.4	28.4	-20.2	-1.81667	0
2023-02-04	2023		2	4	8	6	-12.0	-23	-16	2277.5	28.4	-21.0	-3.06667	0
2023-02-04	2023		2	4	9	6	-13.0	-22.7	-17.5	2345.5	28.4	-21.6	-4.43333	0
2023-02-04	2023		2	4	10	6	-14.1	-22.2	-19.6	2409.2	28.4	-22.2	-5.95	0
2023-02-04	2023		2	4	11	6	-15.1	-22.2	-20.8	2442.3	28.4	-22.6	-7.625	0
2023-02-04	2023		2	4	12	6	-16.1	-21.5	-22	2445.8	28.4	-22.8	-9.475	0
2023-02-04	2023		2	4	13	6	-17.1	-20.2	-22.9	2441.3	28.4	-22.8	-11.4083	0
2023-02-04	2023		2	4	14	6	-17.9	-18.2	-23.2	2409.2	28.4	-22.7	-13.15	0
2023-02-04	2023		2	4	15	6	-18.6	-16	-23.7	2352.0	28.4	-22.3	-14.8917	0
2023-02-04	2023		2	4	16	6	-19.1	-14.9	-23.5	2336.1	28.4	-21.7	-16.5167	0
2023-02-04	2023		2	4	17	6	-19.5	-13.5	-23.7	2364.1	28.4	-21.0	-17.9917	0
2023-02-04	2023		2	4	18	6	-19.7	-14	-23.4	2416.5	28.4	-20.1	-19.2	0
2023-02-04	2023		2	4	19	6	-19.7	-14.4	-23	2422.7	28.4	-19.3	-20.1583	0
2023-02-04	2023		2	4	20	6	-19.8	-14.4	-22.7	2373.9	28.4	-18.6	-20.95	0
2023-02-04	2023		2	4	21	6	-19.7	-13.9	-22.2	2327.0	28.4	-17.9	-21.6083	0
2023-02-04	2023		2	4	22	6	-19.6	-13.7	-22.2	2253.0	28.4	-17.1	-22.1667	0
2023-02-04	2023		2	4	23	6	-19.5	-13.3	-21.5	2172.9	28.4	-16.4	-22.5583	0
2023-02-04	2023		2	4	24	6	-19.2	-13.3	-20.2	2094.5	28.4	-15.7	-22.775	0
2023-02-05	2023		2	5	1	7	-18.9	-13.5	-18.2	2034.8	17.8	-15.0	-22.8333	0
2023-02-05	2023		2	5	2	7	-18.6	-13.6	-16	2002.5	17.8	-14.4	-22.6833	0
2023-02-05	2023		2	5	3	7	-18.2	-13.8	-14.9	1982.3	17.8	-14.0	-22.2917	0
2023-02-05	2023		2	5	4	7	-17.8	-13.4	-13.5	1968.9	17.8	-13.9	-21.6917	0
2023-02-05	2023		2	5	5	7	-17.3	-13	-14	1952.7	17.8	-13.7	-20.9583	0
2023-02-05	2023		2	5	6	7	-16.9	-12	-14.4	1955.8	17.8	-13.7	-20.125	0
2023-02-05	2023		2	5	7	7	-16.4	-11.3	-14.4	1973.4	17.8	-13.5	-19.3167	0
2023-02-05	2023		2	5	8	7	-15.9	-10.2	-13.9	2006.2	17.8	-13.3	-18.5667	0
2023-02-05	2023		2	5	9	7	-15.4	-9.7	-13.7	2050.6	17.8	-12.9	-17.85	0
2023-02-05	2023		2	5	10	7	-14.8	-8.3	-13.3	2070.6	17.8	-12.6	-17.1167	0
2023-02-05	2023		2	5	11	7	-14.3	-5.7	-13.3	2043.4	17.8	-12.1	-16.4083	0
2023-02-05	2023		2	5	12	7	-13.6	-1.3	-13.5	2000.3	17.8	-11.5	-15.6667	0
2023-02-05	2023		2	5	13	7	-12.7	-1.3	-13.6	1977.4	17.8	-10.5	-14.9833	0
2023-02-05	2023		2	5	14	7	-11.9	0.6	-13.8	1906.8	17.8	-9.5	-14.425	0
2023-02-05	2023		2	5	15	7	-11.2	1.8	-13.4	1846.7	17.8	-8.3	-14.0417	0
2023-02-05	2023		2	5	16	7	-10.4	1.5	-13	1825.2	17.8	-7.0	-13.8583	0
2023-02-05	2023		2	5	17	7	-9.7	2.8	-12	1847.6	17.8	-5.7	-13.7333	0
2023-02-05	2023		2	5	18	7	-9.1	3.4	-11.3	1878.5	17.8	-4.4	-13.6917	0
2023-02-05	2023		2	5	19	7	-8.3	4	-10.2	1834.3	17.8	-3.1	-13.525	0
2023-02-05	2023		2	5	20	7	-7.6	4.8	-9.7	1770.6	17.8	-1.9	-13.2667	0
2023-02-05	2023		2	5	21	7	-6.8	4.8	-8.3	1694.1	17.8	-0.6	-12.9167	0
2023-02-05	2023		2	5	22	7	-6.0	5.2	-5.7	1593.3	17.8	0.6	-12.5667	0
2023-02-05	2023		2	5	23	7	-5.2	5.3	-1.3	1495.3	17.8	1.7	-12.1167	0
2023-02-05	2023		2	5	24	7	-4.4	5.1	-1.3	1401.3	17.8	2.6	-11.4833	0
2023-02-06	2023		2	6	1	1	-3.7	5.2	0.6	1302.8	11.5	3.2	-10.4833	1
2023-02-06	2023		2	6	2	1	-2.9	5.1	1.8	1266.2	11.5	3.7	-9.46667	1
2023-02-06	2023		2	6	3	1	-2.1	5.6	1.5	1250.2	11.5	4.1	-8.28333	1
2023-02-06	2023		2	6	4	1	-1.3	5.3	2.8	1249.5	11.5	4.4	-6.98333	1
2023-02-06	2023		2	6	5	1	-0.5	5.3	3.4	1262.1	11.5	4.7	-5.74167	1
2023-02-06	2023		2	6	6	1	0.3	4.4	4	1312.7	11.5	4.9	-4.425	1
2023-02-06	2023		2	6	7	1	0.9	4.3	4.8	1442.6	11.5	5.0	-3.14167	1
2023-02-06	2023		2	6	8	1	1.6	3.7	4.8	1552.7	11.5	5.0	-1.86667	1
2023-02-06	2023		2	6	9	1	2.2	4	5.2	1583.9	11.5	4.9	-0.61667	1
2023-02-06	2023		2	6	10	1	2.7	4.1	5.3	1580.3	11.5	4.9	0.591667	1
2023-02-06	2023		2	6	11	1	3.3	5.1	5.1	1563.7	11.5	4.8	1.716667	1
2023-02-06	2023		2	6	12	1	3.7	5.5	5.2	1557.5	11.5	4.8	2.633333	1
2023-02-06	2023		2	6	13	1	4.0	5.7	5.1	1545.5	11.5	4.8	3.166667	1
2023-02-06	2023		2	6	14	1	4.3	6.2	5.6	1503.6	11.5	4.8	3.708333	1
2023-02-06	2023		2	6	15	1	4.5	6	5.3	1482.2	11.5	4.9	4.083333	1
2023-02-06	2023		2	6	16	1	4.7	5.8	5.3	1499.1	11.5	5.0	4.4	1
2023-02-06	2023		2	6	17	1	4.9	5.2	4.4	1555.2	11.5	5.0	4.716667	1
2023-02-06	2023		2	6	18	1	5.0	4.4	4.3	1646.7	11.5	5.0	4.925	1
2023-02-06	2023		2	6	19	1	5.0	3.1	3.7	1661.7	11.5	5.0	5.008333	1
2023-02-06	2023		2	6	20	1	5.0	1.5	4	1655.5	11.5	4.9	5.033333	1
2023-02-06	2023		2	6	21	1	4.8	-1.2	4.1	1631.1	11.5	4.7	4.941667	1
2023-02-06	2023		2	6	22	1	4.6	-1.7	5.1	1572.3	11.5	4.3	4.875	1
2023-02-06	2023		2	6	23	1	4.3	-1.9	5.5	1496.0	11.5	3.8	4.783333	1
2023-02-06	2023		2	6	24	1	4.0	-2	5.7	1492.7	11.5	3.2	4.766667	1
2023-02-07	2023		2	7	1	2	3.7	-1.7	6.2	1478.7	23.3	2.6	4.8	1
2023-02-07	2023		2	7	2	2	3.4	-2.1	6	1467.3	23.3	2.0	4.841667	1
2023-02-07	2023		2	7	3	2	3.1	-3.1	5.8	1463.7	23.3	1.3	4.933333	1
2023-02-07	2023		2	7	4	2	2.7	-3.7	5.2	1467.5	23.3	0.5	4.966667	1
2023-02-07	2023		2	7	5	2	2.4	-4.2	4.4	1488.5	23.3	-0.3	5.008333	1
2023-02-07	2023		2	7	6	2	2.0	-4.4	3.1	1556.4	23.3	-1.1	5	1
2023-02-07	2023		2	7	7	2	1.6	-4.4	1.5	1685.9	23.3	-1.8	5	1
2023-02-07	2023		2	7	8	2	1.2	-4.4	-1.2	1796.7	23.3	-2.4	4.9	1
2023-02-07	2023		2	7	9	2	0.9	-4.3	-1.7	1823.0	23.3	-2.9	4.716667	1
2023-02-07	2023		2	7	10	2	0.6	-3.6	-1.9	1774.5</				

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLag	Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLag	Weekdays	
2023-02-07	2023		2	7	24	2	-2.5	-5.8	0	1585.0	23.3	-1.7	-3.34167	1
2023-02-08	2023		2	8	1	3	-2.7	-6.2	0.6	1561.1	9.5	-2.1	-3.29167	1
2023-02-08	2023		2	8	2	3	-2.9	-5.4	0.9	1525.3	9.5	-2.6	-3.15	1
2023-02-08	2023		2	8	3	3	-3.0	-4.9	1.1	1496.4	9.5	-3.1	-2.925	1
2023-02-08	2023		2	8	4	3	-3.1	-4.1	0.1	1470.7	9.5	-3.6	-2.59167	1
2023-02-08	2023		2	8	5	3	-3.1	-4	-1.1	1464.6	9.5	-4.0	-2.19167	1
2023-02-08	2023		2	8	6	3	-3.1	-3.1	-2.6	1503.7	9.5	-4.4	-1.83333	1
2023-02-08	2023		2	8	7	3	-3.0	-1.7	-3.3	1624.0	9.5	-4.5	-1.55833	1
2023-02-08	2023		2	8	8	3	-2.9	-1.1	-4.3	1719.7	9.5	-4.5	-1.40833	1
2023-02-08	2023		2	8	9	3	-2.8	-0.7	-5	1743.8	9.5	-4.3	-1.31667	1
2023-02-08	2023		2	8	10	3	-2.6	0.1	-5.6	1720.3	9.5	-4.0	-1.31667	1
2023-02-08	2023		2	8	11	3	-2.5	0.6	-5.8	1691.2	9.5	-3.5	-1.43333	1
2023-02-08	2023		2	8	12	3	-2.4	1.3	-6.2	1665.3	9.5	-3.0	-1.71667	1
2023-02-08	2023		2	8	13	3	-2.3	2.6	-5.4	1643.8	9.5	-2.4	-2.08333	1
2023-02-08	2023		2	8	14	3	-2.2	2.5	-4.9	1580.2	9.5	-1.7	-2.6	1
2023-02-08	2023		2	8	15	3	-2.1	3.7	-4.1	1535.5	9.5	-1.0	-3.1	1
2023-02-08	2023		2	8	16	3	-2.0	4.4	-4	1540.9	9.5	-0.3	-3.58333	1
2023-02-08	2023		2	8	17	3	-1.8	5.2	-3.1	1594.8	9.5	0.4	-4.01667	1
2023-02-08	2023		2	8	18	3	-1.6	3.5	-1.7	1663.4	9.5	1.2	-4.35833	1
2023-02-08	2023		2	8	19	3	-1.4	3.2	-1.1	1663.0	9.5	1.7	-4.525	1
2023-02-08	2023		2	8	20	3	-1.2	3	-0.7	1634.4	9.5	2.1	-4.45	1
2023-02-08	2023		2	8	21	3	-0.9	2.8	0.1	1586.0	9.5	2.5	-4.26667	1
2023-02-08	2023		2	8	22	3	-0.6	2.4	0.6	1508.8	9.5	2.7	-3.96667	1
2023-02-08	2023		2	8	23	3	-0.3	2.1	1.3	1432.2	9.5	2.9	-3.54167	1
2023-02-08	2023		2	8	24	3	0.0	1.3	2.6	1411.7	9.5	3.1	-3.025	1
2023-02-09	2023		2	9	1	4	0.3	0.6	2.5	1388.7	14.5	3.1	-2.43333	1
2023-02-09	2023		2	9	2	4	0.6	0.7	3.7	1369.7	14.5	2.9	-1.7	1
2023-02-09	2023		2	9	3	4	0.9	-0.1	4.4	1362.9	14.5	2.7	-1.04167	1
2023-02-09	2023		2	9	4	4	1.1	-1.2	5.2	1373.4	14.5	2.4	-0.325	1
2023-02-09	2023		2	9	5	4	1.2	-2.4	3.5	1406.4	14.5	2.0	0.383333	1
2023-02-09	2023		2	9	6	4	1.2	-3.3	3.2	1481.5	14.5	1.3	1.15	1
2023-02-09	2023		2	9	7	4	1.2	-4.1	3	1637.0	14.5	0.8	1.7	1
2023-02-09	2023		2	9	8	4	1.1	-4.7	2.8	1755.1	14.5	0.2	2.108333	1
2023-02-09	2023		2	9	9	4	1.0	-4.7	2.4	1758.0	14.5	-0.5	2.45	1
2023-02-09	2023		2	9	10	4	0.8	-4.1	2.1	1691.2	14.5	-1.1	2.741667	1
2023-02-09	2023		2	9	11	4	0.6	-3.3	1.3	1635.7	14.5	-1.7	2.933333	1
2023-02-09	2023		2	9	12	4	0.5	-2.6	0.6	1595.2	14.5	-2.1	3.058333	1
2023-02-09	2023		2	9	13	4	0.3	-1.5	0.7	1571.3	14.5	-2.4	3.058333	1
2023-02-09	2023		2	9	14	4	0.1	-0.5	-0.1	1530.4	14.5	-2.6	2.891667	1
2023-02-09	2023		2	9	15	4	0.0	0.5	-1.2	1502.6	14.5	-2.7	2.741667	1
2023-02-09	2023		2	9	16	4	-0.1	-0.2	-2.4	1524.3	14.5	-2.7	2.425	1
2023-02-09	2023		2	9	17	4	-0.3	-0.4	-3.3	1615.0	14.5	-2.6	1.958333	1
2023-02-09	2023		2	9	18	4	-0.5	-0.7	-4.1	1714.6	14.5	-2.4	1.325	1
2023-02-09	2023		2	9	19	4	-0.7	-1.3	-4.7	1742.8	14.5	-2.2	0.758333	1
2023-02-09	2023		2	9	20	4	-0.9	-1.7	-4.7	1716.9	14.5	-2.0	0.15	1
2023-02-09	2023		2	9	21	4	-1.1	-2	-4.1	1683.0	14.5	-1.7	-0.49167	1
2023-02-09	2023		2	9	22	4	-1.3	-1.8	-3.3	1617.8	14.5	-1.5	-1.11667	1
2023-02-09	2023		2	9	23	4	-1.5	-1.4	-2.6	1531.4	14.5	-1.3	-1.65833	1
2023-02-09	2023		2	9	24	4	-1.6	-1.6	-1.5	1502.1	14.5	-1.1	-2.10833	1
2023-02-10	2023		2	10	1	5	-1.7	-2	-0.5	1469.3	12.7	-1.1	-2.43333	1
2023-02-10	2023		2	10	2	5	-1.9	-1.8	0.5	1442.9	12.7	-1.1	-2.60833	1
2023-02-10	2023		2	10	3	5	-2.0	-2.1	-0.2	1426.2	12.7	-1.2	-2.70833	1
2023-02-10	2023		2	10	4	5	-2.0	-2.8	-0.4	1416.8	12.7	-1.4	-2.65833	1
2023-02-10	2023		2	10	5	5	-2.1	-2.3	-0.7	1426.1	12.7	-1.6	-2.575	1
2023-02-10	2023		2	10	6	5	-2.1	-1	-1.3	1474.6	12.7	-1.8	-2.40833	1
2023-02-10	2023		2	10	7	5	-2.0	0.3	-1.7	1577.1	12.7	-1.8	-2.19167	1
2023-02-10	2023		2	10	8	5	-1.8	1.2	-2	1656.2	12.7	-1.7	-1.95833	1
2023-02-10	2023		2	10	9	5	-1.6	1.6	-1.8	1699.6	12.7	-1.4	-1.70833	1
2023-02-10	2023		2	10	10	5	-1.3	2.2	-1.4	1742.3	12.7	-1.1	-1.48333	1
2023-02-10	2023		2	10	11	5	-1.1	2.7	-1.6	1715.8	12.7	-0.8	-1.29167	1
2023-02-10	2023		2	10	12	5	-0.8	3.5	-2	1697.2	12.7	-0.5	-1.13333	1
2023-02-10	2023		2	10	13	5	-0.5	4.7	-1.8	1670.2	12.7	0.0	-1.05	1
2023-02-10	2023		2	10	14	5	-0.3	6.7	-2.1	1609.8	12.7	0.5	-1.09167	1
2023-02-10	2023		2	10	15	5	0.0	7.7	-2.8	1566.7	12.7	1.2	-1.2	1
2023-02-10	2023		2	10	16	5	0.3	7.5	-2.3	1541.8	12.7	2.0	-1.41667	1
2023-02-10	2023		2	10	17	5	0.6	8	-1	1550.8	12.7	2.9	-1.63333	1
2023-02-10	2023		2	10	18	5	1.0	7.9	0.3	1573.4	12.7	3.8	-1.79167	1
2023-02-10	2023		2	10	19	5	1.3	7.7	1.2	1548.0	12.7	4.5	-1.81667	1
2023-02-10	2023		2	10	20	5	1.7	7.4	1.6	1498.0	12.7	5.1	-1.68333	1
2023-02-10	2023		2	10	21	5	2.1	6.5	2.2	1450.0	12.7	5.6	-1.44167	1
2023-02-10	2023		2	10	22	5	2.5	6	2.7	1395.4	12.7	6.0	-1.14167	1
2023-02-10	2023		2	10	23	5	2.8	5.4	3.5	1322.8	12.7	6.4	-0.80833	1
2023-02-10	2023		2	10	24	5	3.1	5.1	4.7	1298.9	12.7	6.6	-0.46667	1
2023-02-11	2023		2	11	1	6	3.3	5.1	6.7	1273.0	18.4	6.7	-0.04167	0
2023-02-11	2023		2	11	2	6	3.6	4.3	7.7	1244.1	18.4	6.8	0.516667	0
2023-02-11	2023		2	11	3	6	3.9	4	7.5	1219.6	18.4	6.6	1.225	0
2023-02-11	2023		2	11	4	6	4.1	3.5	8	1224.7	18.4	6.2	2.041667	0
2023-02-11	2023		2	11	5	6	4.4	2	7.9	1246.6	18.4	5.9	2.9	0
2023-02-11	2023		2	11	6	6	4.6	1	7.7	1296.2	18.4	5.4	3.758333	0
2023-02-11	2023		2	11	7	6	4.7	-0.7	7.4	1370.2	18.4	4.8	4.5	0
2023-02-11	2023		2	11	8	6	4.6	-1.2	6.5	1455.1	18.4	4.1	5.116667	0
2023-02-11	2023		2	11	9	6	4.5	-1.8	6	1560.2	18.4	3.4	5.633333	0
2023-02-11	2023		2	11	10	6	4.4	-2.1	5.4	1636.2	18.4	2.7	6.041667	0
2023-02-11	2023		2	11	11	6	4.2	-2.4	5.1	1655.4	18.4	2.1	6.358333	0
2023-02-11	2023		2	11	12	6	4.0	-2	5.1	1639.9	18.4	1.4	6.583333	0
2023-02-11	2023		2	11	13	6	3.8	-1.9	4.3	1622.5	18.4	0.8	6.716667	0
2023-02-11	2023		2	11	14	6	3.5	-1.3	4	1605.5	18.4	0.2	6.75	0
2023-02-11	2023		2	11	15	6	3.2	-1.7	3.5	1615.3	18.4	-0.2	6.55	0
2023-02-11	2023		2	11	16	6	2.8	-2.7	2	1641.7	18.4	-0.7	6.241667	0
2023-02-11	2023		2	11	17	6	2.3	-3.1	1	1697.8	18.4	-1.2	5.908333	0
2023-02-11	2023		2	11	18	6	1.9	-3.3	-0.7	1772.4	18.4	-1.7	5.408333	0
2023-02-11	2023		2	11	19	6	1.4	-3.9	-1.2	1789.3	18.4	-2.0	4.833333	0
2023-02-11	2023		2	11	20	6	0.9	-4.2	-1.8	1748.3	18.4	-2.3	4.133333	0
2023-02-11	2023		2	11	21	6	0.4	-4	-2.1	1706.0	18.4	-2.5	3.416667	0
2023-02-11	2023		2	11	22	6	0.0	-3.9	-2.4	1653.1	18.4	-2.7	2.725	0
2023-02-11	2023		2	11	23	6	-0.4	-4.4	-2	159				

DATE	Year	Month	Day	HOUR	DOW	24hrAvgLa	g Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLa	g Weekdays	
2023-02-12	2023	2	12	12	12	7	-3.0	4.8	-5.3	1625.6	11.6	-3.0	-3.03333	0
2023-02-12	2023	2	12	12	13	7	-2.8	5.4	-5.2	1564.4	11.6	-2.2	-3.26667	0
2023-02-12	2023	2	12	14	14	7	-2.4	6.6	-4.8	1493.2	11.6	-1.3	-3.55	0
2023-02-12	2023	2	12	15	15	7	-2.1	6.3	-4.7	1461.1	11.6	-0.4	-3.875	0
2023-02-12	2023	2	12	16	16	7	-1.8	6.7	-5.1	1434.2	11.6	0.6	-4.13333	0
2023-02-12	2023	2	12	17	17	7	-1.4	6.6	-5.8	1467.4	11.6	1.5	-4.3	0
2023-02-12	2023	2	12	18	18	7	-1.0	5.9	-3	1567.4	11.6	2.5	-4.46667	0
2023-02-12	2023	2	12	19	19	7	-0.6	3.6	-2.1	1629.7	11.6	3.5	-4.675	0
2023-02-12	2023	2	12	20	20	7	-0.3	1.1	-0.4	1624.6	11.6	4.0	-4.6	0
2023-02-12	2023	2	12	21	21	7	-0.1	-0.2	1.7	1584.7	11.6	4.3	-4.425	0
2023-02-12	2023	2	12	22	22	7	0.1	-1.2	3.1	1539.0	11.6	4.3	-4.125	0
2023-02-12	2023	2	12	23	23	7	0.2	-0.7	4.8	1469.5	11.6	4.1	-3.65833	0
2023-02-12	2023	2	12	24	24	7	0.4	-0.3	5.4	1416.9	11.6	3.7	-3.03333	0
2023-02-13	2023	2	13	1	1	1	0.5	0.3	6.6	1377.7	14.7	3.3	-2.23333	1
2023-02-13	2023	2	13	2	1	1	0.8	-0.1	6.3	1363.0	14.7	2.9	-1.34167	1
2023-02-13	2023	2	13	3	1	1	1.0	-1.4	6.7	1360.7	14.7	2.3	-0.35833	1
2023-02-13	2023	2	13	4	1	1	1.1	-3	6.6	1372.9	14.7	1.7	0.566667	1
2023-02-13	2023	2	13	5	1	1	1.2	-3.1	5.9	1396.2	14.7	0.9	1.516667	1
2023-02-13	2023	2	13	6	1	1	1.3	-3	3.6	1463.4	14.7	0.1	2.491667	1
2023-02-13	2023	2	13	7	1	1	1.4	-1.8	1.1	1599.6	14.7	-0.7	3.466667	1
2023-02-13	2023	2	13	8	1	1	1.5	-1.5	-0.2	1711.7	14.7	-1.1	4.016667	1
2023-02-13	2023	2	13	9	1	1	1.5	-1.5	-1.2	1743.4	14.7	-1.3	4.283333	1
2023-02-13	2023	2	13	10	1	1	1.4	-1	-0.7	1717.4	14.7	-1.4	4.3	1
2023-02-13	2023	2	13	11	1	1	1.3	-0.4	-0.3	1691.7	14.7	-1.4	4.058333	1
2023-02-13	2023	2	13	12	1	1	1.2	0.5	0.3	1681.6	14.7	-1.4	3.741667	1
2023-02-13	2023	2	13	13	1	1	1.0	1.3	-0.1	1683.3	14.7	-1.3	3.316667	1
2023-02-13	2023	2	13	14	1	1	0.8	1.5	-1.4	1666.3	14.7	-1.3	2.891667	1
2023-02-13	2023	2	13	15	1	1	0.6	1.7	-3	1656.5	14.7	-1.1	2.333333	1
2023-02-13	2023	2	13	16	1	1	0.4	0.7	-3.1	1670.5	14.7	-0.9	1.691667	1
2023-02-13	2023	2	13	17	1	1	0.2	0.5	-3	1721.9	14.7	-0.6	0.883333	1
2023-02-13	2023	2	13	18	1	1	-0.1	-0.2	-1.8	1766.2	14.7	-0.3	0.075	1
2023-02-13	2023	2	13	19	1	1	-0.3	-0.3	-1.5	1765.2	14.7	0.0	-0.66667	1
2023-02-13	2023	2	13	20	1	1	-0.5	-1	-1.5	1726.2	14.7	0.1	-1.11667	1
2023-02-13	2023	2	13	21	1	1	-0.6	-1.3	-1	1669.6	14.7	0.2	-1.33333	1
2023-02-13	2023	2	13	22	1	1	-0.6	-1.5	-0.4	1592.1	14.7	0.2	-1.44167	1
2023-02-13	2023	2	13	23	1	1	-0.7	-1.6	0.5	1512.2	14.7	0.1	-1.425	1
2023-02-13	2023	2	13	24	1	1	-0.7	-1.7	1.3	1491.4	14.7	0.0	-1.4	1
2023-02-14	2023	2	14	1	2	2	-0.7	-1.9	1.5	1465.8	22.8	-0.2	-1.33333	1
2023-02-14	2023	2	14	2	2	2	-0.8	-2.2	1.7	1429.1	22.8	-0.4	-1.25	1
2023-02-14	2023	2	14	3	2	2	-0.9	-2.3	0.7	1389.6	22.8	-0.7	-1.11667	1
2023-02-14	2023	2	14	4	2	2	-1.0	-2.4	0.5	1391.0	22.8	-1.1	-0.85833	1
2023-02-14	2023	2	14	5	2	2	-0.9	-2.5	-0.2	1387.1	22.8	-1.3	-0.55	1
2023-02-14	2023	2	14	6	2	2	-0.9	-2.8	-0.3	1476.5	22.8	-1.6	-0.25	1
2023-02-14	2023	2	14	7	2	2	-0.9	-3.3	-1	1585.1	22.8	-1.8	-0.01667	1
2023-02-14	2023	2	14	8	2	2	-1.0	-3.5	-1.3	1656.1	22.8	-2.0	0.108333	1
2023-02-14	2023	2	14	9	2	2	-1.1	-3.5	-1.5	1705.5	22.8	-2.3	0.15	1
2023-02-14	2023	2	14	10	2	2	-1.1	-3.3	-1.6	1718.8	22.8	-2.4	0.166667	1
2023-02-14	2023	2	14	11	2	2	-1.2	-2.8	-1.7	1711.4	22.8	-2.6	0.125	1
2023-02-14	2023	2	14	12	2	2	-1.3	-2.4	-1.9	1708.0	22.8	-2.7	0.025	1
2023-02-14	2023	2	14	13	2	2	-1.5	-1.8	-2.2	1707.5	22.8	-2.7	-0.15833	1
2023-02-14	2023	2	14	14	2	2	-1.6	-1.1	-2.3	1677.1	22.8	-2.7	-0.425	1
2023-02-14	2023	2	14	15	2	2	-1.7	-0.4	-2.4	1646.1	22.8	-2.6	-0.73333	1
2023-02-14	2023	2	14	16	2	2	-1.8	-0.8	-2.5	1679.7	22.8	-2.5	-1.06667	1
2023-02-14	2023	2	14	17	2	2	-1.8	-1.6	-2.8	1744.0	22.8	-2.4	-1.325	1
2023-02-14	2023	2	14	18	2	2	-1.9	-2.4	-3.3	1804.2	22.8	-2.3	-1.575	1
2023-02-14	2023	2	14	19	2	2	-2.0	-3	-3.5	1826.0	22.8	-2.2	-1.79167	1
2023-02-14	2023	2	14	20	2	2	-2.1	-3.3	-3.5	1796.8	22.8	-2.2	-2.04167	1
2023-02-14	2023	2	14	21	2	2	-2.2	-4.1	-3.3	1761.4	22.8	-2.2	-2.25	1
2023-02-14	2023	2	14	22	2	2	-2.3	-4.7	-2.8	1704.1	22.8	-2.3	-2.43333	1
2023-02-14	2023	2	14	23	2	2	-2.5	-6	-2.4	1623.2	22.8	-2.4	-2.58333	1
2023-02-14	2023	2	14	24	2	2	-2.7	-6.7	-1.8	1607.5	22.8	-2.6	-2.68333	1
2023-02-15	2023	2	15	1	3	3	-2.9	-7.3	-1.1	1592.2	10.7	-3.0	-2.74167	1
2023-02-15	2023	2	15	2	3	3	-3.1	-7.7	-0.4	1572.7	10.7	-3.5	-2.73333	1
2023-02-15	2023	2	15	3	3	3	-3.3	-8	-0.8	1554.4	10.7	-4.0	-2.64167	1
2023-02-15	2023	2	15	4	3	3	-3.6	-8.2	-1.6	1558.4	10.7	-4.6	-2.48333	1
2023-02-15	2023	2	15	5	3	3	-3.8	-8.7	-2.4	1571.7	10.7	-5.3	-2.35	1
2023-02-15	2023	2	15	6	3	3	-4.1	-8	-3	1634.5	10.7	-5.8	-2.275	1
2023-02-15	2023	2	15	7	3	3	-4.3	-8.2	-3.3	1783.3	10.7	-6.3	-2.24167	1
2023-02-15	2023	2	15	8	3	3	-4.5	-9.7	-4.1	1892.5	10.7	-6.7	-2.21667	1
2023-02-15	2023	2	15	9	3	3	-4.7	-7.3	-4.7	1853.4	10.7	-7.3	-2.2	1
2023-02-15	2023	2	15	10	3	3	-4.9	-3.3	-6	1755.3	10.7	-7.5	-2.25	1
2023-02-15	2023	2	15	11	3	3	-4.9	-0.7	-6.7	1639.7	10.7	-7.4	-2.36667	1
2023-02-15	2023	2	15	12	3	3	-4.8	1.5	-7.3	1557.1	10.7	-7.0	-2.63333	1
2023-02-15	2023	2	15	13	3	3	-4.6	2.8	-7.7	1527.4	10.7	-6.3	-2.99167	1
2023-02-15	2023	2	15	14	3	3	-4.5	2.1	-8	1498.5	10.7	-5.5	-3.45	1
2023-02-15	2023	2	15	15	3	3	-4.3	2.6	-8.2	1470.2	10.7	-4.6	-4	1
2023-02-15	2023	2	15	16	3	3	-4.2	2.8	-8.7	1493.5	10.7	-3.8	-4.63333	1
2023-02-15	2023	2	15	17	3	3	-4.0	2.1	-8	1552.9	10.7	-2.8	-5.25	1
2023-02-15	2023	2	15	18	3	3	-3.9	1.8	-8.2	1614.9	10.7	-1.9	-5.84167	1
2023-02-15	2023	2	15	19	3	3	-3.7	1.8	-9.7	1637.7	10.7	-1.1	-6.30833	1
2023-02-15	2023	2	15	20	3	3	-3.5	1.9	-7.3	1622.2	10.7	-0.3	-6.74167	1
2023-02-15	2023	2	15	21	3	3	-3.3	2.2	-3.3	1586.9	10.7	0.7	-7.275	1
2023-02-15	2023	2	15	22	3	3	-3.0	2.8	-0.7	1516.9	10.7	1.5	-7.54167	1
2023-02-15	2023	2	15	23	3	3	-2.7	3	1.5	1417.7	10.7	2.0	-7.425	1
2023-02-15	2023	2	15	24	3	3	-2.4	3.7	2.8	1361.2	10.7	2.3	-6.98333	1
2023-02-16	2023	2	16	1	4	4	-1.9	3.8	2.1	1315.9	12.3	2.5	-6.3	1
2023-02-16	2023	2	16	2	4	4	-1.5	3.9	2.6	1275.5	12.3	2.6	-5.45833	1
2023-02-16	2023	2	16	3	4	4	-1.0	5.9	2.8	1241.2	12.3	2.7	-4.64167	1
2023-02-16	2023	2	16	4	4	4	-0.4	6.5	2.1	1213.4	12.3	3.0	-3.75833	1
2023-02-16	2023	2	16	5	4	4	0.2	5.8	1.8	1208.6	12.3	3.3	-2.84167	1
2023-02-16	2023	2	16	6	4	4	0.8	4.8	1.8	1248.1	12.3	3.6	-1.94167	1
2023-02-16	2023	2	16	7	4	4	1.4	4.8	1.9	1367.6	12.3	3.8	-1.125	1
2023-02-16	2023	2	16	8	4	4	1.9	5.9	2.2	1464.7	12.3	4.1	-0.29167	1
2023-02-16	2023	2	16	9	4	4	2.6	5.7	2.8	1458				

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLag	Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLag	Weekdays	
2023-02-16	2023		2	16	24	4	8.3	6.5	12.5	1220.6	12.3	10.9	5.625	1
2023-02-17	2023		2	17	1	5	8.4	5.8	13.3	1200.7	12.6	10.4	6.291667	1
2023-02-17	2023		2	17	2	5	8.5	5.2	14	1169.8	12.6	9.9	7.016667	1
2023-02-17	2023		2	17	3	5	8.5	4.1	14.2	1145.8	12.6	9.2	7.8	1
2023-02-17	2023		2	17	4	5	8.4	3.4	14.2	1143.5	12.6	8.4	8.475	1
2023-02-17	2023		2	17	5	5	8.3	3.2	12.4	1153.1	12.6	7.5	9.116667	1
2023-02-17	2023		2	17	6	5	8.2	3.4	10.1	1200.3	12.6	6.6	9.816667	1
2023-02-17	2023		2	17	7	5	8.1	3.6	8.7	1320.6	12.6	5.8	10.45	1
2023-02-17	2023		2	17	8	5	8.1	3.6	6.9	1425.4	12.6	5.3	10.89167	1
2023-02-17	2023		2	17	9	5	8.0	3.6	6.2	1474.4	12.6	4.9	11.125	1
2023-02-17	2023		2	17	10	5	7.9	3.4	6.3	1491.1	12.6	4.6	11.225	1
2023-02-17	2023		2	17	11	5	7.7	3.1	6.5	1498.2	12.6	4.3	11.14167	1
2023-02-17	2023		2	17	12	5	7.5	2.6	5.8	1518.2	12.6	4.1	10.875	1
2023-02-17	2023		2	17	13	5	7.1	2.1	5.2	1533.4	12.6	3.8	10.44167	1
2023-02-17	2023		2	17	14	5	6.7	2.1	4.1	1530.2	12.6	3.4	9.883333	1
2023-02-17	2023		2	17	15	5	6.2	2.3	3.4	1521.5	12.6	3.2	9.208333	1
2023-02-17	2023		2	17	16	5	5.7	3.4	3.2	1524.7	12.6	3.0	8.383333	1
2023-02-17	2023		2	17	17	5	5.3	4.4	3.4	1558.1	12.6	3.0	7.483333	1
2023-02-17	2023		2	17	18	5	4.9	5.7	3.6	1588.8	12.6	3.1	6.566667	1
2023-02-17	2023		2	17	19	5	4.6	4.9	3.6	1568.6	12.6	3.3	5.816667	1
2023-02-17	2023		2	17	20	5	4.4	3.5	3.6	1548.6	12.6	3.4	5.275	1
2023-02-17	2023		2	17	21	5	4.1	0.7	3.4	1517.6	12.6	3.4	4.85	1
2023-02-17	2023		2	17	22	5	3.9	0.4	3.1	1471.8	12.6	3.2	4.575	1
2023-02-17	2023		2	17	23	5	3.6	0.1	2.6	1417.3	12.6	2.9	4.341667	1
2023-02-17	2023		2	17	24	5	3.4	-0.4	2.1	1434.6	12.6	2.7	4.075	1
2023-02-18	2023		2	18	1	6	3.1	-0.9	2.1	1434.3	17.6	2.4	3.75	0
2023-02-18	2023		2	18	2	6	2.8	-2.1	2.3	1416.4	17.6	2.2	3.441667	0
2023-02-18	2023		2	18	3	6	2.5	-2.9	3.4	1397.4	17.6	1.8	3.183333	0
2023-02-18	2023		2	18	4	6	2.2	-3.4	4.4	1400.3	17.6	1.4	3.033333	0
2023-02-18	2023		2	18	5	6	1.9	-4.5	5.7	1414.8	17.6	0.8	3.033333	0
2023-02-18	2023		2	18	6	6	1.6	-4.8	4.9	1456.2	17.6	0.1	3.133333	0
2023-02-18	2023		2	18	7	6	1.3	-5.1	3.5	1527.0	17.6	-0.8	3.325	0
2023-02-18	2023		2	18	8	6	0.9	-5.5	0.7	1604.1	17.6	-1.6	3.433333	0
2023-02-18	2023		2	18	9	6	0.5	-6	0.4	1702.2	17.6	-2.4	3.425	0
2023-02-18	2023		2	18	10	6	0.1	-6.2	0.1	1769.4	17.6	-2.9	3.183333	0
2023-02-18	2023		2	18	11	6	-0.3	-5.8	-0.4	1765.3	17.6	-3.5	2.933333	0
2023-02-18	2023		2	18	12	6	-0.6	-5.6	-0.9	1721.7	17.6	-4.0	2.683333	0
2023-02-18	2023		2	18	13	6	-1.0	-4.6	-2.1	1656.7	17.6	-4.4	2.433333	0
2023-02-18	2023		2	18	14	6	-1.3	-4.7	-2.9	1582.2	17.6	-4.7	2.183333	0
2023-02-18	2023		2	18	15	6	-1.5	-3.7	-3.4	1540.9	17.6	-4.9	1.833333	0
2023-02-18	2023		2	18	16	6	-1.8	-3.5	-4.5	1530.3	17.6	-5.0	1.4	0
2023-02-18	2023		2	18	17	6	-2.1	-3.5	-4.8	1577.9	17.6	-5.0	0.833333	0
2023-02-18	2023		2	18	18	6	-2.4	-3.7	-5.1	1692.6	17.6	-4.9	0.091667	0
2023-02-18	2023		2	18	19	6	-2.8	-4.9	-5.5	1753.6	17.6	-4.8	-0.78333	0
2023-02-18	2023		2	18	20	6	-3.2	-5.3	-6	1737.4	17.6	-4.8	-1.61667	0
2023-02-18	2023		2	18	21	6	-3.6	-5.4	-6.2	1708.0	17.6	-4.8	-2.36667	0
2023-02-18	2023		2	18	22	6	-3.8	-5.1	-5.8	1669.5	17.6	-4.7	-2.925	0
2023-02-18	2023		2	18	23	6	-4.1	-5.4	-5.6	1619.8	17.6	-4.7	-3.475	0
2023-02-18	2023		2	18	24	6	-4.3	-5.6	-4.6	1575.4	17.6	-4.6	-3.96667	0
2023-02-19	2023		2	19	1	7	-4.5	-5.9	-4.7	1533.6	9.5	-4.6	-4.4	0
2023-02-19	2023		2	19	2	7	-4.7	-5.8	-3.7	1501.9	9.5	-4.7	-4.70833	0
2023-02-19	2023		2	19	3	7	-4.9	-4.6	-3.5	1484.7	9.5	-4.8	-4.925	0
2023-02-19	2023		2	19	4	7	-4.9	-4.3	-3.5	1482.0	9.5	-4.9	-4.99167	0
2023-02-19	2023		2	19	5	7	-5.0	-4.2	-3.7	1479.8	9.5	-5.0	-5	0
2023-02-19	2023		2	19	6	7	-5.0	-3.2	-4.9	1486.8	9.5	-5.0	-4.91667	0
2023-02-19	2023		2	19	7	7	-4.9	-3.7	-5.3	1525.0	9.5	-5.0	-4.825	0
2023-02-19	2023		2	19	8	7	-4.8	-3.1	-5.4	1579.4	9.5	-4.9	-4.80833	0
2023-02-19	2023		2	19	9	7	-4.7	-2.3	-5.1	1602.5	9.5	-4.7	-4.79167	0
2023-02-19	2023		2	19	10	7	-4.6	-0.4	-5.4	1571.2	9.5	-4.4	-4.74167	0
2023-02-19	2023		2	19	11	7	-4.3	1.9	-5.6	1520.4	9.5	-4.0	-4.65	0
2023-02-19	2023		2	19	12	7	-4.0	2.8	-5.9	1477.4	9.5	-3.4	-4.61667	0
2023-02-19	2023		2	19	13	7	-3.7	1.5	-5.8	1460.3	9.5	-2.7	-4.61667	0
2023-02-19	2023		2	19	14	7	-3.4	2.3	-4.6	1413.1	9.5	-2.1	-4.725	0
2023-02-19	2023		2	19	15	7	-3.1	2.3	-4.3	1374.6	9.5	-1.4	-4.81667	0
2023-02-19	2023		2	19	16	7	-2.9	3	-4.2	1369.9	9.5	-0.9	-4.89167	0
2023-02-19	2023		2	19	17	7	-2.6	3.1	-3.2	1433.7	9.5	-0.3	-4.95833	0
2023-02-19	2023		2	19	18	7	-2.3	1.8	-3.7	1520.7	9.5	0.4	-5.01667	0
2023-02-19	2023		2	19	19	7	-2.1	1.3	-3.1	1564.2	9.5	0.8	-4.975	0
2023-02-19	2023		2	19	20	7	-1.8	1.3	-2.3	1539.2	9.5	1.2	-4.875	0
2023-02-19	2023		2	19	21	7	-1.6	1.8	-0.4	1500.5	9.5	1.6	-4.69167	0
2023-02-19	2023		2	19	22	7	-1.3	2.1	1.9	1445.3	9.5	1.9	-4.43333	0
2023-02-19	2023		2	19	23	7	-1.0	2.5	2.8	1374.0	9.5	2.1	-4.04167	0
2023-02-19	2023		2	19	24	7	-0.6	2.6	1.5	1309.9	9.5	2.2	-3.43333	0
2023-02-20	2023		2	20	1	1	-0.3	2.8	2.3	1259.0	20.7	2.1	-2.73333	0
2023-02-20	2023		2	20	2	1	0.1	2.9	2.3	1231.3	20.7	2.2	-2.11667	0
2023-02-20	2023		2	20	3	1	0.4	3.2	3	1211.7	20.7	2.3	-1.44167	0
2023-02-20	2023		2	20	4	1	0.8	3.4	3.1	1201.8	20.7	2.4	-0.86667	0
2023-02-20	2023		2	20	5	1	1.1	3.5	1.8	1206.5	20.7	2.4	-0.25833	0
2023-02-20	2023		2	20	6	1	1.4	3.6	1.3	1227.7	20.7	2.4	0.35	0
2023-02-20	2023		2	20	7	1	1.7	4	1.3	1274.3	20.7	2.6	0.766667	0
2023-02-20	2023		2	20	8	1	2.0	4.3	1.8	1312.8	20.7	2.8	1.183333	0
2023-02-20	2023		2	20	9	1	2.3	4.9	2.1	1381.8	20.7	3.1	1.55	0
2023-02-20	2023		2	20	10	1	2.6	5.2	2.5	1428.0	20.7	3.3	1.891667	0
2023-02-20	2023		2	20	11	1	2.8	6.2	2.6	1464.5	20.7	3.6	2.1	0
2023-02-20	2023		2	20	12	1	3.0	6.1	2.8	1492.3	20.7	3.9	2.15	0
2023-02-20	2023		2	20	13	1	3.2	6.5	2.9	1508.9	20.7	4.2	2.133333	0
2023-02-20	2023		2	20	14	1	3.4	6.5	3.2	1488.1	20.7	4.5	2.241667	0
2023-02-20	2023		2	20	15	1	3.5	5.9	3.4	1462.4	20.7	4.8	2.291667	0
2023-02-20	2023		2	20	16	1	3.7	7.6	3.5	1447.4	20.7	5.0	2.366667	0
2023-02-20	2023		2	20	17	1	3.9	8.2	3.6	1469.8	20.7	5.4	2.4	0
2023-02-20	2023		2	20	18	1	4.1	8.4	4	1485.0	20.7	5.8	2.433333	0
2023-02-20	2023		2	20	19	1	4.4	7.2	4.3	1466.5	20.7	6.2	2.583333	0
2023-02-20	2023		2	20	20	1	4.6	6.6	4.9	1423.2	20.7	6.4	2.808333	0
2023-02-20	2023		2	20	21	1	4.8	6.9	5.2	1374.4	20.7	6.6	3.058333	0
2023-02-20	2023		2	20	22	1	5.0	6.4	6.2	1302.7	20.7	6.8	3.3	

DATE	Year	Month	Day	HOUR	DOW	24hrAvgLag	Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLag	Weekdays	
2023-02-21	2023	2	21	21	12	2	5.0	3.1	4.9	1406.0	10.5	3.1	6.825	1
2023-02-21	2023	2	21	21	13	2	4.9	3.9	4.3	1406.3	10.5	2.9	6.758333	1
2023-02-21	2023	2	21	21	14	2	4.7	4.6	3.6	1400.4	10.5	2.9	6.625	1
2023-02-21	2023	2	21	21	15	2	4.7	5	3.5	1410.7	10.5	2.9	6.441667	1
2023-02-21	2023	2	21	21	16	2	4.6	3.7	3	1446.2	10.5	3.0	6.25	1
2023-02-21	2023	2	21	21	17	2	4.5	2.8	2.4	1501.0	10.5	3.0	5.908333	1
2023-02-21	2023	2	21	21	18	2	4.2	2	2.2	1573.5	10.5	3.0	5.475	1
2023-02-21	2023	2	21	21	19	2	4.0	1	1.7	1613.5	10.5	3.0	4.975	1
2023-02-21	2023	2	21	21	20	2	3.7	0.4	1.8	1601.0	10.5	2.9	4.558333	1
2023-02-21	2023	2	21	21	21	2	3.5	-0.1	2.2	1572.1	10.5	2.8	4.15	1
2023-02-21	2023	2	21	22	22	2	3.2	-1.1	2.6	1518.0	10.5	2.6	3.725	1
2023-02-21	2023	2	21	23	23	2	2.9	-1.1	3.1	1450.9	10.5	2.3	3.375	1
2023-02-21	2023	2	21	24	24	2	2.6	-1.2	3.9	1436.7	10.5	2.0	3.125	1
2023-02-22	2023	2	22	1	1	3	2.3	-1.4	4.6	1419.6	13.3	1.7	2.941667	1
2023-02-22	2023	2	22	2	2	3	2.0	-1.7	5	1395.4	13.3	1.2	2.858333	1
2023-02-22	2023	2	22	3	3	3	1.8	-2.5	3.7	1374.9	13.3	0.7	2.883333	1
2023-02-22	2023	2	22	4	3	3	1.5	-3.1	2.8	1378.3	13.3	0.1	3	1
2023-02-22	2023	2	22	5	3	3	1.3	-3.8	2	1404.0	13.3	-0.5	3.016667	1
2023-02-22	2023	2	22	6	3	3	1.0	-4.9	1	1470.7	13.3	-1.1	3	1
2023-02-22	2023	2	22	7	3	3	0.7	-4.9	0.4	1609.3	13.3	-1.6	2.966667	1
2023-02-22	2023	2	22	8	3	3	0.4	-4.7	-0.1	1702.6	13.3	-2.1	2.866667	1
2023-02-22	2023	2	22	9	3	3	0.1	-4.1	-1.1	1673.7	13.3	-2.5	2.758333	1
2023-02-22	2023	2	22	10	3	3	-0.1	-2.3	-1.1	1590.2	13.3	-2.9	2.6	1
2023-02-22	2023	2	22	11	3	3	-0.3	-0.2	-1.2	1517.2	13.3	-3.0	2.325	1
2023-02-22	2023	2	22	12	3	3	-0.4	2.1	-1.4	1459.6	13.3	-2.9	2.016667	1
2023-02-22	2023	2	22	13	3	3	-0.5	3.9	-1.7	1434.5	13.3	-2.6	1.658333	1
2023-02-22	2023	2	22	14	3	3	-0.5	6.1	-2.5	1396.3	13.3	-2.2	1.216667	1
2023-02-22	2023	2	22	15	3	3	-0.4	6.3	-3.1	1351.6	13.3	-1.5	0.691667	1
2023-02-22	2023	2	22	16	3	3	-0.4	6.2	-3.8	1353.7	13.3	-0.8	0.066667	1
2023-02-22	2023	2	22	17	3	3	-0.3	5.8	-4.9	1411.4	13.3	0.0	-0.5	1
2023-02-22	2023	2	22	18	3	3	-0.1	3.9	-4.9	1526.1	13.3	0.8	-1.05	1
2023-02-22	2023	2	22	19	3	3	-0.1	2.4	-4.7	1601.1	13.3	1.5	-1.625	1
2023-02-22	2023	2	22	20	3	3	0.0	1.6	-4.1	1608.6	13.3	2.1	-2.11667	1
2023-02-22	2023	2	22	21	3	3	0.1	0.4	-2.3	1600.0	13.3	2.6	-2.54167	1
2023-02-22	2023	2	22	22	3	3	0.1	-0.5	-0.2	1555.4	13.3	3.0	-2.875	1
2023-02-22	2023	2	22	23	3	3	0.1	-1.2	2.1	1496.8	13.3	3.2	-2.975	1
2023-02-22	2023	2	22	24	3	3	0.1	-2	3.9	1487.3	13.3	3.1	-2.9	1
2023-02-23	2023	2	23	1	4	4	0.1	-2.9	6.1	1472.9	14.0	2.7	-2.625	1
2023-02-23	2023	2	23	2	4	4	0.0	-4	6.3	1457.7	14.0	2.2	-2.18333	1
2023-02-23	2023	2	23	3	4	4	-0.1	-4.8	6.2	1452.0	14.0	1.3	-1.53333	1
2023-02-23	2023	2	23	4	4	4	-0.2	-5.8	5.8	1457.4	14.0	0.4	-0.8	1
2023-02-23	2023	2	23	5	4	4	-0.3	-6.5	3.9	1479.0	14.0	-0.6	-0.025	1
2023-02-23	2023	2	23	6	4	4	-0.4	-7.1	2.4	1548.0	14.0	-1.6	0.775	1
2023-02-23	2023	2	23	7	4	4	-0.5	-7.6	1.6	1696.4	14.0	-2.5	1.508333	1
2023-02-23	2023	2	23	8	4	4	-0.6	-8	0.4	1812.5	14.0	-3.4	2.116667	1
2023-02-23	2023	2	23	9	4	4	-0.8	-8.2	-0.5	1849.0	14.0	-4.2	2.641667	1
2023-02-23	2023	2	23	10	4	4	-0.9	-8.2	-1.2	1854.2	14.0	-4.9	3.016667	1
2023-02-23	2023	2	23	11	4	4	-1.2	-8	-2	1856.3	14.0	-5.5	3.166667	1
2023-02-23	2023	2	23	12	4	4	-1.5	-8	-2.9	1861.8	14.0	-6.1	3.083333	1
2023-02-23	2023	2	23	13	4	4	-1.9	-7.4	-4	1858.4	14.0	-6.6	2.741667	1
2023-02-23	2023	2	23	14	4	4	-2.4	-7.1	-4.8	1818.9	14.0	-7.0	2.175	1
2023-02-23	2023	2	23	15	4	4	-2.9	-6.4	-5.8	1784.0	14.0	-7.2	1.333333	1
2023-02-23	2023	2	23	16	4	4	-3.5	-6.2	-6.5	1812.7	14.0	-7.4	0.408333	1
2023-02-23	2023	2	23	17	4	4	-4.0	-6	-7.1	1864.2	14.0	-7.4	-0.59167	1
2023-02-23	2023	2	23	18	4	4	-4.5	-6.3	-7.6	1913.8	14.0	-7.4	-1.61667	1
2023-02-23	2023	2	23	19	4	4	-4.9	-6.4	-8	1925.4	14.0	-7.3	-2.53333	1
2023-02-23	2023	2	23	20	4	4	-5.3	-6.8	-8.2	1895.5	14.0	-7.2	-3.36667	1
2023-02-23	2023	2	23	21	4	4	-5.6	-7.5	-8.2	1852.9	14.0	-7.1	-4.16667	1
2023-02-23	2023	2	23	22	4	4	-6.0	-7.9	-8	1782.1	14.0	-7.0	-4.88333	1
2023-02-23	2023	2	23	23	4	4	-6.3	-8.1	-8	1692.9	14.0	-7.0	-5.525	1
2023-02-23	2023	2	23	24	4	4	-6.6	-8.3	-7.4	1668.9	14.0	-7.0	-6.09167	1
2023-02-24	2023	2	24	1	5	5	-6.8	-8.2	-7.1	1650.0	19.4	-7.0	-6.59167	1
2023-02-24	2023	2	24	2	5	5	-7.0	-8.7	-6.4	1634.3	19.4	-7.1	-6.96667	1
2023-02-24	2023	2	24	3	5	5	-7.2	-8.9	-6.2	1618.5	19.4	-7.2	-7.225	1
2023-02-24	2023	2	24	4	5	5	-7.4	-9.3	-6	1609.6	19.4	-7.4	-7.35833	1
2023-02-24	2023	2	24	5	5	5	-7.5	-9	-6.3	1626.0	19.4	-7.7	-7.39167	1
2023-02-24	2023	2	24	6	5	5	-7.7	-8.9	-6.4	1679.4	19.4	-8.0	-7.35	1
2023-02-24	2023	2	24	7	5	5	-7.7	-8.9	-6.8	1787.0	19.4	-8.2	-7.28333	1
2023-02-24	2023	2	24	8	5	5	-7.8	-8.9	-7.5	1857.6	19.4	-8.4	-7.18333	1
2023-02-24	2023	2	24	9	5	5	-7.8	-8.6	-7.9	1907.6	19.4	-8.6	-7.08333	1
2023-02-24	2023	2	24	10	5	5	-7.8	-8.1	-8.1	1919.2	19.4	-8.6	-7.025	1
2023-02-24	2023	2	24	11	5	5	-7.8	-7.8	-8.3	1918.5	19.4	-8.7	-7	1
2023-02-24	2023	2	24	12	5	5	-7.8	-7.8	-8.2	1915.3	19.4	-8.6	-7.00833	1
2023-02-24	2023	2	24	13	5	5	-7.8	-7.7	-8.7	1932.1	19.4	-8.6	-7.03333	1
2023-02-24	2023	2	24	14	5	5	-7.8	-7.5	-8.9	1913.0	19.4	-8.6	-7.1	1
2023-02-24	2023	2	24	15	5	5	-7.8	-7.1	-9.3	1892.1	19.4	-8.5	-7.23333	1
2023-02-24	2023	2	24	16	5	5	-7.9	-6.6	-9	1900.2	19.4	-8.3	-7.44167	1
2023-02-24	2023	2	24	17	5	5	-7.9	-6.9	-8.9	1936.3	19.4	-8.1	-7.7	1
2023-02-24	2023	2	24	18	5	5	-7.9	-7.6	-8.9	1992.9	19.4	-7.9	-7.95	1
2023-02-24	2023	2	24	19	5	5	-8.0	-8	-8.9	2016.3	19.4	-7.8	-8.16667	1
2023-02-24	2023	2	24	20	5	5	-8.0	-8.7	-8.6	1979.4	19.4	-7.7	-8.375	1
2023-02-24	2023	2	24	21	5	5	-8.1	-9.3	-8.1	1932.2	19.4	-7.7	-8.55	1
2023-02-24	2023	2	24	22	5	5	-8.2	-9.9	-7.8	1878.3	19.4	-7.8	-8.64167	1
2023-02-24	2023	2	24	23	5	5	-8.3	-10.4	-7.8	1819.5	19.4	-7.9	-8.65833	1
2023-02-24	2023	2	24	24	5	5	-8.4	-11.4	-7.7	1812.7	19.4	-8.1	-8.63333	1
2023-02-25	2023	2	25	1	6	6	-8.5	-12.1	-7.5	1797.9	13.5	-8.4	-8.59167	0
2023-02-25	2023	2	25	2	6	6	-8.7	-12.6	-7.1	1776.8	13.5	-8.8	-8.55	0
2023-02-25	2023	2	25	3	6	6	-8.8	-13.3	-6.6	1771.0	13.5	-9.2	-8.45	0
2023-02-25	2023	2	25	4	6	6	-9.0	-13.8	-6.9	1771.8	13.5	-9.7	-8.3	0
2023-02-25	2023	2	25	5	6	6	-9.2	-14.9	-7.6	1785.5	13.5	-10.3	-8.075	0
2023-02-25	2023	2	25	6	6	6	-9.5	-15.1	-8	1823.4	13.5	-11.0	-7.9	0
2023-02-25	2023	2	25	7	6	6	-9.7	-14.9	-8.7	1896.2	13.5	-11.6	-7.79167	0
2023-02-25	2023	2	25	8	6	6	-10.0	-15.3	-9.3	1956.0	13.5	-12.2	-7.71667	0
2023-02-25	2023	2	25	9	6	6	-10.2	-14.2	-9.9	1959.7				

DATE	Year	Month	Day	HOUR	DOW	24hrAvgLag	Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLag	Weekdays	
2023-02-25	2023		2	25	24	6	-12.4	-12.7	-11.8	1813.6	13.5	-11.1	-13.5833	0
2023-02-26	2023		2	26	1	7	-12.4	-13.4	-9.7	1778.8	5.9	-11.2	-13.625	0
2023-02-26	2023		2	26	2	7	-12.5	-13.8	-9.6	1773.8	5.9	-11.3	-13.6	0
2023-02-26	2023		2	26	3	7	-12.5	-15.4	-9.5	1777.6	5.9	-11.7	-13.3583	0
2023-02-26	2023		2	26	4	7	-12.6	-15.5	-9.6	1794.6	5.9	-12.2	-13.05	0
2023-02-26	2023		2	26	5	7	-12.7	-14.4	-10.8	1822.9	5.9	-12.7	-12.6917	0
2023-02-26	2023		2	26	6	7	-12.7	-14.9	-11.6	1863.6	5.9	-13.1	-12.25	0
2023-02-26	2023		2	26	7	7	-12.6	-16.2	-12.1	1913.9	5.9	-13.4	-11.8917	0
2023-02-26	2023		2	26	8	7	-12.7	-15.3	-12.3	1966.2	5.9	-13.8	-11.6167	0
2023-02-26	2023		2	26	9	7	-12.7	-12.3	-12.3	1960.8	5.9	-14.0	-11.35	0
2023-02-26	2023		2	26	10	7	-12.6	-10.7	-12.3	1921.2	5.9	-14.0	-11.1917	0
2023-02-26	2023		2	26	11	7	-12.5	-9.9	-12.7	1875.5	5.9	-13.9	-11.125	0
2023-02-26	2023		2	26	12	7	-12.4	-8.3	-13.4	1830.4	5.9	-13.7	-11.125	0
2023-02-26	2023		2	26	13	7	-12.3	-6.6	-13.8	1788.9	5.9	-13.3	-11.1917	0
2023-02-26	2023		2	26	14	7	-12.1	-7.8	-15.4	1722.4	5.9	-12.8	-11.325	0
2023-02-26	2023		2	26	15	7	-12.0	-7.4	-15.5	1689.6	5.9	-12.3	-11.6667	0
2023-02-26	2023		2	26	16	7	-11.9	-7.5	-14.4	1715.4	5.9	-11.6	-12.15	0
2023-02-26	2023		2	26	17	7	-11.8	-8	-14.9	1807.2	5.9	-10.9	-12.65	0
2023-02-26	2023		2	26	18	7	-11.7	-8.2	-16.2	1888.2	5.9	-10.4	-13.05	0
2023-02-26	2023		2	26	19	7	-11.6	-8.4	-15.3	1945.9	5.9	-9.9	-13.3917	0
2023-02-26	2023		2	26	20	7	-11.5	-8.5	-12.3	1940.3	5.9	-9.2	-13.775	0
2023-02-26	2023		2	26	21	7	-11.3	-8.3	-10.7	1898.0	5.9	-8.6	-14.0417	0
2023-02-26	2023		2	26	22	7	-11.2	-8.3	-9.9	1833.8	5.9	-8.3	-14.0417	0
2023-02-26	2023		2	26	23	7	-11.0	-8.6	-8.3	1748.9	5.9	-8.1	-13.9083	0
2023-02-26	2023		2	26	24	7	-10.9	-9.1	-6.6	1686.9	5.9	-8.0	-13.7083	0
2023-02-27	2023		2	27	1	1	-10.7	-10.3	-7.8	1655.1	13.4	-8.1	-13.3417	1
2023-02-27	2023		2	27	2	1	-10.6	-11.3	-7.4	1658.0	13.4	-8.4	-12.775	1
2023-02-27	2023		2	27	3	1	-10.5	-11.1	-7.5	1664.0	13.4	-8.7	-12.275	1
2023-02-27	2023		2	27	4	1	-10.3	-12.1	-8	1688.6	13.4	-9.0	-11.6083	1
2023-02-27	2023		2	27	5	1	-10.1	-12.4	-8.2	1728.6	13.4	-9.4	-10.9417	1
2023-02-27	2023		2	27	6	1	-10.1	-12.1	-8.4	1813.7	13.4	-9.7	-10.4083	1
2023-02-27	2023		2	27	7	1	-9.9	-12.5	-8.5	1967.3	13.4	-10.0	-9.85	1
2023-02-27	2023		2	27	8	1	-9.8	-12.7	-8.3	2045.4	13.4	-10.4	-9.2	1
2023-02-27	2023		2	27	9	1	-9.7	-11.8	-8.3	1990.4	13.4	-10.7	-8.63333	1
2023-02-27	2023		2	27	10	1	-9.7	-9.8	-8.6	1889.9	13.4	-11.0	-8.3	1
2023-02-27	2023		2	27	11	1	-9.6	-8.2	-9.1	1811.4	13.4	-11.2	-8.1	1
2023-02-27	2023		2	27	12	1	-9.6	-6.8	-10.3	1764.9	13.4	-11.1	-7.99167	1
2023-02-27	2023		2	27	13	1	-9.5	-5.8	-11.3	1739.3	13.4	-10.9	-8.05833	1
2023-02-27	2023		2	27	14	1	-9.5	-5.2	-11.1	1683.2	13.4	-10.6	-8.36667	1
2023-02-27	2023		2	27	15	1	-9.4	-4.6	-12.1	1640.2	13.4	-10.0	-8.65833	1
2023-02-27	2023		2	27	16	1	-9.2	-4.4	-12.4	1648.2	13.4	-9.5	-8.96667	1
2023-02-27	2023		2	27	17	1	-9.1	-4.3	-12.1	1708.4	13.4	-8.9	-9.35	1
2023-02-27	2023		2	27	18	1	-9.0	-5.2	-12.5	1812.5	13.4	-8.2	-9.71667	1
2023-02-27	2023		2	27	19	1	-8.8	-6.8	-12.7	1893.4	13.4	-7.6	-10.0417	1
2023-02-27	2023		2	27	20	1	-8.8	-7.8	-11.8	1906.9	13.4	-7.1	-10.3833	1
2023-02-27	2023		2	27	21	1	-8.7	-8.7	-9.8	1890.0	13.4	-6.7	-10.7333	1
2023-02-27	2023		2	27	22	1	-8.7	-9.8	-8.2	1842.1	13.4	-6.5	-11.025	1
2023-02-27	2023		2	27	23	1	-8.8	-10.7	-6.8	1780.5	13.4	-6.5	-11.15	1
2023-02-27	2023		2	27	24	1	-8.9	-10.7	-5.8	1781.8	13.4	-6.7	-11.1167	1
2023-02-28	2023		2	28	1	2	-9.0	-12.4	-5.2	1777.2	12.9	-7.0	-10.925	1
2023-02-28	2023		2	28	2	2	-9.1	-11.7	-4.6	1767.7	12.9	-7.6	-10.55	1
2023-02-28	2023		2	28	3	2	-9.1	-11.5	-4.4	1766.5	12.9	-8.1	-10.0417	1
2023-02-28	2023		2	28	4	2	-9.1	-11.6	-4.3	1773.6	12.9	-8.7	-9.5	1
2023-02-28	2023		2	28	5	2	-9.1	-11.6	-5.2	1783.2	12.9	-9.3	-8.85833	1
2023-02-28	2023		2	28	6	2	-9.0	-12	-6.8	1848.3	12.9	-9.9	-8.18333	1
2023-02-28	2023		2	28	7	2	-9.0	-12.4	-7.8	1980.5	12.9	-10.4	-7.60833	1
2023-02-28	2023		2	28	8	2	-9.0	-12.4	-8.7	2047.5	12.9	-10.9	-7.13333	1
2023-02-28	2023		2	28	9	2	-9.0	-11.2	-9.8	1999.9	12.9	-11.3	-6.725	1
2023-02-28	2023		2	28	10	2	-9.0	-9	-10.7	1899.1	12.9	-11.5	-6.46667	1
2023-02-28	2023		2	28	11	2	-9.0	-6.4	-10.7	1798.4	12.9	-11.4	-6.46667	1
2023-02-28	2023		2	28	12	2	-8.9	-5.3	-12.4	1749.6	12.9	-11.1	-6.675	1
2023-02-28	2023		2	28	13	2	-8.8	-4.8	-11.7	1726.1	12.9	-10.6	-7	1
2023-02-28	2023		2	28	14	2	-8.8	-3.9	-11.5	1686.7	12.9	-10.0	-7.55	1
2023-02-28	2023		2	28	15	2	-8.7	-4.7	-11.6	1657.9	12.9	-9.3	-8.09167	1
2023-02-28	2023		2	28	16	2	-8.7	-3.6	-11.6	1659.6	12.9	-8.8	-8.66667	1
2023-02-28	2023		2	28	17	2	-8.7	-4.6	-12	1724.0	12.9	-8.1	-9.26667	1
2023-02-28	2023		2	28	18	2	-8.7	-4.7	-12.4	1814.7	12.9	-7.5	-9.875	1
2023-02-28	2023		2	28	19	2	-8.7	-5	-12.4	1881.0	12.9	-6.9	-10.4417	1
2023-02-28	2023		2	28	20	2	-8.6	-5.1	-11.2	1870.3	12.9	-6.3	-10.9083	1
2023-02-28	2023		2	28	21	2	-8.5	-4.4	-9	1826.0	12.9	-5.7	-11.2917	1
2023-02-28	2023		2	28	22	2	-8.3	-4.8	-6.4	1753.6	12.9	-5.1	-11.5	1
2023-02-28	2023		2	28	23	2	-8.1	-3.4	-5.3	1658.3	12.9	-4.8	-11.4333	1
2023-02-28	2023		2	28	24	2	-7.8	-3.1	-4.8	1623.8	12.9	-4.5	-11.075	1
2023-03-01	2023		3	1	1	3	-7.5	-2.9	-3.9	1588.2	12.2	-4.3	-10.625	1
2023-03-01	2023		3	1	2	3	-7.1	-2.8	-4.7	1560.0	12.2	-4.2	-9.99167	1
2023-03-01	2023		3	1	3	3	-6.7	-2.6	-3.6	1532.1	12.2	-4.1	-9.34167	1
2023-03-01	2023		3	1	4	3	-6.3	-2.3	-4.6	1527.6	12.2	-3.9	-8.775	1
2023-03-01	2023		3	1	5	3	-6.0	-5.4	-4.7	1542.3	12.2	-3.8	-8.10833	1
2023-03-01	2023		3	1	6	3	-5.7	-6	-5	1600.2	12.2	-3.9	-7.525	1
2023-03-01	2023		3	1	7	3	-5.5	-5.8	-5.1	1732.9	12.2	-4.0	-6.91667	1
2023-03-01	2023		3	1	8	3	-5.2	-5.9	-4.4	1831.4	12.2	-4.1	-6.3	1
2023-03-01	2023		3	1	9	3	-4.9	-5.8	-4.8	1857.3	12.2	-4.1	-5.69167	1
2023-03-01	2023		3	1	10	3	-4.7	-5.4	-3.4	1821.7	12.2	-4.2	-5.125	1
2023-03-01	2023		3	1	11	3	-4.5	-4.7	-3.1	1756.6	12.2	-4.3	-4.775	1
2023-03-01	2023		3	1	12	3	-4.5	-3.5	-2.9	1714.7	12.2	-4.4	-4.525	1
2023-03-01	2023		3	1	13	3	-4.4	-2.6	-2.8	1674.8	12.2	-4.4	-4.34167	1
2023-03-01	2023		3	1	14	3	-4.3	-1	-2.6	1623.1	12.2	-4.4	-4.18333	1
2023-03-01	2023		3	1	15	3	-4.2	-1.3	-2.3	1610.6	12.2	-4.3	-4.09167	1
2023-03-01	2023		3	1	16	3	-4.0	-1.6	-5.4	1626.9	12.2	-4.1	-3.91667	1
2023-03-01	2023		3	1	17	3	-3.9	-1.5	-6	1675.3	12.2	-4.1	-3.80833	1
2023-03-01	2023		3	1	18	3	-3.8	-1.9	-5.8	1739.4	12.2	-3.8	-3.875	1
2023-03-01	2023		3	1	19	3	-3.7	-2.2	-5.9	1766.8	12.2	-3.4	-3.98333	1
2023-03-01	2023		3	1	20	3	-3.6	-2.3	-5.8	1735.3	12.2	-3.1	-4.05	1
2023-03-01	2023		3	1	21	3	-3.5	-2.2	-5.4	1695.6	12.2	-2.8	-4.11667	1
2023-03-01	2023		3	1	22	3	-3.4	-2.						

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLag	Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLag	Weekdays	
2023-03-02	2023		3	2	12	4	-2.2	1	-1.7	1580.5	9.8	-2.3	-2.1	1
2023-03-02	2023		3	2	13	4	-2.0	0.7	-1.9	1564.1	9.8	-2.1	-1.95833	1
2023-03-02	2023		3	2	14	4	-1.9	0.2	-2.3	1553.2	9.8	-1.9	-1.88333	1
2023-03-02	2023		3	2	15	4	-1.8	0.5	-2.5	1544.5	9.8	-1.7	-1.95833	1
2023-03-02	2023		3	2	16	4	-1.7	-0.4	-2.1	1583.5	9.8	-1.4	-2.04167	1
2023-03-02	2023		3	2	17	4	-1.7	-0.3	-2.8	1646.8	9.8	-1.3	-2.11667	1
2023-03-02	2023		3	2	18	4	-1.6	-0.7	-3.9	1700.9	9.8	-1.1	-2.16667	1
2023-03-02	2023		3	2	19	4	-1.6	-0.6	-5.1	1711.1	9.8	-0.9	-2.24167	1
2023-03-02	2023		3	2	20	4	-1.5	0	-3.2	1670.3	9.8	-0.7	-2.38333	1
2023-03-02	2023		3	2	21	4	-1.4	0.1	0	1606.8	9.8	-0.2	-2.61667	1
2023-03-02	2023		3	2	22	4	-1.3	0.1	-0.1	1546.0	9.8	0.0	-2.7	1
2023-03-02	2023		3	2	23	4	-1.2	0.3	1	1469.3	9.8	0.0	-2.51667	1
2023-03-02	2023		3	2	24	4	-1.1	0.2	0.7	1436.3	9.8	0.1	-2.28333	1
2023-03-03	2023		3	3	1	5	-1.0	0	0.2	1427.8	22.4	0.0	-2.05	1
2023-03-03	2023		3	3	2	5	-1.0	-0.3	0.5	1416.4	22.4	-0.1	-1.85	1
2023-03-03	2023		3	3	3	5	-0.9	-2.3	-0.4	1426.4	22.4	-0.1	-1.675	1
2023-03-03	2023		3	3	4	5	-0.9	-4.1	-0.3	1432.4	22.4	-0.3	-1.44167	1
2023-03-03	2023		3	3	5	5	-1.0	-3.5	-0.7	1444.4	22.4	-0.6	-1.26667	1
2023-03-03	2023		3	3	6	5	-1.0	-4.3	-0.6	1487.9	22.4	-0.9	-1.11667	1
2023-03-03	2023		3	3	7	5	-1.1	-4.9	0	1577.1	22.4	-1.2	-0.94167	1
2023-03-03	2023		3	3	8	5	-1.1	-5	0.1	1649.7	22.4	-1.6	-0.66667	1
2023-03-03	2023		3	3	9	5	-1.1	-4.8	0.1	1676.4	22.4	-2.0	-0.24167	1
2023-03-03	2023		3	3	10	5	-1.2	-4	0.3	1658.7	22.4	-2.4	0.033333	1
2023-03-03	2023		3	3	11	5	-1.3	-2.8	0.2	1641.2	22.4	-2.7	0.041667	1
2023-03-03	2023		3	3	12	5	-1.5	-1.8	0	1649.0	22.4	-3.0	0.075	1
2023-03-03	2023		3	3	13	5	-1.6	-1.3	-0.3	1650.5	22.4	-3.2	0.008333	1
2023-03-03	2023		3	3	14	5	-1.7	-0.8	-2.3	1610.9	22.4	-3.3	-0.05	1
2023-03-03	2023		3	3	15	5	-1.7	-0.8	-4.1	1576.3	22.4	-3.3	-0.09167	1
2023-03-03	2023		3	3	16	5	-1.8	-0.5	-3.5	1549.1	22.4	-3.2	-0.325	1
2023-03-03	2023		3	3	17	5	-1.8	-0.5	-4.3	1550.9	22.4	-2.9	-0.63333	1
2023-03-03	2023		3	3	18	5	-1.8	0.3	-4.9	1607.0	22.4	-2.6	-0.9	1
2023-03-03	2023		3	3	19	5	-1.7	-0.9	-5	1673.3	22.4	-2.2	-1.2	1
2023-03-03	2023		3	3	20	5	-1.7	-1.4	-4.8	1679.2	22.4	-1.9	-1.55833	1
2023-03-03	2023		3	3	21	5	-1.8	-2.2	-4	1647.5	22.4	-1.6	-1.975	1
2023-03-03	2023		3	3	22	5	-1.9	-2.7	-2.8	1606.6	22.4	-1.4	-2.38333	1
2023-03-03	2023		3	3	23	5	-2.0	-3.8	-1.8	1563.8	22.4	-1.3	-2.725	1
2023-03-03	2023		3	3	24	5	-2.2	-4	-1.3	1556.4	22.4	-1.4	-2.98333	1
2023-03-04	2023		3	4	1	6	-2.4	-4.7	-0.8	1543.2	6.7	-1.6	-3.15	0
2023-03-04	2023		3	4	2	6	-2.5	-5.3	-0.8	1525.8	6.7	-1.8	-3.25833	0
2023-03-04	2023		3	4	3	6	-2.8	-6	-0.5	1510.7	6.7	-2.2	-3.3	0
2023-03-04	2023		3	4	4	6	-2.9	-6.7	-0.5	1513.8	6.7	-2.6	-3.175	0
2023-03-04	2023		3	4	5	6	-3.0	-7.3	0.3	1527.2	6.7	-3.2	-2.875	0
2023-03-04	2023		3	4	6	6	-3.2	-7.7	-0.9	1577.2	6.7	-3.7	-2.625	0
2023-03-04	2023		3	4	7	6	-3.3	-9.5	-1.4	1634.3	6.7	-4.4	-2.24167	0
2023-03-04	2023		3	4	8	6	-3.5	-8.6	-2.2	1693.4	6.7	-5.1	-1.90833	0
2023-03-04	2023		3	4	9	6	-3.7	-7.5	-2.7	1742.4	6.7	-5.7	-1.60833	0
2023-03-04	2023		3	4	10	6	-3.8	-5.9	-3.8	1757.9	6.7	-6.2	-1.39167	0
2023-03-04	2023		3	4	11	6	-3.9	-6.2	-4	1759.6	6.7	-6.4	-1.28333	0
2023-03-04	2023		3	4	12	6	-4.0	-6	-4.7	1743.8	6.7	-6.6	-1.36667	0
2023-03-04	2023		3	4	13	6	-4.2	-4.9	-5.3	1696.9	6.7	-6.8	-1.55	0
2023-03-04	2023		3	4	14	6	-4.3	-4.7	-6	1642.8	6.7	-6.8	-1.83333	0
2023-03-04	2023		3	4	15	6	-4.5	-4	-6.7	1605.8	6.7	-6.8	-2.20833	0
2023-03-04	2023		3	4	16	6	-4.6	-3.6	-7.3	1594.3	6.7	-6.6	-2.64167	0
2023-03-04	2023		3	4	17	6	-4.7	-3.6	-7.7	1639.8	6.7	-6.3	-3.15833	0
2023-03-04	2023		3	4	18	6	-4.9	-3.7	-9.5	1699.5	6.7	-6.0	-3.725	0
2023-03-04	2023		3	4	19	6	-5.0	-3.8	-8.6	1726.7	6.7	-5.7	-4.39167	0
2023-03-04	2023		3	4	20	6	-5.2	-3.6	-7.5	1700.7	6.7	-5.2	-5.10833	0
2023-03-04	2023		3	4	21	6	-5.3	-2.7	-5.9	1659.9	6.7	-4.8	-5.70833	0
2023-03-04	2023		3	4	22	6	-5.3	-3.9	-6.2	1619.1	6.7	-4.4	-6.15	0
2023-03-04	2023		3	4	23	6	-5.3	-5.3	-6	1560.5	6.7	-4.2	-6.41667	0
2023-03-04	2023		3	4	24	6	-5.4	-6.1	-4.9	1528.6	6.7	-4.2	-6.61667	0
2023-03-05	2023		3	5	1	7	-5.5	-6.4	-4.7	1490.2	15.8	-4.2	-6.78333	0
2023-03-05	2023		3	5	2	7	-5.5	-6.1	-4	1477.7	15.8	-4.3	-6.8	0
2023-03-05	2023		3	5	3	7	-5.6	-6.6	-3.6	1477.7	15.8	-4.4	-6.75	0
2023-03-05	2023		3	5	4	7	-5.6	-6.7	-3.6	1490.5	15.8	-4.6	-6.58333	0
2023-03-05	2023		3	5	5	7	-5.6	-6.9	-3.7	1503.7	15.8	-4.9	-6.325	0
2023-03-05	2023		3	5	6	7	-5.6	-7.1	-3.8	1528.2	15.8	-5.2	-6.01667	0
2023-03-05	2023		3	5	7	7	-5.6	-7	-3.6	1574.2	15.8	-5.4	-5.68333	0
2023-03-05	2023		3	5	8	7	-5.5	-5.9	-2.7	1624.4	15.8	-5.7	-5.20833	0
2023-03-05	2023		3	5	9	7	-5.3	-4.3	-3.9	1628.4	15.8	-5.9	-4.79167	0
2023-03-05	2023		3	5	10	7	-5.2	-2.9	-5.3	1604.5	15.8	-6.0	-4.39167	0
2023-03-05	2023		3	5	11	7	-5.1	-1.8	-6.1	1572.9	15.8	-5.9	-4.225	0
2023-03-05	2023		3	5	12	7	-4.9	-0.7	-6.4	1541.2	15.8	-5.7	-4.15	0
2023-03-05	2023		3	5	13	7	-4.7	1.1	-6.1	1502.9	15.8	-5.2	-4.15833	0
2023-03-05	2023		3	5	14	7	-4.4	2	-6.6	1450.9	15.8	-4.6	-4.28333	0
2023-03-05	2023		3	5	15	7	-4.2	2.8	-6.7	1417.3	15.8	-3.9	-4.4	0
2023-03-05	2023		3	5	16	7	-3.9	3.6	-6.9	1411.7	15.8	-3.1	-4.61667	0
2023-03-05	2023		3	5	17	7	-3.6	3.8	-7.1	1462.2	15.8	-2.3	-4.875	0
2023-03-05	2023		3	5	18	7	-3.3	4	-7	1519.5	15.8	-1.4	-5.15	0
2023-03-05	2023		3	5	19	7	-2.9	3.2	-5.9	1592.0	15.8	-0.4	-5.43333	0
2023-03-05	2023		3	5	20	7	-2.6	2.6	-4.3	1609.3	15.8	0.4	-5.7	0
2023-03-05	2023		3	5	21	7	-2.4	2.1	-2.9	1576.8	15.8	1.1	-5.89167	0
2023-03-05	2023		3	5	22	7	-2.2	1.7	-1.8	1519.3	15.8	1.7	-6.025	0
2023-03-05	2023		3	5	23	7	-2.0	2.5	-0.7	1449.7	15.8	2.0	-5.94167	0
2023-03-05	2023		3	5	24	7	-1.6	2.7	1.1	1378.1	15.8	2.4	-5.65	0
2023-03-06	2023		3	6	1	1	-1.3	2.5	2	1332.4	17.2	2.7	-5.2	1
2023-03-06	2023		3	6	2	1	-0.9	2	2.8	1315.4	17.2	2.8	-4.575	1
2023-03-06	2023		3	6	3	1	-0.6	1.4	3.6	1311.0	17.2	2.8	-3.9	1
2023-03-06	2023		3	6	4	1	-0.2	1.1	3.8	1318.0	17.2	2.7	-3.11667	1
2023-03-06	2023		3	6	5	1	0.1	0.8	4	1343.4	17.2	2.5	-2.25833	1
2023-03-06	2023		3	6	6	1	0.4	1.1	3.2	1404.6	17.2	2.2	-1.36667	1
2023-03-06	2023		3	6	7	1	0.8	1	2.6	1508.8	17.2	2.0	-0.44167	1
2023-03-06	2023		3	6	8	1	1.1	0	2.1	1622.7	17.2	1.8	0.408333	1
2023-03-06	2023		3	6	9	1	1.3	-0.5	1.7	1673.8	17.2	1.6	1.116667	1
2023-03-06	2023		3	6	10	1	1.5	-0.3	2.5	1662.8	17.2	1.4	1.65	1
2023-03-06	2023		3	6	11	1	1.6	0.3	2.7	1622.9	17.2	1.2	2.033333	1
2023-03-06	2023		3	6	12	1	1.7	1.6						

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLag	Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLag	Weekdays
2023-03-06	2023	3	6	24	1	0.5	-2.1	1.4	1452.8	17.2	-0.1	1.008333	1
2023-03-07	2023	3	7	1	2	0.3	-2.1	1.7	1427.5	13.9	-0.4	0.916667	1
2023-03-07	2023	3	7	2	2	0.1	-2	0.9	1390.3	13.9	-0.7	0.825	1
2023-03-07	2023	3	7	3	2	-0.1	-1.9	1.2	1361.5	13.9	-1.0	0.8	1
2023-03-07	2023	3	7	4	2	-0.2	-2	0.9	1346.9	13.9	-1.2	0.758333	1
2023-03-07	2023	3	7	5	2	-0.4	-2	-0.8	1357.1	13.9	-1.5	0.766667	1
2023-03-07	2023	3	7	6	2	-0.5	-2	-0.5	1413.6	13.9	-1.8	0.775	1
2023-03-07	2023	3	7	7	2	-0.6	-2.2	-1.6	1540.8	13.9	-1.9	0.616667	1
2023-03-07	2023	3	7	8	2	-0.8	-2	-2	1632.8	13.9	-2.0	0.491667	1
2023-03-07	2023	3	7	9	2	-0.8	-1.7	-2	1638.2	13.9	-2.0	0.358333	1
2023-03-07	2023	3	7	10	2	-0.9	-0.9	-2	1603.2	13.9	-2.0	0.233333	1
2023-03-07	2023	3	7	11	2	-0.9	-0.1	-2.1	1557.9	13.9	-1.9	0.091667	1
2023-03-07	2023	3	7	12	2	-0.9	0.4	-2.1	1536.2	13.9	-1.8	-0.1	1
2023-03-07	2023	3	7	13	2	-1.0	0	-2	1529.7	13.9	-1.5	-0.40833	1
2023-03-07	2023	3	7	14	2	-1.0	0	-1.9	1500.3	13.9	-1.4	-0.7	1
2023-03-07	2023	3	7	15	2	-1.1	1.9	-2	1483.8	13.9	-1.2	-1.00833	1
2023-03-07	2023	3	7	16	2	-1.1	2.1	-2	1509.9	13.9	-0.9	-1.24167	1
2023-03-07	2023	3	7	17	2	-1.0	2.2	-2	1563.4	13.9	-0.5	-1.50833	1
2023-03-07	2023	3	7	18	2	-1.0	1.7	-2.2	1619.6	13.9	-0.2	-1.75	1
2023-03-07	2023	3	7	19	2	-0.9	1	-2	1641.4	13.9	0.1	-1.85	1
2023-03-07	2023	3	7	20	2	-0.8	1.2	-1.7	1626.5	13.9	0.4	-1.99167	1
2023-03-07	2023	3	7	21	2	-0.7	0.6	-0.9	1591.5	13.9	0.7	-2.025	1
2023-03-07	2023	3	7	22	2	-0.6	0.2	-0.1	1532.5	13.9	0.8	-2	1
2023-03-07	2023	3	7	23	2	-0.5	-0.4	0.4	1465.0	13.9	0.9	-1.90833	1
2023-03-07	2023	3	7	24	2	-0.4	-1.1	0	1447.3	13.9	0.9	-1.75	1
2023-03-08	2023	3	8	1	3	-0.4	-1.1	0	1412.3	22.4	0.8	-1.54167	1
2023-03-08	2023	3	8	2	3	-0.3	-1.1	1.9	1382.5	22.4	0.7	-1.36667	1
2023-03-08	2023	3	8	3	3	-0.3	-1.2	2.1	1343.3	22.4	0.6	-1.2	1
2023-03-08	2023	3	8	4	3	-0.3	-1.6	2.2	1327.7	22.4	0.3	-0.88333	1
2023-03-08	2023	3	8	5	3	-0.3	-1	1.7	1330.2	22.4	0.0	-0.54167	1
2023-03-08	2023	3	8	6	3	-0.2	-0.4	1	1375.4	22.4	-0.2	-0.19167	1
2023-03-08	2023	3	8	7	3	-0.1	0.4	1.2	1491.0	22.4	-0.4	0.116667	1
2023-03-08	2023	3	8	8	3	0.0	0.9	0.6	1581.7	22.4	-0.5	0.383333	1
2023-03-08	2023	3	8	9	3	0.1	1.6	0.2	1587.3	22.4	-0.5	0.65	1
2023-03-08	2023	3	8	10	3	0.2	2.7	-0.4	1547.3	22.4	-0.4	0.841667	1
2023-03-08	2023	3	8	11	3	0.4	3.5	-1.1	1516.8	22.4	-0.2	0.933333	1
2023-03-08	2023	3	8	12	3	0.5	4	-1.1	1503.5	22.4	0.1	0.908333	1
2023-03-08	2023	3	8	13	3	0.7	4.4	-1.1	1500.4	22.4	0.6	0.783333	1
2023-03-08	2023	3	8	14	3	0.9	4.1	-1.2	1480.9	22.4	1.0	0.691667	1
2023-03-08	2023	3	8	15	3	1.0	3.6	-1.6	1469.9	22.4	1.5	0.6	1
2023-03-08	2023	3	8	16	3	1.1	3.5	-1	1498.2	22.4	1.9	0.341667	1
2023-03-08	2023	3	8	17	3	1.2	2.6	-0.4	1559.0	22.4	2.3	0.033333	1
2023-03-08	2023	3	8	18	3	1.2	2.3	0.4	1619.1	22.4	2.6	-0.23333	1
2023-03-08	2023	3	8	19	3	1.2	1.7	0.9	1656.9	22.4	2.8	-0.40833	1
2023-03-08	2023	3	8	20	3	1.2	1.4	1.6	1644.0	22.4	2.9	-0.45833	1
2023-03-08	2023	3	8	21	3	1.2	1.2	2.7	1603.5	22.4	3.0	-0.48333	1
2023-03-08	2023	3	8	22	3	1.3	0.8	3.5	1530.0	22.4	2.9	-0.4	1
2023-03-08	2023	3	8	23	3	1.3	0.6	4	1445.3	22.4	2.8	-0.19167	1
2023-03-08	2023	3	8	24	3	1.3	0.8	4.4	1415.0	22.4	2.5	0.133333	1
2023-03-09	2023	3	9	1	4	1.4	0.3	4.1	1387.8	19.0	2.3	0.558333	1
2023-03-09	2023	3	9	2	4	1.5	0.4	3.6	1357.8	19.0	1.9	1.016667	1
2023-03-09	2023	3	9	3	4	1.5	0.2	3.5	1328.0	19.0	1.6	1.45	1
2023-03-09	2023	3	9	4	4	1.6	0.3	2.6	1316.9	19.0	1.3	1.85	1
2023-03-09	2023	3	9	5	4	1.7	0	2.3	1331.8	19.0	1.1	2.275	1
2023-03-09	2023	3	9	6	4	1.7	-0.2	1.7	1388.5	19.0	0.8	2.575	1
2023-03-09	2023	3	9	7	4	1.7	-0.2	1.4	1511.6	19.0	0.6	2.8	1
2023-03-09	2023	3	9	8	4	1.7	-0.1	1.2	1601.5	19.0	0.5	2.908333	1
2023-03-09	2023	3	9	9	4	1.6	0.8	0.8	1613.1	19.0	0.3	2.95	1
2023-03-09	2023	3	9	10	4	1.6	0.9	0.6	1594.7	19.0	0.3	2.916667	1
2023-03-09	2023	3	9	11	4	1.5	1	0.8	1572.6	19.0	0.3	2.758333	1
2023-03-09	2023	3	9	12	4	1.4	1.4	0.3	1549.6	19.0	0.4	2.516667	1
2023-03-09	2023	3	9	13	4	1.3	2	0.4	1510.7	19.0	0.4	2.25	1
2023-03-09	2023	3	9	14	4	1.2	2.9	0.2	1488.6	19.0	0.5	1.908333	1
2023-03-09	2023	3	9	15	4	1.2	1.8	0.3	1469.7	19.0	0.8	1.6	1
2023-03-09	2023	3	9	16	4	1.1	2	0	1488.0	19.0	0.9	1.316667	1
2023-03-09	2023	3	9	17	4	1.0	0.6	-0.2	1537.4	19.0	1.0	1.05	1
2023-03-09	2023	3	9	18	4	1.0	1.7	-0.2	1591.8	19.0	1.1	0.833333	1
2023-03-09	2023	3	9	19	4	0.9	1.1	-0.1	1636.1	19.0	1.2	0.625	1
2023-03-09	2023	3	9	20	4	0.9	0.8	0.8	1636.2	19.0	1.3	0.466667	1
2023-03-09	2023	3	9	21	4	0.9	0.3	0.9	1604.3	19.0	1.4	0.341667	1
2023-03-09	2023	3	9	22	4	0.8	-0.3	1	1548.1	19.0	1.4	0.308333	1
2023-03-09	2023	3	9	23	4	0.8	-0.7	1.4	1471.7	19.0	1.3	0.316667	1
2023-03-09	2023	3	9	24	4	0.7	-0.8	2	1447.7	19.0	1.1	0.35	1
2023-03-10	2023	3	10	1	5	0.7	-0.6	2.9	1427.5	14.5	1.0	0.4	1
2023-03-10	2023	3	10	2	5	0.6	-1.2	1.8	1402.2	14.5	0.7	0.541667	1
2023-03-10	2023	3	10	3	5	0.6	-1.5	2	1377.1	14.5	0.4	0.75	1
2023-03-10	2023	3	10	4	5	0.5	-1.9	0.6	1365.5	14.5	0.1	0.883333	1
2023-03-10	2023	3	10	5	5	0.4	-1.1	1.7	1379.8	14.5	-0.2	1.025	1
2023-03-10	2023	3	10	6	5	0.4	-1.4	1.1	1440.0	14.5	-0.4	1.075	1
2023-03-10	2023	3	10	7	5	0.3	-1.3	0.8	1549.3	14.5	-0.6	1.233333	1
2023-03-10	2023	3	10	8	5	0.3	-1.3	0.3	1616.7	14.5	-0.8	1.341667	1
2023-03-10	2023	3	10	9	5	0.2	0	-0.3	1580.3	14.5	-1.0	1.416667	1
2023-03-10	2023	3	10	10	5	0.2	0.9	-0.7	1512.2	14.5	-1.0	1.375	1
2023-03-10	2023	3	10	11	5	0.2	2.6	-0.8	1485.3	14.5	-0.9	1.275	1
2023-03-10	2023	3	10	12	5	0.3	2.5	-0.6	1487.8	14.5	-0.6	1.133333	1
2023-03-10	2023	3	10	13	5	0.3	2.6	-1.2	1489.0	14.5	-0.4	0.95	1
2023-03-10	2023	3	10	14	5	0.3	2.7	-1.5	1481.5	14.5	-0.1	0.733333	1
2023-03-10	2023	3	10	15	5	0.3	2.1	-1.9	1476.4	14.5	0.2	0.391667	1
2023-03-10	2023	3	10	16	5	0.3	1.7	-1.1	1490.2	14.5	0.5	0.116667	1
2023-03-10	2023	3	10	17	5	0.3	0.9	-1.4	1533.9	14.5	0.8	-0.20833	1
2023-03-10	2023	3	10	18	5	0.3	0.8	-1.3	1574.3	14.5	1.0	-0.35	1
2023-03-10	2023	3	10	19	5	0.3	0.4	-1.3	1604.1	14.5	1.2	-0.60833	1
2023-03-10	2023	3	10	20	5	0.3	-0.2	0	1600.3	14.5	1.3	-0.80833	1
2023-03-10	2023	3	10	21	5	0.2	-0.8	0.9	1578.2	14.5	1.4	-0.98333	1
2023-03-10	2023	3	10	22	5	0.2	-2.1	2.6	1531.5	14.5	1.4	-1.00833	1
2023-03-10	2023	3	10	23	5	0.1	-3.3	2.5	1477.7	14.5	1.1	-0.90833	1
2023-03-10	2023	3	10	24	5	0.0	-3.7	2.6	1476.6	14.5	0.6	-0.63333	1
2023-03-11	2023	3	11	1	6	-0.1	-4	2.7	1460.0	15.4	0.1	-0.35833	0
2023-03-11	2023	3	11	2	6	-0.3	-4.3	2.1	1433.6	15.4	-0.5	-0.09167	0

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLag	Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLag	Weekdays	
2023-03-11	2023		3	11	12	6	-1.5	2.6	-4	1415.2	15.4	-3.7	0.608333	0
2023-03-11	2023		3	11	13	6	-1.5	3.5	-4.3	1372.3	15.4	-3.2	0.091667	0
2023-03-11	2023		3	11	14	6	-1.5	4.9	-5.1	1321.5	15.4	-2.6	-0.45833	0
2023-03-11	2023		3	11	15	6	-1.4	5.2	-4.3	1296.4	15.4	-1.8	-1.04167	0
2023-03-11	2023		3	11	16	6	-1.3	5.9	-4.8	1298.8	15.4	-0.9	-1.64167	0
2023-03-11	2023		3	11	17	6	-1.1	6.1	-5	1353.9	15.4	-0.1	-2.14167	0
2023-03-11	2023		3	11	18	6	-0.9	4.3	-5.2	1431.7	15.4	0.8	-2.61667	0
2023-03-11	2023		3	11	19	6	-0.7	2.2	-5.1	1491.9	15.4	1.6	-3.1	0
2023-03-11	2023		3	11	20	6	-0.7	0.8	-3.4	1494.3	15.4	2.2	-3.56667	0
2023-03-11	2023		3	11	21	6	-0.6	0.4	-0.9	1466.1	15.4	2.7	-3.975	0
2023-03-11	2023		3	11	22	6	-0.6	0.2	1.4	1424.2	15.4	3.0	-4.19167	0
2023-03-11	2023		3	11	23	6	-0.5	-0.1	2.6	1369.0	15.4	3.1	-4.09167	0
2023-03-11	2023		3	11	24	6	-0.4	-0.2	3.5	1321.8	15.4	3.0	-3.7	0
2023-03-12	2023		3	12	1	7	-0.2	-0.3	4.9	1279.4	18.3	2.8	-3.175	0
2023-03-12	2023		3	12	2	7	0.0	-0.4	5.2	1258.3	18.3	2.5	-2.55	0
2023-03-12	2023		3	12	3	7	0.1	-0.1	5.9	1264.3	18.3	2.0	-1.78333	0
2023-03-12	2023		3	12	4	7	0.3	-0.1	6.1	1270.2	18.3	1.6	-0.925	0
2023-03-12	2023		3	12	5	7	0.5	-0.3	4.3	1182.3	18.3	1.1	-0.075	0
2023-03-12	2023		3	12	6	7	0.7	-0.1	2.2	1252.5	18.3	0.5	0.833333	0
2023-03-12	2023		3	12	7	7	0.9	-0.1	0.8	1370.8	18.3	0.2	1.608333	0
2023-03-12	2023		3	12	8	7	1.1	0.2	0.4	1481.0	18.3	0.0	2.225	0
2023-03-12	2023		3	12	9	7	1.3	1.5	0.2	1502.1	18.3	-0.1	2.716667	0
2023-03-12	2023		3	12	10	7	1.5	2.9	-0.1	1449.5	18.3	0.0	3.033333	0
2023-03-12	2023		3	12	11	7	1.7	4.1	-0.2	1370.1	18.3	0.2	3.125	0
2023-03-12	2023		3	12	12	7	1.8	5.7	-0.3	1313.7	18.3	0.6	3	0
2023-03-12	2023		3	12	13	7	1.9	6.8	-0.4	1304.9	18.3	1.1	2.766667	0
2023-03-12	2023		3	12	14	7	2.1	7.5	-0.1	1253.6	18.3	1.7	2.45	0
2023-03-12	2023		3	12	15	7	2.2	7.9	-0.1	1209.3	18.3	2.3	2.008333	0
2023-03-12	2023		3	12	16	7	2.3	8.1	-0.3	1224.1	18.3	3.0	1.566667	0
2023-03-12	2023		3	12	17	7	2.4	7.3	-0.1	1249.8	18.3	3.7	1.066667	0
2023-03-12	2023		3	12	18	7	2.4	6.3	-0.1	1286.8	18.3	4.3	0.533333	0
2023-03-12	2023		3	12	19	7	2.5	4.9	0.2	1303.7	18.3	4.9	0.166667	0
2023-03-12	2023		3	12	20	7	2.6	3.2	1.5	1367.0	18.3	5.3	-0.025	0
2023-03-12	2023		3	12	21	7	2.7	1.9	2.9	1395.7	18.3	5.5	-0.075	0
2023-03-12	2023		3	12	22	7	2.8	0.6	4.1	1371.5	18.3	5.6	0.016667	0
2023-03-12	2023		3	12	23	7	2.8	-0.3	5.7	1326.9	18.3	5.4	0.241667	0
2023-03-12	2023		3	12	24	7	2.8	-0.6	6.8	1305.1	18.3	5.0	0.591667	0
2023-03-13	2023		3	13	1	1	2.8	-1.2	7.5	1303.2	10.2	4.5	1.083333	1
2023-03-13	2023		3	13	2	1	2.7	-1.7	7.9	1295.6	10.2	3.8	1.675	1
2023-03-13	2023		3	13	3	1	2.7	-2.3	8.1	1284.7	10.2	3.0	2.333333	1
2023-03-13	2023		3	13	4	1	2.6	-2.4	7.3	1281.3	10.2	2.2	3	1
2023-03-13	2023		3	13	5	1	2.5	-2.6	6.3	1294.0	10.2	1.3	3.683333	1
2023-03-13	2023		3	13	6	1	2.4	-3	4.9	1334.6	10.2	0.5	4.316667	1
2023-03-13	2023		3	13	7	1	2.3	-3.1	3.2	1443.1	10.2	-0.3	4.85	1
2023-03-13	2023		3	13	8	1	2.2	-3	1.9	1542.0	10.2	-1.0	5.266667	1
2023-03-13	2023		3	13	9	1	2.0	-1.4	0.6	1587.1	10.2	-1.5	5.516667	1
2023-03-13	2023		3	13	10	1	1.9	0.6	-0.3	1558.0	10.2	-1.8	5.55	1
2023-03-13	2023		3	13	11	1	1.8	2.3	-0.6	1501.2	10.2	-1.8	5.358333	1
2023-03-13	2023		3	13	12	1	1.7	3.3	-1.2	1490.7	10.2	-1.5	4.991667	1
2023-03-13	2023		3	13	13	1	1.6	4.2	-1.7	1487.5	10.2	-1.2	4.466667	1
2023-03-13	2023		3	13	14	1	1.5	3.5	-2.3	1490.1	10.2	-0.8	3.8	1
2023-03-13	2023		3	13	15	1	1.4	3.6	-2.4	1487.9	10.2	-0.3	3.033333	1
2023-03-13	2023		3	13	16	1	1.2	3.4	-2.6	1520.9	10.2	0.2	2.183333	1
2023-03-13	2023		3	13	17	1	1.0	2.3	-3	1581.5	10.2	0.7	1.308333	1
2023-03-13	2023		3	13	18	1	0.8	2.2	-3.1	1638.4	10.2	1.1	0.483333	1
2023-03-13	2023		3	13	19	1	0.6	1.1	-3	1600.6	10.2	1.5	-0.29167	1
2023-03-13	2023		3	13	20	1	0.4	-0.2	-1.4	1595.5	10.2	1.8	-0.95833	1
2023-03-13	2023		3	13	21	1	0.3	-1.1	0.6	1585.4	10.2	2.1	-1.475	1
2023-03-13	2023		3	13	22	1	0.2	-1.9	2.3	1513.4	10.2	2.1	-1.75	1
2023-03-13	2023		3	13	23	1	0.1	-1.8	3.3	1413.4	10.2	1.9	-1.75	1
2023-03-13	2023		3	13	24	1	0.0	-2.4	4.2	1358.2	10.2	1.6	-1.53333	1
2023-03-14	2023		3	14	1	2	-0.1	-2	3.5	1327.1	24.8	1.1	-1.20833	1
2023-03-14	2023		3	14	2	2	-0.1	-1.9	3.6	1301.3	24.8	0.6	-0.75833	1
2023-03-14	2023		3	14	3	2	-0.1	-2.2	3.4	1266.7	24.8	0.1	-0.325	1
2023-03-14	2023		3	14	4	2	-0.1	-1.3	2.3	1243.2	24.8	-0.4	0.166667	1
2023-03-14	2023		3	14	5	2	-0.1	0.2	2.2	1238.5	24.8	-0.8	0.65	1
2023-03-14	2023		3	14	6	2	0.1	0.4	1.1	1271.8	24.8	-0.9	1.058333	1
2023-03-14	2023		3	14	7	2	0.2	0.4	-0.2	1373.6	24.8	-1.1	1.491667	1
2023-03-14	2023		3	14	8	2	0.3	0.3	-1.1	1454.8	24.8	-1.2	1.841667	1
2023-03-14	2023		3	14	9	2	0.5	0.3	-1.9	1495.0	24.8	-1.1	2.075	1
2023-03-14	2023		3	14	10	2	0.6	1.1	-1.8	1522.8	24.8	-1.0	2.1	1
2023-03-14	2023		3	14	11	2	0.6	1	-2.4	1539.7	24.8	-0.7	1.891667	1
2023-03-14	2023		3	14	12	2	0.5	1.8	-2	1545.3	24.8	-0.5	1.55	1
2023-03-14	2023		3	14	13	2	0.5	2.3	-1.9	1517.2	24.8	-0.2	1.075	1
2023-03-14	2023		3	14	14	2	0.4	2	-2.2	1465.3	24.8	0.2	0.558333	1
2023-03-14	2023		3	14	15	2	0.3	2.1	-1.3	1406.8	24.8	0.5	0.108333	1
2023-03-14	2023		3	14	16	2	0.3	1.9	0.2	1422.3	24.8	0.9	-0.375	1
2023-03-14	2023		3	14	17	2	0.2	0.8	0.4	1472.1	24.8	1.2	-0.76667	1
2023-03-14	2023		3	14	18	2	0.1	0	0.4	1511.9	24.8	1.2	-0.94167	1
2023-03-14	2023		3	14	19	2	0.0	0.7	0.3	1509.8	24.8	1.2	-1.09167	1
2023-03-14	2023		3	14	20	2	0.0	0.9	0.3	1520.1	24.8	1.2	-1.15	1
2023-03-14	2023		3	14	21	2	0.1	1	1.1	1502.1	24.8	1.2	-1.10833	1
2023-03-14	2023		3	14	22	2	0.2	1.5	1	1446.6	24.8	1.3	-0.99167	1
2023-03-14	2023		3	14	23	2	0.3	1.8	1.8	1375.2	24.8	1.3	-0.74167	1
2023-03-15	2023		3	15	24	3	0.4	1	2.3	1567.5	19.3	1.4	-0.50833	1
2023-03-15	2023		3	15	1	3	0.6	2.2	2	1329.8	19.3	1.3	-0.15833	1
2023-03-15	2023		3	15	2	3	0.8	2.8	2.1	1315.1	19.3	1.3	0.2	1
2023-03-15	2023		3	15	3	3	1.0	3	1.9	1290.7	19.3	1.4	0.525	1
2023-03-15	2023		3	15	4	3	1.2	3.2	0.8	1281.1	19.3	1.5	0.883333	1
2023-03-15	2023		3	15	5	3	1.4	2.9	0	1294.3	19.3	1.6	1.15	1
2023-03-15	2023		3	15	6	3	1.5	3.2	0.7	1347.2	19.3	1.8	1.2	1
2023-03-15	2023		3	15	7	3	1.6	2.9	0.9	1456.0	19.3	2.0	1.166667	1
2023-03-15	2023		3	15	8	3	1.7	3	1	1541.5	19.3	2.2	1.191667	1
2023-03-15	2023		3	15	9	3	1.8	3.2	1.5	1586.5	19.3	2.4	1.241667	1
2023-03-15	2023		3	15	10	3	1.9	3.8	1.8	1633.3	19.3	2.6	1.3	1
2023-03-15														

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLag	Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLag	Weekdays	
2023-03-16	2023	3	16	16	24	4	3.6	-0.4	4.9	1198.1	23.1	4.3	2.925	1
2023-03-16	2023	3	16	16	1	4	3.5	0.4	7.6	1542.8	23.1	3.9	3.15	1
2023-03-16	2023	3	16	16	2	4	3.5	0	7.4	1516.8	23.1	3.6	3.375	1
2023-03-16	2023	3	16	16	3	4	3.4	-0.3	5.8	1495.7	23.1	2.9	3.775	1
2023-03-16	2023	3	16	16	4	4	3.2	-0.4	4.5	1476.1	23.1	2.3	4.141667	1
2023-03-16	2023	3	16	16	5	4	3.1	-0.5	4.1	1486.8	23.1	1.8	4.358333	1
2023-03-16	2023	3	16	16	6	4	2.9	-0.7	3.4	1529.7	23.1	1.4	4.491667	1
2023-03-16	2023	3	16	16	7	4	2.8	-0.7	2.9	1564.5	23.1	1.0	4.566667	1
2023-03-16	2023	3	16	16	8	4	2.6	-0.7	2.7	1613.8	23.1	0.6	4.608333	1
2023-03-16	2023	3	16	16	9	4	2.5	-0.2	2.4	1630.1	23.1	0.3	4.6	1
2023-03-16	2023	3	16	16	10	4	2.3	0.4	2	1578.3	23.1	0.1	4.558333	1
2023-03-16	2023	3	16	16	11	4	2.2	0.8	-0.4	1522.9	23.1	-0.1	4.441667	1
2023-03-16	2023	3	16	16	12	4	2.0	1.3	0.4	1472.8	23.1	-0.2	4.283333	1
2023-03-16	2023	3	16	16	13	4	1.9	2.2	0	1449.7	23.1	-0.1	3.941667	1
2023-03-16	2023	3	16	16	14	4	1.8	2.7	-0.3	1372.1	23.1	0.1	3.566667	1
2023-03-16	2023	3	16	16	15	4	1.6	2.3	-0.4	1325.7	23.1	0.3	2.933333	1
2023-03-16	2023	3	16	16	16	4	1.4	1.8	-0.5	1304.6	23.1	0.5	2.291667	1
2023-03-16	2023	3	16	16	17	4	1.3	0.3	-0.7	1327.2	23.1	0.7	1.775	1
2023-03-16	2023	3	16	16	18	4	1.1	0.5	-0.7	1331.3	23.1	0.8	1.358333	1
2023-03-16	2023	3	16	16	19	4	0.9	0.1	-0.7	1364.1	23.1	0.9	0.958333	1
2023-03-16	2023	3	16	16	20	4	0.8	-0.4	-0.2	1360.4	23.1	1.0	0.616667	1
2023-03-16	2023	3	16	16	21	4	0.7	-0.6	0.4	1357.9	23.1	1.0	0.316667	1
2023-03-16	2023	3	16	16	22	4	0.5	-0.6	0.8	1317.3	23.1	1.0	0.075	1
2023-03-16	2023	3	16	16	23	4	0.4	-0.5	1.3	1239.2	23.1	0.9	-0.09167	1
2023-03-17	2023	3	17	17	24	5	0.3	1.9	2.2	1219.7	16.6	0.8	-0.19167	1
2023-03-17	2023	3	17	17	1	5	0.4	-0.2	2.7	1191.9	16.6	0.8	-0.05	1
2023-03-17	2023	3	17	17	2	5	0.4	-0.2	2.3	1210.3	16.6	0.6	0.1	1
2023-03-17	2023	3	17	17	3	5	0.3	-0.1	1.8	1191.3	16.6	0.4	0.325	1
2023-03-17	2023	3	17	17	4	5	0.4	-0.1	0.3	1173.5	16.6	0.2	0.541667	1
2023-03-17	2023	3	17	17	5	5	0.4	-0.1	0.5	1136.4	16.6	0.0	0.725	1
2023-03-17	2023	3	17	17	6	5	0.4	0	0.1	1145.7	16.6	0.0	0.791667	1
2023-03-17	2023	3	17	17	7	5	0.4	0.1	-0.4	1240.3	16.6	-0.1	0.891667	1
2023-03-17	2023	3	17	17	8	5	0.4	0.3	-0.6	1341.8	16.6	-0.1	0.958333	1
2023-03-17	2023	3	17	17	9	5	0.5	0.8	-0.6	1416.1	16.6	0.0	0.983333	1
2023-03-17	2023	3	17	17	10	5	0.5	1.7	-0.5	1472.0	16.6	0.1	0.95	1
2023-03-17	2023	3	17	17	11	5	0.6	2.7	1.9	1489.7	16.6	0.3	0.866667	1
2023-03-17	2023	3	17	17	12	5	0.7	3.8	-0.2	1482.2	16.6	0.6	0.758333	1
2023-03-17	2023	3	17	17	13	5	0.8	4.3	-0.2	1416.5	16.6	0.7	0.808333	1
2023-03-17	2023	3	17	17	14	5	0.9	4.9	-0.1	1373.2	16.6	1.1	0.608333	1
2023-03-17	2023	3	17	17	15	5	0.9	5.4	-0.1	1341.2	16.6	1.5	0.366667	1
2023-03-17	2023	3	17	17	16	5	1.1	5.2	-0.1	1355.2	16.6	2.0	0.166667	1
2023-03-17	2023	3	17	17	17	5	1.2	5.5	0	1368.0	16.6	2.4	0.008333	1
2023-03-17	2023	3	17	17	18	5	1.4	5.3	0.1	1393.4	16.6	2.9	-0.025	1
2023-03-17	2023	3	17	17	19	5	1.6	4	0.3	1383.4	16.6	3.3	-0.06667	1
2023-03-17	2023	3	17	17	20	5	1.8	3	0.8	1404.4	16.6	3.7	-0.06667	1
2023-03-17	2023	3	17	17	21	5	1.9	1.1	1.7	1398.4	16.6	3.9	-0.00833	1
2023-03-17	2023	3	17	17	22	5	2.0	1.3	2.7	1348.7	16.6	3.9	0.108333	1
2023-03-17	2023	3	17	17	23	5	2.1	1.6	3.8	1277.5	16.6	3.9	0.3	1
2023-03-18	2023	3	18	18	24	6	2.2	3.3	4.3	1283.8	8.4	3.8	0.566667	0
2023-03-18	2023	3	18	18	1	6	2.2	1.8	4.9	1167.0	8.4	3.7	0.725	0
2023-03-18	2023	3	18	18	2	6	2.3	1.5	5.4	1088.9	8.4	3.5	1.1	0
2023-03-18	2023	3	18	18	3	6	2.4	1.5	5.2	1072.0	8.4	3.3	1.525	0
2023-03-18	2023	3	18	18	4	6	2.5	2.2	5.5	1075.9	8.4	2.9	1.983333	0
2023-03-18	2023	3	18	18	5	6	2.6	2.1	5.3	1113.8	8.4	2.7	2.425	0
2023-03-18	2023	3	18	18	6	6	2.6	2.6	4	1159.2	8.4	2.4	2.891667	0
2023-03-18	2023	3	18	18	7	6	2.8	2.3	3	1216.2	8.4	2.2	3.333333	0
2023-03-18	2023	3	18	18	8	6	2.8	2.6	1.1	1291.6	8.4	2.0	3.658333	0
2023-03-18	2023	3	18	18	9	6	2.9	3.1	1.3	1336.3	8.4	2.0	3.883333	0
2023-03-18	2023	3	18	18	10	6	3.0	2.9	1.6	1339.0	8.4	2.2	3.908333	0
2023-03-18	2023	3	18	18	11	6	3.1	3.6	3.3	1329.8	8.4	2.3	3.875	0
2023-03-18	2023	3	18	18	12	6	3.1	4.3	1.8	1315.6	8.4	2.5	3.783333	0
2023-03-18	2023	3	18	18	13	6	3.1	4.3	1.5	1297.7	8.4	2.5	3.741667	0
2023-03-18	2023	3	18	18	14	6	3.1	5.9	1.5	1269.2	8.4	2.8	3.533333	0
2023-03-18	2023	3	18	18	15	6	3.2	4	2.2	1276.8	8.4	3.1	3.25	0
2023-03-18	2023	3	18	18	16	6	3.1	4.5	2.1	1315.0	8.4	3.3	2.925	0
2023-03-18	2023	3	18	18	17	6	3.1	5.9	2.6	1388.6	8.4	3.5	2.675	0
2023-03-18	2023	3	18	18	18	6	3.1	6.1	2.3	1457.0	8.4	3.8	2.391667	0
2023-03-18	2023	3	18	18	19	6	3.1	3.9	2.6	1470.9	8.4	4.1	2.166667	0
2023-03-18	2023	3	18	18	20	6	3.1	2.9	3.1	1513.5	8.4	4.3	2.025	0
2023-03-18	2023	3	18	18	21	6	3.1	3.1	2.9	1536.1	8.4	4.3	1.991667	0
2023-03-18	2023	3	18	18	22	6	3.2	2.9	3.6	1496.5	8.4	4.3	2.158333	0
2023-03-18	2023	3	18	18	23	6	3.3	2.8	4.3	1390.4	8.4	4.3	2.291667	0
2023-03-19	2023	3	19	19	24	7	3.3	-0.6	4.3	1348.2	17.1	4.2	2.458333	0
2023-03-19	2023	3	19	19	1	7	3.2	3.6	5.9	1246.6	17.1	3.8	2.541667	0
2023-03-19	2023	3	19	19	2	7	3.3	4	4	1265.9	17.1	3.8	2.75	0
2023-03-19	2023	3	19	19	3	7	3.4	4.4	4.5	1274.5	17.1	3.6	3.116667	0
2023-03-19	2023	3	19	19	4	7	3.5	4.6	5.9	1303.6	17.1	3.6	3.325	0
2023-03-19	2023	3	19	19	5	7	3.6	4.9	6.1	1343.1	17.1	3.6	3.516667	0
2023-03-19	2023	3	19	19	6	7	3.7	3.7	3.9	1416.4	17.1	3.6	3.833333	0
2023-03-19	2023	3	19	19	7	7	3.7	2.5	2.9	1566.3	17.1	3.4	4.125	0
2023-03-19	2023	3	19	19	8	7	3.7	1.9	3.1	1685.9	17.1	3.2	4.258333	0
2023-03-19	2023	3	19	19	9	7	3.7	2.6	2.9	1674.2	17.1	3.2	4.283333	0
2023-03-19	2023	3	19	19	10	7	3.7	4	2.8	1605.7	17.1	3.1	4.283333	0
2023-03-19	2023	3	19	19	11	7	3.7	5.1	-0.6	1549.5	17.1	3.2	4.283333	0
2023-03-19	2023	3	19	19	12	7	3.8	5.9	3.6	1494.5	17.1	3.4	4.216667	0
2023-03-19	2023	3	19	19	13	7	3.9	6.4	4	1483.3	17.1	3.9	3.808333	0
2023-03-19	2023	3	19	19	14	7	4.0	6.2	4.4	1457.1	17.1	4.2	3.75	0
2023-03-19	2023	3	19	19	15	7	4.0	5.7	4.6	1399.4	17.1	4.4	3.591667	0
2023-03-19	2023	3	19	19	16	7	4.0	4.5	4.9	1375.5	17.1	4.5	3.625	0
2023-03-19	2023	3	19	19	17	7	4.0	3.2	3.7	1387.4	17.1	4.5	3.633333	0
2023-03-19	2023	3	19	19	18	7	3.9	2.3	2.5	1407.1	17.1	4.3	3.55	0
2023-03-19	2023	3	19	19	19	7	3.8	1.4	1.9	1403.2	17.1	4.2	3.35	0
2023-03-19	2023	3	19	19	20	7	3.7	0.8	2.6	1454.1	17.			

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLa	g Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLa	Weekdays
2023-03-20	2023	3	20	12	1	0.6	1.3	-0.5	1339.9	17.8	-1.8	3.025	1
2023-03-20	2023	3	20	13	1	0.4	2.9	-0.8	1277.0	17.8	-1.8	2.558333	1
2023-03-20	2023	3	20	14	1	0.3	4.4	-1.4	1226.1	17.8	-1.5	1.983333	1
2023-03-20	2023	3	20	15	1	0.2	5	-2.1	1201.0	17.8	-1.0	1.4	1
2023-03-20	2023	3	20	16	1	0.2	5.5	-2.9	1173.0	17.8	-0.5	0.808333	1
2023-03-20	2023	3	20	17	1	0.2	5.8	-3.5	1235.4	17.8	0.1	0.258333	1
2023-03-20	2023	3	20	18	1	0.3	5.4	-3.8	1289.5	17.8	0.9	-0.25	1
2023-03-20	2023	3	20	19	1	0.4	4.5	-3.4	1309.0	17.8	1.6	-0.73333	1
2023-03-20	2023	3	20	20	1	0.6	3.4	-2.4	1352.9	17.8	2.3	-1.16667	1
2023-03-20	2023	3	20	21	1	0.7	2.5	-1.3	1389.3	17.8	2.9	-1.51667	1
2023-03-20	2023	3	20	22	1	0.8	1.7	-0.2	1354.0	17.8	3.3	-1.75	1
2023-03-20	2023	3	20	23	1	0.8	1.1	1.3	1288.6	17.8	3.5	-1.85	1
2023-03-21	2023	3	21	24	2	0.9	-0.2	2.9	1310.3	7.3	3.6	-1.83333	1
2023-03-21	2023	3	21	1	2	0.9	-0.2	4.4	1176.4	7.3	3.5	-1.75	1
2023-03-21	2023	3	21	2	2	0.9	0.3	5	1183.8	7.3	3.2	-1.46667	1
2023-03-21	2023	3	21	3	2	0.9	0	5.5	1175.1	7.3	2.9	-1.03333	1
2023-03-21	2023	3	21	4	2	1.0	-0.2	5.8	1169.2	7.3	2.5	-0.5	1
2023-03-21	2023	3	21	5	2	1.1	0	5.4	1195.7	7.3	2.0	0.133333	1
2023-03-21	2023	3	21	6	2	1.2	-0.3	4.5	1267.5	7.3	1.5	0.858333	1
2023-03-21	2023	3	21	7	2	1.3	-0.8	3.4	1414.0	7.3	1.1	1.6	1
2023-03-21	2023	3	21	8	2	1.5	-0.5	2.5	1521.7	7.3	0.6	2.291667	1
2023-03-21	2023	3	21	9	2	1.6	1.7	1.7	1509.4	7.3	0.3	2.858333	1
2023-03-21	2023	3	21	10	2	1.7	4	1.1	1434.6	7.3	0.2	3.266667	1
2023-03-21	2023	3	21	11	2	2.0	5.7	-0.2	1366.1	7.3	0.4	3.516667	1
2023-03-21	2023	3	21	12	2	2.2	6.7	-0.2	1312.9	7.3	0.8	3.625	1
2023-03-21	2023	3	21	13	2	2.4	6.5	0.3	1283.7	7.3	1.4	3.5	1
2023-03-21	2023	3	21	14	2	2.6	7.3	0	1260.3	7.3	1.9	3.241667	1
2023-03-21	2023	3	21	15	2	2.7	10.5	-0.2	1204.1	7.3	2.5	2.9	1
2023-03-21	2023	3	21	16	2	2.9	9.2	0	1208.7	7.3	3.4	2.483333	1
2023-03-21	2023	3	21	17	2	3.1	7.8	-0.3	1257.3	7.3	4.2	2.008333	1
2023-03-21	2023	3	21	18	2	3.2	6	-0.8	1281.8	7.3	4.8	1.525	1
2023-03-21	2023	3	21	19	2	3.2	4.8	-0.5	1297.2	7.3	5.3	1.05	1
2023-03-21	2023	3	21	20	2	3.2	2.9	1.7	1358.3	7.3	5.8	0.608333	1
2023-03-21	2023	3	21	21	2	3.2	1.7	4	1411.0	7.3	6.1	0.283333	1
2023-03-21	2023	3	21	22	2	3.2	0.5	5.7	1381.3	7.3	6.1	0.216667	1
2023-03-21	2023	3	21	23	2	3.1	0.4	6.7	1307.1	7.3	5.8	0.408333	1
2023-03-22	2023	3	22	24	3	3.1	0	6.5	1246.4	11.4	5.4	0.791667	1
2023-03-22	2023	3	22	1	3	3.1	1.6	7.3	1313.6	11.4	4.8	1.366667	1
2023-03-22	2023	3	22	2	3	3.2	2.2	10.5	1281.7	11.4	4.4	1.925	1
2023-03-22	2023	3	22	3	3	3.2	1.8	9.2	1275.6	11.4	4.0	2.508333	1
2023-03-22	2023	3	22	4	3	3.3	1.6	7.8	1284.0	11.4	3.2	3.383333	1
2023-03-22	2023	3	22	5	3	3.4	1.2	6	1294.4	11.4	2.6	4.166667	1
2023-03-22	2023	3	22	6	3	3.4	0.3	4.8	1347.5	11.4	2.1	4.816667	1
2023-03-22	2023	3	22	7	3	3.5	-0.4	2.9	1385.6	11.4	1.6	5.341667	1
2023-03-22	2023	3	22	8	3	3.5	-0.1	1.7	1511.2	11.4	1.2	5.808333	1
2023-03-22	2023	3	22	9	3	3.5	1.1	0.5	1532.5	11.4	0.9	6.091667	1
2023-03-22	2023	3	22	10	3	3.5	2	0.4	1490.2	11.4	0.9	6.091667	1
2023-03-22	2023	3	22	11	3	3.4	3.3	0	1405.4	11.4	1.0	5.8	1
2023-03-22	2023	3	22	12	3	3.3	4.4	1.6	1364.5	11.4	1.2	5.358333	1
2023-03-22	2023	3	22	13	3	3.2	4.8	2.2	1424.4	11.4	1.6	4.8	1
2023-03-22	2023	3	22	14	3	3.1	5.4	1.8	1427.6	11.4	1.9	4.391667	1
2023-03-22	2023	3	22	15	3	3.0	6.7	1.6	1408.7	11.4	2.1	3.966667	1
2023-03-22	2023	3	22	16	3	2.9	7.1	1.2	1442.9	11.4	2.5	3.241667	1
2023-03-22	2023	3	22	17	3	2.8	6.8	0.3	1445.8	11.4	3.0	2.608333	1
2023-03-22	2023	3	22	18	3	2.8	6	-0.4	1489.3	11.4	3.5	2.058333	1
2023-03-22	2023	3	22	19	3	2.8	4.5	-0.1	1479.7	11.4	3.9	1.583333	1
2023-03-22	2023	3	22	20	3	2.7	3.1	1.1	1503.8	11.4	4.3	1.15	1
2023-03-22	2023	3	22	21	3	2.8	2.3	2	1482.2	11.4	4.6	0.9	1
2023-03-22	2023	3	22	22	3	2.8	1.6	3.3	1418.7	11.4	4.7	0.85	1
2023-03-22	2023	3	22	23	3	2.8	1	4.4	1313.5	11.4	4.7	0.975	1
2023-03-23	2023	3	23	24	4	2.8	1.4	4.8	1400.8	14.4	4.5	1.216667	1
2023-03-23	2023	3	23	1	4	2.9	-0.2	5.4	1213.5	14.4	4.2	1.583333	1
2023-03-23	2023	3	23	2	4	2.8	-0.8	6.7	1147.7	14.4	3.8	1.85	1
2023-03-23	2023	3	23	3	4	2.7	-1.1	7.1	1119.6	14.4	3.3	2.116667	1
2023-03-23	2023	3	23	4	4	2.6	-1.5	6.8	1099.4	14.4	2.6	2.525	1
2023-03-23	2023	3	23	5	4	2.5	-1.6	6	1110.7	14.4	1.9	2.983333	1
2023-03-23	2023	3	23	6	4	2.3	-2.1	4.5	1158.7	14.4	1.2	3.45	1
2023-03-23	2023	3	23	7	4	2.2	-2.2	3.1	1363.5	14.4	0.6	3.925	1
2023-03-23	2023	3	23	8	4	2.2	-2.1	2.3	1487.6	14.4	0.0	4.333333	1
2023-03-23	2023	3	23	9	4	2.1	-0.4	1.6	1519.9	14.4	-0.4	4.6	1
2023-03-23	2023	3	23	10	4	2.0	1.5	1	1519.9	14.4	-0.7	4.7	1
2023-03-23	2023	3	23	11	4	2.0	2	1.4	1527.2	14.4	-0.7	4.666667	1
2023-03-23	2023	3	23	12	4	1.9	2.2	-0.2	1523.2	14.4	-0.6	4.475	1
2023-03-23	2023	3	23	13	4	1.9	2.7	-0.8	1475.9	14.4	-0.5	4.225	1
2023-03-23	2023	3	23	14	4	1.8	2.3	-1.1	1459.3	14.4	-0.3	3.808333	1
2023-03-23	2023	3	23	15	4	1.6	2.5	-1.5	1498.2	14.4	0.0	3.291667	1
2023-03-23	2023	3	23	16	4	1.5	2.5	-1.6	1489.7	14.4	0.3	2.641667	1
2023-03-23	2023	3	23	17	4	1.3	0.4	-2.1	1519.4	14.4	0.6	1.925	1
2023-03-23	2023	3	23	18	4	1.0	-0.2	-2.2	1527.9	14.4	0.8	1.225	1
2023-03-23	2023	3	23	19	4	0.7	0.1	-2.1	1526.7	14.4	0.9	0.55	1
2023-03-23	2023	3	23	20	4	0.6	0.3	-0.4	1542.5	14.4	1.1	-0.00833	1
2023-03-23	2023	3	23	21	4	0.4	0.6	1.5	1539.1	14.4	1.3	-0.44167	1
2023-03-23	2023	3	23	22	4	0.4	1	2	1480.1	14.4	1.4	-0.66667	1
2023-03-23	2023	3	23	23	4	0.3	1.3	2.2	1427.7	14.4	1.4	-0.675	1
2023-03-24	2023	3	24	24	5	0.4	-0.5	2.7	1253.3	23.2	1.3	-0.59167	1
2023-03-24	2023	3	24	1	5	0.3	1.4	2.3	1385.6	23.2	1.1	-0.525	1
2023-03-24	2023	3	24	2	5	0.3	1.5	2.5	1408.4	23.2	1.0	-0.28333	1
2023-03-24	2023	3	24	3	5	0.4	1.8	2.5	1384.7	23.2	0.9	-0.025	1
2023-03-24	2023	3	24	4	5	0.6	1.8	0.4	1375.2	23.2	0.9	0.275	1
2023-03-24	2023	3	24	5	5	0.7	1.6	-0.2	1370.3	23.2	0.8	0.608333	1
2023-03-24	2023	3	24	6	5	0.8	1.7	0.1	1393.1	23.2	0.9	0.775	1
2023-03-24	2023	3	24	7	5	1.0	2.1	0.3	1446.5	23.2	1.1	0.933333	1
2023-03-24	2023	3	24	8	5	1.2	2.7	0.6	1517.9	23.2	1.2	1.125	1
2023-03-24	2023	3	24	9	5	1.4	2.9	1	1589.1	23.2	1.4	1.325	1
2023-03-24	2023	3	24	10	5	1.5	2.5	1.3	1615.5	23.2	1.6	1.408333	1
2023-03-24	2023	3	24	11	5	1.6	2.2	-0.5	1574.5	23.2	1.7	1.366667	1
2023-03-24	2023	3	24	12	5	1.6	1.8	1.4	1513.4	23.2	1.8	1.308333	1
2023-03-24	2023	3	24	13	5	1.5	1.3	1.5	1459.7	23.2	2.0	1.083333	1
2023-03-24	2023	3	24	14									

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLa	gTemp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLa	gWeekdays
2023-03-25	2023	3	25	24	6	1.4	0.3	1.3	1285.5	15.8	1.1	1.808333	0
2023-03-25	2023	3	25	1	6	1.5	-0.7	1.4	1212.6	15.8	1.0	2	0
2023-03-25	2023	3	25	2	6	1.4	-0.9	1.7	1191.2	15.8	0.8	1.991667	0
2023-03-25	2023	3	25	3	6	1.3	-1.2	1.7	1235.9	15.8	0.6	1.983333	0
2023-03-25	2023	3	25	4	6	1.2	-1.4	2.3	1241.8	15.8	0.4	1.975	0
2023-03-25	2023	3	25	5	6	1.0	-1.5	2.4	1255.9	15.8	0.1	1.966667	0
2023-03-25	2023	3	25	6	6	0.9	-1.9	0.7	1279.1	15.8	-0.2	2.025	0
2023-03-25	2023	3	25	7	6	0.8	-1.4	0.2	1282.7	15.8	-0.6	2.083333	0
2023-03-25	2023	3	25	8	6	0.6	-1.3	-0.1	1342.5	15.8	-0.8	1.966667	0
2023-03-25	2023	3	25	9	6	0.4	-0.7	-0.2	1425.4	15.8	-0.9	1.758333	0
2023-03-25	2023	3	25	10	6	0.3	0.1	-0.3	1500.6	15.8	-0.9	1.508333	0
2023-03-25	2023	3	25	11	6	0.2	0.7	0.3	1556.4	15.8	-0.9	1.283333	0
2023-03-25	2023	3	25	12	6	0.1	1.6	-0.7	1581.5	15.8	-0.8	1.075	0
2023-03-25	2023	3	25	13	6	0.1	2.7	-0.9	1577.8	15.8	-0.7	0.95	0
2023-03-25	2023	3	25	14	6	0.2	4.6	-1.2	1552.2	15.8	-0.4	0.783333	0
2023-03-25	2023	3	25	15	6	0.3	4.9	-1.4	1530.2	15.8	0.0	0.591667	0
2023-03-25	2023	3	25	16	6	0.4	4.8	-1.5	1535.0	15.8	0.5	0.35	0
2023-03-25	2023	3	25	17	6	0.6	4.6	-1.9	1564.6	15.8	1.1	0.091667	0
2023-03-25	2023	3	25	18	6	0.7	3.9	-1.4	1571.7	15.8	1.6	-0.225	0
2023-03-25	2023	3	25	19	6	0.7	3.2	-1.3	1555.9	15.8	2.0	-0.58333	0
2023-03-25	2023	3	25	20	6	0.8	2.4	-0.7	1556.9	15.8	2.4	-0.75833	0
2023-03-25	2023	3	25	21	6	0.9	1.5	0.1	1542.5	15.8	2.7	-0.88333	0
2023-03-25	2023	3	25	22	6	1.0	1	0.7	1477.3	15.8	2.9	-0.93333	0
2023-03-25	2023	3	25	23	6	1.0	0.9	1.6	1384.4	15.8	3.0	-0.90833	0
2023-03-26	2023	3	26	24	7	1.1	1.3	2.7	1195.4	16.2	3.0	-0.825	0
2023-03-26	2023	3	26	1	7	1.1	0.1	4.6	1234.7	16.2	3.0	-0.71667	0
2023-03-26	2023	3	26	2	7	1.2	0.1	4.9	1216.2	16.2	2.8	-0.43333	0
2023-03-26	2023	3	26	3	7	1.2	0.2	4.8	1151.3	16.2	2.4	0.025	0
2023-03-26	2023	3	26	4	7	1.3	0.3	4.6	1141.7	16.2	2.0	0.533333	0
2023-03-26	2023	3	26	5	7	1.3	0.1	3.9	1151.5	16.2	1.6	1.05	0
2023-03-26	2023	3	26	6	7	1.4	0	3.2	1193.2	16.2	1.3	1.558333	0
2023-03-26	2023	3	26	7	7	1.5	-0.1	2.4	1340.3	16.2	0.9	2.041667	0
2023-03-26	2023	3	26	8	7	1.5	0	1.5	1467.4	16.2	0.7	2.425	0
2023-03-26	2023	3	26	9	7	1.6	0.3	1	1477.7	16.2	0.5	2.733333	0
2023-03-26	2023	3	26	10	7	1.6	0.7	0.9	1432.6	16.2	0.4	2.916667	0
2023-03-26	2023	3	26	11	7	1.7	0.8	1.3	1382.9	16.2	0.3	2.991667	0
2023-03-26	2023	3	26	12	7	1.7	1.4	0.1	1338.2	16.2	0.3	3.008333	0
2023-03-26	2023	3	26	13	7	1.7	1.3	0.1	1300.8	16.2	0.3	2.983333	0
2023-03-26	2023	3	26	14	7	1.6	1.5	0.2	1259.6	16.2	0.4	2.766667	0
2023-03-26	2023	3	26	15	7	1.5	1.4	0.3	1210.9	16.2	0.5	2.391667	0
2023-03-26	2023	3	26	16	7	1.3	1.3	0.1	1201.8	16.2	0.6	2	0
2023-03-26	2023	3	26	17	7	1.2	1.3	0	1244.7	16.2	0.7	1.625	0
2023-03-26	2023	3	26	18	7	1.0	1.2	-0.1	1286.2	16.2	0.8	1.25	0
2023-03-26	2023	3	26	19	7	0.9	1.3	0	1296.9	16.2	0.9	0.925	0
2023-03-26	2023	3	26	20	7	0.8	1.4	0.3	1329.5	16.2	1.0	0.65	0
2023-03-26	2023	3	26	21	7	0.8	1.5	0.7	1342.9	16.2	1.2	0.45	0
2023-03-26	2023	3	26	22	7	0.8	1.5	0.8	1293.1	16.2	1.3	0.35	0
2023-03-26	2023	3	26	23	7	0.8	1.4	1.4	1212.8	16.2	1.3	0.325	0
2023-03-27	2023	3	27	24	1	0.8	1	1.3	1261.2	15.0	1.4	0.316667	1
2023-03-27	2023	3	27	1	1	0.8	1.1	1.5	1181.8	15.0	1.3	0.325	1
2023-03-27	2023	3	27	2	1	0.9	1.4	1.4	1169.1	15.0	1.3	0.425	1
2023-03-27	2023	3	27	3	1	0.9	1.2	1.3	1164.6	15.0	1.3	0.541667	1
2023-03-27	2023	3	27	4	1	1.0	1.1	1.3	1173.9	15.0	1.3	0.641667	1
2023-03-27	2023	3	27	5	1	1.0	0.5	1.2	1198.7	15.0	1.3	0.725	1
2023-03-27	2023	3	27	6	1	1.0	0.5	1.3	1264.9	15.0	1.2	0.825	1
2023-03-27	2023	3	27	7	1	1.0	0.3	1.4	1419.1	15.0	1.2	0.925	1
2023-03-27	2023	3	27	8	1	1.1	0.3	1.5	1539.4	15.0	1.1	1.041667	1
2023-03-27	2023	3	27	9	1	1.1	0.7	1.5	1553.5	15.0	1.0	1.158333	1
2023-03-27	2023	3	27	10	1	1.1	1.8	1.4	1514.3	15.0	0.9	1.258333	1
2023-03-27	2023	3	27	11	1	1.1	3.1	1	1449.1	15.0	0.9	1.325	1
2023-03-27	2023	3	27	12	1	1.2	3.5	1.1	1382.8	15.0	1.1	1.375	1
2023-03-27	2023	3	27	13	1	1.3	4.6	1.4	1339.9	15.0	1.3	1.341667	1
2023-03-27	2023	3	27	14	1	1.5	5.2	1.2	1302.6	15.0	1.6	1.325	1
2023-03-27	2023	3	27	15	1	1.6	5.9	1.1	1277.9	15.0	1.9	1.316667	1
2023-03-27	2023	3	27	16	1	1.8	6.7	0.5	1280.2	15.0	2.3	1.3	1
2023-03-27	2023	3	27	17	1	2.0	6.1	0.5	1334.4	15.0	2.8	1.283333	1
2023-03-27	2023	3	27	18	1	2.2	5.9	0.3	1382.9	15.0	3.2	1.216667	1
2023-03-27	2023	3	27	19	1	2.4	4.4	0.3	1393.4	15.0	3.7	1.158333	1
2023-03-27	2023	3	27	20	1	2.5	4	0.7	1422.1	15.0	4.0	1.075	1
2023-03-27	2023	3	27	21	1	2.7	3.5	1.8	1437.7	15.0	4.3	0.983333	1
2023-03-27	2023	3	27	22	1	2.7	2.6	3.1	1386.9	15.0	4.6	0.916667	1
2023-03-27	2023	3	27	23	1	2.8	1.7	3.5	1306.9	15.0	4.6	0.941667	1
2023-03-28	2023	3	28	24	2	2.8	0.7	4.6	1298.2	10.3	4.5	1.083333	1
2023-03-28	2023	3	28	1	2	2.8	0.4	5.2	1248.4	10.3	4.3	1.291667	1
2023-03-28	2023	3	28	2	2	2.8	0.4	5.9	1237.8	10.3	3.9	1.583333	1
2023-03-28	2023	3	28	3	2	2.7	-0.8	6.7	1229.2	10.3	3.5	1.9	1
2023-03-28	2023	3	28	4	2	2.6	0.2	6.1	1226.7	10.3	3.0	2.291667	1
2023-03-28	2023	3	28	5	2	2.6	-0.7	5.9	1244.1	10.3	2.4	2.758333	1
2023-03-28	2023	3	28	6	2	2.5	-0.7	4.4	1299.5	10.3	1.9	3.225	1
2023-03-28	2023	3	28	7	2	2.5	-1.3	4	1440.3	10.3	1.3	3.675	1
2023-03-28	2023	3	28	8	2	2.4	-0.8	3.5	1554.3	10.3	0.8	4.016667	1
2023-03-28	2023	3	28	9	2	2.4	0	2.6	1537.7	10.3	0.4	4.325	1
2023-03-28	2023	3	28	10	2	2.4	1.1	1.7	1466.4	10.3	0.1	4.558333	1
2023-03-28	2023	3	28	11	2	2.3	2.8	0.7	1404.8	10.3	0.0	4.625	1
2023-03-28	2023	3	28	12	2	2.3	4.3	0.4	1360.9	10.3	0.1	4.508333	1
2023-03-28	2023	3	28	13	2	2.3	4.6	0.4	1326.8	10.3	0.4	4.275	1
2023-03-28	2023	3	28	14	2	2.3	5.6	-0.8	1298.8	10.3	0.8	3.925	1
2023-03-28	2023	3	28	15	2	2.4	6.5	0.2	1278.0	10.3	1.2	3.525	1
2023-03-28	2023	3	28	16	2	2.4	6.8	-0.7	1284.9	10.3	1.8	2.966667	1
2023-03-28	2023	3	28	17	2	2.4	5.9	-0.7	1316.5	10.3	2.4	2.425	1
2023-03-28	2023	3	28	18	2	2.4	5.2	-1.3	1340.7	10.3	2.9	1.858333	1
2023-03-28	2023	3	28	19	2	2.4	4.4	-0.8	1341.8	10.3	3.4	1.308333	1
2023-03-28	2023	3	28	20	2	2.4	3.5	0	1386.8	10.3	3.9	0.833333	1
2023-03-28	2023	3	28	21	2	2.3	2.7	1.1	1444.8	10.3	4.2	0.433333	1
2023-03-28	2023	3	28	22	2	2.3	1.9	2.8	1416.1	10.3	4.5	0.141667	1
2023-03-28	2023	3	28	23	2	2.3	1	4.3	1339.8	10.3	4.5	0.016667	1
2023-03-29	2023	3	29	24	3	2.2	0.3	4.6	1485.4	7.8	4.4	0.108333	1
2023-03-29	2023	3	29	1	3	2.2	0.5	5.6	1293.5	7.8	4.0	0.408333	

DATE	Year	Month	Day	HOUR	DOW	24hrAvgLa	g Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLa	g Weekdays	
2023-03-29	2023	3	29	29	12	3	2.3	3.4	0.5	1497.9	7.8	0.2	4.366667	1
2023-03-29	2023	3	29	13	13	3	2.3	4.7	-0.1	1511.6	7.8	0.5	4.033333	1
2023-03-29	2023	3	29	14	14	3	2.3	6.1	-0.5	1508.5	7.8	0.8	3.691667	1
2023-03-29	2023	3	29	15	15	3	2.3	3.3	0	1507.4	7.8	1.3	3.216667	1
2023-03-29	2023	3	29	16	16	3	2.1	3.9	-0.5	1535.8	7.8	1.7	2.633333	1
2023-03-29	2023	3	29	17	17	3	2.0	5.1	-0.4	1562.2	7.8	2.0	2.066667	1
2023-03-29	2023	3	29	18	18	3	2.0	4.8	-0.9	1587.6	7.8	2.4	1.533333	1
2023-03-29	2023	3	29	19	19	3	2.0	3.1	-0.4	1569.8	7.8	2.9	1.066667	1
2023-03-29	2023	3	29	20	20	3	1.9	2.3	0.8	1604.0	7.8	3.2	0.625	1
2023-03-29	2023	3	29	21	21	3	1.9	1.6	1.2	1620.8	7.8	3.4	0.3	1
2023-03-29	2023	3	29	22	22	3	1.8	0.9	2.5	1580.8	7.8	3.5	0.141667	1
2023-03-29	2023	3	29	23	23	3	1.8	0.3	3.4	1512.7	7.8	3.5	0.083333	1
2023-03-30	2023	3	30	24	4	4	1.8	-3.6	4.7	1149.5	15.5	3.3	0.208333	1
2023-03-30	2023	3	30	1	4	4	1.6	-0.6	6.1	1482.4	15.5	2.7	0.466667	1
2023-03-30	2023	3	30	2	4	4	1.5	1.3	3.3	1476.1	15.5	2.3	0.816667	1
2023-03-30	2023	3	30	3	4	4	1.6	1.8	3.9	1420.7	15.5	1.9	1.333333	1
2023-03-30	2023	3	30	4	4	4	1.7	2	5.1	1417.8	15.5	1.7	1.65	1
2023-03-30	2023	3	30	5	4	4	1.8	1.5	4.8	1407.6	15.5	1.6	1.975	1
2023-03-30	2023	3	30	6	4	4	1.9	1.3	3.1	1460.1	15.5	1.3	2.441667	1
2023-03-30	2023	3	30	7	4	4	1.9	1.6	2.3	1591.7	15.5	1.0	2.875	1
2023-03-30	2023	3	30	8	4	4	2.0	1.9	1.6	1679.1	15.5	0.9	3.208333	1
2023-03-30	2023	3	30	9	4	4	2.1	3.8	0.9	1602.5	15.5	0.8	3.433333	1
2023-03-30	2023	3	30	10	4	4	2.3	4.3	0.3	1567.9	15.5	1.0	3.5	1
2023-03-30	2023	3	30	11	4	4	2.4	5.1	-3.6	1564.8	15.5	1.3	3.475	1
2023-03-30	2023	3	30	12	4	4	2.5	4.7	-0.6	1514.2	15.5	1.7	3.291667	1
2023-03-30	2023	3	30	13	4	4	2.6	5.3	1.3	1412.8	15.5	2.4	2.708333	1
2023-03-30	2023	3	30	14	4	4	2.6	4.6	1.8	1325.0	15.5	2.9	2.266667	1
2023-03-30	2023	3	30	15	4	4	2.5	3.2	2	1258.9	15.5	3.2	1.866667	1
2023-03-30	2023	3	30	16	4	4	2.5	3.2	1.5	1226.7	15.5	3.3	1.741667	1
2023-03-30	2023	3	30	17	4	4	2.5	0.4	1.3	1243.3	15.5	3.4	1.583333	1
2023-03-30	2023	3	30	18	4	4	2.3	0.7	1.6	1257.6	15.5	3.3	1.283333	1
2023-03-30	2023	3	30	19	4	4	2.1	0.9	1.9	1247.9	15.5	3.2	0.991667	1
2023-03-30	2023	3	30	20	4	4	2.0	-0.1	3.8	1261.1	15.5	3.2	0.866667	1
2023-03-30	2023	3	30	21	4	4	1.9	-1.2	4.3	1291.6	15.5	3.0	0.833333	1
2023-03-30	2023	3	30	22	4	4	1.8	-2.1	5.1	1245.7	15.5	2.6	1.016667	1
2023-03-30	2023	3	30	23	4	4	1.7	-2.9	4.7	1182.7	15.5	2.1	1.3	1
2023-03-31	2023	3	31	24	5	5	1.5	1.6	5.3	1301.6	15.8	1.4	1.7	1
2023-03-31	2023	3	31	1	5	5	1.8	-3.9	4.6	1129.1	15.8	1.1	2.391667	1
2023-03-31	2023	3	31	2	5	5	1.6	-4.2	3.2	1102.6	15.8	0.4	2.883333	1
2023-03-31	2023	3	31	3	5	5	1.4	-4.5	3.2	1075.8	15.8	-0.4	3.158333	1
2023-03-31	2023	3	31	4	5	5	1.1	-4.8	0.4	1063.1	15.8	-1.0	3.275	1
2023-03-31	2023	3	31	5	5	5	0.9	-5	0.7	1066.8	15.8	-1.7	3.375	1
2023-03-31	2023	3	31	6	5	5	0.6	-5	0.9	1095.7	15.8	-2.1	3.283333	1
2023-03-31	2023	3	31	7	5	5	0.3	-5.3	-0.1	1157.2	15.8	-2.6	3.233333	1
2023-03-31	2023	3	31	8	5	5	0.0	-4.8	-1.2	1252.1	15.8	-3.1	3.175	1
2023-03-31	2023	3	31	9	5	5	-0.3	-3.8	-2.1	1399.9	15.8	-3.5	3.008333	1
2023-03-31	2023	3	31	10	5	5	-0.6	-3.4	-2.9	1468.7	15.8	-3.7	2.591667	1
2023-03-31	2023	3	31	11	5	5	-0.9	-2.3	1.6	1499.1	15.8	-3.8	2.058333	1
2023-03-31	2023	3	31	12	5	5	-1.2	-1.2	-3.9	1526.3	15.8	-3.8	1.391667	1
2023-03-31	2023	3	31	13	5	5	-1.4	0.9	-4.2	1545.7	15.8	-4.0	1.133333	1
2023-03-31	2023	3	31	14	5	5	-1.6	2.6	-4.5	1571.9	15.8	-3.6	0.366667	1
2023-03-31	2023	3	31	15	5	5	-1.7	3.7	-4.8	1584.0	15.8	-3.1	-0.36667	1
2023-03-31	2023	3	31	16	5	5	-1.7	4.6	-5	1601.9	15.8	-2.4	-1.00833	1
2023-03-31	2023	3	31	17	5	5	-1.6	5.2	-5	1628.2	15.8	-1.6	-1.675	1
2023-03-31	2023	3	31	18	5	5	-1.4	5.2	-5.3	1638.2	15.8	-0.7	-2.125	1
2023-03-31	2023	3	31	19	5	5	-1.2	4.6	-4.8	1583.5	15.8	0.1	-2.6	1
2023-03-31	2023	3	31	20	5	5	-1.1	2.4	-3.8	1563.7	15.8	0.9	-3.11667	1
2023-03-31	2023	3	31	21	5	5	-1.0	1.9	-3.4	1524.7	15.8	1.5	-3.50833	1
2023-03-31	2023	3	31	22	5	5	-0.9	1.8	-2.3	1458.3	15.8	2.0	-3.725	1
2023-03-31	2023	3	31	23	5	5	-0.7	1.6	-1.2	1374.2	15.8	2.5	-3.83333	1
2023-11-01	2023	11	1	24	3	3	4.7	1.1	6.8	1217.9	14.0	5.3	4.016667	1
2023-11-01	2023	11	1	1	3	3	4.6	1.8	7.4	1101.9	14.0	4.9	4.275	1
2023-11-01	2023	11	1	2	3	3	4.5	1.3	7.7	1088.2	14.0	4.5	4.508333	1
2023-11-01	2023	11	1	3	3	3	4.4	0.9	7.1	1074.8	14.0	4.0	4.8	1
2023-11-01	2023	11	1	4	3	3	4.3	1	5.5	1073.2	14.0	3.4	5.125	1
2023-11-01	2023	11	1	5	3	3	4.1	1.1	4.7	1082.3	14.0	2.9	5.4	1
2023-11-01	2023	11	1	6	3	3	4.0	1.4	4.2	1136.1	14.0	2.5	5.533333	1
2023-11-01	2023	11	1	7	3	3	3.9	1.3	3.6	1273.8	14.0	2.3	5.566667	1
2023-11-01	2023	11	1	8	3	3	3.8	1.4	3.2	1405.1	14.0	2.0	5.566667	1
2023-11-01	2023	11	1	9	3	3	3.7	1.5	3.6	1445.3	14.0	1.8	5.516667	1
2023-11-01	2023	11	1	10	3	3	3.6	1.5	3.8	1453.3	14.0	1.7	5.433333	1
2023-11-01	2023	11	1	11	3	3	3.5	1.1	1.1	1458.3	14.0	1.5	5.416667	1
2023-11-01	2023	11	1	12	3	3	3.3	-0.4	1.8	1469.7	14.0	1.3	5.308333	1
2023-11-01	2023	11	1	13	3	3	3.0	-0.7	1.3	1489.8	14.0	1.2	4.891667	1
2023-11-01	2023	11	1	14	3	3	2.7	-0.7	0.9	1497.1	14.0	1.0	4.475	1
2023-11-01	2023	11	1	15	3	3	2.4	-0.6	1	1487.9	14.0	0.8	3.966667	1
2023-11-01	2023	11	1	16	3	3	2.0	-0.2	1.1	1498.2	14.0	0.7	3.4	1
2023-11-01	2023	11	1	17	3	3	1.7	0.2	1.4	1533.1	14.0	0.6	2.891667	1
2023-11-01	2023	11	1	18	3	3	1.5	0.6	1.3	1567.3	14.0	0.5	2.525	1
2023-11-01	2023	11	1	19	3	3	1.3	0.9	1.4	1563.6	14.0	0.4	2.25	1
2023-11-01	2023	11	1	20	3	3	1.2	1	1.5	1527.1	14.0	0.4	2.008333	1
2023-11-01	2023	11	1	21	3	3	1.1	1.3	1.5	1468.3	14.0	0.4	1.825	1
2023-11-01	2023	11	1	22	3	3	1.0	1.2	1.1	1386.3	14.0	0.3	1.683333	1
2023-11-01	2023	11	1	23	3	3	0.9	1	-0.4	1277.8	14.0	0.3	1.508333	1
2023-11-02	2023	11	2	24	4	4	0.8	2.5	-0.7	1224.5	15.6	0.3	1.283333	1
2023-11-02	2023	11	2	1	4	4	0.9	1.1	-0.7	1185.4	15.6	0.5	1.158333	1
2023-11-02	2023	11	2	2	4	4	0.8	0.3	-0.6	1170.8	15.6	0.7	0.95	1
2023-11-02	2023	11	2	3	4	4	0.8	-0.1	-0.2	1149.6	15.6	0.8	0.783333	1
2023-11-02	2023	11	2	4	4	4	0.7	-0.5	0.2	1145.7	15.6	0.8	0.658333	1
2023-11-02	2023	11	2	5	4	4	0.7	-1	0.6	1165.8	15.6	0.8	0.558333	1
2023-11-02	2023	11	2	6	4	4	0.6	-1.4	0.9	1225.8	15.6	0.7	0.483333	1
2023-11-02	2023	11	2	7	4	4	0.5	-1.6	1	1367.1	15.6	0.5	0.416667	1
2023-11-02	2023	11	2	8	4	4	0.4	-1.8	1.3	1499.4	15.6	0.3	0.383333	1
2023-11-02	2023</													

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLa	gTemp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLa	Weekdays	
2023-11-03	2023	11	11	3	24	5	1.6	7.1	3.4	1140.0	8.7	3.4	-0.06667	1
2023-11-03	2023	11	11	3	1	5	1.8	2.3	3.9	1198.5	8.7	3.7	-0.05	1
2023-11-03	2023	11	11	3	2	5	1.9	3	4.1	1181.8	8.7	3.6	0.141667	1
2023-11-03	2023	11	11	3	3	5	2.0	2.8	4.6	1162.5	8.7	3.6	0.441667	1
2023-11-03	2023	11	11	3	4	5	2.1	2.5	4.6	1157.5	8.7	3.5	0.791667	1
2023-11-03	2023	11	11	3	5	5	2.2	3	3.6	1175.6	8.7	3.3	1.216667	1
2023-11-03	2023	11	11	3	6	5	2.4	3.2	3.1	1228.0	8.7	3.1	1.683333	1
2023-11-03	2023	11	11	3	7	5	2.6	1.6	2.7	1364.2	8.7	3.1	2.1	1
2023-11-03	2023	11	11	3	8	5	2.7	2.5	2.8	1490.8	8.7	3.0	2.491667	1
2023-11-03	2023	11	11	3	9	5	2.9	3.9	2.4	1510.1	8.7	3.0	2.866667	1
2023-11-03	2023	11	11	3	10	5	3.1	6.1	2.4	1457.7	8.7	3.1	3.166667	1
2023-11-03	2023	11	11	3	11	5	3.3	7.2	7.1	1406.1	8.7	3.4	3.316667	1
2023-11-03	2023	11	11	3	12	5	3.6	7.6	2.3	1359.7	8.7	3.8	3.358333	1
2023-11-03	2023	11	11	3	13	5	3.8	7.5	3	1341.6	8.7	3.8	3.725	1
2023-11-03	2023	11	11	3	14	5	3.9	9	2.8	1319.7	8.7	4.2	3.633333	1
2023-11-03	2023	11	11	3	15	5	4.2	7.3	2.5	1285.2	8.7	4.7	3.558333	1
2023-11-03	2023	11	11	3	16	5	4.3	7.5	3	1277.2	8.7	5.1	3.45	1
2023-11-03	2023	11	11	3	17	5	4.4	7.8	3.2	1297.3	8.7	5.5	3.275	1
2023-11-03	2023	11	11	3	18	5	4.5	7.2	1.6	1330.6	8.7	5.9	3.141667	1
2023-11-03	2023	11	11	3	19	5	4.7	7.1	2.5	1360.3	8.7	6.3	3.108333	1
2023-11-03	2023	11	11	3	20	5	4.9	6.5	3.9	1339.7	8.7	6.7	2.983333	1
2023-11-03	2023	11	11	3	21	5	5.0	6.4	6.1	1303.2	8.7	7.1	2.966667	1
2023-11-03	2023	11	11	3	22	5	5.2	6.4	7.2	1247.7	8.7	7.3	3.058333	1
2023-11-03	2023	11	11	3	23	5	5.3	6.4	7.6	1182.1	8.7	7.3	3.366667	1
2023-11-04	2023	11	11	4	24	6	5.5	10	7.5	981.6	14.6	7.2	3.766667	0
2023-11-04	2023	11	11	4	1	6	5.6	8	9	1098.5	14.6	7.4	3.808333	0
2023-11-04	2023	11	11	4	2	6	5.9	9.1	7.3	1055.1	14.6	7.5	4.241667	0
2023-11-04	2023	11	11	4	3	6	6.1	8.9	7.5	1021.2	14.6	7.5	4.741667	0
2023-11-04	2023	11	11	4	4	6	6.4	9.6	7.8	999.1	14.6	7.6	5.116667	0
2023-11-04	2023	11	11	4	5	6	6.7	10.1	7.2	993.4	14.6	7.8	5.533333	0
2023-11-04	2023	11	11	4	6	6	7.0	10.4	7.1	995.2	14.6	8.0	5.933333	0
2023-11-04	2023	11	11	4	7	6	7.3	10.5	6.5	1040.0	14.6	8.2	6.266667	0
2023-11-04	2023	11	11	4	8	6	7.6	10.6	6.4	1106.4	14.6	8.5	6.725	0
2023-11-04	2023	11	11	4	9	6	8.0	11.2	6.4	1172.9	14.6	8.9	7.058333	0
2023-11-04	2023	11	11	4	10	6	8.3	12.2	6.4	1218.7	14.6	9.3	7.266667	0
2023-11-04	2023	11	11	4	11	6	8.5	12.7	10	1210.8	14.6	9.8	7.291667	0
2023-11-04	2023	11	11	4	12	6	8.8	13.2	8	1181.0	14.6	10.3	7.225	0
2023-11-04	2023	11	11	4	13	6	9.0	13.5	9.1	1151.2	14.6	10.5	7.425	0
2023-11-04	2023	11	11	4	14	6	9.2	14.8	8.9	1118.6	14.6	11.0	7.466667	0
2023-11-04	2023	11	11	4	15	6	9.5	14.9	9.6	1086.0	14.6	11.5	7.475	0
2023-11-04	2023	11	11	4	16	6	9.8	14.2	10.1	1091.7	14.6	12.0	7.608333	0
2023-11-04	2023	11	11	4	17	6	10.1	12.9	10.4	1144.5	14.6	12.4	7.783333	0
2023-11-04	2023	11	11	4	18	6	10.3	12.1	10.5	1207.4	14.6	12.6	7.975	0
2023-11-04	2023	11	11	4	19	6	10.5	11.4	10.6	1231.4	14.6	12.7	8.241667	0
2023-11-04	2023	11	11	4	20	6	10.7	10.6	11.2	1209.0	14.6	12.8	8.525	0
2023-11-04	2023	11	11	4	21	6	10.8	10.6	12.2	1157.6	14.6	12.8	8.866667	0
2023-11-04	2023	11	11	4	22	6	11.0	10.4	12.7	1105.2	14.6	12.8	9.266667	0
2023-11-04	2023	11	11	4	23	6	11.2	10	13.2	1039.3	14.6	12.6	9.75	0
2023-11-05	2023	11	11	5	24	7	11.3	4.3	13.5	1058.6	5.9	12.4	10.275	0
2023-11-05	2023	11	11	5	1	7	11.1	10	14.8	919.9	5.9	11.6	10.54167	0
2023-11-05	2023	11	11	5	2	7	11.2	9.6	14.9	889.5	5.9	11.4	11	0
2023-11-05	2023	11	11	5	3	7	11.2	8.6	14.2	883.8	5.9	10.9	11.475	0
2023-11-05	2023	11	11	5	4	7	11.2	8.4	12.9	887.0	5.9	10.4	11.975	0
2023-11-05	2023	11	11	5	5	7	11.1	8	12.1	899.9	5.9	9.9	12.35833	0
2023-11-05	2023	11	11	5	6	7	11.0	8	11.4	932.8	5.9	9.5	12.59167	0
2023-11-05	2023	11	11	5	7	7	10.9	8.1	10.6	987.4	5.9	9.2	12.73333	0
2023-11-05	2023	11	11	5	8	7	10.8	7.9	10.6	1064.3	5.9	8.9	12.80833	0
2023-11-05	2023	11	11	5	9	7	10.7	7.5	10.4	1152.1	5.9	8.7	12.80833	0
2023-11-05	2023	11	11	5	10	7	10.6	8.8	10	1204.3	5.9	8.4	12.75833	0
2023-11-05	2023	11	11	5	11	7	10.4	9.7	4.3	1210.4	5.9	8.3	12.60833	0
2023-11-05	2023	11	11	5	12	7	10.3	10.7	10	1187.2	5.9	8.2	12.38333	0
2023-11-05	2023	11	11	5	13	7	10.2	11.7	9.6	1161.2	5.9	8.8	11.64167	0
2023-11-05	2023	11	11	5	14	7	10.1	11.7	8.6	1147.9	5.9	8.9	11.35	0
2023-11-05	2023	11	11	5	15	7	10.0	11.6	8.4	1155.3	5.9	9.1	10.91667	0
2023-11-05	2023	11	11	5	16	7	9.9	10.6	8	1200.3	5.9	9.3	10.39167	0
2023-11-05	2023	11	11	5	17	7	9.7	10.6	8	1285.3	5.9	9.5	9.908333	0
2023-11-05	2023	11	11	5	18	7	9.6	10	8.1	1353.0	5.9	9.7	9.5	0
2023-11-05	2023	11	11	5	19	7	9.5	8.7	7.9	1326.7	5.9	9.9	9.158333	0
2023-11-05	2023	11	11	5	20	7	9.4	7.5	7.5	1288.4	5.9	10.0	8.883333	0
2023-11-05	2023	11	11	5	21	7	9.3	6.7	8.8	1245.2	5.9	9.9	8.658333	0
2023-11-05	2023	11	11	5	22	7	9.1	5.7	9.7	1191.2	5.9	9.9	8.4	0
2023-11-05	2023	11	11	5	23	7	8.9	5.2	10.7	1119.7	5.9	9.6	8.266667	0
2023-11-06	2023	11	11	6	24	1	8.7	3.3	11.7	1192.1	7.8	9.2	8.241667	1
2023-11-06	2023	11	11	6	1	1	8.7	4	11.7	1019.9	7.8	8.6	8.775	1
2023-11-06	2023	11	11	6	2	1	8.4	3.3	11.6	1009.6	7.8	8.0	8.916667	1
2023-11-06	2023	11	11	6	3	1	8.2	2.9	10.6	1015.9	7.8	7.3	9.091667	1
2023-11-06	2023	11	11	6	4	1	7.9	2	10.6	1030.0	7.8	6.5	9.341667	1
2023-11-06	2023	11	11	6	5	1	7.7	1.7	10	1055.3	7.8	5.8	9.525	1
2023-11-06	2023	11	11	6	6	1	7.4	1.1	8.7	1129.0	7.8	5.1	9.741667	1
2023-11-06	2023	11	11	6	7	1	7.1	0.3	7.5	1279.2	7.8	4.3	9.908333	1
2023-11-06	2023	11	11	6	8	1	6.8	-0.2	6.7	1400.2	7.8	3.6	9.958333	1
2023-11-06	2023	11	11	6	9	1	6.5	0.7	5.7	1388.2	7.8	3.0	9.925	1
2023-11-06	2023	11	11	6	10	1	6.2	2.9	5.2	1319.2	7.8	2.5	9.858333	1
2023-11-06	2023	11	11	6	11	1	5.9	4.2	3.3	1269.5	7.8	2.3	9.6	1
2023-11-06	2023	11	11	6	12	1	5.7	5.2	4	1239.5	7.8	2.2	9.225	1
2023-11-06	2023	11	11	6	13	1	5.5	5.9	3.3	1211.3	7.8	2.3	8.608333	1
2023-11-06	2023	11	11	6	14	1	5.2	6.3	2.9	1182.4	7.8	2.5	7.966667	1
2023-11-06	2023	11	11	6	15	1	5.0	6.4	2	1171.9	7.8	2.8	7.266667	1
2023-11-06	2023	11	11	6	16	1	4.8	6.3	1.7	1200.4	7.8	3.0	6.541667	1
2023-11-06	2023	11	11	6	17	1	4.6	5.4	1.1	1312.8	7.8	3.4	5.825	1
2023-11-06	2023	11	11	6	18	1	4.4	4	0.3	1438.9	7.8	3.7	5.083333	1
2023-11-06	2023	11	11	6	19	1	4.1	3.6	-0.2	1436.3	7.8	4.0	4.341667	1
2023-11-06	2023	11	11	6	20									

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLag	Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLag	Weekdays	
2023-11-07	2023	11	7	7	12	2	4.8	10.1	2.8	1302.8	15.8	5.0	4.666667	1
2023-11-07	2023	11	7	7	13	2	5.0	10.5	2.9	1300.6	15.8	4.8	5.266667	1
2023-11-07	2023	11	7	7	14	2	5.2	10.5	2.7	1294.1	15.8	5.4	5.008333	1
2023-11-07	2023	11	7	7	15	2	5.4	10.5	2.7	1280.0	15.8	6.0	4.725	1
2023-11-07	2023	11	7	7	16	2	5.6	10.5	3.1	1301.7	15.8	6.7	4.416667	1
2023-11-07	2023	11	7	7	17	2	5.7	10.4	2.4	1369.5	15.8	7.3	4.116667	1
2023-11-07	2023	11	7	7	18	2	5.9	10.2	2.9	1416.4	15.8	8.0	3.925	1
2023-11-07	2023	11	7	7	19	2	6.2	10.4	3.7	1374.7	15.8	8.6	3.791667	1
2023-11-07	2023	11	7	7	20	2	6.5	10.5	5.1	1320.6	15.8	9.2	3.733333	1
2023-11-07	2023	11	7	7	21	2	6.8	11.1	8.9	1255.9	15.8	9.8	3.741667	1
2023-11-07	2023	11	7	7	22	2	7.1	11.2	9.9	1179.4	15.8	10.3	3.891667	1
2023-11-07	2023	11	7	7	23	2	7.4	11.8	10.1	1088.5	15.8	10.5	4.4	1
2023-11-07	2023	11	7	7	24	2	7.8	12.4	10.5	1014.8	15.8	10.6	4.958333	1
2023-11-08	2023	11	8	1	3	3	7.8	12.5	10.5	957.0	17.6	10.8	4.766667	1
2023-11-08	2023	11	8	2	3	3	8.2	12.2	10.5	919.3	17.6	11.0	5.408333	1
2023-11-08	2023	11	8	3	3	3	8.6	11.9	10.5	898.0	17.6	11.1	6.041667	1
2023-11-08	2023	11	8	4	3	3	9.0	11.8	10.4	899.6	17.6	11.3	6.691667	1
2023-11-08	2023	11	8	5	3	3	9.4	11.3	10.2	917.0	17.6	11.4	7.341667	1
2023-11-08	2023	11	8	6	3	3	9.7	9.7	10.4	981.9	17.6	11.4	7.95	1
2023-11-08	2023	11	8	7	3	3	10.0	8.7	10.5	1116.4	17.6	11.4	8.6	1
2023-11-08	2023	11	8	8	3	3	10.2	7.1	11.1	1230.3	17.6	11.3	9.225	1
2023-11-08	2023	11	8	9	3	3	10.4	5.9	11.2	1269.9	17.6	11.0	9.791667	1
2023-11-08	2023	11	8	10	3	3	10.4	5.1	11.8	1260.6	17.6	10.5	10.29167	1
2023-11-08	2023	11	8	11	3	3	10.3	5.4	12.4	1261.9	17.6	10.0	10.48333	1
2023-11-08	2023	11	8	12	3	3	10.1	6	12.5	1286.1	17.6	9.5	10.64167	1
2023-11-08	2023	11	8	13	3	3	9.9	5.4	12.2	1297.8	17.6	9.0	10.83333	1
2023-11-08	2023	11	8	14	3	3	9.7	5.2	11.9	1305.0	17.6	8.4	11	1
2023-11-08	2023	11	8	15	3	3	9.5	4.5	11.8	1318.2	17.6	7.8	11.14167	1
2023-11-08	2023	11	8	16	3	3	9.2	3.1	11.3	1359.5	17.6	7.2	11.25833	1
2023-11-08	2023	11	8	17	3	3	8.9	2.8	9.7	1452.7	17.6	6.5	11.36667	1
2023-11-08	2023	11	8	18	3	3	8.6	1.9	8.7	1531.8	17.6	5.7	11.44167	1
2023-11-08	2023	11	8	19	3	3	8.2	2	7.1	1506.7	17.6	5.1	11.4	1
2023-11-08	2023	11	8	20	3	3	7.9	2	5.9	1467.9	17.6	4.5	11.25833	1
2023-11-08	2023	11	8	21	3	3	7.5	1.9	5.1	1426.3	17.6	4.1	10.975	1
2023-11-08	2023	11	8	22	3	3	7.2	1.8	5.4	1364.5	17.6	3.8	10.54167	1
2023-11-08	2023	11	8	23	3	3	6.8	1.7	6	1289.6	17.6	3.5	10.03333	1
2023-11-08	2023	11	8	24	3	3	6.3	1	5.4	1240.9	17.6	3.2	9.5	1
2023-11-09	2023	11	9	1	4	4	5.9	1.3	5.2	1205.5	17.0	2.8	8.966667	1
2023-11-09	2023	11	9	2	4	4	5.4	1.1	4.5	1174.8	17.0	2.4	8.375	1
2023-11-09	2023	11	9	3	4	4	4.9	1.3	3.1	1148.2	17.0	2.1	7.791667	1
2023-11-09	2023	11	9	4	4	4	4.5	1.3	2.8	1144.8	17.0	1.8	7.175	1
2023-11-09	2023	11	9	5	4	4	4.1	0.9	1.9	1167.6	17.0	1.7	6.45	1
2023-11-09	2023	11	9	6	4	4	3.6	1.2	2	1226.6	17.0	1.5	5.741667	1
2023-11-09	2023	11	9	7	4	4	3.3	1.4	2	1350.2	17.0	1.5	5.091667	1
2023-11-09	2023	11	9	8	4	4	3.0	1.3	1.9	1438.0	17.0	1.4	4.533333	1
2023-11-09	2023	11	9	9	4	4	2.7	2.1	1.8	1432.1	17.0	1.4	4.108333	1
2023-11-09	2023	11	9	10	4	4	2.6	3.5	1.7	1408.3	17.0	1.4	3.775	1
2023-11-09	2023	11	9	11	4	4	2.5	4.2	1	1382.8	17.0	1.5	3.5	1
2023-11-09	2023	11	9	12	4	4	2.5	5.2	1.3	1372.1	17.0	1.7	3.191667	1
2023-11-09	2023	11	9	13	4	4	2.4	5.6	1.1	1344.6	17.0	2.1	2.775	1
2023-11-09	2023	11	9	14	4	4	2.4	6	1.3	1318.9	17.0	2.4	2.433333	1
2023-11-09	2023	11	9	15	4	4	2.5	6.4	1.3	1319.5	17.0	2.8	2.091667	1
2023-11-09	2023	11	9	16	4	4	2.5	6.2	0.9	1345.4	17.0	3.3	1.825	1
2023-11-09	2023	11	9	17	4	4	2.7	6.1	1.2	1412.4	17.0	3.7	1.675	1
2023-11-09	2023	11	9	18	4	4	2.8	5.6	1.4	1480.6	17.0	4.1	1.516667	1
2023-11-09	2023	11	9	19	4	4	3.0	5.4	1.3	1447.6	17.0	4.5	1.458333	1
2023-11-09	2023	11	9	20	4	4	3.1	5.2	2.1	1406.4	17.0	4.8	1.408333	1
2023-11-09	2023	11	9	21	4	4	3.2	4.8	3.5	1362.8	17.0	5.1	1.35	1
2023-11-09	2023	11	9	22	4	4	3.4	4.7	4.2	1290.9	17.0	5.4	1.366667	1
2023-11-09	2023	11	9	23	4	4	3.5	4.5	5.2	1208.8	17.0	5.5	1.508333	1
2023-11-09	2023	11	9	24	4	4	3.6	4.4	5.6	1156.1	17.0	5.5	1.716667	1
2023-11-10	2023	11	10	1	5	5	3.7	4.2	6	1112.2	9.2	5.4	2.066667	1
2023-11-10	2023	11	10	2	5	5	3.9	4	6.4	1071.6	9.2	5.3	2.425	1
2023-11-10	2023	11	10	3	5	5	4.0	3.7	6.2	1050.1	9.2	5.1	2.833333	1
2023-11-10	2023	11	10	4	5	5	4.1	3.1	6.1	1048.6	9.2	4.9	3.258333	1
2023-11-10	2023	11	10	5	5	5	4.2	2.7	5.6	1070.5	9.2	4.6	3.666667	1
2023-11-10	2023	11	10	6	5	5	4.2	2.4	5.4	1124.9	9.2	4.4	4.1	1
2023-11-10	2023	11	10	7	5	5	4.3	3.4	5.2	1241.5	9.2	4.1	4.466667	1
2023-11-10	2023	11	10	8	5	5	4.4	3.9	4.8	1342.3	9.2	3.9	4.8	1
2023-11-10	2023	11	10	9	5	5	4.5	4.2	4.7	1355.1	9.2	3.8	5.125	1
2023-11-10	2023	11	10	10	5	5	4.6	5.3	4.5	1313.8	9.2	3.8	5.35	1
2023-11-10	2023	11	10	11	5	5	4.6	7	4.4	1281.3	9.2	3.8	5.45	1
2023-11-10	2023	11	10	12	5	5	4.8	7.4	4.2	1275.7	9.2	4.0	5.475	1
2023-11-10	2023	11	10	13	5	5	4.8	9	4	1252.2	9.2	4.3	5.408333	1
2023-11-10	2023	11	10	14	5	5	5.0	10	3.7	1244.3	9.2	4.7	5.291667	1
2023-11-10	2023	11	10	15	5	5	5.2	9	3.1	1232.2	9.2	5.2	5.125	1
2023-11-10	2023	11	10	16	5	5	5.3	9.1	2.7	1257.6	9.2	5.6	4.9	1
2023-11-10	2023	11	10	17	5	5	5.4	7.6	2.4	1324.0	9.2	6.1	4.641667	1
2023-11-10	2023	11	10	18	5	5	5.4	6.4	3.4	1398.2	9.2	6.5	4.358333	1
2023-11-10	2023	11	10	19	5	5	5.5	6.1	3.9	1361.6	9.2	6.9	4.091667	1
2023-11-10	2023	11	10	20	5	5	5.5	5.7	4.2	1324.3	9.2	7.1	3.925	1
2023-11-10	2023	11	10	21	5	5	5.5	5.6	5.3	1286.2	9.2	7.2	3.816667	1
2023-11-10	2023	11	10	22	5	5	5.6	5.2	7	1242.0	9.2	7.4	3.766667	1
2023-11-10	2023	11	10	23	5	5	5.6	5.1	7.4	1187.4	9.2	7.3	3.816667	1
2023-11-10	2023	11	10	24	5	5	5.6	5.1	9	1154.0	9.2	7.2	4.025	1
2023-11-11	2023	11	11	1	6	6	5.6	4.5	10	1117.2	11.0	7.0	4.275	0
2023-11-11	2023	11	11	2	6	6	5.6	5	9	1078.7	11.0	6.6	4.675	0
2023-11-11	2023	11	11	3	6	6	5.7	4.9	9.1	1050.1	11.0	6.2	5.175	0
2023-11-11	2023	11	11	4	6	6	5.7	4.8	7.6	1034.1	11.0	5.9	5.616667	0
2023-11-11	2023	11	11	5	6	6	5.8	4.8	6.4	1038.3	11.0	5.5	6.116667	0
2023-11-11	2023	11	11	6	6	6	5.9	4.8	6.1	1065.0	11.0	5.3	6.525	0
2023-11-11	2023	11	11	7	6	6	6.0	4.7	5.7	1108.1	11.0	5.1	6.858333	0
2023-11-11	2023	11	11	8	6	6	6.1	4.3	5.6	1171.2	11.0	5.0	7.083333	0

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLag	Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLag	Weekdays	
2023-11-11	2023	11	11	11	24	6	4.5	1.7	7.3	1164.7	11.0	4.2	4.9	0
2023-11-12	2023	11	12	12	1	7	4.4	1.8	6.6	1125.9	12.1	3.8	4.95	0
2023-11-12	2023	11	12	2	7	7	4.3	2.2	6	1104.5	12.1	3.4	5.183333	0
2023-11-12	2023	11	12	3	7	7	4.2	1.6	4.5	1095.7	12.1	3.0	5.316667	0
2023-11-12	2023	11	12	4	7	7	4.0	1.1	4.9	1097.5	12.1	2.6	5.408333	0
2023-11-12	2023	11	12	5	7	7	3.9	0.5	3.5	1109.5	12.1	2.4	5.383333	0
2023-11-12	2023	11	12	6	7	7	3.7	0.1	2.7	1140.9	12.1	2.0	5.391667	0
2023-11-12	2023	11	12	7	7	7	3.5	0.3	2.8	1191.9	12.1	1.7	5.283333	0
2023-11-12	2023	11	12	8	7	7	3.3	0.8	2.3	1255.6	12.1	1.5	5.116667	0
2023-11-12	2023	11	12	9	7	7	3.2	1.3	2	1312.4	12.1	1.3	4.991667	0
2023-11-12	2023	11	12	10	7	7	3.0	2.6	1.7	1321.3	12.1	1.3	4.808333	0
2023-11-12	2023	11	12	11	7	7	2.9	4	1.7	1302.9	12.1	1.3	4.525	0
2023-11-12	2023	11	12	12	7	7	2.8	5.1	1.8	1296.9	12.1	1.5	4.166667	0
2023-11-12	2023	11	12	13	7	7	2.8	4.6	2.2	1277.8	12.1	1.8	3.833333	0
2023-11-12	2023	11	12	14	7	7	2.7	5.5	1.6	1245.4	12.1	2.0	3.375	0
2023-11-12	2023	11	12	15	7	7	2.7	5.9	1.1	1239.1	12.1	2.3	3.008333	0
2023-11-12	2023	11	12	16	7	7	2.6	5.6	0.5	1273.3	12.1	2.7	2.641667	0
2023-11-12	2023	11	12	17	7	7	2.7	4.9	0.1	1371.7	12.1	3.0	2.358333	0
2023-11-12	2023	11	12	18	7	7	2.7	3.6	0.3	1469.6	12.1	3.4	1.991667	0
2023-11-12	2023	11	12	19	7	7	2.7	2.8	0.8	1444.1	12.1	3.7	1.708333	0
2023-11-12	2023	11	12	20	7	7	2.7	3.3	1.3	1408.1	12.1	3.9	1.508333	0
2023-11-12	2023	11	12	21	7	7	2.7	2.8	2.6	1368.1	12.1	4.1	1.341667	0
2023-11-12	2023	11	12	22	7	7	2.7	1.3	4	1322.6	12.1	4.2	1.258333	0
2023-11-12	2023	11	12	23	7	7	2.7	0.6	5.1	1261.0	12.1	4.1	1.308333	0
2023-11-12	2023	11	12	24	7	7	2.7	0.4	4.6	1213.2	12.1	3.8	1.5	0
2023-11-13	2023	11	13	1	1	1	2.6	0.1	5.5	1169.0	7.5	3.4	1.783333	1
2023-11-13	2023	11	13	2	1	1	2.5	0.3	5.9	1151.9	7.5	3.1	2.016667	1
2023-11-13	2023	11	13	3	1	1	2.5	0.1	5.6	1148.8	7.5	2.6	2.291667	1
2023-11-13	2023	11	13	4	1	1	2.4	-0.5	4.9	1158.9	7.5	2.2	2.65	1
2023-11-13	2023	11	13	5	1	1	2.3	-1.4	3.6	1174.2	7.5	1.6	3.025	1
2023-11-13	2023	11	13	6	1	1	2.3	-1.5	2.8	1222.7	7.5	1.1	3.391667	1
2023-11-13	2023	11	13	7	1	1	2.2	-1.6	3.3	1306.8	7.5	0.7	3.683333	1
2023-11-13	2023	11	13	8	1	1	2.1	-2.5	2.8	1385.7	7.5	0.3	3.891667	1
2023-11-13	2023	11	13	9	1	1	2.0	-0.8	1.3	1429.3	7.5	-0.2	4.1	1
2023-11-13	2023	11	13	10	1	1	1.9	1.5	0.6	1445.2	7.5	-0.5	4.225	1
2023-11-13	2023	11	13	11	1	1	1.8	1.7	0.4	1440.2	7.5	-0.4	4.116667	1
2023-11-13	2023	11	13	12	1	1	1.7	2.9	0.1	1425.9	7.5	-0.4	3.833333	1
2023-11-13	2023	11	13	13	1	1	1.7	3.6	0.3	1396.9	7.5	-0.1	3.441667	1
2023-11-13	2023	11	13	14	1	1	1.6	3.9	0.1	1363.5	7.5	0.2	3.066667	1
2023-11-13	2023	11	13	15	1	1	1.5	4.3	-0.5	1341.7	7.5	0.5	2.633333	1
2023-11-13	2023	11	13	16	1	1	1.5	4.4	-1.4	1366.8	7.5	0.8	2.15	1
2023-11-13	2023	11	13	17	1	1	1.4	4.3	-1.5	1470.8	7.5	1.2	1.641667	1
2023-11-13	2023	11	13	18	1	1	1.4	2.6	-1.6	1571.6	7.5	1.7	1.116667	1
2023-11-13	2023	11	13	19	1	1	1.4	1.8	-2.5	1543.8	7.5	2.0	0.691667	1
2023-11-13	2023	11	13	20	1	1	1.3	0.9	-0.8	1515.3	7.5	2.3	0.325	1
2023-11-13	2023	11	13	21	1	1	1.2	0.9	1.5	1471.2	7.5	2.6	-0.15833	1
2023-11-13	2023	11	13	22	1	1	1.1	1.3	1.7	1397.7	7.5	2.7	-0.45833	1
2023-11-13	2023	11	13	23	1	1	1.1	0.9	2.9	1317.1	7.5	2.7	-0.44167	1
2023-11-13	2023	11	13	24	1	1	1.2	0.5	3.6	1264.2	7.5	2.7	-0.35	1
2023-11-14	2023	11	14	1	2	2	1.2	1	3.9	1222.8	10.1	2.5	-0.14167	1
2023-11-14	2023	11	14	2	2	2	1.2	1.2	4.3	1189.8	10.1	2.2	0.15	1
2023-11-14	2023	11	14	3	2	2	1.2	1.1	4.4	1164.6	10.1	2.0	0.45	1
2023-11-14	2023	11	14	4	2	2	1.3	1	4.3	1158.9	10.1	1.7	0.8	1
2023-11-14	2023	11	14	5	2	2	1.3	1.2	2.6	1168.8	10.1	1.5	1.208333	1
2023-11-14	2023	11	14	6	2	2	1.4	1.2	1.8	1228.1	10.1	1.2	1.683333	1
2023-11-14	2023	11	14	7	2	2	1.6	1.5	0.9	1358.2	10.1	1.1	2.025	1
2023-11-14	2023	11	14	8	2	2	1.7	1.5	0.9	1482.8	10.1	1.1	2.308333	1
2023-11-14	2023	11	14	9	2	2	1.9	1.9	1.3	1493.6	10.1	1.1	2.591667	1
2023-11-14	2023	11	14	10	2	2	2.0	2.6	0.9	1451.6	10.1	1.2	2.733333	1
2023-11-14	2023	11	14	11	2	2	2.0	2.9	0.5	1410.5	10.1	1.3	2.716667	1
2023-11-14	2023	11	14	12	2	2	2.1	3.8	1	1382.8	10.1	1.5	2.65	1
2023-11-14	2023	11	14	13	2	2	2.1	4.7	1.2	1352.6	10.1	1.7	2.45	1
2023-11-14	2023	11	14	14	2	2	2.1	4.7	1.1	1339.7	10.1	2.1	2.233333	1
2023-11-14	2023	11	14	15	2	2	2.2	4.8	1	1346.7	10.1	2.3	2.008333	1
2023-11-14	2023	11	14	16	2	2	2.2	5	1.2	1373.5	10.1	2.7	1.741667	1
2023-11-14	2023	11	14	17	2	2	2.2	4.7	1.2	1465.4	10.1	3.0	1.458333	1
2023-11-14	2023	11	14	18	2	2	2.2	3.9	1.5	1558.2	10.1	3.3	1.2	1
2023-11-14	2023	11	14	19	2	2	2.3	2.4	1.5	1530.2	10.1	3.5	1.083333	1
2023-11-14	2023	11	14	20	2	2	2.3	1.6	1.9	1496.4	10.1	3.6	1.058333	1
2023-11-14	2023	11	14	21	2	2	2.3	1.1	2.6	1448.4	10.1	3.6	1.108333	1
2023-11-14	2023	11	14	22	2	2	2.4	0.6	2.9	1375.1	10.1	3.5	1.191667	1
2023-11-14	2023	11	14	23	2	2	2.3	0.9	3.8	1291.3	10.1	3.4	1.3	1
2023-11-14	2023	11	14	24	2	2	2.3	2.2	4.7	1244.8	10.1	3.2	1.466667	1
2023-11-15	2023	11	15	1	3	3	2.4	2.3	4.7	1206.2	9.6	3.1	1.741667	1
2023-11-15	2023	11	15	2	3	3	2.5	2.2	4.8	1171.0	9.6	2.9	2.05	1
2023-11-15	2023	11	15	3	3	3	2.5	1.9	5	1144.5	9.6	2.6	2.341667	1
2023-11-15	2023	11	15	4	3	3	2.5	1.8	4.7	1140.8	9.6	2.4	2.65	1
2023-11-15	2023	11	15	5	3	3	2.6	2.1	3.9	1151.7	9.6	2.1	2.983333	1
2023-11-15	2023	11	15	6	3	3	2.6	2.1	2.4	1212.0	9.6	1.9	3.275	1
2023-11-15	2023	11	15	7	3	3	2.6	1.1	1.6	1361.1	9.6	1.8	3.5	1
2023-11-15	2023	11	15	8	3	3	2.6	0.2	1.1	1474.1	9.6	1.7	3.575	1
2023-11-15	2023	11	15	9	3	3	2.6	1.7	0.6	1481.5	9.6	1.5	3.583333	1
2023-11-15	2023	11	15	10	3	3	2.6	3	0.9	1426.0	9.6	1.6	3.516667	1
2023-11-15	2023	11	15	11	3	3	2.6	4.6	2.2	1367.3	9.6	1.8	3.35	1
2023-11-15	2023	11	15	12	3	3	2.6	5.2	2.3	1348.9	9.6	2.1	3.183333	1
2023-11-15	2023	11	15	13	3	3	2.7	5.2	2.2	1324.5	9.6	2.4	3.05	1
2023-11-15	2023	11	15	14	3	3	2.7	6.7	1.9	1291.0	9.6	2.6	2.85	1
2023-11-15	2023	11	15	15	3	3	2.8	5.8	1.8	1277.0	9.6	3.0	2.641667	1
2023-11-15	2023	11	15	16	3	3	2.8	6.1	2.1	1309.7	9.6	3.3	2.4	1
2023-11-15	2023	11	15	17	3	3	2.9	5.3	2.1	1411.9	9.6	3.7	2.133333	1
2023-11-15	2023	11	15	18	3	3	2.9	4.7	1.1	1526.4	9.6	3.9	1.916667	1
2023-11-15	2023	11	15	19	3	3	3.0	2.7	0.2	1516.1	9.6	4.1	1.766667	1
2023-11-15	2023	11	15	20	3	3	3.0	0.9	1.7	1498.5	9.6	4.3	1.6583	

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLa	gTemp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLa	Weekdays
2023-11-16	2023	11	16	16	12	4	4.5	10.2	2.6	1250.4	10.9	5.2 3.733333	1
2023-11-16	2023	11	16	16	13	4	4.7	10.6	2.8	1223.8	10.9	5.8 3.5	1
2023-11-16	2023	11	16	16	14	4	4.9	11.1	2.3	1207.8	10.9	6.5 3.283333	1
2023-11-16	2023	11	16	16	15	4	5.1	11	2.7	1194.6	10.9	7.2 2.958333	1
2023-11-16	2023	11	16	16	16	4	5.3	11.4	3.6	1218.0	10.9	7.9 2.666667	1
2023-11-16	2023	11	16	17	4	4	5.5	10.2	6.2	1306.3	10.9	8.6 2.383333	1
2023-11-16	2023	11	16	18	4	4	5.7	8.4	7.1	1408.4	10.9	9.2 2.241667	1
2023-11-16	2023	11	16	19	4	4	5.9	7.2	7.5	1402.3	10.9	9.4 2.366667	1
2023-11-16	2023	11	16	20	4	4	6.1	6.4	7.5	1384.6	10.9	9.4 2.733333	1
2023-11-16	2023	11	16	21	4	4	6.3	5.7	8.6	1357.8	10.9	9.3 3.283333	1
2023-11-16	2023	11	16	22	4	4	6.5	5.3	8.9	1309.7	10.9	9.1 3.875	1
2023-11-16	2023	11	16	23	4	4	6.7	4.9	10.2	1247.2	10.9	8.9 4.608333	1
2023-11-16	2023	11	16	24	4	4	6.9	4	10.6	1209.4	10.9	8.5 5.183333	1
2023-11-17	2023	11	17	1	5	5	6.9	2.8	11.1	1185.7	10.5	8.0 5.833333	1
2023-11-17	2023	11	17	2	5	5	6.9	2.2	11	1169.3	10.5	7.4 6.5	1
2023-11-17	2023	11	17	3	5	5	6.9	0.3	11.4	1152.8	10.5	6.6 7.191667	1
2023-11-17	2023	11	17	4	5	5	6.8	0.4	10.2	1159.1	10.5	5.7 7.916667	1
2023-11-17	2023	11	17	5	5	5	6.7	1	8.4	1185.7	10.5	4.8 8.641667	1
2023-11-17	2023	11	17	6	5	5	6.6	0.1	7.2	1254.5	10.5	4.1 9.191667	1
2023-11-17	2023	11	17	7	5	5	6.4	-0.8	6.4	1387.3	10.5	3.4 9.375	1
2023-11-17	2023	11	17	8	5	5	6.0	-1	5.7	1485.6	10.5	2.7 9.383333	1
2023-11-17	2023	11	17	9	5	5	5.7	0.2	5.3	1464.1	10.5	2.1 9.291667	1
2023-11-17	2023	11	17	10	5	5	5.4	4.2	4.9	1374.2	10.5	1.6 9.141667	1
2023-11-17	2023	11	17	11	5	5	5.2	7.6	4	1294.4	10.5	1.5 8.866667	1
2023-11-17	2023	11	17	12	5	5	5.1	9.6	2.8	1243.4	10.5	1.8 8.533333	1
2023-11-17	2023	11	17	13	5	5	5.1	10.1	2.2	1219.1	10.5	2.2 8.016667	1
2023-11-17	2023	11	17	14	5	5	5.1	9.6	0.3	1182.8	10.5	2.8 7.366667	1
2023-11-17	2023	11	17	15	5	5	5.0	10.4	0.4	1161.7	10.5	3.4 6.625	1
2023-11-17	2023	11	17	16	5	5	5.0	10.4	1	1186.3	10.5	4.3 5.733333	1
2023-11-17	2023	11	17	17	5	5	5.0	9.4	0.1	1273.0	10.5	5.1 4.816667	1
2023-11-17	2023	11	17	18	5	5	4.9	8.7	-0.8	1349.0	10.5	5.8 4.05	1
2023-11-17	2023	11	17	19	5	5	4.9	8.5	-1	1321.1	10.5	6.5 3.358333	1
2023-11-17	2023	11	17	20	5	5	5.0	9	0.2	1275.3	10.5	7.3 2.691667	1
2023-11-17	2023	11	17	21	5	5	5.1	10	4.2	1232.4	10.5	8.1 2.075	1
2023-11-17	2023	11	17	22	5	5	5.3	9.9	7.6	1170.3	10.5	9.0 1.616667	1
2023-11-17	2023	11	17	23	5	5	5.5	10	9.6	1104.7	10.5	9.4 1.525	1
2023-11-17	2023	11	17	24	5	5	5.7	9.9	10.1	1058.1	10.5	9.6 1.75	1
2023-11-18	2023	11	18	1	6	6	5.9	9.7	9.6	999.6	17.8	9.7 2.216667	0
2023-11-18	2023	11	18	2	6	6	6.2	10.1	10.4	948.0	17.8	9.6 2.825	0
2023-11-18	2023	11	18	3	6	6	6.6	10.9	10.4	917.5	17.8	9.7 3.441667	0
2023-11-18	2023	11	18	4	6	6	7.0	11.2	9.4	904.0	17.8	9.7 4.283333	0
2023-11-18	2023	11	18	5	6	6	7.4	11.4	8.7	894.6	17.8	9.8 5.116667	0
2023-11-18	2023	11	18	6	6	6	7.9	11.4	8.5	912.7	17.8	9.9 5.816667	0
2023-11-18	2023	11	18	7	6	6	8.4	11.7	9	953.8	17.8	10.2 6.533333	0
2023-11-18	2023	11	18	8	6	6	8.9	12.2	10	1011.0	17.8	10.4 7.308333	0
2023-11-18	2023	11	18	9	6	6	9.4	11.7	9.9	1082.3	17.8	10.7 8.141667	0
2023-11-18	2023	11	18	10	6	6	9.9	12.3	10	1128.4	17.8	10.8 8.958333	0
2023-11-18	2023	11	18	11	6	6	10.2	12.2	9.9	1142.2	17.8	11.0 9.433333	0
2023-11-18	2023	11	18	12	6	6	10.4	12.4	9.7	1157.4	17.8	11.2 9.633333	0
2023-11-18	2023	11	18	13	6	6	10.5	11.8	10.1	1168.4	17.8	11.4 9.658333	0
2023-11-18	2023	11	18	14	6	6	10.6	11.7	10.9	1168.5	17.8	11.6 9.625	0
2023-11-18	2023	11	18	15	6	6	10.7	11.4	11.2	1169.7	17.8	11.7 9.666667	0
2023-11-18	2023	11	18	16	6	6	10.7	11.2	11.4	1179.1	17.8	11.8 9.708333	0
2023-11-18	2023	11	18	17	6	6	10.8	11.6	11.4	1249.6	17.8	11.8 9.775	0
2023-11-18	2023	11	18	18	6	6	10.9	12.7	11.7	1294.3	17.8	11.8 9.941667	0
2023-11-18	2023	11	18	19	6	6	11.0	12.7	12.2	1237.3	17.8	11.9 10.16667	0
2023-11-18	2023	11	18	20	6	6	11.2	12.7	11.7	1193.2	17.8	12.0 10.43333	0
2023-11-18	2023	11	18	21	6	6	11.4	12.5	12.3	1140.7	17.8	12.0 10.7	0
2023-11-18	2023	11	18	22	6	6	11.5	13.2	12.2	1087.3	17.8	12.1 10.84167	0
2023-11-18	2023	11	18	23	6	6	11.6	12.9	12.4	1054.1	17.8	12.2 11.04167	0
2023-11-18	2023	11	18	24	6	6	11.7	8.9	11.8	995.5	17.8	12.2 11.225	0
2023-11-19	2023	11	19	1	7	7	11.7	7.3	11.7	939.9	13.7	11.9 11.43333	0
2023-11-19	2023	11	19	2	7	7	11.6	7	11.4	915.5	13.7	11.6 11.60833	0
2023-11-19	2023	11	19	3	7	7	11.5	6.4	11.2	908.8	13.7	11.2 11.74167	0
2023-11-19	2023	11	19	4	7	7	11.3	5.9	11.6	918.3	13.7	10.8 11.78333	0
2023-11-19	2023	11	19	5	7	7	11.1	5	12.7	935.9	13.7	10.3 11.78333	0
2023-11-19	2023	11	19	6	7	7	10.8	4.4	12.7	974.4	13.7	9.8 11.8	0
2023-11-19	2023	11	19	7	7	7	10.5	4	12.7	1030.3	13.7	9.1 11.90833	0
2023-11-19	2023	11	19	8	7	7	10.2	3.6	12.5	1107.7	13.7	8.4 11.99167	0
2023-11-19	2023	11	19	9	7	7	9.8	3.3	13.2	1198.9	13.7	7.6 12.03333	0
2023-11-19	2023	11	19	10	7	7	9.5	3.4	12.9	1233.7	13.7	6.8 12.1	0
2023-11-19	2023	11	19	11	7	7	9.1	4.5	8.9	1226.6	13.7	6.0 12.175	0
2023-11-19	2023	11	19	12	7	7	8.8	4.6	7.3	1208.7	13.7	5.3 12.23333	0
2023-11-19	2023	11	19	13	7	7	8.4	5.3	7	1187.9	13.7	5.0 11.94167	0
2023-11-19	2023	11	19	14	7	7	8.2	6.3	6.4	1161.0	13.7	4.8 11.56667	0
2023-11-19	2023	11	19	15	7	7	8.0	6.7	5.9	1156.7	13.7	4.7 11.175	0
2023-11-19	2023	11	19	16	7	7	7.8	6.8	5	1202.4	13.7	4.8 10.75833	0
2023-11-19	2023	11	19	17	7	7	7.6	6.4	4.4	1324.0	13.7	4.8 10.31667	0
2023-11-19	2023	11	19	18	7	7	7.4	5.2	4	1429.9	13.7	4.9 9.766667	0
2023-11-19	2023	11	19	19	7	7	7.0	3.8	3.6	1417.2	13.7	5.0 9.075	0
2023-11-19	2023	11	19	20	7	7	6.7	3.6	3.3	1403.2	13.7	5.0 8.35	0
2023-11-19	2023	11	19	21	7	7	6.3	3.2	3.4	1379.5	13.7	5.0 7.591667	0
2023-11-19	2023	11	19	22	7	7	5.9	1.2	4.5	1321.2	13.7	5.0 6.825	0
2023-11-19	2023	11	19	23	7	7	5.4	-0.6	4.6	1242.1	13.7	4.8 6.008333	0
2023-11-19	2023	11	19	24	7	7	4.8	0.4	5.3	1174.9	13.7	4.4 5.308333	0
2023-11-20	2023	11	20	1	1	1	4.5	1.7	6.3	1130.6	13.0	4.0 4.95	1
2023-11-20	2023	11	20	2	1	1	4.3	2.6	6.7	1099.5	13.0	3.7 4.783333	1
2023-11-20	2023	11	20	3	1	1	4.1	3.1	6.8	1096.5	13.0	3.4 4.725	1
2023-11-20	2023	11	20	4	1	1	3.9	1.9	6.4	1100.6	13.0	3.1 4.75	1
2023-11-20	2023	11	20	5	1	1	3.8	1.8	5.2	1111.0	13.0	2.7 4.825	1
2023-11-20	2023	11	20	6	1	1	3.6	1.8	3.8	1172.2	13.0	2.3 4.941667	1
2023-11-20	2023	11	20	7	1	1	3.5	1.5	3.6	1310.0	13.0	2.0 5.008333	1
2023-11-20	2023	11	20	8	1	1	3.4	1.8	3.2	1426.6	13.0	1.9 4.991667	1
2023-11-20	2023	11	20	9	1	1	3.3	2.2	1.2	1464.1	13.0	1.7 4.991667	1
2023-11-20	2023	11	20	10	1	1	3.3						

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLag	Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLag	Weekdays	
2023-11-20	2023	11	20	24	24	1	1.4	-1.1	3.4	1347.8	13.0	1.0	1.891667	1
2023-11-21	2023	11	21	1	1	2	1.4	-1.4	2.7	1310.1	14.3	0.6	2.083333	1
2023-11-21	2023	11	21	2	2	2	1.2	-1.5	2.4	1279.0	14.3	0.2	2.225	1
2023-11-21	2023	11	21	3	2	2	1.1	-1.6	1.7	1256.2	14.3	-0.1	2.233333	1
2023-11-21	2023	11	21	4	2	2	0.9	-1.8	1	1253.3	14.3	-0.4	2.175	1
2023-11-21	2023	11	21	5	2	2	0.7	-2	0.2	1272.5	14.3	-0.7	2.158333	1
2023-11-21	2023	11	21	6	2	2	0.6	-2.1	-0.1	1335.5	14.3	-1.0	2.091667	1
2023-11-21	2023	11	21	7	2	2	0.4	-2.4	-0.1	1474.2	14.3	-1.2	1.958333	1
2023-11-21	2023	11	21	8	2	2	0.2	-2.7	-0.6	1583.2	14.3	-1.4	1.825	1
2023-11-21	2023	11	21	9	2	2	0.0	-2.2	-0.8	1569.8	14.3	-1.6	1.666667	1
2023-11-21	2023	11	21	10	2	2	-0.1	-1	-1	1502.2	14.3	-1.7	1.433333	1
2023-11-21	2023	11	21	11	2	2	-0.3	0.5	-1.1	1440.9	14.3	-1.7	1.216667	1
2023-11-21	2023	11	21	12	2	2	-0.3	1.7	-1.4	1404.4	14.3	-1.6	0.958333	1
2023-11-21	2023	11	21	13	2	2	-0.4	2.7	-1.5	1378.4	14.3	-1.4	0.641667	1
2023-11-21	2023	11	21	14	2	2	-0.4	2.5	-1.6	1361.7	14.3	-1.0	0.241667	1
2023-11-21	2023	11	21	15	2	2	-0.4	3.3	-1.8	1350.2	14.3	-0.7	-0.10833	1
2023-11-21	2023	11	21	16	2	2	-0.4	3.3	-2	1388.4	14.3	-0.3	-0.44167	1
2023-11-21	2023	11	21	17	2	2	-0.3	2.6	-2.1	1502.1	14.3	0.1	-0.73333	1
2023-11-21	2023	11	21	18	2	2	-0.2	1.3	-2.4	1623.3	14.3	0.5	-0.98333	1
2023-11-21	2023	11	21	19	2	2	-0.2	-0.2	-2.7	1618.0	14.3	0.8	-1.175	1
2023-11-21	2023	11	21	20	2	2	-0.2	-0.4	-2.2	1600.6	14.3	1.0	-1.36667	1
2023-11-21	2023	11	21	21	2	2	-0.2	-1.2	-1	1563.7	14.3	1.2	-1.58333	1
2023-11-21	2023	11	21	22	2	2	-0.2	-1.2	0.5	1499.7	14.3	1.3	-1.71667	1
2023-11-21	2023	11	21	23	2	2	-0.2	-2.4	1.7	1424.1	14.3	1.2	-1.73333	1
2023-11-21	2023	11	21	24	2	2	-0.3	-1.9	2.7	1384.5	14.3	1.0	-1.60833	1
2023-11-22	2023	11	22	1	3	3	-0.3	-2.3	2.5	1348.6	14.3	0.7	-1.375	1
2023-11-22	2023	11	22	2	3	3	-0.4	-2.2	3.3	1325.5	14.3	0.3	-1.03333	1
2023-11-22	2023	11	22	3	3	3	-0.4	-2.3	3.3	1302.7	14.3	-0.1	-0.7	1
2023-11-22	2023	11	22	4	3	3	-0.4	-3	2.6	1298.8	14.3	-0.6	-0.29167	1
2023-11-22	2023	11	22	5	3	3	-0.5	-3.4	1.3	1312.5	14.3	-1.1	0.133333	1
2023-11-22	2023	11	22	6	3	3	-0.5	-1.7	-0.2	1370.2	14.3	-1.6	0.516667	1
2023-11-22	2023	11	22	7	3	3	-0.5	-1.3	-0.4	1504.4	14.3	-1.9	0.8	1
2023-11-22	2023	11	22	8	3	3	-0.5	-1.4	-1.2	1614.5	14.3	-1.9	0.983333	1
2023-11-22	2023	11	22	9	3	3	-0.4	-1.4	-1.2	1623.7	14.3	-2.0	1.175	1
2023-11-22	2023	11	22	10	3	3	-0.4	-0.2	-2.4	1589.5	14.3	-2.0	1.258333	1
2023-11-22	2023	11	22	11	3	3	-0.4	2.7	-1.9	1558.8	14.3	-2.0	1.241667	1
2023-11-22	2023	11	22	12	3	3	-0.3	3.1	-2.3	1559.9	14.3	-1.5	1	1
2023-11-22	2023	11	22	13	3	3	-0.2	3.5	-2.2	1563.5	14.3	-1.1	0.7	1
2023-11-22	2023	11	22	14	3	3	-0.2	3.8	-2.3	1535.7	14.3	-0.6	0.283333	1
2023-11-22	2023	11	22	15	3	3	-0.1	4.3	-3	1519.0	14.3	-0.1	-0.10833	1
2023-11-22	2023	11	22	16	3	3	-0.1	4.5	-3.4	1546.7	14.3	0.4	-0.575	1
2023-11-22	2023	11	22	17	3	3	0.0	4.7	-1.7	1615.4	14.3	1.0	-1.1	1
2023-11-22	2023	11	22	18	3	3	0.1	4.6	-1.3	1656.6	14.3	1.7	-1.6	1
2023-11-22	2023	11	22	19	3	3	0.2	4.1	-1.4	1607.3	14.3	2.2	-1.85	1
2023-11-22	2023	11	22	20	3	3	0.4	3.8	-1.4	1557.7	14.3	2.7	-1.94167	1
2023-11-22	2023	11	22	21	3	3	0.6	3.9	-0.2	1514.6	14.3	3.1	-2.025	1
2023-11-22	2023	11	22	22	3	3	0.8	4.5	2.7	1427.6	14.3	3.6	-2.04167	1
2023-11-22	2023	11	22	23	3	3	1.0	4.9	3.1	1329.5	14.3	4.0	-1.95833	1
2023-11-22	2023	11	22	24	3	3	1.3	5.5	3.5	1274.4	14.3	4.1	-1.53333	1
2023-11-23	2023	11	23	1	4	4	1.6	6.1	3.8	1219.0	18.2	4.3	-1.11667	1
2023-11-23	2023	11	23	2	4	4	2.0	6.5	4.3	1166.2	18.2	4.6	-0.63333	1
2023-11-23	2023	11	23	3	4	4	2.3	6.9	4.5	1128.0	18.2	4.8	-0.13333	1
2023-11-23	2023	11	23	4	4	4	2.7	7.1	4.7	1107.8	18.2	5.0	0.416667	1
2023-11-23	2023	11	23	5	4	4	3.1	7.7	4.6	1107.5	18.2	5.2	1.041667	1
2023-11-23	2023	11	23	6	4	4	3.6	9.9	4.1	1148.5	18.2	5.5	1.716667	1
2023-11-23	2023	11	23	7	4	4	4.1	9.8	3.8	1254.2	18.2	5.9	2.241667	1
2023-11-23	2023	11	23	8	4	4	4.5	9.7	3.9	1347.5	18.2	6.4	2.691667	1
2023-11-23	2023	11	23	9	4	4	5.0	10.1	4.5	1369.2	18.2	6.9	3.125	1
2023-11-23	2023	11	23	10	4	4	5.5	10.1	4.9	1372.2	18.2	7.4	3.566667	1
2023-11-23	2023	11	23	11	4	4	5.9	10.7	5.5	1353.2	18.2	7.9	3.958333	1
2023-11-23	2023	11	23	12	4	4	6.2	10.8	6.1	1340.8	18.2	8.3	4.141667	1
2023-11-23	2023	11	23	13	4	4	6.6	11.7	6.5	1333.1	18.2	8.8	4.341667	1
2023-11-23	2023	11	23	14	4	4	6.9	11.4	6.9	1313.4	18.2	9.3	4.558333	1
2023-11-23	2023	11	23	15	4	4	7.2	9.8	7.1	1297.2	18.2	9.7	4.783333	1
2023-11-23	2023	11	23	16	4	4	7.5	9.6	7.7	1305.1	18.2	9.9	5	1
2023-11-23	2023	11	23	17	4	4	7.7	9.2	9.9	1382.1	18.2	10.1	5.216667	1
2023-11-23	2023	11	23	18	4	4	7.9	8.4	9.8	1445.8	18.2	10.2	5.466667	1
2023-11-23	2023	11	23	19	4	4	8.0	7.1	9.7	1417.5	18.2	10.1	5.908333	1
2023-11-23	2023	11	23	20	4	4	8.1	6.6	10.1	1386.8	18.2	9.9	6.383333	1
2023-11-23	2023	11	23	21	4	4	8.3	5.8	10.1	1348.6	18.2	9.6	6.875	1
2023-11-23	2023	11	23	22	4	4	8.3	5.8	10.7	1289.9	18.2	9.3	7.391667	1
2023-11-23	2023	11	23	23	4	4	8.4	5.6	10.8	1215.8	18.2	8.9	7.858333	1
2023-11-23	2023	11	23	24	4	4	8.4	5.2	11.7	1171.6	18.2	8.5	8.341667	1
2023-11-24	2023	11	24	1	5	5	8.4	5.1	11.4	1130.3	15.8	8.0	8.783333	1
2023-11-24	2023	11	24	2	5	5	8.4	5.1	9.8	1100.5	15.8	7.5	9.25	1
2023-11-24	2023	11	24	3	5	5	8.3	4.9	9.6	1074.9	15.8	6.9	9.658333	1
2023-11-24	2023	11	24	4	5	5	8.2	4.5	9.2	1069.6	15.8	6.5	9.9	1
2023-11-24	2023	11	24	5	5	5	8.1	4.4	8.4	1090.1	15.8	6.1	10.10833	1
2023-11-24	2023	11	24	6	5	5	8.0	3.9	7.1	1153.1	15.8	5.7	10.23333	1
2023-11-24	2023	11	24	7	5	5	7.7	3.6	6.6	1283.6	15.8	5.3	10.10833	1
2023-11-24	2023	11	24	8	5	5	7.5	3	5.8	1403.7	15.8	5.0	9.883333	1
2023-11-24	2023	11	24	9	5	5	7.2	3.1	5.8	1411.3	15.8	4.7	9.625	1
2023-11-24	2023	11	24	10	5	5	6.9	3.9	5.6	1361.2	15.8	4.5	9.266667	1
2023-11-24	2023	11	24	11	5	5	6.6	4.8	5.2	1321.7	15.8	4.4	8.908333	1
2023-11-24	2023	11	24	12	5	5	6.4	5.5	5.1	1303.3	15.8	4.3	8.483333	1
2023-11-24	2023	11	24	13	5	5	6.2	6.1	5.1	1301.0	15.8	4.3	8.016667	1
2023-11-24	2023	11	24	14	5	5	5.9	5.9	4.9	1291.9	15.8	4.4	7.466667	1
2023-11-24	2023	11	24	15	5	5	5.7	7.1	4.5	1288.3	15.8	4.5	6.941667	1
2023-11-24	2023	11	24	16	5	5	5.6	6.7	4.4	1326.9	15.8	4.7	6.533333	1
2023-11-24	2023	11	24	17	5	5	5.5	6	3.9	1407.9	15.8	4.8	6.108333	1
2023-11-24	2023	11	24	18	5	5	5.3	5.7	3.6	1476.3	15.8	5.0	5.708333	1
2023-11-24	2023	11	24	19	5	5	5.2	4.9	3	1447.4	15.8	5.1	5.333333	1
2023-11-24	2023	11	24	20</										

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLa	g Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLa	g Weekdays	
2023-11-25	2023	11	11	25	12	6	0.9	-4	-0.3	1530.1	16.6	-3.4	5.141667	0
2023-11-25	2023	11	11	25	13	6	0.5	-3.6	-1.3	1491.7	16.6	-3.8	4.783333	0
2023-11-25	2023	11	11	25	14	6	0.1	-2.9	-2	1457.1	16.6	-4.1	4.25	0
2023-11-25	2023	11	11	25	15	6	-0.3	-2.4	-3.3	1443.2	16.6	-4.3	3.65	0
2023-11-25	2023	11	11	25	16	6	-0.7	-2.1	-3.8	1484.5	16.6	-4.3	2.891667	0
2023-11-25	2023	11	11	25	17	6	-1.1	-2.4	-4.4	1606.9	16.6	-4.2	2.058333	0
2023-11-25	2023	11	11	25	18	6	-1.4	-2.9	-5.1	1712.2	16.6	-4.1	1.241667	0
2023-11-25	2023	11	11	25	19	6	-1.8	-3.1	-5.6	1682.9	16.6	-3.9	0.4	0
2023-11-25	2023	11	11	25	20	6	-2.1	-3.3	-5.8	1661.7	16.6	-3.8	-0.43333	0
2023-11-25	2023	11	11	25	21	6	-2.4	-3.5	-5.5	1638.3	16.6	-3.6	-1.24167	0
2023-11-25	2023	11	11	25	22	6	-2.7	-3.5	-5	1590.8	16.6	-3.4	-2.05833	0
2023-11-25	2023	11	11	25	23	6	-3.0	-4	-4	1518.8	16.6	-3.2	-2.825	0
2023-11-25	2023	11	11	25	24	6	-3.3	-4.3	-3.6	1468.5	16.6	-3.1	-3.40833	0
2023-11-26	2023	11	11	26	1	7	-3.5	-3	-2.9	1417.0	9.3	-3.2	-3.84167	0
2023-11-26	2023	11	11	26	2	7	-3.6	-2.6	-2.4	1385.1	9.3	-3.1	-4.11667	0
2023-11-26	2023	11	11	26	3	7	-3.7	-2.5	-2.1	1372.0	9.3	-3.1	-4.25	0
2023-11-26	2023	11	11	26	4	7	-3.7	-2.4	-2.4	1367.1	9.3	-3.1	-4.28333	0
2023-11-26	2023	11	11	26	5	7	-3.7	-2.5	-2.9	1374.1	9.3	-3.1	-4.18333	0
2023-11-26	2023	11	11	26	6	7	-3.6	-2.3	-3.1	1407.0	9.3	-3.1	-4.06667	0
2023-11-26	2023	11	11	26	7	7	-3.5	-2.3	-3.3	1446.5	9.3	-3.1	-3.94167	0
2023-11-26	2023	11	11	26	8	7	-3.4	-2.1	-3.5	1505.4	9.3	-3.0	-3.775	0
2023-11-26	2023	11	11	26	9	7	-3.3	-1.5	-3.5	1574.1	9.3	-2.9	-3.58333	0
2023-11-26	2023	11	11	26	10	7	-3.1	-0.2	-4	1596.8	9.3	-2.8	-3.39167	0
2023-11-26	2023	11	11	26	11	7	-2.9	2.5	-4.3	1562.2	9.3	-2.5	-3.225	0
2023-11-26	2023	11	11	26	12	7	-2.5	3.4	-3	1532.5	9.3	-1.9	-3.14167	0
2023-11-26	2023	11	11	26	13	7	-2.2	3.8	-2.6	1497.8	9.3	-1.3	-3.16667	0
2023-11-26	2023	11	11	26	14	7	-1.9	4.3	-2.5	1458.9	9.3	-0.7	-3.11667	0
2023-11-26	2023	11	11	26	15	7	-1.6	4	-2.4	1436.1	9.3	-0.2	-3.09167	0
2023-11-26	2023	11	11	26	16	7	-1.4	4	-2.5	1463.5	9.3	0.4	-3.1	0
2023-11-26	2023	11	11	26	17	7	-1.1	3.5	-2.3	1560.9	9.3	0.9	-3.125	0
2023-11-26	2023	11	11	26	18	7	-0.9	3.5	-2.3	1638.7	9.3	1.4	-3.13333	0
2023-11-26	2023	11	11	26	19	7	-0.6	3.3	-2.1	1602.7	9.3	1.9	-3.08333	0
2023-11-26	2023	11	11	26	20	7	-0.3	3.3	-1.5	1568.9	9.3	2.4	-3.01667	0
2023-11-26	2023	11	11	26	21	7	0.0	3.7	-0.2	1514.6	9.3	2.8	-2.91667	0
2023-11-26	2023	11	11	26	22	7	0.3	3.6	2.5	1446.4	9.3	3.3	-2.75	0
2023-11-26	2023	11	11	26	23	7	0.6	3.8	3.4	1349.3	9.3	3.6	-2.475	0
2023-11-26	2023	11	11	26	24	7	0.9	3.6	3.8	1269.3	9.3	3.7	-1.93333	0
2023-11-27	2023	11	11	27	1	1	1.2	3.6	4.3	1215.3	26.9	3.7	-1.29167	1
2023-11-27	2023	11	11	27	2	1	1.5	3.7	4	1179.8	26.9	3.7	-0.725	1
2023-11-27	2023	11	11	27	3	1	1.7	4.1	4	1164.8	26.9	3.6	-0.15	1
2023-11-27	2023	11	11	27	4	1	2.0	4.3	3.5	1158.8	26.9	3.6	0.391667	1
2023-11-27	2023	11	11	27	5	1	2.3	4	3.5	1166.6	26.9	3.7	0.925	1
2023-11-27	2023	11	11	27	6	1	2.6	5.2	3.3	1213.7	26.9	3.7	1.425	1
2023-11-27	2023	11	11	27	7	1	2.9	5.6	3.3	1332.0	26.9	3.9	1.908333	1
2023-11-27	2023	11	11	27	8	1	3.2	5.9	3.7	1439.8	26.9	4.0	2.375	1
2023-11-27	2023	11	11	27	9	1	3.5	6.6	3.6	1464.8	26.9	4.3	2.825	1
2023-11-27	2023	11	11	27	10	1	3.9	7	3.8	1469.9	26.9	4.5	3.258333	1
2023-11-27	2023	11	11	27	11	1	4.2	7.5	3.6	1470.9	26.9	4.8	3.575	1
2023-11-27	2023	11	11	27	12	1	4.4	8	3.6	1481.7	26.9	5.1	3.683333	1
2023-11-27	2023	11	11	27	13	1	4.6	8.1	3.7	1475.5	26.9	5.5	3.7	1
2023-11-27	2023	11	11	27	14	1	4.8	8.2	4.1	1458.7	26.9	5.8	3.683333	1
2023-11-27	2023	11	11	27	15	1	4.9	8.4	4.3	1442.4	26.9	6.2	3.633333	1
2023-11-27	2023	11	11	27	16	1	5.1	9.2	4	1450.9	26.9	6.6	3.641667	1
2023-11-27	2023	11	11	27	17	1	5.3	10.3	5.2	1464.1	26.9	7.0	3.666667	1
2023-11-27	2023	11	11	27	18	1	5.6	10.4	5.6	1517.8	26.9	7.5	3.708333	1
2023-11-27	2023	11	11	27	19	1	5.9	10.6	5.9	1473.8	26.9	7.9	3.85	1
2023-11-27	2023	11	11	27	20	1	6.2	10.2	6.6	1407.6	26.9	8.4	4.041667	1
2023-11-27	2023	11	11	27	21	1	6.5	9.9	7	1353.5	26.9	8.7	4.258333	1
2023-11-27	2023	11	11	27	22	1	6.7	10.4	7.5	1277.1	26.9	9.0	4.5	1
2023-11-27	2023	11	11	27	23	1	7.0	10	8	1195.0	26.9	9.3	4.783333	1
2023-11-27	2023	11	11	27	24	1	7.3	9.6	8.1	1129.5	26.9	9.5	5.091667	1
2023-11-28	2023	11	11	28	1	2	7.5	8.5	8.2	1094.5	10.6	9.6	5.458333	1
2023-11-28	2023	11	11	28	2	2	7.7	6.8	8.4	1058.8	10.6	9.6	5.833333	1
2023-11-28	2023	11	11	28	3	2	7.9	6.2	9.2	1042.1	10.6	9.5	6.208333	1
2023-11-28	2023	11	11	28	4	2	8.0	4.7	10.3	1040.1	10.6	9.3	6.566667	1
2023-11-28	2023	11	11	28	5	2	8.0	4.1	10.4	1069.7	10.6	9.0	6.975	1
2023-11-28	2023	11	11	28	6	2	8.0	3.8	10.6	1144.0	10.6	8.5	7.5	1
2023-11-28	2023	11	11	28	7	2	7.9	3.2	10.2	1291.3	10.6	7.9	7.933333	1
2023-11-28	2023	11	11	28	8	2	7.8	2.8	9.9	1408.3	10.6	7.3	8.35	1
2023-11-28	2023	11	11	28	9	2	7.7	2.8	10.4	1418.8	10.6	6.7	8.708333	1
2023-11-28	2023	11	11	28	10	2	7.5	3.7	10	1389.8	10.6	6.1	8.983333	1
2023-11-28	2023	11	11	28	11	2	7.4	3.9	9.6	1378.8	10.6	5.5	9.266667	1
2023-11-28	2023	11	11	28	12	2	7.2	4.3	8.5	1383.5	10.6	5.0	9.475	1
2023-11-28	2023	11	11	28	13	2	7.1	4.3	6.8	1395.2	10.6	4.6	9.608333	1
2023-11-28	2023	11	11	28	14	2	6.9	3.9	6.2	1399.8	10.6	4.2	9.641667	1
2023-11-28	2023	11	11	28	15	2	6.8	3.5	4.7	1400.3	10.6	4.0	9.525	1
2023-11-28	2023	11	11	28	16	2	6.5	3.2	4.1	1438.1	10.6	3.8	9.341667	1
2023-11-28	2023	11	11	28	17	2	6.3	1.7	3.8	1538.0	10.6	3.6	8.966667	1
2023-11-28	2023	11	11	28	18	2	5.9	1.5	3.2	1616.3	10.6	3.4	8.45	1
2023-11-28	2023	11	11	28	19	2	5.6	1.1	2.8	1591.0	10.6	3.2	7.9	1
2023-11-28	2023	11	11	28	20	2	5.2	0.8	2.8	1566.8	10.6	3.1	7.283333	1
2023-11-28	2023	11	11	28	21	2	4.8	1.1	3.7	1530.9	10.6	2.9	6.666667	1
2023-11-28	2023	11	11	28	22	2	4.4	1.3	3.9	1466.4	10.6	2.8	6.075	1
2023-11-28	2023	11	11	28	23	2	4.0	0.8	4.3	1396.1	10.6	2.6	5.516667	1
2023-11-28	2023	11	11	28	24	2	3.7	0.4	4.3	1354.9	10.6	2.3	5.008333	1
2023-11-29	2023	11	11	29	1	3	3.3	0	3.9	1317.6	13.8	2.0	4.566667	1
2023-11-29	2023	11	11	29	2	3	2.9	-0.4	3.5	1291.7	13.8	1.6	4.216667	1
2023-11-29	2023	11	11	29	3	3	2.6	-0.7	3.2	1272.0	13.8	1.3	3.975	1
2023-11-29	2023	11	11	29	4	3	2.3	-0.7	1.7	1270.1	13.8	0.9	3.75	1
2023-11-29	2023	11	11	29	5	3	2.1	-0.8	1.5	1286.1	13.8	0.6	3.625	1
2023-11-29	2023	11	11	29	6	3	1.9	-1	1.1	1356.9	13.8	0.4	3.425	1
2023-11-29	2023	11	11	29	7	3	1.7	-0.9	0.8	1494.5	13.8	0.2	3.233333	1
2023-11-29	2023	11	11											

DATE	Year	Month	Day	HOUR	DOW	24hrAvgLa	g Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLa	g Weekdays	
2023-11-29	2023	11	11	29	24	3	-0.9	-2.8	0	1497.9	13.8	-0.9	-1.01667	1
2023-11-30	2023	11	11	30	1	4	-1.1	-2.9	0.6	1463.7	8.0	-1.0	-1.10833	1
2023-11-30	2023	11	11	30	2	4	-1.2	-3.1	0.7	1435.7	8.0	-1.3	-1.10833	1
2023-11-30	2023	11	11	30	3	4	-1.3	-2.9	-0.1	1417.5	8.0	-1.6	-1.025	1
2023-11-30	2023	11	11	30	4	4	-1.4	-3.1	-0.2	1419.7	8.0	-1.9	-0.90833	1
2023-11-30	2023	11	11	30	5	4	-1.5	-3.6	-0.5	1447.4	8.0	-2.1	-0.85833	1
2023-11-30	2023	11	11	30	6	4	-1.6	-4	-1.1	1518.4	8.0	-2.4	-0.80833	1
2023-11-30	2023	11	11	30	7	4	-1.7	-5	-1.7	1651.2	8.0	-2.7	-0.76667	1
2023-11-30	2023	11	11	30	8	4	-1.9	-5.9	-2.1	1756.3	8.0	-3.0	-0.78333	1
2023-11-30	2023	11	11	30	9	4	-2.1	-4.9	-2.4	1758.6	8.0	-3.4	-0.78333	1
2023-11-30	2023	11	11	30	10	4	-2.2	-1.2	-2.8	1674.3	8.0	-3.6	-0.73333	1
2023-11-30	2023	11	11	30	11	4	-2.1	2	-2.8	1609.0	8.0	-3.5	-0.725	1
2023-11-30	2023	11	11	30	12	4	-2.0	2.2	-2.9	1583.6	8.0	-3.1	-0.85833	1
2023-11-30	2023	11	11	30	13	4	-1.9	3.1	-3.1	1569.4	8.0	-2.7	-1.03333	1
2023-11-30	2023	11	11	30	14	4	-1.7	2.1	-2.9	1530.8	8.0	-2.2	-1.275	1
2023-11-30	2023	11	11	30	15	4	-1.7	1.7	-3.1	1496.6	8.0	-1.8	-1.58333	1
2023-11-30	2023	11	11	30	16	4	-1.6	2.9	-3.6	1513.0	8.0	-1.4	-1.88333	1
2023-11-30	2023	11	11	30	17	4	-1.5	2.6	-4	1594.7	8.0	-0.9	-2.13333	1
2023-11-30	2023	11	11	30	18	4	-1.4	1.9	-5	1683.3	8.0	-0.4	-2.41667	1
2023-11-30	2023	11	11	30	19	4	-1.3	1.6	-5.9	1664.8	8.0	0.1	-2.70833	1
2023-11-30	2023	11	11	30	20	4	-1.2	1.4	-4.9	1631.3	8.0	0.7	-3.03333	1
2023-11-30	2023	11	11	30	21	4	-1.1	2.1	-1.2	1588.8	8.0	1.3	-3.38333	1
2023-11-30	2023	11	11	30	22	4	-0.9	1.4	2	1516.3	8.0	1.9	-3.61667	1
2023-11-30	2023	11	11	30	23	4	-0.7	2.9	2.2	1416.1	8.0	2.1	-3.51667	1
2023-11-30	2023	11	11	30	24	4	-0.5	2.8	3.1	1355.4	8.0	2.2	-3.11667	1
2023-12-01	2023	12	1	1	1	5	-0.2	2	2.1	1306.4	14.8	2.2	-2.7	1
2023-12-01	2023	12	1	2	2	5	0.0	3.5	1.7	1257.8	14.8	2.1	-2.2	1
2023-12-01	2023	12	1	3	3	5	0.2	4.8	2.9	1212.3	14.8	2.2	-1.76667	1
2023-12-01	2023	12	1	4	4	5	0.6	5.5	2.6	1180.3	14.8	2.5	-1.38333	1
2023-12-01	2023	12	1	5	5	5	0.9	6.2	1.9	1176.6	14.8	2.7	-0.88333	1
2023-12-01	2023	12	1	6	6	5	1.3	6.6	1.6	1216.4	14.8	3.0	-0.36667	1
2023-12-01	2023	12	1	7	7	5	1.8	6.7	1.4	1328.7	14.8	3.4	0.125	1
2023-12-01	2023	12	1	8	8	5	2.3	6.9	2.1	1430.3	14.8	3.8	0.675	1
2023-12-01	2023	12	1	9	9	5	2.8	7.2	1.4	1454.1	14.8	4.3	1.28333	1
2023-12-01	2023	12	1	10	10	5	3.3	7.5	2.9	1428.0	14.8	4.7	1.866667	1
2023-12-01	2023	12	1	11	11	5	3.7	8	2.8	1387.3	14.8	5.2	2.08333	1
2023-12-01	2023	12	1	12	12	5	3.9	8.4	2	1368.3	14.8	5.6	2.15833	1
2023-12-01	2023	12	1	13	13	5	4.2	8.6	3.5	1325.2	14.8	6.1	2.20833	1
2023-12-01	2023	12	1	14	14	5	4.4	9.4	4.8	1267.9	14.8	6.7	2.116667	1
2023-12-01	2023	12	1	15	15	5	4.7	10.2	5.5	1238.9	14.8	7.2	2.23333	1
2023-12-01	2023	12	1	16	16	5	5.0	9.9	6.2	1259.5	14.8	7.6	2.491667	1
2023-12-01	2023	12	1	17	17	5	5.3	9	6.6	1349.7	14.8	8.0	2.70833	1
2023-12-01	2023	12	1	18	18	5	5.6	7.9	6.7	1428.1	14.8	8.2	3.00833	1
2023-12-01	2023	12	1	19	19	5	5.9	7.4	6.9	1398.7	14.8	8.3	3.4	1
2023-12-01	2023	12	1	20	20	5	6.1	7.3	7.2	1366.7	14.8	8.4	3.825	1
2023-12-01	2023	12	1	21	21	5	6.3	7.2	7.5	1333.5	14.8	8.4	4.28333	1
2023-12-01	2023	12	1	22	22	5	6.6	7.2	8	1289.0	14.8	8.4	4.70833	1
2023-12-01	2023	12	1	23	23	5	6.8	6.9	8.4	1228.1	14.8	8.4	5.216667	1
2023-12-01	2023	12	1	24	24	5	7.0	6.7	8.6	1189.7	14.8	8.3	5.641667	1
2023-12-02	2023	12	2	1	1	6	7.1	6.7	9.4	1146.4	4.4	8.1	6.10833	0
2023-12-02	2023	12	2	2	2	6	7.3	6.3	10.2	1100.3	4.4	8.0	6.65833	0
2023-12-02	2023	12	2	3	3	6	7.4	6.6	9.9	1064.9	4.4	7.7	7.15	0
2023-12-02	2023	12	2	4	4	6	7.5	6.5	9	1049.8	4.4	7.4	7.6	0
2023-12-02	2023	12	2	5	5	6	7.6	6.5	7.9	1048.3	4.4	7.1	7.966667	0
2023-12-02	2023	12	2	6	6	6	7.6	6.4	7.4	1072.9	4.4	6.9	8.2	0
2023-12-02	2023	12	2	7	7	6	7.6	6.3	7.3	1124.1	4.4	6.8	8.30833	0
2023-12-02	2023	12	2	8	8	6	7.5	6.3	7.2	1197.0	4.4	6.7	8.366667	0
2023-12-02	2023	12	2	9	9	6	7.5	6.9	7.2	1272.7	4.4	6.6	8.4	0
2023-12-02	2023	12	2	10	10	6	7.5	7.1	6.9	1319.3	4.4	6.6	8.4	0
2023-12-02	2023	12	2	11	11	6	7.5	7.6	6.7	1332.5	4.4	6.6	8.375	0
2023-12-02	2023	12	2	12	12	6	7.5	7.8	6.7	1343.6	4.4	6.7	8.28333	0
2023-12-02	2023	12	2	13	13	6	7.4	8.2	6.3	1344.0	4.4	6.8	8.141667	0
2023-12-02	2023	12	2	14	14	6	7.4	7.8	6.6	1334.3	4.4	6.9	7.98333	0
2023-12-02	2023	12	2	15	15	6	7.4	7.6	6.5	1327.7	4.4	7.0	7.725	0
2023-12-02	2023	12	2	16	16	6	7.3	7.5	6.5	1346.2	4.4	7.1	7.425	0
2023-12-02	2023	12	2	17	17	6	7.2	7.3	6.4	1410.1	4.4	7.2	7.141667	0
2023-12-02	2023	12	2	18	18	6	7.1	6.9	6.3	1445.5	4.4	7.2	6.93333	0
2023-12-02	2023	12	2	19	19	6	7.0	6.8	6.3	1392.3	4.4	7.3	6.80833	0
2023-12-02	2023	12	2	20	20	6	7.0	6.9	6.9	1354.8	4.4	7.3	6.716667	0
2023-12-02	2023	12	2	21	21	6	7.0	6.5	7.1	1311.8	4.4	7.4	6.63333	0
2023-12-02	2023	12	2	22	22	6	7.0	6.2	7.6	1258.5	4.4	7.3	6.60833	0
2023-12-02	2023	12	2	23	23	6	6.9	6.6	7.8	1194.8	4.4	7.3	6.6	0
2023-12-02	2023	12	2	24	24	6	6.9	5.9	8.2	1148.4	4.4	7.2	6.65833	0
2023-12-03	2023	12	3	1	1	7	6.9	5	7.8	1110.3	14.0	7.0	6.75	0
2023-12-03	2023	12	3	2	2	7	6.8	3.5	7.6	1086.3	14.0	6.8	6.875	0
2023-12-03	2023	12	3	3	3	7	6.7	3.1	7.5	1075.7	14.0	6.4	7	0
2023-12-03	2023	12	3	4	4	7	6.6	2.6	7.3	1074.4	14.0	6.0	7.08333	0
2023-12-03	2023	12	3	5	5	7	6.4	2.4	6.9	1075.5	14.0	5.6	7.166667	0
2023-12-03	2023	12	3	6	6	7	6.2	2.2	6.8	1107.2	14.0	5.2	7.23333	0
2023-12-03	2023	12	3	7	7	7	6.0	2.4	6.9	1157.3	14.0	4.8	7.275	0
2023-12-03	2023	12	3	8	8	7	5.9	2.3	6.5	1234.7	14.0	4.4	7.316667	0
2023-12-03	2023	12	3	9	9	7	5.7	2.2	6.2	1336.5	14.0	4.1	7.366667	0
2023-12-03	2023	12	3	10	10	7	5.5	2.1	6.6	1409.6	14.0	3.7	7.33333	0
2023-12-03	2023	12	3	11	11	7	5.3	2.1	5.9	1445.7	14.0	3.4	7.25833	0
2023-12-03	2023	12	3	12	12	7	5.1	2.3	5	1457.0	14.0	3.0	7.175	0
2023-12-03	2023	12	3	13	13	7	4.9	2.6	3.5	1467.8	14.0	2.7	7.016667	0
2023-12-03	2023	12	3	14	14	7	4.6	2.4	3.1	1465.3	14.0	2.5	6.75	0
2023-12-03	2023	12	3	15	15	7	4.4	2.3	2.6	1458.3	14.0	2.4	6.391667	0
2023-12-03	2023	12	3	16	16	7	4.2	2	2.4	1488.0	14.0	2.3	6.016667	0
2023-12-03	2023	12	3	17	17	7	3.9	1.7	2.2	1584.7	14.0	2.3	5.60833	0
2023-12-03	2023	12	3	18	18	7	3.7	1.6	2.4	1642.5	14.0	2.2	5.2	0
2023-12-03	2023	12	3	19	19	7	3.5	0.9	2.3	1604.3	14.0	2.2	4.80833	0
2023-12-03	2023	12	3	20	20	7	3.2	0.3	2.2	1586.9	14.0	2.0	4.441667	0
2023-12-03	2023	12												

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLagTemp	LagTemp12Load	Wind	12hrAvg	12hrAvgLagWeekdays			
2023-12-04	2023	12	4	12	1	0.7	0.8	-0.1	1625.4	15.0	0.1	1.25	1
2023-12-04	2023	12	4	13	1	0.6	0.7	-0.1	1627.6	15.0	0.2	1.033333	1
2023-12-04	2023	12	4	14	1	0.5	1	-0.2	1609.2	15.0	0.3	0.808333	1
2023-12-04	2023	12	4	15	1	0.5	1.3	0	1598.5	15.0	0.4	0.6	1
2023-12-04	2023	12	4	16	1	0.4	1.2	-0.1	1602.8	15.0	0.5	0.391667	1
2023-12-04	2023	12	4	17	1	0.4	1.2	0	1673.7	15.0	0.6	0.225	1
2023-12-04	2023	12	4	18	1	0.4	0.8	0.2	1742.1	15.0	0.7	0.075	1
2023-12-04	2023	12	4	19	1	0.4	0.6	0.3	1692.8	15.0	0.8	-0.05833	1
2023-12-04	2023	12	4	20	1	0.3	0.4	0.4	1644.1	15.0	0.8	-0.11667	1
2023-12-04	2023	12	4	21	1	0.3	0.4	0.5	1588.2	15.0	0.8	-0.11667	1
2023-12-04	2023	12	4	22	1	0.4	0.2	0.7	1515.6	15.0	0.8	-0.05833	1
2023-12-04	2023	12	4	23	1	0.4	-0.2	0.8	1423.7	15.0	0.8	0.016667	1
2023-12-04	2023	12	4	24	1	0.4	-0.3	0.7	1372.8	15.0	0.7	0.108333	1
2023-12-05	2023	12	5	1	2	0.4	-0.5	1	1330.8	14.5	0.6	0.2	1
2023-12-05	2023	12	5	2	2	0.4	-0.5	1.3	1293.0	14.5	0.5	0.266667	1
2023-12-05	2023	12	5	3	2	0.4	-0.3	1.2	1267.7	14.5	0.4	0.358333	1
2023-12-05	2023	12	5	4	2	0.4	-0.1	1.2	1263.6	14.5	0.3	0.483333	1
2023-12-05	2023	12	5	5	2	0.4	0	0.8	1276.9	14.5	0.1	0.583333	1
2023-12-05	2023	12	5	6	2	0.4	0	0.6	1335.3	14.5	0.0	0.691667	1
2023-12-05	2023	12	5	7	2	0.4	-0.3	0.4	1465.4	14.5	0.0	0.758333	1
2023-12-05	2023	12	5	8	2	0.3	-0.3	0.4	1574.8	14.5	-0.1	0.791667	1
2023-12-05	2023	12	5	9	2	0.3	-0.2	0.2	1604.6	14.5	-0.2	0.8	1
2023-12-05	2023	12	5	10	2	0.3	-0.2	-0.2	1589.9	14.5	-0.2	0.8	1
2023-12-05	2023	12	5	11	2	0.3	0.3	-0.3	1584.4	14.5	-0.2	0.775	1
2023-12-05	2023	12	5	12	2	0.3	0.6	-0.5	1580.7	14.5	-0.2	0.7	1
2023-12-05	2023	12	5	13	2	0.2	0.6	-0.5	1573.8	14.5	-0.1	0.608333	1
2023-12-05	2023	12	5	14	2	0.2	0.8	-0.3	1547.2	14.5	0.0	0.508333	1
2023-12-05	2023	12	5	15	2	0.2	0.8	-0.1	1538.9	14.5	0.1	0.383333	1
2023-12-05	2023	12	5	16	2	0.2	0.1	0	1586.3	14.5	0.2	0.25	1
2023-12-05	2023	12	5	17	2	0.2	-0.5	0	1697.2	14.5	0.2	0.141667	1
2023-12-05	2023	12	5	18	2	0.1	-1.6	-0.3	1783.8	14.5	0.1	0.041667	1
2023-12-05	2023	12	5	19	2	0.0	-1.6	-0.3	1750.1	14.5	0.0	-0.025	1
2023-12-05	2023	12	5	20	2	-0.1	-2.1	-0.2	1719.4	14.5	-0.1	-0.1	1
2023-12-05	2023	12	5	21	2	-0.2	-2.2	-0.2	1677.8	14.5	-0.3	-0.15833	1
2023-12-05	2023	12	5	22	2	-0.3	-2.5	0.3	1605.8	14.5	-0.4	-0.20833	1
2023-12-05	2023	12	5	23	2	-0.4	-2.9	0.6	1515.7	14.5	-0.6	-0.24167	1
2023-12-05	2023	12	5	24	2	-0.5	-3.2	0.6	1476.3	14.5	-0.9	-0.2	1
2023-12-06	2023	12	6	1	3	-0.7	-3.5	0.8	1442.7	8.0	-1.2	-0.125	1
2023-12-06	2023	12	6	2	3	-0.8	-3.9	0.8	1413.8	8.0	-1.5	-0.03333	1
2023-12-06	2023	12	6	3	3	-0.9	-4.9	0.1	1388.6	8.0	-1.9	0.075	1
2023-12-06	2023	12	6	4	3	-1.1	-5.2	-0.5	1391.3	8.0	-2.4	0.166667	1
2023-12-06	2023	12	6	5	3	-1.3	-5.5	-1.6	1412.5	8.0	-2.8	0.183333	1
2023-12-06	2023	12	6	6	3	-1.6	-5.8	-1.6	1480.6	8.0	-3.3	0.141667	1
2023-12-06	2023	12	6	7	3	-1.8	-6.7	-2.1	1628.5	8.0	-3.6	0.008333	1
2023-12-06	2023	12	6	8	3	-2.1	-7	-2.2	1740.0	8.0	-4.0	-0.1	1
2023-12-06	2023	12	6	9	3	-2.3	-7.1	-2.5	1752.1	8.0	-4.4	-0.25	1
2023-12-06	2023	12	6	10	3	-2.6	-5	-2.9	1682.0	8.0	-4.9	-0.41667	1
2023-12-06	2023	12	6	11	3	-2.8	-3.3	-3.2	1620.0	8.0	-5.1	-0.60833	1
2023-12-06	2023	12	6	12	3	-3.0	-2.7	-3.5	1576.7	8.0	-5.1	-0.875	1
2023-12-06	2023	12	6	13	3	-3.1	-0.8	-3.9	1543.1	8.0	-5.1	-1.19167	1
2023-12-06	2023	12	6	14	3	-3.2	-0.5	-4.9	1509.5	8.0	-4.8	-1.53333	1
2023-12-06	2023	12	6	15	3	-3.2	-0.2	-5.2	1496.4	8.0	-4.5	-1.925	1
2023-12-06	2023	12	6	16	3	-3.3	-0.7	-5.5	1545.2	8.0	-4.2	-2.4	1
2023-12-06	2023	12	6	17	3	-3.3	-1.2	-5.8	1680.3	8.0	-3.8	-2.84167	1
2023-12-06	2023	12	6	18	3	-3.3	-2.9	-6.7	1792.2	8.0	-3.4	-3.25833	1
2023-12-06	2023	12	6	19	3	-3.4	-3.8	-7	1776.4	8.0	-3.2	-3.60833	1
2023-12-06	2023	12	6	20	3	-3.5	-4.9	-7.1	1763.4	8.0	-2.9	-4.03333	1
2023-12-06	2023	12	6	21	3	-3.6	-4.4	-5	1734.3	8.0	-2.8	-4.44167	1
2023-12-06	2023	12	6	22	3	-3.7	-4.7	-3.3	1673.5	8.0	-2.5	-4.85	1
2023-12-06	2023	12	6	23	3	-3.8	-5.6	-2.7	1584.9	8.0	-2.5	-5.05833	1
2023-12-06	2023	12	6	24	3	-3.9	-6.5	-0.8	1540.7	8.0	-2.7	-5.09167	1
2023-12-07	2023	12	7	1	4	-4.0	-6.8	-0.5	1496.7	12.8	-3.0	-5.05	1
2023-12-07	2023	12	7	2	4	-4.2	-6	-0.2	1452.8	12.8	-3.5	-4.825	1
2023-12-07	2023	12	7	3	4	-4.3	-5.9	-0.7	1421.4	12.8	-4.0	-4.54167	1
2023-12-07	2023	12	7	4	4	-4.3	-4.9	-1.2	1406.0	12.8	-4.5	-4.15	1
2023-12-07	2023	12	7	5	4	-4.3	-4.5	-2.9	1412.7	12.8	-4.8	-3.775	1
2023-12-07	2023	12	7	6	4	-4.2	-3.9	-3.8	1468.9	12.8	-5.1	-3.41667	1
2023-12-07	2023	12	7	7	4	-4.2	-3	-4.9	1597.4	12.8	-5.2	-3.175	1
2023-12-07	2023	12	7	8	4	-4.0	-2.7	-4.4	1696.1	12.8	-5.1	-2.93333	1
2023-12-07	2023	12	7	9	4	-3.8	-2.5	-4.7	1714.9	12.8	-4.9	-2.75833	1
2023-12-07	2023	12	7	10	4	-3.6	-2.1	-5.6	1681.8	12.8	-4.8	-2.53333	1
2023-12-07	2023	12	7	11	4	-3.5	-1.2	-6.5	1655.9	12.8	-4.5	-2.50833	1
2023-12-07	2023	12	7	12	4	-3.4	-0.6	-6.8	1639.3	12.8	-4.2	-2.7	1
2023-12-07	2023	12	7	13	4	-3.3	0.5	-6	1644.6	12.8	-3.7	-3.01667	1
2023-12-07	2023	12	7	14	4	-3.3	-0.3	-5.9	1655.1	12.8	-3.1	-3.51667	1
2023-12-07	2023	12	7	15	4	-3.3	-0.8	-4.9	1661.5	12.8	-2.6	-3.975	1
2023-12-07	2023	12	7	16	4	-3.3	-1.2	-4.5	1700.5	12.8	-2.2	-4.45	1
2023-12-07	2023	12	7	17	4	-3.3	-1.7	-3.9	1781.4	12.8	-1.9	-4.8	1
2023-12-07	2023	12	7	18	4	-3.4	-2.2	-3	1839.6	12.8	-1.6	-5.075	1
2023-12-07	2023	12	7	19	4	-3.3	-2.4	-2.7	1796.0	12.8	-1.5	-5.15833	1
2023-12-07	2023	12	7	20	4	-3.3	-2.7	-2.5	1764.0	12.8	-1.4	-5.09167	1
2023-12-07	2023	12	7	21	4	-3.2	-3	-2.1	1724.0	12.8	-1.4	-4.90833	1
2023-12-07	2023	12	7	22	4	-3.1	-3.2	-1.2	1661.5	12.8	-1.5	-4.75	1
2023-12-07	2023	12	7	23	4	-3.1	-3.1	-0.6	1567.6	12.8	-1.6	-4.53333	1
2023-12-07	2023	12	7	24	4	-2.9	-3.6	0.5	1527.3	12.8	-1.7	-4.16667	1
2023-12-08	2023	12	8	1	5	-2.8	-4.2	-0.3	1493.5	16.2	-2.0	-3.675	1
2023-12-08	2023	12	8	2	5	-2.7	-4.5	-0.8	1459.6	16.2	-2.4	-3.06667	1
2023-12-08	2023	12	8	3	5	-2.7	-5	-1.2	1433.5	16.2	-2.7	-2.59167	1
2023-12-08	2023	12	8	4	5	-2.6	-4.9	-1.7	1429.3	16.2	-3.1	-2.16667	1
2023-12-08	2023	12	8	5	5	-2.6	-4.5	-2.2	1439.2	16.2	-3.4	-1.85833	1
2023-12-08	2023	12	8	6	5	-2.6	-4.7	-2.4	1498.2	16.2	-3.6	-1.625	1
2023-12-08	2023	12	8	7	5	-2.7	-4.7	-2.7	1635.9	16.2	-3.8	-1.48333	1
2023-12-08	2023	12	8	8	5	-2.7	-5.1	-3	1749.6	16.2	-4.0	-1.43333	1
2023-12-08	2023	12	8	9	5	-2.8	-4.8	-3.2	1769.5	16.2	-4.2	-1.43333	1
2023-12-08	2023	12	8	10	5	-2.9	-3.8	-3.1	1702.9	16.2	-4.4	-1.475	1
2023-12-08	2023	12	8	11	5	-3.0	-2.1	-3.6	1638.1	16.2	-4.4	-1.56667	1
2023-12-08	2023	12	8	12	5	-3.0	-0.2	-4.2	1588.1	16.2	-4.3	-1.725	1
2023-12-08	2023	12	8	13	5	-3.0	1.4	-4.5	1560.6	16.2	-4.0	-1.975	1
2023-12-08	2023	12	8	14	5	-3.0	2.1	-5	1522.				

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLa	gTemp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLa	gWeekdays	
2023-12-08	2023	12	12	8	24	5	-1.8	-1.5	1.4	1470.1	16.2	0.7	-4.325	1
2023-12-09	2023	12	12	9	1	6	-1.7	-1.9	2.1	1438.4	6.8	0.6	-4.04167	0
2023-12-09	2023	12	12	9	2	6	-1.6	-2	2.5	1399.8	6.8	0.3	-3.575	0
2023-12-09	2023	12	12	9	3	6	-1.5	-2	2.4	1373.9	6.8	0.0	-3.025	0
2023-12-09	2023	12	12	9	4	6	-1.4	-2.6	1.7	1365.0	6.8	-0.4	-2.4	0
2023-12-09	2023	12	12	9	5	6	-1.3	-3.1	0.7	1373.9	6.8	-0.8	-1.79167	0
2023-12-09	2023	12	12	9	6	6	-1.2	-3.9	0	1406.4	6.8	-1.2	-1.275	0
2023-12-09	2023	12	12	9	7	6	-1.2	-4.5	-0.1	1480.0	6.8	-1.6	-0.825	0
2023-12-09	2023	12	12	9	8	6	-1.2	-5.3	-0.4	1579.8	6.8	-2.0	-0.43333	0
2023-12-09	2023	12	12	9	9	6	-1.2	-4.8	-0.6	1645.2	6.8	-2.4	-0.01667	0
2023-12-09	2023	12	12	9	10	6	-1.2	-2.5	-1	1618.3	6.8	-2.8	0.35	0
2023-12-09	2023	12	12	9	11	6	-1.2	-1	-1.5	1557.2	6.8	-2.9	0.616667	0
2023-12-09	2023	12	12	9	12	6	-1.1	0.1	-1.9	1508.9	6.8	-2.9	0.708333	0
2023-12-09	2023	12	12	9	13	6	-1.1	0.9	-2	1467.4	6.8	-2.8	0.6	0
2023-12-09	2023	12	12	9	14	6	-1.1	2.3	-2	1417.4	6.8	-2.6	0.325	0
2023-12-09	2023	12	12	9	15	6	-1.1	3.7	-2.6	1402.5	6.8	-2.2	-0.01667	0
2023-12-09	2023	12	12	9	16	6	-1.1	4.3	-3.1	1431.5	6.8	-1.7	-0.39167	0
2023-12-09	2023	12	12	9	17	6	-1.0	3.9	-3.9	1545.0	6.8	-1.2	-0.80833	0
2023-12-09	2023	12	12	9	18	6	-0.9	1.6	-4.5	1652.7	6.8	-0.6	-1.20833	0
2023-12-09	2023	12	12	9	19	6	-0.9	-1	-5.3	1628.3	6.8	-0.1	-1.59167	0
2023-12-09	2023	12	12	9	20	6	-0.9	-2.1	-4.8	1594.1	6.8	0.2	-1.96667	0
2023-12-09	2023	12	12	9	21	6	-1.0	-1.3	-2.5	1558.9	6.8	0.5	-2.4	0
2023-12-09	2023	12	12	9	22	6	-1.0	-1.5	-1	1503.0	6.8	0.7	-2.76667	0
2023-12-09	2023	12	12	9	23	6	-1.1	-1.4	0.1	1436.2	6.8	0.8	-2.925	0
2023-12-09	2023	12	12	9	24	6	-1.1	-0.5	0.9	1371.2	6.8	0.8	-2.925	0
2023-12-10	2023	12	12	10	1	7	-1.0	-0.5	2.3	1310.5	8.8	0.7	-2.79167	0
2023-12-10	2023	12	12	10	2	7	-1.0	-0.6	3.7	1277.5	8.8	0.6	-2.55833	0
2023-12-10	2023	12	12	10	3	7	-0.9	-0.1	4.3	1263.2	8.8	0.4	-2.2	0
2023-12-10	2023	12	12	10	4	7	-0.8	-0.5	3.9	1263.2	8.8	0.1	-1.725	0
2023-12-10	2023	12	12	10	5	7	-0.7	-0.8	1.6	1273.0	8.8	-0.3	-1.15	0
2023-12-10	2023	12	12	10	6	7	-0.6	-0.7	-1	1304.0	8.8	-0.7	-0.56667	0
2023-12-10	2023	12	12	10	7	7	-0.5	-0.8	-2.1	1351.5	8.8	-0.9	-0.10833	0
2023-12-10	2023	12	12	10	8	7	-0.4	-0.1	-1.3	1410.7	8.8	-0.9	0.183333	0
2023-12-10	2023	12	12	10	9	7	-0.1	1	-1.5	1476.7	8.8	-0.7	0.45	0
2023-12-10	2023	12	12	10	10	7	0.1	4.6	-1.4	1509.1	8.8	-0.5	0.741667	0
2023-12-10	2023	12	12	10	11	7	0.4	5.4	-0.5	1497.1	8.8	0.0	0.825	0
2023-12-10	2023	12	12	10	12	7	0.7	5.6	-0.5	1479.8	8.8	0.5	0.791667	0
2023-12-10	2023	12	12	10	13	7	0.9	6	-0.6	1470.0	8.8	1.0	0.741667	0
2023-12-10	2023	12	12	10	14	7	1.1	6.5	-0.1	1438.8	8.8	1.6	0.625	0
2023-12-10	2023	12	12	10	15	7	1.3	6.7	-0.5	1423.8	8.8	2.2	0.383333	0
2023-12-10	2023	12	12	10	16	7	1.4	6.6	-0.8	1446.3	8.8	2.7	0.066667	0
2023-12-10	2023	12	12	10	17	7	1.5	6.9	-0.7	1528.3	8.8	3.3	-0.33333	0
2023-12-10	2023	12	12	10	18	7	1.6	6.9	-0.8	1586.7	8.8	4.0	-0.725	0
2023-12-10	2023	12	12	10	19	7	1.8	7	-0.1	1544.6	8.8	4.6	-0.91667	0
2023-12-10	2023	12	12	10	20	7	2.2	6.4	1	1499.8	8.8	5.3	-0.9	0
2023-12-10	2023	12	12	10	21	7	2.5	6.2	4.6	1443.9	8.8	5.8	-0.73333	0
2023-12-10	2023	12	12	10	22	7	2.8	5.9	5.4	1365.8	8.8	6.2	-0.54167	0
2023-12-10	2023	12	12	10	23	7	3.2	6.2	5.6	1252.1	8.8	6.3	-0.03333	0
2023-12-10	2023	12	12	10	24	7	3.5	7.4	6	1146.6	8.8	6.4	0.533333	0
2023-12-11	2023	12	12	11	1	1	3.8	8.5	6.5	1056.3	30.3	6.6	1.041667	1
2023-12-11	2023	12	12	11	2	1	4.2	10.5	6.7	1011.6	30.3	6.8	1.583333	1
2023-12-11	2023	12	12	11	3	1	4.6	10.8	6.6	988.9	30.3	7.1	2.175	1
2023-12-11	2023	12	12	11	4	1	5.1	11	6.9	974.8	30.3	7.4	2.741667	1
2023-12-11	2023	12	12	11	5	1	5.6	11.4	6.9	976.8	30.3	7.8	3.333333	1
2023-12-11	2023	12	12	11	6	1	6.1	11.3	7	1018.0	30.3	8.2	3.975	1
2023-12-11	2023	12	12	11	7	1	6.6	11.5	6.4	1134.8	30.3	8.6	4.608333	1
2023-12-11	2023	12	12	11	8	1	7.1	11.7	6.2	1246.1	30.3	8.9	5.258333	1
2023-12-11	2023	12	12	11	9	1	7.6	12.2	5.9	1281.6	30.3	9.4	5.8	1
2023-12-11	2023	12	12	11	10	1	8.1	12.9	6.2	1287.4	30.3	9.9	6.233333	1
2023-12-11	2023	12	12	11	11	1	8.4	13	7.4	1276.6	30.3	10.5	6.341667	1
2023-12-11	2023	12	12	11	12	1	8.7	13.1	8.5	1277.7	30.3	11.0	6.408333	1
2023-12-11	2023	12	12	11	13	1	9.0	12.4	10.5	1279.9	30.3	11.5	6.558333	1
2023-12-11	2023	12	12	11	14	1	9.3	12.8	10.8	1243.3	30.3	11.8	6.766667	1
2023-12-11	2023	12	12	11	15	1	9.6	12.8	11	1225.5	30.3	12.0	7.1	1
2023-12-11	2023	12	12	11	16	1	9.8	12.8	11.4	1244.8	30.3	12.2	7.441667	1
2023-12-11	2023	12	12	11	17	1	10.1	11.6	11.3	1312.3	30.3	12.3	7.808333	1
2023-12-11	2023	12	12	11	18	1	10.3	11.9	11.5	1329.2	30.3	12.3	8.183333	1
2023-12-11	2023	12	12	11	19	1	10.5	11.8	11.7	1260.2	30.3	12.4	8.55	1
2023-12-11	2023	12	12	11	20	1	10.7	11.8	12.2	1246.8	30.3	12.4	8.925	1
2023-12-11	2023	12	12	11	21	1	10.9	10.5	12.9	1220.9	30.3	12.4	9.366667	1
2023-12-11	2023	12	12	11	22	1	11.1	8.8	13	1163.4	30.3	12.3	9.866667	1
2023-12-11	2023	12	12	11	23	1	11.2	8.5	13.1	1090.6	30.3	11.9	10.45	1
2023-12-11	2023	12	12	11	24	1	11.3	7.8	12.4	1042.4	30.3	11.6	11.01667	1
2023-12-12	2023	12	12	12	1	2	11.3	6.4	12.8	1016.9	13.3	11.1	11.49167	1
2023-12-12	2023	12	12	12	2	2	11.2	5.4	12.8	1000.8	13.3	10.6	11.81667	1
2023-12-12	2023	12	12	12	3	2	11.0	4.9	12.8	1004.9	13.3	10.0	12.00833	1
2023-12-12	2023	12	12	12	4	2	10.8	4.2	11.6	1026.9	13.3	9.4	12.175	1
2023-12-12	2023	12	12	12	5	2	10.5	3.4	11.9	1054.4	13.3	8.6	12.325	1
2023-12-12	2023	12	12	12	6	2	10.1	3.3	11.8	1128.5	13.3	8.0	12.34167	1
2023-12-12	2023	12	12	12	7	2	9.8	2.6	11.8	1280.7	13.3	7.2	12.39167	1
2023-12-12	2023	12	12	12	8	2	9.4	2.3	10.5	1409.5	13.3	6.5	12.41667	1
2023-12-12	2023	12	12	12	9	2	9.1	2	8.8	1455.9	13.3	5.7	12.425	1
2023-12-12	2023	12	12	12	10	2	8.6	1.6	8.5	1446.2	13.3	5.0	12.28333	1
2023-12-12	2023	12	12	12	11	2	8.2	2.8	7.8	1419.7	13.3	4.4	11.94167	1
2023-12-12	2023	12	12	12	12	2	7.7	3	6.4	1382.3	13.3	3.9	11.56667	1
2023-12-12	2023	12	12	12	13	2	7.3	3.1	5.4	1361.9	13.3	3.5	11.125	1
2023-12-12	2023	12	12	12	14	2	6.9	3.6	4.9	1340.8	13.3	3.2	10.625	1
2023-12-12	2023	12	12	12	15	2	6.5	4	4.2	1337.5	13.3	3.1	10.00833	1
2023-12-12	2023	12	12	12	16	2	6.2	4	3.4	1385.7	13.3	3.0	9.35	1
2023-12-12	2023	12	12	12	17	2	5.8	3.5	3.3	1504.1	13.3	3.0	8.633333	1
2023-12-12	2023	12	12	12	18	2	5.5	2.4	2.6	1623.6	13.3	3.0	7.95	1
2023-12-12	2023	12	12	12	19	2	5.1	2.1	2.3	1618.7	13.3	2.9	7.233333	1
2023-12-12	2023	12												

DATE	Year	Month	Day	HOUR	DOW	24hrAvgLa	g Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLa	g Weekdays	
2023-12-13	2023	12	12	13	12	3	2.9	6.9	0.7	1457.3	13.7	3.3	2.516667	1
2023-12-13	2023	12	12	13	13	3	3.1	6.6	1.1	1456.5	13.7	3.9	2.258333	1
2023-12-13	2023	12	12	13	14	3	3.2	3.7	1.9	1453.0	13.7	4.3	2.058333	1
2023-12-13	2023	12	12	13	15	3	3.2	3.7	2.5	1439.2	13.7	4.6	1.85	1
2023-12-13	2023	12	12	13	16	3	3.2	4.3	3.5	1461.0	13.7	4.7	1.675	1
2023-12-13	2023	12	12	13	17	3	3.2	4.8	4.2	1551.1	13.7	4.9	1.55	1
2023-12-13	2023	12	12	13	18	3	3.3	3.3	4.3	1650.9	13.7	5.0	1.55	1
2023-12-13	2023	12	12	13	19	3	3.3	1.9	4.6	1642.5	13.7	4.9	1.7	1
2023-12-13	2023	12	12	13	20	3	3.3	1.4	5	1628.2	13.7	4.7	1.883333	1
2023-12-13	2023	12	12	13	21	3	3.3	1.1	5.6	1606.0	13.7	4.4	2.108333	1
2023-12-13	2023	12	12	13	22	3	3.3	0.9	5.9	1550.6	13.7	4.1	2.408333	1
2023-12-13	2023	12	12	13	23	3	3.3	0.3	6.9	1477.6	13.7	3.7	2.816667	1
2023-12-13	2023	12	12	13	24	3	3.3	-0.4	6.6	1448.7	13.7	3.2	3.266667	1
2023-12-14	2023	12	12	14	1	4	3.2	-1.4	3.7	1418.6	16.6	2.6	3.85	1
2023-12-14	2023	12	12	14	2	4	3.2	-2.1	3.7	1397.9	16.6	2.0	4.341667	1
2023-12-14	2023	12	12	14	3	4	3.0	-2.4	4.3	1381.1	16.6	1.5	4.558333	1
2023-12-14	2023	12	12	14	4	4	2.8	-3.3	4.8	1389.1	16.6	1.0	4.708333	1
2023-12-14	2023	12	12	14	5	4	2.6	-3.6	3.3	1418.3	16.6	0.3	4.858333	1
2023-12-14	2023	12	12	14	6	4	2.3	-4.3	1.9	1492.5	16.6	-0.4	4.966667	1
2023-12-14	2023	12	12	14	7	4	2.0	-4.9	1.4	1637.1	16.6	-1.0	4.891667	1
2023-12-14	2023	12	12	14	8	4	1.6	-4.9	1.1	1757.1	16.6	-1.6	4.691667	1
2023-12-14	2023	12	12	14	9	4	1.2	-5.2	0.9	1790.3	16.6	-2.1	4.425	1
2023-12-14	2023	12	12	14	10	4	0.7	-4.5	0.3	1758.7	16.6	-2.6	4.1	1
2023-12-14	2023	12	12	14	11	4	0.3	-4.3	-0.4	1736.0	16.6	-3.1	3.708333	1
2023-12-14	2023	12	12	14	12	4	-0.1	-4.6	-1.4	1702.4	16.6	-3.4	3.241667	1
2023-12-14	2023	12	12	14	13	4	-0.6	-3.9	-2.1	1661.2	16.6	-3.8	2.633333	1
2023-12-14	2023	12	12	14	14	4	-1.0	-3.1	-2.4	1623.8	16.6	-4.0	1.966667	1
2023-12-14	2023	12	12	14	15	4	-1.3	-2.7	-3.3	1609.4	16.6	-4.1	1.483333	1
2023-12-14	2023	12	12	14	16	4	-1.6	-2.5	-3.6	1651.3	16.6	-4.1	0.975	1
2023-12-14	2023	12	12	14	17	4	-1.9	-3	-4.3	1777.1	16.6	-4.0	0.341667	1
2023-12-14	2023	12	12	14	18	4	-2.2	-3.2	-4.9	1878.1	16.6	-4.0	-0.35833	1
2023-12-14	2023	12	12	14	19	4	-2.4	-3.3	-4.9	1851.6	16.6	-3.9	-0.99167	1
2023-12-14	2023	12	12	14	20	4	-2.7	-3.6	-5.2	1824.3	16.6	-3.8	-1.55833	1
2023-12-14	2023	12	12	14	21	4	-2.9	-3.6	-4.5	1797.4	16.6	-3.7	-2.08333	1
2023-12-14	2023	12	12	14	22	4	-3.1	-3.7	-4.3	1729.7	16.6	-3.5	-2.60833	1
2023-12-14	2023	12	12	14	23	4	-3.3	-3.7	-4.6	1639.3	16.6	-3.5	-3.05833	1
2023-12-14	2023	12	12	14	24	4	-3.4	-3.3	-3.9	1589.0	16.6	-3.4	-3.44167	1
2023-12-15	2023	12	12	15	1	5	-3.5	-3.5	-3.1	1542.0	17.1	-3.3	-3.79167	1
2023-12-15	2023	12	12	15	2	5	-3.6	-3.4	-2.7	1500.4	17.1	-3.3	-4	1
2023-12-15	2023	12	12	15	3	5	-3.7	-2.9	-2.5	1471.6	17.1	-3.3	-4.08333	1
2023-12-15	2023	12	12	15	4	5	-3.7	-2.7	-3	1459.7	17.1	-3.3	-4.10833	1
2023-12-15	2023	12	12	15	5	5	-3.7	-2.5	-3.2	1464.2	17.1	-3.3	-4.04167	1
2023-12-15	2023	12	12	15	6	5	-3.6	-1.8	-3.3	1515.6	17.1	-3.3	-3.99167	1
2023-12-15	2023	12	12	15	7	5	-3.5	-0.4	-3.6	1626.7	17.1	-3.2	-3.9	1
2023-12-15	2023	12	12	15	8	5	-3.3	0.7	-3.6	1722.0	17.1	-2.9	-3.76667	1
2023-12-15	2023	12	12	15	9	5	-3.1	1.9	-3.7	1719.2	17.1	-2.6	-3.65833	1
2023-12-15	2023	12	12	15	10	5	-2.8	3.2	-3.7	1670.8	17.1	-2.1	-3.525	1
2023-12-15	2023	12	12	15	11	5	-2.5	3.7	-3.3	1623.0	17.1	-1.5	-3.45833	1
2023-12-15	2023	12	12	15	12	5	-2.2	4.6	-3.5	1570.8	17.1	-0.9	-3.40833	1
2023-12-15	2023	12	12	15	13	5	-1.8	5.8	-3.4	1539.8	17.1	-0.3	-3.3	1
2023-12-15	2023	12	12	15	14	5	-1.4	5.6	-2.9	1504.1	17.1	0.5	-3.26667	1
2023-12-15	2023	12	12	15	15	5	-1.0	6.1	-2.7	1473.3	17.1	1.3	-3.29167	1
2023-12-15	2023	12	12	15	16	5	-0.6	6.6	-2.5	1464.5	17.1	2.0	-3.30833	1
2023-12-15	2023	12	12	15	17	5	-0.3	6.3	-1.8	1539.7	17.1	2.8	-3.325	1
2023-12-15	2023	12	12	15	18	5	0.1	5.2	-0.4	1606.9	17.1	3.5	-3.28333	1
2023-12-15	2023	12	12	15	19	5	0.5	4.7	0.7	1578.9	17.1	4.1	-3.16667	1
2023-12-15	2023	12	12	15	20	5	0.8	4	1.9	1535.2	17.1	4.5	-2.925	1
2023-12-15	2023	12	12	15	21	5	1.1	3.6	3.2	1491.3	17.1	4.8	-2.56667	1
2023-12-15	2023	12	12	15	22	5	1.4	2.7	3.7	1437.9	17.1	5.0	-2.10833	1
2023-12-15	2023	12	12	15	23	5	1.7	2.3	4.6	1377.4	17.1	4.9	-1.53333	1
2023-12-15	2023	12	12	15	24	5	1.9	2.2	5.8	1351.2	17.1	4.8	-0.91667	1
2023-12-16	2023	12	12	16	1	6	2.2	2.2	5.6	1314.9	10.3	4.6	-0.25833	0
2023-12-16	2023	12	12	16	2	6	2.4	2.3	6.1	1277.0	10.3	4.3	0.516667	0
2023-12-16	2023	12	12	16	3	6	2.6	1.6	6.6	1249.6	10.3	4.0	1.266667	0
2023-12-16	2023	12	12	16	4	6	2.8	1.3	6.3	1238.3	10.3	3.6	2.016667	0
2023-12-16	2023	12	12	16	5	6	3.0	0.9	5.2	1245.7	10.3	3.2	2.791667	0
2023-12-16	2023	12	12	16	6	6	3.1	1.3	4.7	1265.9	10.3	2.8	3.525	0
2023-12-16	2023	12	12	16	7	6	3.3	2.1	4	1320.3	10.3	2.4	4.108333	0
2023-12-16	2023	12	12	16	8	6	3.4	2.6	3.6	1395.5	10.3	2.2	4.533333	0
2023-12-16	2023	12	12	16	9	6	3.5	1.7	2.7	1472.7	10.3	2.1	4.808333	0
2023-12-16	2023	12	12	16	10	6	3.4	3.2	2.3	1478.4	10.3	1.9	4.95	0
2023-12-16	2023	12	12	16	11	6	3.4	4.7	2.2	1457.9	10.3	2.0	4.908333	0
2023-12-16	2023	12	12	16	12	6	3.5	4.9	2.2	1435.2	10.3	2.2	4.791667	0
2023-12-16	2023	12	12	16	13	6	3.5	5	2.3	1407.9	10.3	2.4	4.591667	0
2023-12-16	2023	12	12	16	14	6	3.5	4.8	1.6	1383.1	10.3	2.6	4.291667	0
2023-12-16	2023	12	12	16	15	6	3.4	4	1.3	1382.8	10.3	2.8	4.016667	0
2023-12-16	2023	12	12	16	16	6	3.3	3.4	0.9	1431.4	10.3	3.0	3.641667	0
2023-12-16	2023	12	12	16	17	6	3.2	2.3	1.3	1559.9	10.3	3.2	3.2	0
2023-12-16	2023	12	12	16	18	6	3.0	0.5	2.1	1676.2	10.3	3.3	2.75	0
2023-12-16	2023	12	12	16	19	6	2.8	-0.5	2.6	1661.1	10.3	3.3	2.425	0
2023-12-16	2023	12	12	16	20	6	2.6	-1.2	1.7	1638.1	10.3	3.1	2.208333	0
2023-12-16	2023	12	12	16	21	6	2.4	-1.7	3.2	1616.6	10.3	2.7	2.091667	0
2023-12-16	2023	12	12	16	22	6	2.2	-2.8	4.7	1559.4	10.3	2.5	1.933333	0
2023-12-16	2023	12	12	16	23	6	2.0	-4	4.9	1498.2	10.3	2.0	1.975	0
2023-12-16	2023	12	12	16	24	6	1.7	-3.5	5	1451.7	10.3	1.2	2.175	0
2023-12-17	2023	12	12	17	1	7	1.5	-4.3	4.8	1415.6	12.8	0.5	2.4	0
2023-12-17	2023	12	12	17	2	7	1.2	-4.4	4	1406.2	12.8	-0.3	2.633333	0
2023-12-17	2023	12	12	17	3	7	0.9	-5.4	3.4	1405.1	12.8	-1.0	2.841667	0
2023-12-17	2023	12	12	17	4	7	0.6	-3.9	2.3	1409.4	12.8	-1.8	3.041667	0
2023-12-17	2023	12	12	17	5	7	0.4	-3.8	0.5	1423.7	12.8	-2.4	3.216667	0
2023-12-17	2023	12	12	17	6	7	0.2	-3.7	-0.5	1460.5	12.8	-2.9	3.333333	0
2023-12-17	2023	12	12	17	7	7	0.0	-4.6	-1.2	1517.2	12.8	-3.3		

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLag	Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLag	Weekdays	
2023-12-17	2023	12	12	17	24	7	0.8	6.8	3.9	1230.9	12.8	4.7	-3.1	0
2023-12-18	2023	12	12	18	1	1	1.3	7.1	4.1	1151.1	30.7	5.0	-2.50833	1
2023-12-18	2023	12	12	18	2	1	1.7	7	4.4	1105.4	30.7	5.3	-1.825	1
2023-12-18	2023	12	12	18	3	1	2.2	7.3	4.7	1079.6	30.7	5.5	-1.11667	1
2023-12-18	2023	12	12	18	4	1	2.7	8.2	4.5	1062.9	30.7	5.8	-0.3	1
2023-12-18	2023	12	12	18	5	1	3.2	8.4	4.7	1063.2	30.7	6.1	0.416667	1
2023-12-18	2023	12	12	18	6	1	3.7	9	4.3	1100.3	30.7	6.4	1.108333	1
2023-12-18	2023	12	12	18	7	1	4.3	9.1	4.9	1213.1	30.7	6.7	1.808333	1
2023-12-18	2023	12	12	18	8	1	4.8	9.5	5.4	1327.4	30.7	7.1	2.55	1
2023-12-18	2023	12	12	18	9	1	5.4	9.2	6.1	1371.6	30.7	7.5	3.366667	1
2023-12-18	2023	12	12	18	10	1	6.0	10	6.3	1374.9	30.7	7.8	4.125	1
2023-12-18	2023	12	12	18	11	1	6.3	10.9	6.8	1372.0	30.7	8.2	4.475	1
2023-12-18	2023	12	12	18	12	1	6.6	10.4	7.1	1372.3	30.7	8.5	4.741667	1
2023-12-18	2023	12	12	18	13	1	6.9	10.3	7	1367.9	30.7	8.8	5.008333	1
2023-12-18	2023	12	12	18	14	1	7.2	10.4	7.3	1356.7	30.7	9.1	5.275	1
2023-12-18	2023	12	12	18	15	1	7.5	10.5	8.2	1344.5	30.7	9.4	5.516667	1
2023-12-18	2023	12	12	18	16	1	7.7	10.7	8.4	1364.3	30.7	9.7	5.758333	1
2023-12-18	2023	12	12	18	17	1	8.0	10.7	9	1438.8	30.7	9.9	6.05	1
2023-12-18	2023	12	12	18	18	1	8.2	10.6	9.1	1474.5	30.7	10.1	6.375	1
2023-12-18	2023	12	12	18	19	1	8.5	10.9	9.5	1426.0	30.7	10.2	6.733333	1
2023-12-18	2023	12	12	18	20	1	8.7	10.7	9.2	1376.9	30.7	10.3	7.133333	1
2023-12-18	2023	12	12	18	21	1	9.0	11	10	1294.7	30.7	10.4	7.516667	1
2023-12-18	2023	12	12	18	22	1	9.2	11.1	10.9	1177.5	30.7	10.6	7.833333	1
2023-12-18	2023	12	12	18	23	1	9.4	11.1	10.4	1072.4	30.7	10.7	8.158333	1
2023-12-18	2023	12	12	18	24	1	9.6	10.7	10.3	994.9	30.7	10.7	8.541667	1
2023-12-19	2023	12	12	19	1	2	9.8	11.9	10.4	935.3	15.3	10.7	8.841667	1
2023-12-19	2023	12	12	19	2	2	10.0	11	10.5	892.3	15.3	10.9	9.108333	1
2023-12-19	2023	12	12	19	3	2	10.2	10.3	10.7	861.7	15.3	10.9	9.391667	1
2023-12-19	2023	12	12	19	4	2	10.3	10.5	10.7	861.4	15.3	10.9	9.658333	1
2023-12-19	2023	12	12	19	5	2	10.4	9.5	10.6	882.4	15.3	10.9	9.866667	1
2023-12-19	2023	12	12	19	6	2	10.4	8.5	10.9	928.8	15.3	10.8	10.05833	1
2023-12-19	2023	12	12	19	7	2	10.4	8.2	10.7	1051.2	15.3	10.6	10.19167	1
2023-12-19	2023	12	12	19	8	2	10.4	7.5	11	1141.3	15.3	10.4	10.34167	1
2023-12-19	2023	12	12	19	9	2	10.3	7.4	11.1	1196.9	15.3	10.1	10.44167	1
2023-12-19	2023	12	12	19	10	2	10.2	7.6	11.1	1238.6	15.3	9.8	10.59167	1
2023-12-19	2023	12	12	19	11	2	10.1	8.2	10.7	1268.3	15.3	9.5	10.68333	1
2023-12-19	2023	12	12	19	12	2	10.0	8.4	11.9	1289.6	15.3	9.3	10.7	1
2023-12-19	2023	12	12	19	13	2	9.9	9	11	1309.7	15.3	9.1	10.725	1
2023-12-19	2023	12	12	19	14	2	9.9	9.9	10.3	1306.9	15.3	8.8	10.85833	1
2023-12-19	2023	12	12	19	15	2	9.8	9.9	10.5	1290.9	15.3	8.8	10.90833	1
2023-12-19	2023	12	12	19	16	2	9.8	10.9	9.5	1302.0	15.3	8.7	10.89167	1
2023-12-19	2023	12	12	19	17	2	9.8	10.1	8.5	1372.6	15.3	8.8	10.875	1
2023-12-19	2023	12	12	19	18	2	9.8	8.2	8.2	1434.4	15.3	8.8	10.775	1
2023-12-19	2023	12	12	19	19	2	9.7	9.4	7.5	1405.9	15.3	8.8	10.6	1
2023-12-19	2023	12	12	19	20	2	9.6	9.1	7.4	1374.0	15.3	8.9	10.375	1
2023-12-19	2023	12	12	19	21	2	9.6	8.5	7.6	1332.3	15.3	9.0	10.10833	1
2023-12-19	2023	12	12	19	22	2	9.5	8.3	8.2	1263.4	15.3	9.1	9.808333	1
2023-12-19	2023	12	12	19	23	2	9.3	8.5	8.4	1171.6	15.3	9.2	9.516667	1
2023-12-19	2023	12	12	19	24	2	9.2	8.3	9	1107.1	15.3	9.2	9.275	1
2023-12-20	2023	12	12	20	1	3	9.1	8	9.9	1061.1	20.3	9.2	9.083333	1
2023-12-20	2023	12	12	20	2	3	9.0	7.8	9.9	1021.8	20.3	9.1	8.841667	1
2023-12-20	2023	12	12	20	3	3	8.8	7.5	10.9	1000.5	20.3	8.9	8.75	1
2023-12-20	2023	12	12	20	4	3	8.7	7.2	10.1	989.8	20.3	8.7	8.716667	1
2023-12-20	2023	12	12	20	5	3	8.6	6.8	8.2	1003.2	20.3	8.4	8.75	1
2023-12-20	2023	12	12	20	6	3	8.5	6.4	9.4	1058.8	20.3	8.1	8.8	1
2023-12-20	2023	12	12	20	7	3	8.4	6.5	9.1	1176.9	20.3	8.0	8.775	1
2023-12-20	2023	12	12	20	8	3	8.3	6.5	8.5	1295.2	20.3	7.7	8.875	1
2023-12-20	2023	12	12	20	9	3	8.3	6.5	8.3	1340.1	20.3	7.5	9.008333	1
2023-12-20	2023	12	12	20	10	3	8.2	6.6	8.5	1362.3	20.3	7.4	9.1	1
2023-12-20	2023	12	12	20	11	3	8.2	6.7	8.3	1389.4	20.3	7.2	9.158333	1
2023-12-20	2023	12	12	20	12	3	8.1	6.6	8	1404.4	20.3	7.1	9.183333	1
2023-12-20	2023	12	12	20	13	3	8.1	6.2	7.8	1417.3	20.3	6.9	9.175	1
2023-12-20	2023	12	12	20	14	3	7.9	5.1	7.5	1427.2	20.3	6.8	9.091667	1
2023-12-20	2023	12	12	20	15	3	7.7	4.7	7.2	1437.0	20.3	6.6	8.916667	1
2023-12-20	2023	12	12	20	16	3	7.5	4.5	6.8	1460.6	20.3	6.3	8.716667	1
2023-12-20	2023	12	12	20	17	3	7.3	3.6	6.4	1535.0	20.3	6.1	8.408333	1
2023-12-20	2023	12	12	20	18	3	7.0	3.2	6.5	1591.0	20.3	5.8	8.133333	1
2023-12-20	2023	12	12	20	19	3	6.8	3.2	6.5	1564.2	20.3	5.6	7.983333	1
2023-12-20	2023	12	12	20	20	3	6.5	3.1	6.5	1538.9	20.3	5.3	7.741667	1
2023-12-20	2023	12	12	20	21	3	6.3	3.2	6.6	1507.1	20.3	5.0	7.525	1
2023-12-20	2023	12	12	20	22	3	6.0	3.2	6.7	1458.8	20.3	4.7	7.358333	1
2023-12-20	2023	12	12	20	23	3	5.8	2.9	6.6	1396.6	20.3	4.4	7.216667	1
2023-12-20	2023	12	12	20	24	3	5.6	2.3	6.2	1367.1	20.3	4.1	7.066667	1
2023-12-21	2023	12	12	21	1	4	5.3	1.2	5.1	1347.1	38.8	3.8	6.925	1
2023-12-21	2023	12	12	21	2	4	5.1	1.2	4.7	1326.6	38.8	3.4	6.775	1
2023-12-21	2023	12	12	21	3	4	4.8	1	4.5	1298.1	38.8	3.0	6.55	1
2023-12-21	2023	12	12	21	4	4	4.5	0.7	3.6	1298.0	38.8	2.7	6.316667	1
2023-12-21	2023	12	12	21	5	4	4.2	0.3	3.2	1314.5	38.8	2.4	6.091667	1
2023-12-21	2023	12	12	21	6	4	4.0	-0.3	3.2	1368.2	38.8	2.1	5.825	1
2023-12-21	2023	12	12	21	7	4	3.7	-0.5	3.1	1464.2	38.8	1.8	5.558333	1
2023-12-21	2023	12	12	21	8	4	3.4	-0.7	3.2	1562.8	38.8	1.5	5.283333	1
2023-12-21	2023	12	12	21	9	4	3.1	-0.8	3.2	1651.2	38.8	1.2	5	1
2023-12-21	2023	12	12	21	10	4	2.8	-0.8	2.9	1703.7	38.8	0.9	4.725	1
2023-12-21	2023	12	12	21	11	4	2.5	-0.6	2.3	1704.2	38.8	0.5	4.441667	1
2023-12-21	2023	12	12	21	12	4	2.2	-0.7	1.2	1743.9	38.8	0.3	4.125	1
2023-12-21	2023	12	12	21	13	4	1.9	-1	1.2	1770.9	38.8	0.0	3.766667	1
2023-12-21	2023	12	12	21	14	4	1.6	-1.5	1	1735.3	38.8	-0.2	3.35	1
2023-12-21	2023	12	12	21	15	4	1.3	-1.7	0.7	1742.4	38.8	-0.4	3.025	1
2023-12-21	2023	12	12	21	16	4	1.0	-2.2	0.3	1793.1	38.8	-0.6	2.716667	1
2023-12-21	2023	12	12	21	17	4	0.8	-2.4	-0.3	1849.5	38.8	-0.9	2.4	1
2023-12-21	2023	12	12	21	18	4	0.5	-2.6	-0.5	1899.7	38.8	-1.1	2.125	1
2023-12-21	2023	12	12	21	19	4	0.3	-2.9						

DATE	Year	Month	Day	HOUR	DOW	24hrAvgLa	g Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLa	g Weekdays	
2023-12-22	2023	12	22	22	12	5	-4.2	-4.6	-4.8	1849.6	23.9	-6.1	-2.325	1
2023-12-22	2023	12	22	22	13	5	-4.4	-3.9	-5.3	1816.5	23.9	-6.1	-2.59167	1
2023-12-22	2023	12	22	22	14	5	-4.5	-2.8	-5.6	1800.9	23.9	-6.0	-2.90833	1
2023-12-22	2023	12	22	22	15	5	-4.5	-2.9	-6	1807.4	23.9	-5.8	-3.225	1
2023-12-22	2023	12	22	22	16	5	-4.6	-3.3	-6.5	1820.8	23.9	-5.6	-3.55	1
2023-12-22	2023	12	22	22	17	5	-4.6	-3.3	-7	1875.0	23.9	-5.4	-3.86667	1
2023-12-22	2023	12	22	22	18	5	-4.7	-3.4	-7.2	1942.2	23.9	-5.1	-4.20833	1
2023-12-22	2023	12	22	22	19	5	-4.7	-3.9	-7.4	1903.5	23.9	-4.8	-4.575	1
2023-12-22	2023	12	22	22	20	5	-4.7	-4	-7.2	1865.0	23.9	-4.5	-4.93333	1
2023-12-22	2023	12	22	22	21	5	-4.8	-4.4	-6.3	1819.8	23.9	-4.3	-5.3	1
2023-12-22	2023	12	22	22	22	5	-4.8	-5.1	-5.5	1764.0	23.9	-4.0	-5.64167	1
2023-12-22	2023	12	22	22	23	5	-4.9	-5.6	-4.6	1696.7	23.9	-3.9	-5.9	1
2023-12-22	2023	12	22	22	24	5	-5.0	-5.9	-3.9	1667.2	23.9	-3.9	-6.05833	1
2023-12-23	2023	12	23	1	6	6	-5.1	-6.4	-2.8	1623.2	7.8	-4.0	-6.11667	0
2023-12-23	2023	12	23	2	6	6	-5.1	-6.5	-2.9	1575.8	7.8	-4.3	-6.04167	0
2023-12-23	2023	12	23	3	6	6	-5.2	-6.7	-3.3	1547.7	7.8	-4.6	-5.83333	0
2023-12-23	2023	12	23	4	6	6	-5.2	-6.7	-3.3	1535.9	7.8	-4.9	-5.60833	0
2023-12-23	2023	12	23	5	6	6	-5.3	-7	-3.4	1540.6	7.8	-5.2	-5.38333	0
2023-12-23	2023	12	23	6	6	6	-5.3	-7.1	-3.9	1573.9	7.8	-5.5	-5.11667	0
2023-12-23	2023	12	23	7	6	6	-5.3	-7.7	-4	1638.5	7.8	-5.8	-4.81667	0
2023-12-23	2023	12	23	8	6	6	-5.3	-7.8	-4.4	1722.7	7.8	-6.1	-4.54167	0
2023-12-23	2023	12	23	9	6	6	-5.3	-7.3	-5.1	1792.1	7.8	-6.4	-4.25833	0
2023-12-23	2023	12	23	10	6	6	-5.3	-5.5	-5.6	1777.5	7.8	-6.7	-4.025	0
2023-12-23	2023	12	23	11	6	6	-5.3	-4.1	-5.9	1718.7	7.8	-6.7	-3.925	0
2023-12-23	2023	12	23	12	6	6	-5.2	-2.4	-6.4	1664.6	7.8	-6.6	-3.93333	0
2023-12-23	2023	12	23	13	6	6	-5.2	-1.2	-6.5	1600.8	7.8	-6.3	-4.04167	0
2023-12-23	2023	12	23	14	6	6	-5.0	-0.5	-6.7	1545.1	7.8	-5.8	-4.25	0
2023-12-23	2023	12	23	15	6	6	-4.9	0.3	-6.7	1517.3	7.8	-5.3	-4.55833	0
2023-12-23	2023	12	23	16	6	6	-4.8	0.6	-7	1547.2	7.8	-4.8	-4.875	0
2023-12-23	2023	12	23	17	6	6	-4.7	-0.2	-7.1	1664.6	7.8	-4.1	-5.15833	0
2023-12-23	2023	12	23	18	6	6	-4.5	-1.1	-7.7	1762.5	7.8	-3.6	-5.46667	0
2023-12-23	2023	12	23	19	6	6	-4.4	-1.4	-7.8	1739.4	7.8	-3.1	-5.775	0
2023-12-23	2023	12	23	20	6	6	-4.3	-0.9	-7.3	1709.3	7.8	-2.6	-6.09167	0
2023-12-23	2023	12	23	21	6	6	-4.2	-0.6	-5.5	1674.4	7.8	-2.0	-6.40833	0
2023-12-23	2023	12	23	22	6	6	-4.0	-0.6	-4.1	1627.2	7.8	-1.4	-6.65	0
2023-12-23	2023	12	23	23	6	6	-3.8	-0.4	-2.4	1552.6	7.8	-1.0	-6.68333	0
2023-12-23	2023	12	23	24	6	6	-3.6	-0.4	-1.2	1479.0	7.8	-0.7	-6.55833	0
2023-12-24	2023	12	24	1	7	7	-3.4	-1.2	-0.5	1422.4	9.1	-0.5	-6.26667	0
2023-12-24	2023	12	24	2	7	7	-3.2	-1.6	0.3	1389.5	9.1	-0.5	-5.83333	0
2023-12-24	2023	12	24	3	7	7	-3.0	-1.6	0.6	1370.9	9.1	-0.6	-5.33333	0
2023-12-24	2023	12	24	4	7	7	-2.8	-1.5	-0.2	1368.0	9.1	-0.8	-4.75	0
2023-12-24	2023	12	24	5	7	7	-2.6	-1.5	-1.1	1368.0	9.1	-1.0	-4.14167	0
2023-12-24	2023	12	24	6	7	7	-2.3	-1	-1.4	1389.0	9.1	-1.1	-3.575	0
2023-12-24	2023	12	24	7	7	7	-2.1	-0.9	-0.9	1442.5	9.1	-1.1	-3.075	0
2023-12-24	2023	12	24	8	7	7	-1.8	-0.9	-0.6	1515.6	9.1	-1.0	-2.55	0
2023-12-24	2023	12	24	9	7	7	-1.5	-0.7	-0.6	1596.8	9.1	-1.0	-1.975	0
2023-12-24	2023	12	24	10	7	7	-1.2	0.4	-0.4	1621.5	9.1	-1.0	-1.41667	0
2023-12-24	2023	12	24	11	7	7	-1.0	2.3	-0.4	1586.3	9.1	-0.9	-1.00833	0
2023-12-24	2023	12	24	12	7	7	-0.7	3.7	-1.2	1551.3	9.1	-0.7	-0.7	0
2023-12-24	2023	12	24	13	7	7	-0.5	3.9	-1.6	1534.8	9.1	-0.4	-0.53333	0
2023-12-24	2023	12	24	14	7	7	-0.2	4.4	-1.6	1493.8	9.1	0.1	-0.53333	0
2023-12-24	2023	12	24	15	7	7	0.0	4.4	-1.5	1460.2	9.1	0.6	-0.625	0
2023-12-24	2023	12	24	16	7	7	0.1	4.3	-1.5	1463.2	9.1	1.1	-0.78333	0
2023-12-24	2023	12	24	17	7	7	0.3	4	-1	1507.7	9.1	1.5	-0.95833	0
2023-12-24	2023	12	24	18	7	7	0.5	3.6	-0.9	1527.8	9.1	2.0	-1.06667	0
2023-12-24	2023	12	24	19	7	7	0.7	4	-0.9	1465.5	9.1	2.4	-1.05833	0
2023-12-24	2023	12	24	20	7	7	0.9	4.1	-0.7	1410.2	9.1	2.8	-1.01667	0
2023-12-24	2023	12	24	21	7	7	1.1	4.2	0.4	1382.3	9.1	3.2	-1.01667	0
2023-12-24	2023	12	24	22	7	7	1.3	4.4	2.3	1353.0	9.1	3.6	-1.025	0
2023-12-24	2023	12	24	23	7	7	1.5	4.4	3.7	1306.8	9.1	3.9	-0.94167	0
2023-12-24	2023	12	24	24	7	7	1.7	4.5	3.9	1248.5	9.1	4.1	-0.71667	0
2023-12-25	2023	12	25	1	1	1	1.9	4.1	4.4	1200.0	4.8	4.2	-0.375	0
2023-12-25	2023	12	25	2	1	1	2.1	3.3	4.4	1169.5	4.8	4.2	0.05	0
2023-12-25	2023	12	25	3	1	1	2.3	2.2	4.3	1161.6	4.8	4.1	0.55	0
2023-12-25	2023	12	25	4	1	1	2.5	1.8	4	1170.4	4.8	3.9	1.05	0
2023-12-25	2023	12	25	5	1	1	2.6	0.4	3.6	1185.4	4.8	3.7	1.533333	0
2023-12-25	2023	12	25	6	1	1	2.7	0.4	4	1226.4	4.8	3.4	1.991667	0
2023-12-25	2023	12	25	7	1	1	2.8	-0.5	4.1	1297.2	4.8	3.2	2.375	0
2023-12-25	2023	12	25	8	1	1	2.8	-1.1	4.2	1362.8	4.8	2.8	2.783333	0
2023-12-25	2023	12	25	9	1	1	2.8	1.1	4.4	1434.0	4.8	2.3	3.2	0
2023-12-25	2023	12	25	10	1	1	2.8	1.1	4.4	1453.3	4.8	2.1	3.608333	0
2023-12-25	2023	12	25	11	1	1	2.9	1.5	4.5	1431.4	4.8	1.8	3.941667	0
2023-12-25	2023	12	25	12	1	1	2.8	1.6	4.1	1411.6	4.8	1.6	4.116667	0
2023-12-25	2023	12	25	13	1	1	2.8	4.2	3.3	1383.6	4.8	1.3	4.183333	0
2023-12-25	2023	12	25	14	1	1	2.8	5.6	2.2	1339.2	4.8	1.3	4.2	0
2023-12-25	2023	12	25	15	1	1	2.8	6.4	1.8	1316.7	4.8	1.5	4.108333	0
2023-12-25	2023	12	25	16	1	1	2.9	6.4	0.4	1329.6	4.8	1.9	3.925	0
2023-12-25	2023	12	25	17	1	1	3.0	3.6	0.4	1379.0	4.8	2.3	3.716667	0
2023-12-25	2023	12	25	18	1	1	3.0	1.7	-0.5	1402.6	4.8	2.5	3.416667	0
2023-12-25	2023	12	25	19	1	1	2.9	1.3	-1.1	1366.4	4.8	2.6	3.15	0
2023-12-25	2023	12	25	20	1	1	2.8	0.9	1.1	1350.4	4.8	2.8	2.775	0
2023-12-25	2023	12	25	21	1	1	2.6	1.1	1.1	1339.2	4.8	3.0	2.341667	0
2023-12-25	2023	12	25	22	1	1	2.5	1.2	1.5	1306.7	4.8	3.0	2.083333	0
2023-12-25	2023	12	25	23	1	1	2.4	1.8	1.6	1254.8	4.8	3.0	1.808333	0
2023-12-25	2023	12	25	24	1	1	2.3	1.8	4.2	1223.2	4.8	3.0	1.566667	0
2023-12-26	2023	12	26	1	2	2	2.2	2	5.6	1188.2	8.0	3.0	1.325	0
2023-12-26	2023	12	26	2	2	2	2.1	2.1	6.4	1150.7	8.0	2.8	1.333333	0
2023-12-26	2023	12	26	3	2	2	2.0	2.3	6.4	1130.5	8.0	2.5	1.525	0
2023-12-26	2023	12	26	4	2	2	2.0	1.5	3.6	1125.1	8.0	2.2	1.875	0
2023-12-26	2023	12	26	5	2	2	2.0	0.9	1.7	1132.3	8.0	1.8	2.258333	0
2023-12-26	2023	12	26	6	2	2	2.0	1.1	1.3	1157.4	8.0	1.6	2.525	0
2023-12-26	2023	12	26	7	2	2	2.1	1.5	0.9	1204.3	8.0	1.5	2.633333	0
2023-12-26	2023	12	26	8	2	2	2.2	2.4	1.1	1242.9	8.0	1.5	2.783333	0
2023-12-26	2023	12	26	9	2	2								

DATE	Year	Month	Day	HOUR	DOW	24hrAvgLa	g Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLa	g Weekdays	
2023-12-26	2023	12	26	26	24	2	4.5	5.7	6.6	1149.4	8.0	6.7	2.333333	0
2023-12-27	2023	12	27	27	1	3	4.7	5.5	6.7	1110.4	4.8	6.7	2.633333	1
2023-12-27	2023	12	27	27	2	3	4.8	4.6	7.3	1075.7	4.8	6.6	3.016667	1
2023-12-27	2023	12	27	27	3	3	4.9	4.2	7.8	1053.5	4.8	6.4	3.4	1
2023-12-27	2023	12	27	27	4	3	5.0	3.8	7.7	1050.2	4.8	6.2	3.816667	1
2023-12-27	2023	12	27	27	5	3	5.1	3.7	6.9	1060.9	4.8	5.9	4.341667	1
2023-12-27	2023	12	27	27	6	3	5.2	3.6	7	1096.7	4.8	5.5	4.908333	1
2023-12-27	2023	12	27	27	7	3	5.3	3.2	7.2	1174.7	4.8	5.2	5.391667	1
2023-12-27	2023	12	27	27	8	3	5.4	3.5	6.1	1248.4	4.8	4.9	5.85	1
2023-12-27	2023	12	27	27	9	3	5.4	3.5	5.6	1324.3	4.8	4.6	6.25	1
2023-12-27	2023	12	27	27	10	3	5.4	3.9	5.9	1370.1	4.8	4.4	6.483333	1
2023-12-27	2023	12	27	27	11	3	5.4	4.4	5.7	1398.2	4.8	4.3	6.608333	1
2023-12-27	2023	12	27	27	12	3	5.4	4.8	5.5	1409.1	4.8	4.1	6.683333	1
2023-12-27	2023	12	27	27	13	3	5.4	5.3	4.6	1411.4	4.8	4.1	6.708333	1
2023-12-27	2023	12	27	27	14	3	5.3	5.3	4.2	1391.2	4.8	4.0	6.616667	1
2023-12-27	2023	12	27	27	15	3	5.3	5.6	3.8	1378.5	4.8	4.1	6.441667	1
2023-12-27	2023	12	27	27	16	3	5.2	5.9	3.7	1381.1	4.8	4.2	6.183333	1
2023-12-27	2023	12	27	27	17	3	5.1	5.7	3.6	1436.0	4.8	4.4	5.85	1
2023-12-27	2023	12	27	27	18	3	5.0	5.4	3.2	1489.9	4.8	4.6	5.516667	1
2023-12-27	2023	12	27	27	19	3	5.0	4.9	3.5	1454.1	4.8	4.7	5.241667	1
2023-12-27	2023	12	27	27	20	3	4.9	4.6	3.5	1416.6	4.8	4.9	4.925	1
2023-12-27	2023	12	27	27	21	3	4.8	4.3	3.9	1371.2	4.8	4.9	4.616667	1
2023-12-27	2023	12	27	27	22	3	4.7	4.3	4.4	1308.5	4.8	5.0	4.4	1
2023-12-27	2023	12	27	27	23	3	4.7	4.2	4.8	1240.6	4.8	5.0	4.258333	1
2023-12-27	2023	12	27	27	24	3	4.6	4.2	5.3	1201.8	4.8	5.0	4.133333	1
2023-12-28	2023	12	28	28	1	4	4.5	4.1	5.3	1163.9	9.4	5.0	4.058333	1
2023-12-28	2023	12	28	28	2	4	4.5	4.1	5.6	1128.5	9.4	4.9	4.041667	1
2023-12-28	2023	12	28	28	3	4	4.4	4	5.9	1102.0	9.4	4.8	4.1	1
2023-12-28	2023	12	28	28	4	4	4.4	3.9	5.7	1094.0	9.4	4.6	4.216667	1
2023-12-28	2023	12	28	28	5	4	4.4	3.8	5.4	1100.5	9.4	4.5	4.391667	1
2023-12-28	2023	12	28	28	6	4	4.4	3.9	4.9	1133.1	9.4	4.3	4.558333	1
2023-12-28	2023	12	28	28	7	4	4.5	3.8	4.6	1202.3	9.4	4.2	4.708333	1
2023-12-28	2023	12	28	28	8	4	4.5	3.6	4.3	1271.3	9.4	4.1	4.85	1
2023-12-28	2023	12	28	28	9	4	4.5	3.5	4.3	1347.2	9.4	4.0	4.941667	1
2023-12-28	2023	12	28	28	10	4	4.5	3.3	4.2	1394.2	9.4	4.0	5.008333	1
2023-12-28	2023	12	28	28	11	4	4.5	3.2	4.2	1404.4	9.4	3.9	5.041667	1
2023-12-28	2023	12	28	28	12	4	4.4	3.2	4.1	1407.6	9.4	3.8	5.025	1
2023-12-28	2023	12	28	28	13	4	4.3	3.4	4.1	1405.6	9.4	3.7	4.975	1
2023-12-28	2023	12	28	28	14	4	4.3	3.9	4	1374.9	9.4	3.6	4.875	1
2023-12-28	2023	12	28	28	15	4	4.2	4.2	3.9	1357.9	9.4	3.6	4.775	1
2023-12-28	2023	12	28	28	16	4	4.1	3.8	3.8	1376.5	9.4	3.6	4.641667	1
2023-12-28	2023	12	28	28	17	4	4.1	3.6	3.9	1452.0	9.4	3.6	4.475	1
2023-12-28	2023	12	28	28	18	4	4.0	3.4	3.8	1530.8	9.4	3.6	4.316667	1
2023-12-28	2023	12	28	28	19	4	3.9	3.2	3.6	1508.2	9.4	3.6	4.191667	1
2023-12-28	2023	12	28	28	20	4	3.8	3	3.5	1479.3	9.4	3.5	4.1	1
2023-12-28	2023	12	28	28	21	4	3.7	2.7	3.3	1445.7	9.4	3.5	4.016667	1
2023-12-28	2023	12	28	28	22	4	3.7	2.6	3.2	1392.1	9.4	3.4	3.95	1
2023-12-28	2023	12	28	28	23	4	3.6	2.5	3.2	1327.3	9.4	3.4	3.866667	1
2023-12-28	2023	12	28	28	24	4	3.5	2.9	3.4	1296.4	9.4	3.3	3.783333	1
2023-12-29	2023	12	29	29	1	5	3.5	2.6	3.9	1257.1	22.0	3.3	3.7	1
2023-12-29	2023	12	29	29	2	5	3.4	2.6	4.2	1213.9	22.0	3.2	3.641667	1
2023-12-29	2023	12	29	29	3	5	3.4	2.1	3.8	1177.3	22.0	3.1	3.625	1
2023-12-29	2023	12	29	29	4	5	3.3	2.4	3.6	1174.6	22.0	2.9	3.641667	1
2023-12-29	2023	12	29	29	5	5	3.2	2.2	3.4	1179.8	22.0	2.8	3.633333	1
2023-12-29	2023	12	29	29	6	5	3.2	2.2	3.2	1220.1	22.0	2.7	3.616667	1
2023-12-29	2023	12	29	29	7	5	3.1	2.2	3	1299.9	22.0	2.6	3.575	1
2023-12-29	2023	12	29	29	8	5	3.0	1.9	2.7	1374.2	22.0	2.5	3.525	1
2023-12-29	2023	12	29	29	9	5	2.9	2	2.6	1454.4	22.0	2.4	3.475	1
2023-12-29	2023	12	29	29	10	5	2.9	2.4	2.5	1528.5	22.0	2.4	3.408333	1
2023-12-29	2023	12	29	29	11	5	2.8	2.7	2.9	1570.1	22.0	2.3	3.35	1
2023-12-29	2023	12	29	29	12	5	2.8	3	2.6	1605.4	22.0	2.4	3.291667	1
2023-12-29	2023	12	29	29	13	5	2.8	3.1	2.6	1614.3	22.0	2.4	3.266667	1
2023-12-29	2023	12	29	29	14	5	2.8	3.3	2.1	1592.3	22.0	2.4	3.2	1
2023-12-29	2023	12	29	29	15	5	2.8	3.4	2.4	1573.5	22.0	2.5	3.091667	1
2023-12-29	2023	12	29	29	16	5	2.7	3.3	2.2	1571.1	22.0	2.6	2.916667	1
2023-12-29	2023	12	29	29	17	5	2.7	2.8	2.2	1610.2	22.0	2.6	2.8	1
2023-12-29	2023	12	29	29	18	5	2.7	2	2.2	1647.0	22.0	2.7	2.683333	1
2023-12-29	2023	12	29	29	19	5	2.6	1.9	1.9	1594.0	22.0	2.7	2.583333	1
2023-12-29	2023	12	29	29	20	5	2.6	1.4	2	1535.3	22.0	2.7	2.5	1
2023-12-29	2023	12	29	29	21	5	2.5	1.1	2.4	1481.4	22.0	2.6	2.408333	1
2023-12-29	2023	12	29	29	22	5	2.4	0.6	2.7	1418.6	22.0	2.5	2.35	1
2023-12-29	2023	12	29	29	23	5	2.4	0.8	3	1353.9	22.0	2.4	2.333333	1
2023-12-29	2023	12	29	29	24	5	2.3	1.4	3.1	1318.2	22.0	2.2	2.35	1
2023-12-30	2023	12	30	30	1	6	2.2	1.5	3.3	1279.9	6.5	2.1	2.358333	0
2023-12-30	2023	12	30	30	2	6	2.2	1.3	3.4	1236.5	6.5	2.0	2.4	0
2023-12-30	2023	12	30	30	3	6	2.1	1	3.3	1197.9	6.5	1.8	2.458333	0
2023-12-30	2023	12	30	30	4	6	2.1	1	2.8	1176.8	6.5	1.6	2.566667	0
2023-12-30	2023	12	30	30	5	6	2.0	0.9	2	1175.3	6.5	1.4	2.641667	0
2023-12-30	2023	12	30	30	6	6	2.0	0.9	1.9	1188.2	6.5	1.2	2.691667	0
2023-12-30	2023	12	30	30	7	6	1.9	0.8	1.4	1235.8	6.5	1.2	2.675	0
2023-12-30	2023	12	30	30	8	6	1.9	1	1.1	1303.6	6.5	1.1	2.65	0
2023-12-30	2023	12	30	30	9	6	1.8	1.2	0.6	1375.2	6.5	1.0	2.608333	0
2023-12-30	2023	12	30	30	10	6	1.8	1.5	0.8	1436.9	6.5	1.0	2.533333	0
2023-12-30	2023	12	30	30	11	6	1.7	1.6	1.4	1474.3	6.5	1.1	2.383333	0
2023-12-30	2023	12	30	30	12	6	1.7	1.6	1.5	1498.4	6.5	1.2	2.225	0
2023-12-30	2023	12	30	30	13	6	1.6	1.4	1.3	1521.4	6.5	1.2	2.091667	0
2023-12-30	2023	12	30	30	14	6	1.6	1.2	1	1512.3	6.5	1.2	1.958333	0
2023-12-30	2023	12	30	30	15	6	1.5	0.9	1	1496.8	6.5	1.2	1.791667	0
2023-12-30	2023	12	30	30	16	6	1.4	0.7	0.9	1499.3	6.5	1.2	1.591667	0
2023-12-30	2023	12	30	30	17	6	1.3	0.7	0.9	1562.7	6.5	1.1	1.4	0
2023-12-30	2023	12	30	30	18	6	1.2	0.6	0.8	1617.6	6.5	1.1	1.241667	0
2023-12-30	2023	12	30	30	19	6	1.1	0.6	1	1588.3	6.5	1.1	1.15	0
2023-12-30	2023	12	30	30	20	6	1.1	0.						

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLa	gTemp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLa	gWeekdays	
2023-12-31	2023	12	31	12	12	7	0.8	1.1	0.9	1513.4	13.3	0.7	0.775	0
2023-12-31	2023	12	31	13	13	7	0.7	1.1	0.8	1520.2	13.3	0.8	0.683333	0
2023-12-31	2023	12	31	14	14	7	0.7	0.5	0.7	1515.3	13.3	0.8	0.641667	0
2023-12-31	2023	12	31	15	15	7	0.7	0.7	0.8	1517.9	13.3	0.8	0.608333	0
2023-12-31	2023	12	31	16	16	7	0.7	0.6	1.1	1545.0	13.3	0.8	0.591667	0
2023-12-31	2023	12	31	17	17	7	0.7	0.4	0.8	1610.8	13.3	0.8	0.6	0
2023-12-31	2023	12	31	18	18	7	0.7	0.2	0.7	1669.7	13.3	0.7	0.633333	0
2023-12-31	2023	12	31	19	19	7	0.6	-0.4	0.3	1611.8	13.3	0.6	0.65	0
2023-12-31	2023	12	31	20	20	7	0.6	-0.5	0.6	1545.7	13.3	0.6	0.658333	0
2023-12-31	2023	12	31	21	21	7	0.6	-0.7	0.4	1491.3	13.3	0.5	0.633333	0
2023-12-31	2023	12	31	22	22	7	0.5	-0.9	1.1	1443.2	13.3	0.4	0.65	0
2023-12-31	2023	12	31	23	23	7	0.5	-1.2	1.1	1392.9	13.3	0.3	0.658333	0
2023-12-31	2023	12	31	24	24	7	0.4	-1.4	1.1	1353.8	13.3	0.1	0.725	0
2024-01-01	2024	1	1	1	1	1	0.3	-1.3	0.5	1318.7	11.2	-0.1	0.775	0
2024-01-01	2024	1	1	2	2	1	0.2	-1.5	0.7	1292.9	11.2	-0.3	0.791667	0
2024-01-01	2024	1	1	3	3	1	0.1	-1.7	0.6	1269.4	11.2	-0.5	0.766667	0
2024-01-01	2024	1	1	4	4	1	0.0	-1.8	0.4	1256.3	11.2	-0.7	0.766667	0
2024-01-01	2024	1	1	5	5	1	-0.1	-2	0.2	1260.2	11.2	-0.9	0.75	0
2024-01-01	2024	1	1	6	6	1	-0.2	-2.1	-0.4	1283.7	11.2	-1.1	0.691667	0
2024-01-01	2024	1	1	7	7	1	-0.3	-2.3	-0.5	1323.5	11.2	-1.3	0.641667	0
2024-01-01	2024	1	1	8	8	1	-0.5	-2.4	-0.7	1356.8	11.2	-1.5	0.55	0
2024-01-01	2024	1	1	9	9	1	-0.6	-2.5	-0.9	1409.4	11.2	-1.6	0.483333	0
2024-01-01	2024	1	1	10	10	1	-0.7	-2.7	-1.2	1483.3	11.2	-1.8	0.375	0
2024-01-01	2024	1	1	11	11	1	-0.8	-2.3	-1.4	1543.2	11.2	-1.9	0.266667	0
2024-01-01	2024	1	1	12	12	1	-1.0	-2.4	-1.3	1597.9	11.2	-2.0	0.075	0
2024-01-01	2024	1	1	13	13	1	-1.1	-1.8	-1.5	1643.6	11.2	-2.1	-0.133333	0
2024-01-01	2024	1	1	14	14	1	-1.2	-2.5	-1.7	1650.7	11.2	-2.1	-0.333333	0
2024-01-01	2024	1	1	15	15	1	-1.4	-2.6	-1.8	1645.6	11.2	-2.2	-0.5	0
2024-01-01	2024	1	1	16	16	1	-1.5	-3	-2	1657.7	11.2	-2.3	-0.7	0
2024-01-01	2024	1	1	17	17	1	-1.6	-3.4	-2.1	1720.6	11.2	-2.4	-0.9	0
2024-01-01	2024	1	1	18	18	1	-1.8	-3.7	-2.3	1766.8	11.2	-2.5	-1.1	0
2024-01-01	2024	1	1	19	19	1	-2.0	-4	-2.4	1727.9	11.2	-2.6	-1.29167	0
2024-01-01	2024	1	1	20	20	1	-2.1	-4	-2.5	1695.2	11.2	-2.8	-1.45	0
2024-01-01	2024	1	1	21	21	1	-2.3	-4	-2.7	1647.1	11.2	-2.9	-1.60833	0
2024-01-01	2024	1	1	22	22	1	-2.4	-3.9	-2.3	1578.5	11.2	-3.0	-1.75833	0
2024-01-01	2024	1	1	23	23	1	-2.5	-3.9	-2.4	1496.9	11.2	-3.1	-1.90833	0
2024-01-01	2024	1	1	24	24	1	-2.6	-3.8	-1.8	1456.8	11.2	-3.3	-2	0
45293	2024	1	2	1	2	2	-2.7	-4.1	-2.5	1424.1	9.6	-3.4	-2.08333	1
45293	2024	1	2	2	2	2	-2.9	-4.3	-2.6	1391.4	9.6	-3.6	-2.125	1
45293	2024	1	2	3	2	2	-3.0	-4.7	-3	1367.5	9.6	-3.7	-2.20833	1
45293	2024	1	2	4	2	2	-3.1	-4.7	-3.4	1361.1	9.6	-3.9	-2.28333	1
45293	2024	1	2	5	2	2	-3.2	-4.6	-3.7	1371.1	9.6	-4.0	-2.38333	1
45293	2024	1	2	6	2	2	-3.3	-4.8	-4	1424.3	9.6	-4.1	-2.5	1
45293	2024	1	2	7	2	2	-3.4	-4.8	-4	1553.4	9.6	-4.2	-2.63333	1
45293	2024	1	2	8	2	2	-3.5	-4.9	-4	1663.9	9.6	-4.3	-2.775	1
45293	2024	1	2	9	2	2	-3.6	-4.6	-3.9	1711.6	9.6	-4.4	-2.90833	1
45293	2024	1	2	10	2	2	-3.7	-4	-3.9	1730.4	9.6	-4.4	-3.03333	1
45293	2024	1	2	11	2	2	-3.8	-3.5	-3.8	1729.0	9.6	-4.4	-3.13333	1
45293	2024	1	2	12	2	2	-3.8	-3.2	-4.1	1714.4	9.6	-4.4	-3.26667	1
45293	2024	1	2	13	2	2	-3.9	-2.4	-4.3	1693.4	9.6	-4.4	-3.38333	1
45293	2024	1	2	14	2	2	-3.9	-1.8	-4.7	1646.2	9.6	-4.2	-3.575	1
45293	2024	1	2	15	2	2	-3.9	-1.1	-4.7	1588.6	9.6	-4.0	-3.725	1
45293	2024	1	2	16	2	2	-3.8	-0.8	-4.6	1587.0	9.6	-3.7	-3.9	1
45293	2024	1	2	17	2	2	-3.7	-0.6	-4.8	1692.0	9.6	-3.4	-4.04167	1
45293	2024	1	2	18	2	2	-3.6	-1.4	-4.8	1810.9	9.6	-3.0	-4.14167	1
45293	2024	1	2	19	2	2	-3.5	-1.7	-4.9	1788.9	9.6	-2.8	-4.23333	1
45293	2024	1	2	20	2	2	-3.4	-1.8	-4.6	1767.8	9.6	-2.5	-4.3	1
45293	2024	1	2	21	2	2	-3.3	-2	-4	1726.6	9.6	-2.2	-4.375	1
45293	2024	1	2	22	2	2	-3.2	-1.4	-3.5	1652.2	9.6	-2.0	-4.425	1
45293	2024	1	2	23	2	2	-3.1	-1.5	-3.2	1562.6	9.6	-1.8	-4.43333	1
45293	2024	1	2	24	2	2	-3.0	-1	-2.4	1529.6	9.6	-1.6	-4.4	1
45294	2024	1	3	1	3	3	-2.9	-1.8	-1.8	1501.0	6.2	-1.5	-4.35	1
45294	2024	1	3	2	3	3	-2.8	-1.7	-1.1	1471.8	6.2	-1.4	-4.20833	1
45294	2024	1	3	3	3	3	-2.7	-1.3	-0.8	1449.0	6.2	-1.4	-4	1
45294	2024	1	3	4	3	3	-2.6	-1.7	-0.6	1442.2	6.2	-1.4	-3.7	1
45294	2024	1	3	5	3	3	-2.4	-1.6	-1.4	1455.9	6.2	-1.5	-3.375	1
45294	2024	1	3	6	3	3	-2.3	-2	-1.7	1505.0	6.2	-1.6	-3.04167	1
45294	2024	1	3	7	3	3	-2.2	-3.1	-1.8	1631.3	6.2	-1.6	-2.75833	1
45294	2024	1	3	8	3	3	-2.1	-3.7	-2	1739.5	6.2	-1.7	-2.5	1
45294	2024	1	3	9	3	3	-2.1	-4.3	-1.4	1754.7	6.2	-1.9	-2.24167	1
45294	2024	1	3	10	3	3	-2.1	-2	-1.5	1727.2	6.2	-2.1	-2.025	1
45294	2024	1	3	11	3	3	-2.0	-1.7	-1	1691.5	6.2	-2.1	-1.80833	1
45294	2024	1	3	12	3	3	-1.9	-1.6	-1.8	1677.9	6.2	-2.2	-1.64167	1
45294	2024	1	3	13	3	3	-1.8	-1.4	-1.7	1668.9	6.2	-2.2	-1.45833	1
45294	2024	1	3	14	3	3	-1.8	-1	-1.3	1646.8	6.2	-2.2	-1.40833	1
45294	2024	1	3	15	3	3	-1.8	-0.7	-1.7	1631.6	6.2	-2.1	-1.4	1
45294	2024	1	3	16	3	3	-1.7	0	-1.6	1643.8	6.2	-2.1	-1.41667	1
45294	2024	1	3	17	3	3	-1.7	-0.1	-2	1709.3	6.2	-1.9	-1.49167	1
45294	2024	1	3	18	3	3	-1.7	-1.1	-3.1	1800.1	6.2	-1.8	-1.575	1
45294	2024	1	3	19	3	3	-1.7	-2.1	-3.7	1772.6	6.2	-1.7	-1.625	1
45294	2024	1	3	20	3	3	-1.7	-3.4	-4.3	1745.8	6.2	-1.6	-1.74167	1
45294	2024	1	3	21	3	3	-1.8	-4.6	-2	1706.4	6.2	-1.6	-1.9	1
45294	2024	1	3	22	3	3	-1.9	-4.8	-1.7	1631.0	6.2	-1.6	-2.09167	1
45294	2024	1	3	23	3	3	-2.0	-3	-1.6	1535.7	6.2	-1.9	-2.14167	1
45294	2024	1	3	24	3	3	-2.1	-2.9	-1.4	1487.5	6.2	-2.0	-2.15833	1
45295	2024	1	4	1	4	4	-2.2	-2.5	-1	1439.3	2.8	-2.1	-2.20833	1
45295	2024	1	4	2	4	4	-2.2	-2.3	-0.7	1398.0	2.8	-2.2	-2.175	1
45295	2024	1	4	3	4	4	-2.2	-1.9	0	1360.9	2.8	-2.3	-2.11667	1
45295	2024	1	4	4	4	4	-2.2	-1.4	-0.1	1343.4	2.8	-2.4	-2.06667	1
45295	2024	1	4	5	4	4	-2.2	-1.3	-1.1	1347.8	2.8	-2.5	-1.925	1
45295	2024	1	4	6	4	4	-2.2	-1	-2.1	1390.5	2.8	-2.6	-1.8	1
45295	2024	1	4	7	4	4	-2.2	-1.1	-3.4	1512.8	2.8	-2.6	-1.725	1
45295	2024	1	4	8	4	4	-2.1	0.1	-4.6	1624.2	2.8	-2.5	-1.64167	1
45295	2024	1	4	9	4	4	-1.9	0	-4.8	1653.3	2.8	-2.2	-1.61667	1
45295	2024	1	4	10	4	4	-1.7	0.5	-3	1654.0	2.8	-1.8	-1.64167	1
45295	2024	1	4	11	4	4	-1.6	0.7	-2.9	1648.6	2.8	-1.4	-1.875	1
45295	2024	1	4	12	4	4	-1.5	1.4	-2.5	1640.9	2.8	-1.1	-1.98333	1
45295	2024	1	4											

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLag	Temp	LagTemp12	Load	Wind	12hrAvg	12hrAvgLag	Weekdays	
45295	2024		1	4	24	4	-0.3	-0.4	1.5	1434.9	2.8	0.5	-1.09167	1
45296	2024		1	5	1	5	-0.2	0.2	1.5	1397.0	18.9	0.3	-0.73333	1
45296	2024		1	5	2	5	-0.1	0.5	1.8	1369.1	18.9	0.2	-0.4	1
45296	2024		1	5	3	5	0.0	0.6	1.4	1346.9	18.9	0.1	-0.08333	1
45296	2024		1	5	4	5	0.1	-0.6	1.3	1363.2	18.9	0.0	0.225	1
45296	2024		1	5	5	5	0.2	-2	0.7	1401.0	18.9	-0.2	0.458333	1
45296	2024		1	5	6	5	0.1	-4.5	-0.8	1484.1	18.9	-0.4	0.675	1
45296	2024		1	5	7	5	0.0	-6	-0.5	1620.4	18.9	-0.9	0.816667	1
45296	2024		1	5	8	5	-0.2	-6	-0.7	1743.0	18.9	-1.3	0.841667	1
45296	2024		1	5	9	5	-0.5	-6.1	-0.9	1795.0	18.9	-1.8	0.791667	1
45296	2024		1	5	10	5	-0.7	-5.9	-1.3	1809.5	18.9	-2.2	0.733333	1
45296	2024		1	5	11	5	-1.0	-5.3	-0.4	1796.9	18.9	-2.6	0.616667	1
45296	2024		1	5	12	5	-1.3	-5	0.2	1783.1	18.9	-3.0	0.45	1
45296	2024		1	5	13	5	-1.5	-5.3	0.5	1781.2	18.9	-3.3	0.3	1
45296	2024		1	5	14	5	-1.8	-5.4	0.6	1767.6	18.9	-3.8	0.191667	1
45296	2024		1	5	15	5	-2.1	-5.4	-0.6	1760.3	18.9	-4.3	0.108333	1
45296	2024		1	5	16	5	-2.4	-5.3	-2	1786.7	18.9	-4.8	0.008333	1
45296	2024		1	5	17	5	-2.7	-5.9	-4.5	1849.8	18.9	-5.2	-0.15833	1
45296	2024		1	5	18	5	-3.0	-6.3	-6	1929.8	18.9	-5.5	-0.43333	1
45296	2024		1	5	19	5	-3.3	-6.3	-6	1900.6	18.9	-5.7	-0.86667	1
45296	2024		1	5	20	5	-3.5	-6	-6.1	1855.2	18.9	-5.7	-1.3	1
45296	2024		1	5	21	5	-3.7	-6.1	-5.9	1812.6	18.9	-5.7	-1.75833	1
45296	2024		1	5	22	5	-3.9	-6.5	-5.3	1767.2	18.9	-5.7	-2.20833	1
45296	2024		1	5	23	5	-4.2	-6.7	-5	1706.0	18.9	-5.7	-2.625	1
45296	2024		1	5	24	5	-4.4	-7.2	-5.3	1679.7	18.9	-5.9	-2.95833	1
45297	2024		1	6	1	6	-4.7	-7.1	-5.4	1635.5	15.0	-6.0	-3.34167	0
45297	2024		1	6	2	6	-5.0	-7	-5.4	1598.5	15.0	-6.2	-3.8	0
45297	2024		1	6	3	6	-5.3	-6.8	-5.3	1567.8	15.0	-6.3	-4.29167	0
45297	2024		1	6	4	6	-5.6	-6.9	-5.9	1558.1	15.0	-6.4	-4.79167	0
45297	2024		1	6	5	6	-5.9	-7.5	-6.3	1575.2	15.0	-6.6	-5.18333	0
45297	2024		1	6	6	6	-6.1	-8.6	-6.3	1614.7	15.0	-6.7	-5.50833	0
45297	2024		1	6	7	6	-6.3	-8.2	-6	1679.5	15.0	-6.9	-5.65833	0
45297	2024		1	6	8	6	-6.4	-8.4	-6.1	1769.3	15.0	-7.1	-5.68333	0
45297	2024		1	6	9	6	-6.5	-9.3	-6.5	1851.5	15.0	-7.3	-5.68333	0
45297	2024		1	6	10	6	-6.6	-9.1	-6.7	1879.5	15.0	-7.5	-5.68333	0
45297	2024		1	6	11	6	-6.7	-8.6	-7.2	1865.8	15.0	-7.7	-5.73333	0
45297	2024		1	6	12	6	-6.9	-7.9	-7.1	1841.0	15.0	-7.9	-5.85	0
45297	2024		1	6	13	6	-7.0	-7.5	-7	1805.8	15.0	-8.0	-6.03333	0
45297	2024		1	6	14	6	-7.1	-6.8	-6.8	1756.1	15.0	-8.0	-6.18333	0
45297	2024		1	6	15	6	-7.1	-6.2	-6.9	1729.2	15.0	-8.0	-6.31667	0
45297	2024		1	6	16	6	-7.2	-6	-7.5	1759.1	15.0	-7.9	-6.43333	0
45297	2024		1	6	17	6	-7.2	-6.6	-8.6	1874.1	15.0	-7.8	-6.56667	0
45297	2024		1	6	18	6	-7.2	-7.7	-8.2	1976.4	15.0	-7.8	-6.7	0
45297	2024		1	6	19	6	-7.3	-8.2	-8.4	1948.2	15.0	-7.7	-6.89167	0
45297	2024		1	6	20	6	-7.4	-8.5	-9.3	1901.9	15.0	-7.7	-7.05	0
45297	2024		1	6	21	6	-7.5	-8.5	-9.1	1862.8	15.0	-7.7	-7.25	0
45297	2024		1	6	22	6	-7.6	-9.1	-8.6	1819.2	15.0	-7.6	-7.51667	0
45297	2024		1	6	23	6	-7.7	-9.6	-7.9	1756.3	15.0	-7.6	-7.73333	0
45297	2024		1	6	24	6	-7.8	-9.6	-7.5	1693.3	15.0	-7.7	-7.89167	0
45298	2024		1	7	1	7	-7.9	-9.4	-6.8	1641.3	15.9	-7.9	-7.95	0
45298	2024		1	7	2	7	-8.0	-9.9	-6.2	1620.6	15.9	-8.0	-7.98333	0
45298	2024		1	7	3	7	-8.1	-10.7	-6	1604.0	15.9	-8.3	-7.96667	0
45298	2024		1	7	4	7	-8.3	-9.8	-6.6	1596.0	15.9	-8.7	-7.91667	0
45298	2024		1	7	5	7	-8.4	-9	-7.7	1604.1	15.9	-9.0	-7.84167	0
45298	2024		1	7	6	7	-8.5	-9.4	-8.2	1631.0	15.9	-9.2	-7.76667	0
45298	2024		1	7	7	7	-8.5	-9.4	-8.5	1674.8	15.9	-9.3	-7.69167	0
45298	2024		1	7	8	7	-8.6	-9.2	-8.5	1728.3	15.9	-9.4	-7.69167	0
45298	2024		1	7	9	7	-8.6	-8.6	-9.1	1805.4	15.9	-9.5	-7.7	0
45298	2024		1	7	10	7	-8.6	-7.9	-9.6	1852.8	15.9	-9.5	-7.63333	0
45298	2024		1	7	11	7	-8.5	-6.5	-9.6	1867.1	15.9	-9.4	-7.63333	0
45298	2024		1	7	12	7	-8.4	-5.2	-9.4	1857.7	15.9	-9.1	-7.71667	0
45298	2024		1	7	13	7	-8.3	-4.2	-9.9	1849.9	15.9	-8.8	-7.85833	0
45298	2024		1	7	14	7	-8.2	-3.7	-10.7	1820.2	15.9	-8.3	-8.01667	0
45298	2024		1	7	15	7	-8.0	-3.2	-9.8	1811.5	15.9	-7.8	-8.275	0
45298	2024		1	7	16	7	-7.9	-3	-9	1842.0	15.9	-7.2	-8.65	0
45298	2024		1	7	17	7	-7.8	-3	-9.4	1917.1	15.9	-6.6	-8.96667	0
45298	2024		1	7	18	7	-7.6	-3.1	-9.4	1969.1	15.9	-6.1	-9.16667	0
45298	2024		1	7	19	7	-7.4	-3.3	-9.2	1920.6	15.9	-5.6	-9.30833	0
45298	2024		1	7	20	7	-7.2	-3.8	-8.6	1878.1	15.9	-5.1	-9.40833	0
45298	2024		1	7	21	7	-7.0	-4.4	-7.9	1822.0	15.9	-4.6	-9.46667	0
45298	2024		1	7	22	7	-6.9	-4.2	-6.5	1740.0	15.9	-4.3	-9.475	0
45298	2024		1	7	23	7	-6.7	-4.8	-5.2	1635.7	15.9	-4.0	-9.375	0
45298	2024		1	7	24	7	-6.5	-5.7	-4.2	1549.9	15.9	-3.8	-9.11667	0
45299	2024		1	8	1	1	-6.3	-5.2	-3.7	1485.9	18.7	-3.9	-8.75	1
45299	2024		1	8	2	1	-6.1	-5	-3.2	1457.9	18.7	-4.0	-8.31667	1
45299	2024		1	8	3	1	-5.9	-4.5	-3	1451.2	18.7	-4.1	-7.8	1
45299	2024		1	8	4	1	-5.7	-3.9	-3	1457.8	18.7	-4.2	-7.175	1
45299	2024		1	8	5	1	-5.4	-4	-3.1	1473.6	18.7	-4.2	-6.60833	1
45299	2024		1	8	6	1	-5.2	-3.9	-3.3	1529.2	18.7	-4.3	-6.10833	1
45299	2024		1	8	7	1	-5.0	-3.8	-3.8	1657.6	18.7	-4.4	-5.58333	1
45299	2024		1	8	8	1	-4.8	-3.8	-4.4	1772.8	18.7	-4.4	-5.075	1
45299	2024		1	8	9	1	-4.5	-4.1	-4.2	1813.0	18.7	-4.4	-4.625	1
45299	2024		1	8	10	1	-4.3	-3.5	-4.8	1804.2	18.7	-4.4	-4.275	1
45299	2024		1	8	11	1	-4.2	-3.2	-5.7	1782.9	18.7	-4.4	-3.96667	1
45299	2024		1	8	12	1	-4.0	-3	-5.2	1758.3	18.7	-4.2	-3.825	1
45299	2024		1	8	13	1	-3.9	-2.4	-5	1754.4	18.7	-4.0	-3.86667	1
45299	2024		1	8	14	1	-3.9	-2.8	-4.5	1724.1	18.7	-3.8	-3.95	1
45299	2024		1	8	15	1	-3.8	-3.1	-3.9	1715.2	18.7	-3.6	-4.05833	1
45299	2024		1	8	16	1	-3.8	-3.1	-4	1745.9	18.7	-3.5	-4.16667	1
45299	2024		1	8	17	1	-3.8	-4.1	-3.9	1834.0	18.7	-3.4	-4.24167	1
45299	2024		1	8	18	1	-3.9	-4.3	-3.8	1929.1	18.7	-3.4	-4.325	1
45299	2024		1	8	19	1	-3.9	-4.9	-3.8	1902.3	18.7	-3.4	-4.39167	1
45299	2024		1	8	20	1	-4.0	-5	-4.1	1861.8	18.7	-3.5	-4.43333	1
45299	2024		1	8	21	1	-4.0	-5.3	-3.5	1814.1	18.7	-3.6	-4.43333	1
45299	2024		1	8	22	1	-4.1	-5	-3.2	1750.2	18.7	-3.7	-4.40833	1
45299	2024		1	8	23	1	-4.1	-4.8	-3	1662.3	18.7	-3.9	-4.35	1
45299	2024		1	8	24	1	-4.1	-4.8	-2.4	1616.9	18.7	-4.0	-4.21667	1
45300	2024		1	9	1	2	-4.1	-5.2	-2.8	1584.3	11.8	-4.1	-3.99167	1
45300	2024		1	9	2	2	-4.1	-5.3	-3.1	1559.9	11.8	-4.4	-3.75833	1
45300	2024		1	9	3	2	-4.1	-4.8	-3.1	1531.3	11.8	-4.6	-3.575	1

DATE	Year	Month	Day	HOUR	DOW	24hrAvgLa	gTemp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLa	gWeekdays
45300	2024	1	9	12	2	-4.6	-2.9	-5.2	1693.0	11.8	-5.2	-3.98333	1
45300	2024	1	9	13	2	-4.6	-2.2	-5.3	1661.0	11.8	-5.0	-4.13333	1
45300	2024	1	9	14	2	-4.6	-1.4	-4.8	1619.4	11.8	-4.8	-4.36667	1
45300	2024	1	9	15	2	-4.5	-0.5	-5.1	1595.8	11.8	-4.5	-4.575	1
45300	2024	1	9	16	2	-4.4	-0.3	-5.5	1633.0	11.8	-4.1	-4.71667	1
45300	2024	1	9	17	2	-4.3	-1	-5.1	1730.8	11.8	-3.7	-4.88333	1
45300	2024	1	9	18	2	-4.2	-2.3	-5.6	1852.9	11.8	-3.3	-5	1
45300	2024	1	9	19	2	-4.1	-3.4	-5.8	1860.4	11.8	-3.1	-5.06667	1
45300	2024	1	9	20	2	-4.0	-3.7	-6.1	1836.8	11.8	-2.9	-5.125	1
45300	2024	1	9	21	2	-4.0	-4.3	-5	1805.7	11.8	-2.7	-5.19167	1
45300	2024	1	9	22	2	-3.9	-4.9	-4	1745.2	11.8	-2.6	-5.25833	1
45300	2024	1	9	23	2	-3.9	-5.9	-2.9	1666.8	11.8	-2.6	-5.25833	1
45300	2024	1	9	24	2	-4.0	-6.9	-2.2	1634.4	11.8	-2.7	-5.19167	1
45301	2024	1	10	1	3	-4.1	-6.7	-1.4	1596.8	27.2	-3.1	-5.03333	1
45301	2024	1	10	2	3	-4.1	-6.1	-0.5	1557.6	27.2	-3.4	-4.78333	1
45301	2024	1	10	3	3	-4.1	-5.8	-0.3	1519.6	27.2	-3.8	-4.45833	1
45301	2024	1	10	4	3	-4.2	-5.1	-1	1498.5	27.2	-4.3	-4.1	1
45301	2024	1	10	5	3	-4.2	-1.8	-2.3	1491.9	27.2	-4.7	-3.7	1
45301	2024	1	10	6	3	-4.0	-0.5	-3.4	1528.2	27.2	-4.7	-3.325	1
45301	2024	1	10	7	3	-3.8	0.6	-3.7	1634.9	27.2	-4.6	-3.09167	1
45301	2024	1	10	8	3	-3.6	-0.3	-4.3	1736.1	27.2	-4.3	-2.90833	1
45301	2024	1	10	9	3	-3.4	0.3	-4.9	1788.7	27.2	-4.0	-2.73333	1
45301	2024	1	10	10	3	-3.1	1.5	-5.9	1791.7	27.2	-3.6	-2.58333	1
45301	2024	1	10	11	3	-2.8	2.2	-6.9	1793.1	27.2	-3.1	-2.575	1
45301	2024	1	10	12	3	-2.6	2.5	-6.7	1804.9	27.2	-2.4	-2.73333	1
45301	2024	1	10	13	3	-2.3	2.9	-6.1	1814.1	27.2	-1.6	-3.06667	1
45301	2024	1	10	14	3	-2.1	3.8	-5.8	1789.2	27.2	-0.8	-3.44167	1
45301	2024	1	10	15	3	-1.9	4.8	-5.1	1750.5	27.2	0.0	-3.83333	1
45301	2024	1	10	16	3	-1.7	5.7	-1.8	1707.2	27.2	0.9	-4.275	1
45301	2024	1	10	17	3	-1.4	6.9	-0.5	1723.4	27.2	1.8	-4.675	1
45301	2024	1	10	18	3	-1.1	7.7	0.6	1736.4	27.2	2.5	-4.74167	1
45301	2024	1	10	19	3	-0.7	7.6	-0.3	1645.3	27.2	3.2	-4.59167	1
45301	2024	1	10	20	3	-0.2	7.6	0.3	1578.0	27.2	3.8	-4.25833	1
45301	2024	1	10	21	3	0.2	7	1.5	1516.7	27.2	4.5	-3.975	1
45301	2024	1	10	22	3	0.7	6.4	2.2	1434.8	27.2	5.0	-3.59167	1
45301	2024	1	10	23	3	1.2	6.4	2.5	1336.1	27.2	5.4	-3.05833	1
45301	2024	1	10	24	3	1.7	5.8	2.9	1282.6	27.2	5.8	-2.38333	1
45302	2024	1	11	1	4	2.2	5.4	3.8	1245.7	15.8	6.1	-1.6	1
45302	2024	1	11	2	4	2.7	5.1	4.8	1202.1	15.8	6.3	-0.8	1
45302	2024	1	11	3	4	3.2	5	5.7	1175.5	15.8	6.4	0.025	1
45302	2024	1	11	4	4	3.6	4.2	6.9	1178.7	15.8	6.4	0.908333	1
45302	2024	1	11	5	4	4.0	3.8	7.7	1194.6	15.8	6.3	1.808333	1
45302	2024	1	11	6	4	4.3	3.4	7.6	1255.1	15.8	6.0	2.533333	1
45302	2024	1	11	7	4	4.4	3.4	7.6	1385.2	15.8	5.6	3.216667	1
45302	2024	1	11	8	4	4.5	3.4	7	1499.4	15.8	5.3	3.8	1
45302	2024	1	11	9	4	4.7	3.5	6.4	1513.5	15.8	4.9	4.458333	1
45302	2024	1	11	10	4	4.8	4.3	6.4	1469.4	15.8	4.7	5.016667	1
45302	2024	1	11	11	4	5.0	5.8	5.8	1420.3	15.8	4.5	5.425	1
45302	2024	1	11	12	4	5.1	6	5.4	1398.2	15.8	4.4	5.775	1
45302	2024	1	11	13	4	5.2	5.4	5.1	1408.3	15.8	4.4	6.05	1
45302	2024	1	11	14	4	5.4	5.4	5	1395.3	15.8	4.4	6.258333	1
45302	2024	1	11	15	4	5.4	5.4	4.2	1398.8	15.8	4.5	6.366667	1
45302	2024	1	11	16	4	5.4	5.6	3.8	1416.7	15.8	4.5	6.383333	1
45302	2024	1	11	17	4	5.4	4.7	3.4	1492.1	15.8	4.6	6.258333	1
45302	2024	1	11	18	4	5.3	3.9	3.4	1583.7	15.8	4.7	6	1
45302	2024	1	11	19	4	5.2	3	3.4	1571.2	15.8	4.7	5.641667	1
45302	2024	1	11	20	4	5.0	3.7	3.5	1540.0	15.8	4.7	5.291667	1
45302	2024	1	11	21	4	4.8	3.7	4.3	1500.6	15.8	4.7	4.941667	1
45302	2024	1	11	22	4	4.7	3.4	5.8	1437.3	15.8	4.7	4.65	1
45302	2024	1	11	23	4	4.6	3	6	1361.3	15.8	4.7	4.475	1
45302	2024	1	11	24	4	4.4	2.7	5.4	1330.1	15.8	4.4	4.425	1
45303	2024	1	12	1	5	4.3	2.3	5.4	1292.1	12.1	4.2	4.441667	1
45303	2024	1	12	2	5	4.2	1.9	5.4	1265.0	12.1	3.9	4.441667	1
45303	2024	1	12	3	5	4.0	1.3	5.6	1242.2	12.1	3.6	4.466667	1
45303	2024	1	12	4	5	3.9	0.9	4.7	1239.1	12.1	3.3	4.5	1
45303	2024	1	12	5	5	3.7	0.4	3.9	1265.4	12.1	2.9	4.616667	1
45303	2024	1	12	6	5	3.6	0.4	3	1321.8	12.1	2.5	4.691667	1
45303	2024	1	12	7	5	3.5	0.7	3.7	1455.8	12.1	2.2	4.733333	1
45303	2024	1	12	8	5	3.4	0.4	3.7	1573.5	12.1	2.0	4.7	1
45303	2024	1	12	9	5	3.2	0.4	3.4	1609.8	12.1	1.8	4.725	1
45303	2024	1	12	10	5	3.1	0.4	3	1611.9	12.1	1.5	4.741667	1
45303	2024	1	12	11	5	3.0	0.2	2.7	1606.9	12.1	1.2	4.666667	1
45303	2024	1	12	12	5	2.7	0.4	2.3	1586.4	12.1	1.0	4.433333	1
45303	2024	1	12	13	5	2.5	0.2	1.9	1553.4	12.1	0.8	4.158333	1
45303	2024	1	12	14	5	2.3	0.5	1.3	1499.9	12.1	0.6	3.9	1
45303	2024	1	12	15	5	2.1	2	0.9	1461.4	12.1	0.5	3.608333	1
45303	2024	1	12	16	5	1.9	1.5	0.4	1487.0	12.1	0.6	3.266667	1
45303	2024	1	12	17	5	1.8	0.9	0.4	1574.7	12.1	0.6	2.875	1
45303	2024	1	12	18	5	1.6	0	0.7	1700.1	12.1	0.7	2.516667	1
45303	2024	1	12	19	5	1.4	-1	0.4	1692.0	12.1	0.6	2.225	1
45303	2024	1	12	20	5	1.3	-1.3	0.4	1663.5	12.1	0.5	2.033333	1
45303	2024	1	12	21	5	1.1	-1.7	0.4	1631.0	12.1	0.4	1.758333	1
45303	2024	1	12	22	5	0.8	-2.4	0.2	1596.8	12.1	0.2	1.483333	1
45303	2024	1	12	23	5	0.6	-3.2	0.4	1545.9	12.1	-0.1	1.233333	1
45303	2024	1	12	24	5	0.3	-4.3	0.2	1543.0	12.1	-0.3	1	1
45304	2024	1	13	1	6	0.0	-5.7	0.5	1525.6	19.0	-0.7	0.808333	0
45304	2024	1	13	2	6	-0.3	-6.4	2	1499.9	19.0	-1.2	0.633333	0
45304	2024	1	13	3	6	-0.6	-5.8	1.5	1473.2	19.0	-1.8	0.516667	0
45304	2024	1	13	4	6	-0.9	-6	0.9	1464.5	19.0	-2.5	0.575	0
45304	2024	1	13	5	6	-1.2	-6.3	0	1470.1	19.0	-3.1	0.625	0
45304	2024	1	13	6	6	-1.5	-6.5	-1	1492.7	19.0	-3.7	0.666667	0
45304	2024	1	13	7	6	-1.8	-6	-1.3	1539.5	19.0	-4.2	0.633333	0
45304	2024	1	13	8	6	-2.1	-5.8	-1.7	1608.8	19.0	-4.6	0.491667	0
45304	2024	1	13	9	6	-2.3	-5.3	-2.4	1685.7	19.0	-5.0	0.35	0
45304	2024	1	13	10	6	-2.6	-4.6	-3.2	1742.1	19.0	-5.3	0.175	0
45304	2024	1	13	11	6	-2.8	-1.5	-4.3	1766.4	19.0	-5.5	-0.05833	0
45304	2024	1	13	12	6	-2.8	-0.6	-5.7	1777.5	19.0	-5.4	-0.34167	0
45304	2024	1	13	13	6	-2.9	-0.1	-6.4	1772.2	19.0	-5.0	-0.73333	0
45304	2024	1	13	14	6	-2.9	0.8	-5.8	1761.7	19.0	-4.6	-1.225	0
45304	2024	1	13	15	6	-2.9	1.4	-6	1758.3	19.0	-4.0	-1.8	0
45304	2024	1	13	16	6	-2.9	1.1	-6.3	1751.8	19.0	-3.4	-2.45	0
45304	2024	1	13	17	6	-2.9	1.9	-6.5	1777.3	19.0	-2.8	-3.075	0
45304	2024	1	13	18	6	-2.9	2.5</						

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLag	Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLag	Weekdays	
45304	2024		1	13	24	6	-1.5	7.1	-0.1	1317.2	19.0	2.4	-5.35	0
45305	2024		1	14	1	7	-1.0	7	0.8	1242.0	22.1	3.0	-5.04167	0
45305	2024		1	14	2	7	-0.5	7.4	1.4	1188.2	22.1	3.6	-4.575	0
45305	2024		1	14	3	7	0.1	7.3	1.1	1163.6	22.1	4.2	-3.975	0
45305	2024		1	14	4	7	0.6	6.5	1.9	1151.4	22.1	4.7	-3.375	0
45305	2024		1	14	5	7	1.2	5.4	2.5	1154.0	22.1	5.1	-2.78333	0
45305	2024		1	14	6	7	1.7	4.7	2.8	1169.4	22.1	5.4	-2.1	0
45305	2024		1	14	7	7	2.1	4.7	3.4	1208.1	22.1	5.6	-1.35	0
45305	2024		1	14	8	7	2.6	4.2	4.2	1273.1	22.1	5.8	-0.61667	0
45305	2024		1	14	9	7	3.0	3.7	5	1356.5	22.1	5.8	0.15	0
45305	2024		1	14	10	7	3.4	4.1	6.3	1393.4	22.1	5.8	0.941667	0
45305	2024		1	14	11	7	3.7	4.7	7.1	1414.1	22.1	5.7	1.741667	0
45305	2024		1	14	12	7	4.0	4.4	7	1424.5	22.1	5.6	2.391667	0
45305	2024		1	14	13	7	4.2	4.5	7.4	1440.1	22.1	5.3	3.033333	0
45305	2024		1	14	14	7	4.4	5.7	7.3	1423.0	22.1	5.1	3.625	0
45305	2024		1	14	15	7	4.6	4.8	6.5	1405.0	22.1	5.0	4.175	0
45305	2024		1	14	16	7	4.7	4.6	5.4	1419.6	22.1	4.8	4.666667	0
45305	2024		1	14	17	7	4.9	4.2	4.7	1523.7	22.1	4.6	5.116667	0
45305	2024		1	14	18	7	5.0	3.1	4.7	1627.8	22.1	4.5	5.408333	0
45305	2024		1	14	19	7	5.0	3.4	4.2	1605.1	22.1	4.4	5.591667	0
45305	2024		1	14	20	7	5.0	3.6	3.7	1570.7	22.1	4.3	5.75	0
45305	2024		1	14	21	7	5.0	3.3	4.1	1530.8	22.1	4.2	5.816667	0
45305	2024		1	14	22	7	5.0	1.2	4.7	1478.8	22.1	4.2	5.775	0
45305	2024		1	14	23	7	4.8	1.9	4.4	1390.4	22.1	4.0	5.7	0
45305	2024		1	14	24	7	4.6	2.3	4.5	1319.2	22.1	3.7	5.566667	0
45306	2024		1	15	1	1	4.4	0.6	5.7	1260.7	10.3	3.6	5.341667	1
45306	2024		1	15	2	1	4.2	0.2	4.8	1247.1	10.3	3.2	5.133333	1
45306	2024		1	15	3	1	3.9	-0.1	4.6	1236.7	10.3	2.8	4.991667	1
45306	2024		1	15	4	1	3.6	0	4.2	1274.5	10.3	2.4	4.783333	1
45306	2024		1	15	5	1	3.3	-0.7	3.1	1310.0	10.3	2.0	4.625	1
45306	2024		1	15	6	1	3.0	-1.2	3.4	1383.7	10.3	1.6	4.525	1
45306	2024		1	15	7	1	2.8	-1.8	3.6	1535.7	10.3	1.2	4.391667	1
45306	2024		1	15	8	1	2.5	-2.6	3.3	1656.9	10.3	0.8	4.283333	1
45306	2024		1	15	9	1	2.2	-2.8	1.2	1684.2	10.3	0.3	4.233333	1
45306	2024		1	15	10	1	2.0	-2	1.9	1643.4	10.3	-0.3	4.2	1
45306	2024		1	15	11	1	1.7	-1.1	2.3	1610.1	10.3	-0.5	3.958333	1
45306	2024		1	15	12	1	1.5	-0.6	0.6	1589.3	10.3	-0.8	3.725	1
45306	2024		1	15	13	1	1.3	-0.1	0.2	1595.0	10.3	-1.0	3.55	1
45306	2024		1	15	14	1	1.1	0	-0.1	1598.3	10.3	-1.1	3.225	1
45306	2024		1	15	15	1	0.8	-1.1	0	1585.7	10.3	-1.1	2.766667	1
45306	2024		1	15	16	1	0.6	-0.4	-0.7	1594.7	10.3	-1.2	2.358333	1
45306	2024		1	15	17	1	0.4	-0.4	-1.2	1683.1	10.3	-1.2	1.975	1
45306	2024		1	15	18	1	0.2	-1.4	-1.8	1792.7	10.3	-1.2	1.566667	1
45306	2024		1	15	19	1	0.0	-1.9	-2.6	1784.6	10.3	-1.2	1.208333	1
45306	2024		1	15	20	1	-0.2	-2.2	-2.8	1756.6	10.3	-1.2	0.775	1
45306	2024		1	15	21	1	-0.5	-2.8	-2	1717.6	10.3	-1.2	0.258333	1
45306	2024		1	15	22	1	-0.7	-5.3	-1.1	1652.9	10.3	-1.2	-0.25	1
45306	2024		1	15	23	1	-1.0	-4.8	-0.6	1571.4	10.3	-1.4	-0.51667	1
45306	2024		1	15	24	1	-1.3	-5.8	-0.1	1538.3	10.3	-1.8	-0.76667	1
45307	2024		1	16	1	2	-1.6	-5.2	0	1508.3	13.0	-2.2	-1.00833	1
45307	2024		1	16	2	2	-1.8	-5.4	-1.1	1477.1	13.0	-2.6	-1.06667	1
45307	2024		1	16	3	2	-2.1	-6.4	-0.4	1456.6	13.0	-3.1	-1.08333	1
45307	2024		1	16	4	2	-2.3	-4.6	-0.4	1445.6	13.0	-3.5	-1.16667	1
45307	2024		1	16	5	2	-2.5	-4.4	-1.4	1448.6	13.0	-3.9	-1.2	1
45307	2024		1	16	6	2	-2.7	-4.4	-1.9	1500.6	13.0	-4.2	-1.175	1
45307	2024		1	16	7	2	-2.8	-3.7	-2.2	1625.3	13.0	-4.4	-1.19167	1
45307	2024		1	16	8	2	-2.9	-2.1	-2.8	1727.9	13.0	-4.6	-1.2	1
45307	2024		1	16	9	2	-2.9	-1.2	-5.3	1751.3	13.0	-4.6	-1.16667	1
45307	2024		1	16	10	2	-2.8	0	-4.8	1731.2	13.0	-4.4	-1.16667	1
45307	2024		1	16	11	2	-2.7	0.7	-5.8	1701.4	13.0	-4.0	-1.44167	1
45307	2024		1	16	12	2	-2.6	0.6	-5.2	1686.9	13.0	-3.5	-1.75	1
45307	2024		1	16	13	2	-2.6	1	-5.4	1691.1	13.0	-3.0	-2.18333	1
45307	2024		1	16	14	2	-2.6	1.4	-6.4	1680.4	13.0	-2.5	-2.60833	1
45307	2024		1	16	15	2	-2.5	1.8	-4.6	1670.6	13.0	-1.9	-3.05833	1
45307	2024		1	16	16	2	-2.4	2	-4.4	1685.1	13.0	-1.2	-3.5	1
45307	2024		1	16	17	2	-2.3	1.5	-4.4	1750.7	13.0	-0.7	-3.85	1
45307	2024		1	16	18	2	-2.2	1.7	-3.7	1807.7	13.0	-0.2	-4.18333	1
45307	2024		1	16	19	2	-2.1	2.1	-2.1	1764.0	13.0	0.3	-4.43333	1
45307	2024		1	16	20	2	-1.9	2.4	-1.2	1714.4	13.0	0.8	-4.58333	1
45307	2024		1	16	21	2	-1.7	3.1	0	1640.8	13.0	1.2	-4.575	1
45307	2024		1	16	22	2	-1.5	4.2	0.7	1552.4	13.0	1.5	-4.44167	1
45307	2024		1	16	23	2	-1.1	6.2	0.6	1425.5	13.0	1.9	-4	1
45307	2024		1	16	24	2	-0.6	7.4	1	1345.8	13.0	2.3	-3.54167	1
45308	2024		1	17	1	3	-0.1	7.7	1.4	1270.5	19.1	2.9	-3.00833	1
45308	2024		1	17	2	3	0.5	8	1.8	1200.1	19.1	3.5	-2.49167	1
45308	2024		1	17	3	3	1.0	8.6	2	1150.0	19.1	4.0	-1.925	1
45308	2024		1	17	4	3	1.7	9.1	1.5	1128.6	19.1	4.6	-1.24167	1
45308	2024		1	17	5	3	2.2	8.4	1.7	1139.6	19.1	5.2	-0.69167	1
45308	2024		1	17	6	3	2.8	7	2.1	1201.5	19.1	5.7	-0.2	1
45308	2024		1	17	7	3	3.2	5.9	2.4	1347.4	19.1	6.2	0.308333	1
45308	2024		1	17	8	3	3.6	5	3.1	1490.0	19.1	6.5	0.791667	1
45308	2024		1	17	9	3	3.9	1.9	4.2	1539.1	19.1	6.7	1.166667	1
45308	2024		1	17	10	3	4.1	0.9	6.2	1547.7	19.1	6.6	1.525	1
45308	2024		1	17	11	3	4.1	0.5	7.4	1562.3	19.1	6.3	1.875	1
45308	2024		1	17	12	3	4.1	-0.3	7.7	1583.5	19.1	5.9	2.333333	1
45308	2024		1	17	13	3	4.1	-0.4	8	1588.1	19.1	5.2	2.9	1
45308	2024		1	17	14	3	4.0	-0.8	8.6	1572.4	19.1	4.6	3.458333	1
45308	2024		1	17	15	3	3.9	-0.9	9.1	1594.8	19.1	3.8	4.008333	1
45308	2024		1	17	16	3	3.8	-1.6	8.4	1649.6	19.1	3.0	4.575	1
45308	2024		1	17	17	3	3.7	-1.3	7	1739.8	19.1	2.1	5.166667	1
45308	2024		1	17	18	3	3.5	-2.1	5.9	1835.5	19.1	1.3	5.741667	1
45308	2024		1	17	19	3	3.4	-2.6	5	1821.7	19.1	0.6	6.183333	1
45308	2024		1	17	20	3	3.2	-2.5	1.9	1789.5	19.1	-0.1	6.5	1
45308	2024		1	17	21	3	3.0	-2.8	0.9	1749.3	19.1	-0.8	6.716667	1
45308	2024		1	17	22	3	2.7	-3.2	0.5	1688.2	19.1	-1.2	6.616667	1
45308	2024		1	17	23	3	2.4	-3.1	-0.3	1604.7	19.1	-1.5	6.341667	1
45308	2024		1	17	24	3	2.0	-3.7	-0.4	1571.7	19.1	-1.8	5.866667	1
45309	2024		1	18	1	4	1.6	-3.8	-0.8	1547.5	18.9	-2.1	5.225	1
45309	2024		1	18	2	4	1.1	-4.7	-0.9	1530.4	18.9	-2.4	4.55	1
45309</														

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLag	Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLag	Weekdays	
45309	2024		1	18	12	4	-3.5	-3.9	-3.8	1804.5	18.9	-5.2	-1.8	1
45309	2024		1	18	13	4	-3.7	-4.1	-4.7	1801.1	18.9	-5.2	-2.08333	1
45309	2024		1	18	14	4	-3.8	-4	-5.2	1783.7	18.9	-5.3	-2.36667	1
45309	2024		1	18	15	4	-3.9	-3.9	-5.1	1776.3	18.9	-5.2	-2.69167	1
45309	2024		1	18	16	4	-4.1	-3.2	-5.6	1804.9	18.9	-5.1	-3.05	1
45309	2024		1	18	17	4	-4.1	-3.9	-5.7	1892.0	18.9	-4.9	-3.34167	1
45309	2024		1	18	18	4	-4.2	-3.9	-6.2	1976.9	18.9	-4.8	-3.7	1
45309	2024		1	18	19	4	-4.3	-4.6	-6.2	1966.4	18.9	-4.6	-4	1
45309	2024		1	18	20	4	-4.4	-4.9	-6.3	1931.6	18.9	-4.5	-4.3	1
45309	2024		1	18	21	4	-4.5	-5.2	-5.4	1889.0	18.9	-4.4	-4.60833	1
45309	2024		1	18	22	4	-4.6	-4.9	-4.7	1812.0	18.9	-4.3	-4.9	1
45309	2024		1	18	23	4	-4.7	-4.1	-3.9	1719.6	18.9	-4.3	-5.08333	1
45309	2024		1	18	24	4	-4.7	-3.9	-4.1	1680.6	18.9	-4.2	-5.21667	1
45310	2024		1	19	1	5	-4.7	-4	-4	1647.4	15.8	-4.2	-5.23333	1
45310	2024		1	19	2	5	-4.7	-4	-3.9	1616.2	15.8	-4.2	-5.25833	1
45310	2024		1	19	3	5	-4.7	-4.1	-3.2	1599.3	15.8	-4.2	-5.2	1
45310	2024		1	19	4	5	-4.7	-4.9	-3.9	1590.5	15.8	-4.2	-5.09167	1
45310	2024		1	19	5	5	-4.7	-4.8	-3.9	1601.1	15.8	-4.4	-4.93333	1
45310	2024		1	19	6	5	-4.6	-4.6	-4.6	1657.6	15.8	-4.4	-4.79167	1
45310	2024		1	19	7	5	-4.6	-4.6	-4.9	1789.6	15.8	-4.5	-4.64167	1
45310	2024		1	19	8	5	-4.5	-4.8	-5.2	1897.8	15.8	-4.5	-4.50833	1
45310	2024		1	19	9	5	-4.4	-5.5	-4.9	1925.1	15.8	-4.5	-4.4	1
45310	2024		1	19	10	5	-4.4	-5.3	-4.1	1860.8	15.8	-4.5	-4.30833	1
45310	2024		1	19	11	5	-4.4	-4.6	-3.9	1777.4	15.8	-4.6	-4.26667	1
45310	2024		1	19	12	5	-4.4	-3.4	-4	1729.7	15.8	-4.6	-4.21667	1
45310	2024		1	19	13	5	-4.4	-2.8	-4	1694.7	15.8	-4.6	-4.21667	1
45310	2024		1	19	14	5	-4.3	-2.3	-4.1	1655.4	15.8	-4.5	-4.20833	1
45310	2024		1	19	15	5	-4.3	-2	-4.9	1639.8	15.8	-4.3	-4.20833	1
45310	2024		1	19	16	5	-4.2	-1.7	-4.8	1668.8	15.8	-4.1	-4.225	1
45310	2024		1	19	17	5	-4.1	-2.8	-4.6	1769.5	15.8	-3.9	-4.36667	1
45310	2024		1	19	18	5	-4.1	-3.3	-4.6	1861.8	15.8	-3.7	-4.44167	1
45310	2024		1	19	19	5	-4.0	-3.8	-4.8	1852.0	15.8	-3.6	-4.5	1
45310	2024		1	19	20	5	-4.0	-4.3	-5.5	1813.3	15.8	-3.5	-4.5	1
45310	2024		1	19	21	5	-4.0	-4.8	-5.3	1781.7	15.8	-3.5	-4.49167	1
45310	2024		1	19	22	5	-4.0	-5.7	-4.6	1739.7	15.8	-3.4	-4.51667	1
45310	2024		1	19	23	5	-4.0	-6.2	-3.4	1679.5	15.8	-3.5	-4.55	1
45310	2024		1	19	24	5	-4.1	-6.9	-2.8	1668.4	15.8	-3.6	-4.59167	1
45311	2024		1	20	1	6	-4.2	-7.9	-2.3	1639.0	11.4	-3.9	-4.55	0
45311	2024		1	20	2	6	-4.4	-8.8	-2	1612.3	11.4	-4.3	-4.45	0
45311	2024		1	20	3	6	-4.6	-9	-1.7	1585.1	11.4	-4.9	-4.30833	0
45311	2024		1	20	4	6	-4.8	-9	-2.8	1576.6	11.4	-5.4	-4.13333	0
45311	2024		1	20	5	6	-5.0	-9.2	-3.3	1584.0	11.4	-6.0	-3.86667	0
45311	2024		1	20	6	6	-5.1	-9.1	-3.8	1607.8	11.4	-6.6	-3.7	0
45311	2024		1	20	7	6	-5.3	-8.7	-4.3	1663.1	11.4	-7.1	-3.59167	0
45311	2024		1	20	8	6	-5.5	-8.2	-4.8	1738.6	11.4	-7.5	-3.525	0
45311	2024		1	20	9	6	-5.6	-8.1	-5.7	1825.8	11.4	-7.8	-3.48333	0
45311	2024		1	20	10	6	-5.7	-7.4	-6.2	1877.0	11.4	-8.1	-3.425	0
45311	2024		1	20	11	6	-5.8	-6.6	-6.9	1856.1	11.4	-8.2	-3.45833	0
45311	2024		1	20	12	6	-5.9	-5.5	-7.9	1842.2	11.4	-8.2	-3.59167	0
45311	2024		1	20	13	6	-6.0	-4.2	-8.8	1799.3	11.4	-8.1	-3.88333	0
45311	2024		1	20	14	6	-6.1	-3.4	-9	1753.0	11.4	-7.8	-4.30833	0
45311	2024		1	20	15	6	-6.1	-2.7	-9	1729.6	11.4	-7.4	-4.85	0
45311	2024		1	20	16	6	-6.1	-2.4	-9.2	1749.3	11.4	-6.8	-5.43333	0
45311	2024		1	20	17	6	-6.2	-2.7	-9.1	1798.0	11.4	-6.3	-6.04167	0
45311	2024		1	20	18	6	-6.2	-2.7	-8.7	1848.2	11.4	-5.8	-6.575	0
45311	2024		1	20	19	6	-6.1	-2.6	-8.2	1800.7	11.4	-5.2	-7.05833	0
45311	2024		1	20	20	6	-6.1	-2.6	-8.1	1751.1	11.4	-4.7	-7.46667	0
45311	2024		1	20	21	6	-6.0	-2.6	-7.4	1700.9	11.4	-4.2	-7.79167	0
45311	2024		1	20	22	6	-5.9	-2.5	-6.6	1640.5	11.4	-3.8	-8.06667	0
45311	2024		1	20	23	6	-5.8	-2.6	-5.5	1567.9	11.4	-3.4	-8.20833	0
45311	2024		1	20	24	6	-5.6	-2.7	-4.2	1504.4	11.4	-3.0	-8.24167	0
45312	2024		1	21	1	7	-5.5	-2.5	-3.4	1453.0	16.9	-2.8	-8.125	0
45312	2024		1	21	2	7	-5.2	-2.5	-2.7	1416.0	16.9	-2.7	-7.81667	0
45312	2024		1	21	3	7	-5.0	-2.7	-2.4	1399.7	16.9	-2.6	-7.36667	0
45312	2024		1	21	4	7	-4.7	-3.3	-2.7	1401.6	16.9	-2.6	-6.84167	0
45312	2024		1	21	5	7	-4.5	-3.3	-2.7	1408.5	16.9	-2.7	-6.29167	0
45312	2024		1	21	6	7	-4.2	-2.7	-2.6	1431.7	16.9	-2.7	-5.75	0
45312	2024		1	21	7	7	-4.0	-2.4	-2.6	1480.3	16.9	-2.7	-5.21667	0
45312	2024		1	21	8	7	-3.7	-2.3	-2.6	1540.1	16.9	-2.7	-4.70833	0
45312	2024		1	21	9	7	-3.5	-2.3	-2.5	1622.8	16.9	-2.7	-4.24167	0
45312	2024		1	21	10	7	-3.2	-1.7	-2.6	1688.3	16.9	-2.7	-3.78333	0
45312	2024		1	21	11	7	-3.0	-0.9	-2.7	1697.4	16.9	-2.6	-3.375	0
45312	2024		1	21	12	7	-2.7	0.5	-2.5	1684.2	16.9	-2.4	-3.04167	0
45312	2024		1	21	13	7	-2.5	-0.1	-2.5	1704.2	16.9	-2.2	-2.80833	0
45312	2024		1	21	14	7	-2.3	-0.3	-2.7	1688.4	16.9	-2.0	-2.66667	0
45312	2024		1	21	15	7	-2.2	-0.3	-3.3	1675.9	16.9	-1.8	-2.59167	0
45312	2024		1	21	16	7	-2.1	-0.9	-3.3	1699.9	16.9	-1.6	-2.59167	0
45312	2024		1	21	17	7	-2.0	-1.1	-2.7	1780.7	16.9	-1.4	-2.66667	0
45312	2024		1	21	18	7	-2.0	-1.2	-2.4	1850.4	16.9	-1.2	-2.71667	0
45312	2024		1	21	19	7	-1.9	-1.3	-2.3	1823.2	16.9	-1.1	-2.71667	0
45312	2024		1	21	20	7	-1.8	-1.9	-2.3	1793.2	16.9	-1.0	-2.7	0
45312	2024		1	21	21	7	-1.8	-2.2	-1.7	1748.6	16.9	-1.0	-2.675	0
45312	2024		1	21	22	7	-1.8	-2.4	-0.9	1684.0	16.9	-1.0	-2.65	0
45312	2024		1	21	23	7	-1.8	-2.7	0.5	1593.3	16.9	-1.0	-2.58333	0
45312	2024		1	21	24	7	-1.8	-2.8	-0.1	1522.1	16.9	-1.2	-2.44167	0
45313	2024		1	22	1	1	-1.8	-3.8	-0.3	1480.4	14.0	-1.4	-2.175	1
45313	2024		1	22	2	1	-1.9	-4.5	-0.3	1464.2	14.0	-1.7	-1.975	1
45313	2024		1	22	3	1	-1.9	-5.2	-0.9	1468.9	14.0	-2.1	-1.79167	1
45313	2024		1	22	4	1	-2.0	-6	-1.1	1482.0	14.0	-2.5	-1.59167	1
45313	2024		1	22	5	1	-2.2	-6.8	-1.2	1513.5	14.0	-2.9	-1.39167	1
45313	2024		1	22	6	1	-2.3	-7.5	-1.3	1592.3	14.0	-3.4	-1.20833	1
45313	2024		1	22	7	1	-2.5	-8	-1.9	1753.8	14.0	-3.9	-1.08333	1
45313	2024		1	22	8	1	-2.7	-8.3	-2.2	1881.9	14.0	-4.5	-0.99167	1
45313	2024		1	22	9	1	-3.0	-8.1	-2.4	1910.2	14.0	-5.0	-0.95833	1
45313	2024		1	22	10	1	-3.2	-7.6	-2.7	1844.6	14.0	-5.5	-0.95	1
45313	2024		1	22	11	1	-3.5	-6.1	-2.8	1766.4	14.0	-5.9	-1.00833	1
45313	2024		1	22	12	1	-3.7	-4.1	-3.8	1698.6	14.0	-6.2	-1.15833	1
45313	2024		1	22	13	1	-3.9	-2.5	-4.5	1642.3	14.0	-6.3	-1.43333	1
45313	2024		1	22	14	1	-4.0	-0.8	-5.2	1578.7	14.0	-6.2	-1.74167	1
45313														

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLag	Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLag	Weekdays	
45313	2024		1	22	24	1	-3.0	0.8	-2.5	1454.4	14.0	0.3	-6.225	1
45314	2024		1	23	1	2	-2.8	1	-0.8	1409.3	18.1	0.7	-6.33333	1
45314	2024		1	23	2	2	-2.6	1.3	1.1	1363.1	18.1	1.0	-6.225	1
45314	2024		1	23	3	2	-2.4	1.5	1.9	1331.1	18.1	1.2	-5.91667	1
45314	2024		1	23	4	2	-2.1	1.5	1.6	1315.9	18.1	1.2	-5.39167	1
45314	2024		1	23	5	2	-1.8	1.8	1.3	1314.5	18.1	1.2	-4.73333	1
45314	2024		1	23	6	2	-1.4	2.1	1.3	1364.4	18.1	1.2	-4.03333	1
45314	2024		1	23	7	2	-1.0	2.4	1.1	1490.6	18.1	1.2	-3.3	1
45314	2024		1	23	8	2	-0.6	2.6	1.1	1600.8	18.1	1.3	-2.525	1
45314	2024		1	23	9	2	-0.1	2.4	0.7	1632.7	18.1	1.5	-1.74167	1
45314	2024		1	23	10	2	0.3	2.2	0.6	1601.4	18.1	1.6	-0.975	1
45314	2024		1	23	11	2	0.7	2.4	0.8	1555.8	18.1	1.7	-0.28333	1
45314	2024		1	23	12	2	1.1	2.8	1	1535.2	18.1	1.8	0.275	1
45314	2024		1	23	13	2	1.3	3.4	1.3	1531.2	18.1	2.0	0.683333	1
45314	2024		1	23	14	2	1.6	2.7	1.5	1519.4	18.1	2.2	0.975	1
45314	2024		1	23	15	2	1.7	2.7	1.5	1520.3	18.1	2.3	1.15	1
45314	2024		1	23	16	2	1.8	2.4	1.8	1555.5	18.1	2.4	1.183333	1
45314	2024		1	23	17	2	1.8	1.9	2.1	1663.2	18.1	2.5	1.15	1
45314	2024		1	23	18	2	1.8	0.7	2.4	1793.0	18.1	2.5	1.166667	1
45314	2024		1	23	19	2	1.8	-0.8	2.6	1807.0	18.1	2.4	1.233333	1
45314	2024		1	23	20	2	1.7	-2.5	2.4	1799.0	18.1	2.1	1.325	1
45314	2024		1	23	21	2	1.6	-3.6	2.2	1774.9	18.1	1.7	1.45	1
45314	2024		1	23	22	2	1.4	-4.7	2.4	1717.9	18.1	1.2	1.558333	1
45314	2024		1	23	23	2	1.2	-5.3	2.8	1653.6	18.1	0.6	1.683333	1
45314	2024		1	23	24	2	0.9	-6.1	3.4	1630.1	18.1	0.0	1.833333	1
45315	2024		1	24	1	3	0.6	-6.8	2.7	1616.6	10.5	-0.8	2	1
45315	2024		1	24	2	3	0.3	-7.9	2.7	1605.8	10.5	-1.6	2.2	1
45315	2024		1	24	3	3	-0.1	-8.9	2.4	1599.1	10.5	-2.5	2.316667	1
45315	2024		1	24	4	3	-0.5	-9.6	1.9	1607.1	10.5	-3.5	2.416667	1
45315	2024		1	24	5	3	-1.0	-10.2	0.7	1636.9	10.5	-4.5	2.491667	1
45315	2024		1	24	6	3	-1.5	-10.8	-0.8	1710.0	10.5	-5.5	2.5	1
45315	2024		1	24	7	3	-2.0	-11.1	-2.5	1858.5	10.5	-6.4	2.383333	1
45315	2024		1	24	8	3	-2.6	-11.3	-3.6	1979.3	10.5	-7.3	2.116667	1
45315	2024		1	24	9	3	-3.2	-11.6	-4.7	1987.5	10.5	-8.0	1.691667	1
45315	2024		1	24	10	3	-3.8	-10.5	-5.3	1918.6	10.5	-8.7	1.191667	1
45315	2024		1	24	11	3	-4.3	-8.4	-6.1	1862.0	10.5	-9.2	0.616667	1
45315	2024		1	24	12	3	-4.7	-7.4	-6.8	1837.8	10.5	-9.4	-0.025	1
45315	2024		1	24	13	3	-5.2	-6.8	-7.9	1810.8	10.5	-9.5	-0.76667	1
45315	2024		1	24	14	3	-5.6	-5.7	-8.9	1755.5	10.5	-9.5	-1.61667	1
45315	2024		1	24	15	3	-5.9	-5.5	-9.6	1718.4	10.5	-9.4	-2.5	1
45315	2024		1	24	16	3	-6.3	-4.5	-10.2	1741.0	10.5	-9.1	-3.46667	1
45315	2024		1	24	17	3	-6.6	-4.8	-10.8	1826.2	10.5	-8.7	-4.46667	1
45315	2024		1	24	18	3	-6.8	-5	-11.1	1924.4	10.5	-8.2	-5.475	1
45315	2024		1	24	19	3	-7.1	-4.7	-11.3	1904.0	10.5	-7.7	-6.43333	1
45315	2024		1	24	20	3	-7.2	-3.8	-11.6	1859.0	10.5	-7.2	-7.29167	1
45315	2024		1	24	21	3	-7.3	-3.1	-10.5	1795.0	10.5	-6.6	-8.025	1
45315	2024		1	24	22	3	-7.3	-2.6	-8.4	1715.0	10.5	-5.9	-8.69167	1
45315	2024		1	24	23	3	-7.2	-2	-7.4	1611.8	10.5	-5.2	-9.175	1
45315	2024		1	24	24	3	-7.0	-1.4	-6.8	1565.5	10.5	-4.7	-9.43333	1
45316	2024		1	25	1	4	-6.9	-0.8	-5.7	1519.0	13.9	-4.2	-9.54167	1
45316	2024		1	25	2	4	-6.6	-0.1	-5.5	1464.8	13.9	-3.7	-9.54167	1
45316	2024		1	25	3	4	-6.3	0.5	-4.5	1417.2	13.9	-3.2	-9.35833	1
45316	2024		1	25	4	4	-5.9	1.1	-4.8	1396.3	13.9	-2.7	-9.075	1
45316	2024		1	25	5	4	-5.4	0.8	-5	1397.3	13.9	-2.2	-8.65	1
45316	2024		1	25	6	4	-5.0	0.5	-4.7	1442.7	13.9	-1.8	-8.2	1
45316	2024		1	25	7	4	-4.5	0.3	-3.8	1557.5	13.9	-1.3	-7.71667	1
45316	2024		1	25	8	4	-4.0	0.4	-3.1	1655.1	13.9	-0.9	-7.18333	1
45316	2024		1	25	9	4	-3.5	0.9	-2.6	1683.2	13.9	-0.5	-6.55833	1
45316	2024		1	25	10	4	-3.0	0.6	-2	1688.5	13.9	-0.2	-5.85	1
45316	2024		1	25	11	4	-2.6	0.7	-1.4	1664.4	13.9	0.1	-5.19167	1
45316	2024		1	25	12	4	-2.2	1.1	-0.8	1641.0	13.9	0.3	-4.65833	1
45316	2024		1	25	13	4	-1.8	2.1	-0.1	1622.3	13.9	0.5	-4.15833	1
45316	2024		1	25	14	4	-1.5	3	0.5	1567.3	13.9	0.7	-3.65833	1
45316	2024		1	25	15	4	-1.1	3.7	1.1	1539.2	13.9	1.0	-3.19167	1
45316	2024		1	25	16	4	-0.7	3.9	0.8	1570.1	13.9	1.3	-2.69167	1
45316	2024		1	25	17	4	-0.4	2.9	0.5	1637.8	13.9	1.5	-2.225	1
45316	2024		1	25	18	4	0.0	1.8	0.3	1710.8	13.9	1.7	-1.75833	1
45316	2024		1	25	19	4	0.2	0.8	0.4	1696.1	13.9	1.8	-1.3	1
45316	2024		1	25	20	4	0.5	0.7	0.9	1666.4	13.9	1.8	-0.88333	1
45316	2024		1	25	21	4	0.7	0.3	0.6	1634.5	13.9	1.9	-0.53333	1
45316	2024		1	25	22	4	0.8	0	0.7	1579.4	13.9	1.8	-0.2	1
45316	2024		1	25	23	4	0.9	-1	1.1	1506.7	13.9	1.8	0.066667	1
45316	2024		1	25	24	4	1.0	-1.7	2.1	1484.5	13.9	1.6	0.291667	1
45317	2024		1	26	1	5	0.9	-2.3	3	1460.3	9.7	1.4	0.5	1
45317	2024		1	26	2	5	0.9	-2.7	3.7	1435.9	9.7	1.0	0.741667	1
45317	2024		1	26	3	5	0.8	-2.9	3.9	1422.1	9.7	0.5	1	1
45317	2024		1	26	4	5	0.6	-3.5	2.9	1425.2	9.7	0.0	1.266667	1
45317	2024		1	26	5	5	0.4	-3.8	1.8	1455.2	9.7	-0.6	1.5	1
45317	2024		1	26	6	5	0.2	-4	0.8	1523.5	9.7	-1.2	1.675	1
45317	2024		1	26	7	5	0.1	-4.7	0.7	1665.9	9.7	-1.7	1.783333	1
45317	2024		1	26	8	5	-0.2	-4.8	0.3	1780.9	9.7	-2.1	1.825	1
45317	2024		1	26	9	5	-0.4	-4.3	0	1814.3	9.7	-2.6	1.85	1
45317	2024		1	26	10	5	-0.6	-3.9	-1	1807.3	9.7	-3.0	1.8	1
45317	2024		1	26	11	5	-0.8	-3.2	-1.7	1793.6	9.7	-3.3	1.75	1
45317	2024		1	26	12	5	-0.9	-2.8	-2.3	1799.6	9.7	-3.5	1.608333	1
45317	2024		1	26	13	5	-1.1	-2.5	-2.7	1803.4	9.7	-3.6	1.375	1
45317	2024		1	26	14	5	-1.3	-0.4	-2.9	1775.5	9.7	-3.6	1.008333	1
45317	2024		1	26	15	5	-1.4	-0.3	-3.5	1748.1	9.7	-3.4	0.533333	1
45317	2024		1	26	16	5	-1.6	0	-3.8	1749.7	9.7	-3.2	-0.01667	1
45317	2024		1	26	17	5	-1.8	0.2	-4	1772.9	9.7	-2.9	-0.63333	1
45317	2024		1	26	18	5	-1.9	0.1	-4.7	1816.5	9.7	-2.6	-1.19167	1
45317	2024		1	26	19	5	-1.9	0	-4.8	1781.4	9.7	-2.2	-1.675	1
45317	2024		1	26	20	5	-2.0	-0.2	-4.3	1735.1	9.7	-1.8	-2.13333	1
45317	2024		1	26	21	5	-2.0	-0.3	-3.9	1688.3	9.7	-1.4	-2.59167	1
45317	2024		1	26	22	5	-2.0	-1	-3.2	1615.0	9.7	-1.1	-2.975	1
45317	2024		1	26	23	5	-2.1	-1.2	-2.8	1537.5	9.7	-0.9	-3.3	1
45317	2024		1	26	24	5	-2.1	-1.2	-2.5	1514.2	9.7	-0.7	-3.48333	1
45318	2024		1	27	1	6	-2.1	-1.1	-0.4	1482.8	10.1	-0.6	-3.575	0
45318	2024		1	27	2	6	-2.0	-1	-0.3	1445.6	10.1	-0.5	-3.59167	0
45318	2024		1	27										

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLa	g Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLa	g Weekdays	
45318	2024		1	27	12	6	-0.7	0.4	-1.1	1688.7	10.1	-0.8	-0.7	0
45318	2024		1	27	13	6	-0.6	1	-1	1657.9	10.1	-0.7	-0.56667	0
45318	2024		1	27	14	6	-0.5	1.3	-0.8	1629.3	10.1	-0.5	-0.45	0
45318	2024		1	27	15	6	-0.4	1.2	-0.5	1615.5	10.1	-0.3	-0.5	0
45318	2024		1	27	16	6	-0.3	1.1	-0.7	1624.6	10.1	-0.1	-0.54167	0
45318	2024		1	27	17	6	-0.3	0.6	-0.9	1680.5	10.1	0.0	-0.58333	0
45318	2024		1	27	18	6	-0.3	0.4	-0.8	1748.1	10.1	0.1	-0.65833	0
45318	2024		1	27	19	6	-0.3	0.3	-0.8	1721.5	10.1	0.2	-0.74167	0
45318	2024		1	27	20	6	-0.2	0.1	-0.8	1671.1	10.1	0.3	-0.80833	0
45318	2024		1	27	21	6	-0.2	0	-0.6	1624.6	10.1	0.4	-0.85833	0
45318	2024		1	27	22	6	-0.2	-0.4	-0.2	1559.9	10.1	0.5	-0.9	0
45318	2024		1	27	23	6	-0.2	-0.5	0.4	1487.0	10.1	0.5	-0.86667	0
45318	2024		1	27	24	6	-0.2	-1.1	1	1424.7	10.1	0.5	-0.78333	0
45319	2024		1	28	1	7	-0.2	-0.7	1.3	1370.8	5.7	0.3	-0.65	0
45319	2024		1	28	2	7	-0.1	-0.3	1.2	1340.7	5.7	0.2	-0.475	0
45319	2024		1	28	3	7	-0.1	-0.3	1.1	1325.3	5.7	0.1	-0.28333	0
45319	2024		1	28	4	7	-0.1	-0.4	0.6	1325.6	5.7	-0.1	-0.11667	0
45319	2024		1	28	5	7	-0.1	-0.4	0.4	1325.7	5.7	-0.2	0.016667	0
45319	2024		1	28	6	7	-0.1	-0.3	0.3	1344.6	5.7	-0.3	0.125	0
45319	2024		1	28	7	7	-0.1	-0.1	0.1	1394.3	5.7	-0.3	0.233333	0
45319	2024		1	28	8	7	0.0	-0.1	0	1462.7	5.7	-0.4	0.325	0
45319	2024		1	28	9	7	0.0	0.1	-0.4	1552.5	5.7	-0.4	0.4	0
45319	2024		1	28	10	7	0.0	0.3	-0.5	1620.0	5.7	-0.4	0.466667	0
45319	2024		1	28	11	7	0.1	0.3	-1.1	1646.9	5.7	-0.3	0.483333	0
45319	2024		1	28	12	7	0.1	0.9	-0.7	1646.4	5.7	-0.3	0.458333	0
45319	2024		1	28	13	7	0.1	1.4	-0.3	1639.8	5.7	-0.1	0.333333	0
45319	2024		1	28	14	7	0.1	1.2	-0.3	1611.2	5.7	0.1	0.191667	0
45319	2024		1	28	15	7	0.1	1.3	-0.4	1593.0	5.7	0.2	0.058333	0
45319	2024		1	28	16	7	0.1	0.5	-0.4	1612.4	5.7	0.4	-0.06667	0
45319	2024		1	28	17	7	0.1	0.6	-0.3	1675.8	5.7	0.4	-0.19167	0
45319	2024		1	28	18	7	0.1	0.8	-0.1	1740.6	5.7	0.5	-0.275	0
45319	2024		1	28	19	7	0.1	0.6	-0.1	1721.4	5.7	0.6	-0.33333	0
45319	2024		1	28	20	7	0.1	0.5	0.1	1679.9	5.7	0.7	-0.36667	0
45319	2024		1	28	21	7	0.2	0.3	0.3	1623.1	5.7	0.7	-0.38333	0
45319	2024		1	28	22	7	0.2	0.2	0.3	1547.0	5.7	0.7	-0.375	0
45319	2024		1	28	23	7	0.2	0.2	0.9	1456.2	5.7	0.7	-0.31667	0
45319	2024		1	28	24	7	0.2	-0.1	1.4	1379.4	5.7	0.7	-0.25	0
45320	2024		1	29	1	1	0.3	-0.1	1.2	1321.1	25.2	0.6	-0.08333	1
45320	2024		1	29	2	1	0.3	-0.2	1.3	1294.9	25.2	0.5	0.091667	1
45320	2024		1	29	3	1	0.3	-0.4	0.5	1286.5	25.2	0.4	0.216667	1
45320	2024		1	29	4	1	0.3	-0.5	0.6	1299.9	25.2	0.2	0.35	1
45320	2024		1	29	5	1	0.3	-0.6	0.8	1334.6	25.2	0.2	0.425	1
45320	2024		1	29	6	1	0.3	-0.9	0.6	1388.7	25.2	0.1	0.508333	1
45320	2024		1	29	7	1	0.3	-1.1	0.5	1491.0	25.2	-0.1	0.6	1
45320	2024		1	29	8	1	0.2	-1.3	0.3	1585.3	25.2	-0.2	0.658333	1
45320	2024		1	29	9	1	0.2	-1.5	0.2	1665.0	25.2	-0.4	0.708333	1
45320	2024		1	29	10	1	0.1	-1.6	0.2	1714.5	25.2	-0.5	0.725	1
45320	2024		1	29	11	1	0.0	-1.7	-0.1	1740.6	25.2	-0.7	0.716667	1
45320	2024		1	29	12	1	-0.1	-1.6	-0.1	1749.7	25.2	-0.8	0.708333	1
45320	2024		1	29	13	1	-0.2	-1.2	-0.2	1766.0	25.2	-1.0	0.625	1
45320	2024		1	29	14	1	-0.3	-0.8	-0.4	1740.9	25.2	-1.1	0.5	1
45320	2024		1	29	15	1	-0.4	-1	-0.5	1717.5	25.2	-1.1	0.383333	1
45320	2024		1	29	16	1	-0.5	-1.8	-0.6	1741.1	25.2	-1.2	0.241667	1
45320	2024		1	29	17	1	-0.6	-2.5	-0.9	1818.7	25.2	-1.3	0.158333	1
45320	2024		1	29	18	1	-0.7	-3.4	-1.1	1918.7	25.2	-1.4	0.058333	1
45320	2024		1	29	19	1	-0.9	-4.2	-1.3	1914.4	25.2	-1.6	-0.08333	1
45320	2024		1	29	20	1	-1.1	-4.9	-1.5	1888.0	25.2	-1.9	-0.225	1
45320	2024		1	29	21	1	-1.3	-5.8	-1.6	1847.4	25.2	-2.2	-0.375	1
45320	2024		1	29	22	1	-1.5	-6.3	-1.7	1777.7	25.2	-2.5	-0.525	1
45320	2024		1	29	23	1	-1.8	-6.6	-1.6	1699.1	25.2	-2.9	-0.675	1
45320	2024		1	29	24	1	-2.1	-6.9	-1.2	1677.5	25.2	-3.3	-0.83333	1
45321	2024		1	30	1	2	-2.4	-7	-0.8	1655.8	19.8	-3.8	-0.95833	1
45321	2024		1	30	2	2	-2.7	-7.3	-1	1637.5	19.8	-4.3	-1.05	1
45321	2024		1	30	3	2	-3.0	-7.6	-1.8	1616.8	19.8	-4.8	-1.1	1
45321	2024		1	30	4	2	-3.3	-7.5	-2.5	1616.4	19.8	-5.4	-1.15	1
45321	2024		1	30	5	2	-3.5	-7.5	-3.4	1628.7	19.8	-5.8	-1.25833	1
45321	2024		1	30	6	2	-3.8	-7.5	-4.2	1691.2	19.8	-6.3	-1.41667	1
45321	2024		1	30	7	2	-4.1	-7.3	-4.9	1812.9	19.8	-6.6	-1.625	1
45321	2024		1	30	8	2	-4.4	-7.3	-5.8	1904.1	19.8	-6.9	-1.88333	1
45321	2024		1	30	9	2	-4.6	-7.1	-6.3	1924.9	19.8	-7.1	-2.18333	1
45321	2024		1	30	10	2	-4.9	-6.5	-6.6	1893.7	19.8	-7.2	-2.54167	1
45321	2024		1	30	11	2	-5.1	-5.5	-6.9	1853.9	19.8	-7.2	-2.93333	1
45321	2024		1	30	12	2	-5.2	-4.7	-7	1834.6	19.8	-7.1	-3.34167	1
45321	2024		1	30	13	2	-5.3	-4.7	-7.3	1820.7	19.8	-6.9	-3.78333	1
45321	2024		1	30	14	2	-5.5	-4.6	-7.6	1785.3	19.8	-6.7	-4.26667	1
45321	2024		1	30	15	2	-5.6	-4.3	-7.5	1765.8	19.8	-6.5	-4.80833	1
45321	2024		1	30	16	2	-5.8	-3.9	-7.5	1788.6	19.8	-6.2	-5.35833	1
45321	2024		1	30	17	2	-5.9	-4.4	-7.5	1863.8	19.8	-5.9	-5.83333	1
45321	2024		1	30	18	2	-6.0	-5.3	-7.3	1964.7	19.8	-5.7	-6.25	1
45321	2024		1	30	19	2	-6.0	-5.7	-7.3	1964.1	19.8	-5.5	-6.59167	1
45321	2024		1	30	20	2	-6.1	-6.4	-7.1	1937.9	19.8	-5.3	-6.85	1
45321	2024		1	30	21	2	-6.2	-7.2	-6.5	1891.3	19.8	-5.3	-7.05	1
45321	2024		1	30	22	2	-6.2	-8.1	-5.5	1826.5	19.8	-5.3	-7.15833	1
45321	2024		1	30	23	2	-6.3	-8.4	-4.7	1746.4	19.8	-5.4	-7.175	1
45321	2024		1	30	24	2	-6.4	-9.6	-4.7	1720.9	19.8	-5.6	-7.08333	1
45322	2024		1	31	1	3	-6.5	-9	-4.6	1694.5	8.0	-6.1	-6.9	1
45322	2024		1	31	2	3	-6.6	-8.8	-4.3	1665.7	8.0	-6.4	-6.70833	1
45322	2024		1	31	3	3	-6.6	-8.5	-3.9	1644.3	8.0	-6.8	-6.48333	1
45322	2024		1	31	4	3	-6.7	-8.3	-4.4	1636.5	8.0	-7.1	-6.20833	1
45322	2024		1	31	5	3	-6.7	-7.9	-5.3	1645.2	8.0	-7.5	-5.90833	1
45322	2024		1	31	6	3	-6.7	-8.1	-5.7	1702.1	8.0	-7.8	-5.65	1
45322	2024		1	31	7	3	-6.7	-8.4	-6.4	1818.9	8.0	-8.0	-5.46667	1
45322	2024		1	31	8	3	-6.8	-8.5	-7.2	1923.7	8.0	-8.2	-5.33333	1
45322	2024		1	31	9	3	-6.8	-8.8	-8.1	1956.0	8.0	-8.4	-5.25833	1
45322	2024		1	31	10	3	-6.9	-8.5	-8.4	1929.4	8.0	-8.5	-5.26667	1
45322	2024		1	31	11	3	-7.0	-7.5	-9.6	1895.1	8.0	-8.6	-5.4	1
45322	2024		1	31	12	3	-7.1	-7.1	-9	1859.5	8.0	-8.5	-5.64167	1
45322	2024		1	31	13	3	-7.2	-6.5	-8.8	1814.0	8.0	-8.3	-6.05	1
45322	2024		1	31	14	3	-7.2	-5.1	-8.5	1729.9	8.0	-8.1	-6.40833	1
45322	2024		1											

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLa	gTemp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLa	gWeekdays	
45322	2024		1	31	24	3	-6.9	-5.5	-6.5	1665.7	8.0	-5.3	-8.49167	1
45323	2024		2	1	1	4	-6.7	-4.6	-5.1	1619.4	7.2	-5.2	-8.28333	1
45323	2024		2	1	2	4	-6.5	-3.8	-4.4	1571.7	7.2	-5.0	-8.075	1
45323	2024		2	1	3	4	-6.3	-3	-3.3	1537.6	7.2	-4.9	-7.76667	1
45323	2024		2	1	4	4	-6.1	-2.6	-3.5	1517.6	7.2	-4.8	-7.425	1
45323	2024		2	1	5	4	-5.9	-2.3	-4.2	1521.9	7.2	-4.7	-7.00833	1
45323	2024		2	1	6	4	-5.6	-2.1	-5.6	1576.7	7.2	-4.6	-6.64167	1
45323	2024		2	1	7	4	-5.4	-1.9	-6	1704.3	7.2	-4.5	-6.31667	1
45323	2024		2	1	8	4	-5.1	-1.8	-6.1	1804.0	7.2	-4.2	-6.08333	1
45323	2024		2	1	9	4	-4.8	-1.5	-6.3	1819.1	7.2	-3.8	-5.875	1
45323	2024		2	1	10	4	-4.5	-1.1	-5.6	1788.3	7.2	-3.4	-5.65	1
45323	2024		2	1	11	4	-4.2	-0.2	-5.5	1751.3	7.2	-3.0	-5.46667	1
45323	2024		2	1	12	4	-3.9	0.8	-4.6	1726.0	7.2	-2.5	-5.30833	1
45323	2024		2	1	13	4	-3.6	1.3	-3.8	1701.7	7.2	-2.0	-5.175	1
45323	2024		2	1	14	4	-3.3	1.3	-3	1670.3	7.2	-1.5	-5.01667	1
45323	2024		2	1	15	4	-3.0	1.6	-2.6	1647.3	7.2	-1.1	-4.90833	1
45323	2024		2	1	16	4	-2.8	1.7	-2.3	1655.3	7.2	-0.7	-4.79167	1
45323	2024		2	1	17	4	-2.5	1.5	-2.1	1693.2	7.2	-0.4	-4.73333	1
45323	2024		2	1	18	4	-2.3	0.8	-1.9	1752.3	7.2	0.0	-4.63333	1
45323	2024		2	1	19	4	-2.1	0.5	-1.8	1742.0	7.2	0.2	-4.45833	1
45323	2024		2	1	20	4	-1.9	0.5	-1.5	1703.3	7.2	0.4	-4.15	1
45323	2024		2	1	21	4	-1.6	0.8	-1.1	1653.2	7.2	0.6	-3.8	1
45323	2024		2	1	22	4	-1.3	0.5	-0.2	1576.4	7.2	0.8	-3.41667	1
45323	2024		2	1	23	4	-1.0	0.7	0.8	1480.7	7.2	0.9	-2.98333	1
45323	2024		2	1	24	4	-0.8	0.9	1.3	1440.1	7.2	1.0	-2.53333	1
45324	2024		2	2	1	5	-0.5	0.7	1.3	1402.4	10.5	1.0	-2.00833	1
45324	2024		2	2	2	5	-0.3	0.7	1.6	1362.9	10.5	1.0	-1.51667	1
45324	2024		2	2	3	5	-0.1	0.6	1.7	1331.3	10.5	0.9	-1.09167	1
45324	2024		2	2	4	5	0.1	0.8	1.5	1317.5	10.5	0.8	-0.70833	1
45324	2024		2	2	5	5	0.2	0.8	0.8	1325.1	10.5	0.8	-0.35	1
45324	2024		2	2	6	5	0.3	0.8	0.5	1375.9	10.5	0.7	-0.03333	1
45324	2024		2	2	7	5	0.5	0.6	0.5	1498.1	10.5	0.7	0.208333	1
45324	2024		2	2	8	5	0.6	0.5	0.8	1611.7	10.5	0.7	0.408333	1
45324	2024		2	2	9	5	0.7	0.8	0.5	1647.6	10.5	0.7	0.6	1
45324	2024		2	2	10	5	0.7	1.1	0.7	1649.8	10.5	0.7	0.791667	1
45324	2024		2	2	11	5	0.8	0.9	0.9	1641.7	10.5	0.8	0.925	1
45324	2024		2	2	12	5	0.9	0.7	0.7	1638.2	10.5	0.8	1	1
45324	2024		2	2	13	5	0.9	0.8	0.7	1640.6	10.5	0.8	1.008333	1
45324	2024		2	2	14	5	0.9	0.9	0.6	1630.3	10.5	0.8	0.958333	1
45324	2024		2	2	15	5	0.8	0.8	0.8	1620.8	10.5	0.8	0.908333	1
45324	2024		2	2	16	5	0.8	1	0.8	1631.8	10.5	0.8	0.825	1
45324	2024		2	2	17	5	0.8	0.8	0.8	1672.3	10.5	0.8	0.75	1
45324	2024		2	2	18	5	0.8	0.7	0.6	1727.7	10.5	0.8	0.691667	1
45324	2024		2	2	19	5	0.7	0.8	0.5	1707.6	10.5	0.8	0.691667	1
45324	2024		2	2	20	5	0.8	0.7	0.8	1658.7	10.5	0.8	0.7	1
45324	2024		2	2	21	5	0.8	0.4	1.1	1612.7	10.5	0.8	0.7	1
45324	2024		2	2	22	5	0.8	-0.1	0.9	1553.8	10.5	0.8	0.7	1
45324	2024		2	2	23	5	0.7	-0.3	0.7	1485.4	10.5	0.7	0.75	1
45324	2024		2	2	24	5	0.7	-0.5	0.8	1461.8	10.5	0.6	0.766667	1
45325	2024		2	3	1	6	0.6	-0.6	0.9	1437.1	30.8	0.5	0.75	0
45325	2024		2	3	2	6	0.6	-0.7	0.8	1402.1	30.8	0.4	0.758333	0
45325	2024		2	3	3	6	0.5	-0.9	1	1388.8	30.8	0.3	0.775	0
45325	2024		2	3	4	6	0.5	-1.5	0.8	1386.1	30.8	0.1	0.791667	0
45325	2024		2	3	5	6	0.4	-2	0.7	1402.5	30.8	-0.1	0.808333	0
45325	2024		2	3	6	6	0.2	-2.2	0.8	1430.4	30.8	-0.3	0.808333	0
45325	2024		2	3	7	6	0.1	-2.5	0.7	1485.9	30.8	-0.6	0.8	0
45325	2024		2	3	8	6	0.0	-2.7	0.4	1552.6	30.8	-0.9	0.816667	0
45325	2024		2	3	9	6	-0.2	-2.7	-0.1	1637.6	30.8	-1.1	0.833333	0
45325	2024		2	3	10	6	-0.3	-2.8	-0.3	1716.6	30.8	-1.4	0.8	0
45325	2024		2	3	11	6	-0.5	-2.6	-0.5	1755.2	30.8	-1.6	0.7	0
45325	2024		2	3	12	6	-0.6	-2.6	-0.6	1800.2	30.8	-1.8	0.6	0
45325	2024		2	3	13	6	-0.7	-2.5	-0.7	1798.5	30.8	-2.0	0.5	0
45325	2024		2	3	14	6	-0.9	-2.7	-0.9	1783.9	30.8	-2.1	0.383333	0
45325	2024		2	3	15	6	-1.0	-3	-1.5	1769.2	30.8	-2.3	0.25	0
45325	2024		2	3	16	6	-1.2	-3.1	-2	1788.9	30.8	-2.5	0.108333	0
45325	2024		2	3	17	6	-1.4	-3.4	-2.2	1843.5	30.8	-2.6	-0.1	0
45325	2024		2	3	18	6	-1.5	-3.6	-2.5	1900.9	30.8	-2.7	-0.33333	0
45325	2024		2	3	19	6	-1.7	-3.7	-2.7	1881.7	30.8	-2.9	-0.575	0
45325	2024		2	3	20	6	-1.9	-3.8	-2.7	1820.7	30.8	-3.0	-0.85	0
45325	2024		2	3	21	6	-2.1	-3.8	-2.8	1761.6	30.8	-3.0	-1.13333	0
45325	2024		2	3	22	6	-2.3	-3.9	-2.6	1700.5	30.8	-3.1	-1.39167	0
45325	2024		2	3	23	6	-2.4	-3.8	-2.6	1628.8	30.8	-3.2	-1.61667	0
45325	2024		2	3	24	6	-2.6	-3.9	-2.5	1575.5	30.8	-3.3	-1.80833	0
45326	2024		2	4	1	7	-2.7	-4.1	-2.7	1525.8	32.4	-3.4	-1.98333	0
45326	2024		2	4	2	7	-2.9	-4.3	-3	1499.0	32.4	-3.6	-2.14167	0
45326	2024		2	4	3	7	-3.0	-4.6	-3.1	1484.9	32.4	-3.7	-2.30833	0
45326	2024		2	4	4	7	-3.2	-4.5	-3.4	1480.5	32.4	-3.8	-2.48333	0
45326	2024		2	4	5	7	-3.3	-4.6	-3.6	1489.9	32.4	-4.0	-2.61667	0
45326	2024		2	4	6	7	-3.4	-4.3	-3.7	1512.0	32.4	-4.1	-2.73333	0
45326	2024		2	4	7	7	-3.5	-4.1	-3.8	1555.0	32.4	-4.1	-2.85	0
45326	2024		2	4	8	7	-3.5	-3.7	-3.8	1606.6	32.4	-4.1	-2.95	0
45326	2024		2	4	9	7	-3.6	-3.4	-3.9	1683.2	32.4	-4.1	-3.04167	0
45326	2024		2	4	10	7	-3.6	-3.2	-3.8	1756.4	32.4	-4.1	-3.13333	0
45326	2024		2	4	11	7	-3.6	-3.1	-3.9	1798.2	32.4	-4.0	-3.225	0
45326	2024		2	4	12	7	-3.7	-3	-4.1	1844.9	32.4	-4.0	-3.325	0
45326	2024		2	4	13	7	-3.7	-2.7	-4.3	1862.7	32.4	-3.9	-3.43333	0
45326	2024		2	4	14	7	-3.7	-2.8	-4.6	1849.4	32.4	-3.8	-3.56667	0
45326	2024		2	4	15	7	-3.7	-2.7	-4.5	1827.8	32.4	-3.7	-3.7	0
45326	2024		2	4	16	7	-3.7	-2.7	-4.6	1832.4	32.4	-3.5	-3.83333	0
45326	2024		2	4	17	7	-3.7	-2.7	-4.3	1871.8	32.4	-3.4	-3.95	0
45326	2024		2	4	18	7	-3.6	-2.8	-4.1	1931.9	32.4	-3.2	-4.05	0
45326	2024		2	4	19	7	-3.6	-2.9	-3.7	1894.6	32.4	-3.1	-4.10833	0
45326	2024		2	4	20	7	-3.6	-2.7	-3.4	1831.9	32.4	-3.0	-4.14167	0
45326	2024		2	4	21	7	-3.5	-2.5	-3.2	1760.2	32.4	-2.9	-4.13333	0
45326	2024		2	4	22	7	-3.5	-2.3	-3.1	1686.0	32.4	-2.8	-4.1	0
45326	2024		2	4	23	7	-3.4	-2.4	-3	1593.6	32.4	-2.7	-4.04167	0
45326	2024		2	4	24	7	-3.3	-2.1	-2.7	1516.5	32.4	-2.7	-3.98333	0
45327	2024		2	5	1	1	-3.3	-1.9	-2.8	1459.0	26.3	-2.6	-3.90833	1
45327	2024		2	5	2	1	-3.2	-1.8	-2.7	1423.4	26.3	-2.5	-3.79167	1
45327	2024		2	5	3	1	-3.1	-1.3	-2.7	1406.9	26.3	-2.5	-3.66667	1
45327	202													

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLag	Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLag	Weekdays
45327	2024	2	5	12	1	-1.7	1.5	-1.9	1631.0	26.3	-0.7	-2.68333	1
45327	2024	2	5	13	1	-1.5	1.5	-1.8	1644.7	26.3	-0.4	-2.60833	1
45327	2024	2	5	14	1	-1.3	1.8	-1.3	1620.2	26.3	-0.1	-2.54167	1
45327	2024	2	5	15	1	-1.1	1.7	-1	1603.7	26.3	0.2	-2.45833	1
45327	2024	2	5	16	1	-0.9	1.4	-1.1	1620.5	26.3	0.5	-2.34167	1
45327	2024	2	5	17	1	-0.8	1.2	-0.5	1673.0	26.3	0.7	-2.2	1
45327	2024	2	5	18	1	-0.6	1.1	-0.2	1739.8	26.3	0.8	-2.06667	1
45327	2024	2	5	19	1	-0.5	0.9	0	1730.6	26.3	1.0	-1.875	1
45327	2024	2	5	20	1	-0.3	0.8	0.1	1698.6	26.3	1.1	-1.65	1
45327	2024	2	5	21	1	-0.1	0.7	0.6	1650.6	26.3	1.1	-1.425	1
45327	2024	2	5	22	1	0.0	0.6	1	1576.8	26.3	1.2	-1.20833	1
45327	2024	2	5	23	1	0.1	0.4	1.5	1492.0	26.3	1.2	-0.96667	1
45327	2024	2	5	24	1	0.2	0	1.5	1457.5	26.3	1.1	-0.68333	1
45328	2024	2	6	1	2	0.3	0.2	1.8	1420.3	20.0	1.0	-0.38333	1
45328	2024	2	6	2	2	0.4	-0.1	1.7	1385.7	20.0	0.9	-0.1	1
45328	2024	2	6	3	2	0.5	0.2	1.4	1355.8	20.0	0.7	0.2	1
45328	2024	2	6	4	2	0.5	0.1	1.2	1339.8	20.0	0.6	0.45	1
45328	2024	2	6	5	2	0.6	0	1.1	1348.7	20.0	0.5	0.65	1
45328	2024	2	6	6	2	0.6	0	0.9	1406.5	20.0	0.4	0.841667	1
45328	2024	2	6	7	2	0.6	-0.1	0.8	1522.1	20.0	0.3	0.975	1
45328	2024	2	6	8	2	0.7	0	0.7	1616.2	20.0	0.2	1.066667	1
45328	2024	2	6	9	2	0.7	0.2	0.6	1653.9	20.0	0.2	1.133333	1
45328	2024	2	6	10	2	0.7	0.3	0.4	1654.1	20.0	0.1	1.183333	1
45328	2024	2	6	11	2	0.6	0.4	0	1649.9	20.0	0.1	1.183333	1
45328	2024	2	6	12	2	0.6	0.9	0.2	1630.6	20.0	0.1	1.133333	1
45328	2024	2	6	13	2	0.6	0.9	-0.1	1625.6	20.0	0.2	1.008333	1
45328	2024	2	6	14	2	0.6	1.4	0.2	1587.1	20.0	0.2	0.9	1
45328	2024	2	6	15	2	0.6	1.2	0.1	1587.3	20.0	0.4	0.741667	1
45328	2024	2	6	16	2	0.5	0.9	0	1611.8	20.0	0.4	0.616667	1
45328	2024	2	6	17	2	0.5	0.6	0	1673.4	20.0	0.5	0.508333	1
45328	2024	2	6	18	2	0.5	0.1	-0.1	1746.7	20.0	0.6	0.408333	1
45328	2024	2	6	19	2	0.4	-0.4	0	1757.1	20.0	0.6	0.316667	1
45328	2024	2	6	20	2	0.4	-0.5	0.2	1731.0	20.0	0.5	0.233333	1
45328	2024	2	6	21	2	0.3	-0.8	0.3	1688.3	20.0	0.5	0.166667	1
45328	2024	2	6	22	2	0.3	-1	0.4	1631.0	20.0	0.4	0.125	1
45328	2024	2	6	23	2	0.2	-1	0.9	1544.9	20.0	0.3	0.1	1
45328	2024	2	6	24	2	0.1	-1.2	0.9	1514.3	20.0	0.2	0.1	1
45329	2024	2	7	1	3	0.1	-1.5	1.4	1479.1	13.0	0.0	0.175	1
45329	2024	2	7	2	3	0.0	-1.7	1.2	1438.8	13.0	-0.2	0.233333	1
45329	2024	2	7	3	3	0.0	-1.7	0.9	1411.1	13.0	-0.4	0.358333	1
45329	2024	2	7	4	3	-0.1	-1.9	0.6	1401.3	13.0	-0.7	0.441667	1
45329	2024	2	7	5	3	-0.2	-2	0.1	1412.3	13.0	-0.9	0.508333	1
45329	2024	2	7	6	3	-0.3	-2.2	-0.4	1466.1	13.0	-1.1	0.558333	1
45329	2024	2	7	7	3	-0.4	-2.2	-0.5	1595.4	13.0	-1.3	0.566667	1
45329	2024	2	7	8	3	-0.5	-2.5	-0.8	1693.2	13.0	-1.5	0.541667	1
45329	2024	2	7	9	3	-0.6	-2.6	-1	1726.5	13.0	-1.6	0.5	1
45329	2024	2	7	10	3	-0.7	-2.5	-1	1716.9	13.0	-1.8	0.416667	1
45329	2024	2	7	11	3	-0.8	-2.4	-1.2	1694.7	13.0	-1.9	0.308333	1
45329	2024	2	7	12	3	-0.9	-1.9	-1.5	1680.1	13.0	-2.0	0.191667	1
45329	2024	2	7	13	3	-1.0	-1.5	-1.7	1654.8	13.0	-2.1	0.016667	1
45329	2024	2	7	14	3	-1.1	-0.8	-1.7	1599.9	13.0	-2.1	-0.18333	1
45329	2024	2	7	15	3	-1.2	-0.7	-1.9	1565.4	13.0	-2.0	-0.44167	1
45329	2024	2	7	16	3	-1.3	-0.4	-2	1602.0	13.0	-1.9	-0.68333	1
45329	2024	2	7	17	3	-1.4	-0.7	-2.2	1673.4	13.0	-1.8	-0.91667	1
45329	2024	2	7	18	3	-1.4	-1.4	-2.2	1751.0	13.0	-1.7	-1.13333	1
45329	2024	2	7	19	3	-1.5	-1.8	-2.5	1777.4	13.0	-1.6	-1.325	1
45329	2024	2	7	20	3	-1.5	-2.2	-2.6	1759.7	13.0	-1.6	-1.475	1
45329	2024	2	7	21	3	-1.6	-2.4	-2.5	1723.8	13.0	-1.6	-1.64167	1
45329	2024	2	7	22	3	-1.7	-2.5	-2.4	1672.6	13.0	-1.6	-1.79167	1
45329	2024	2	7	23	3	-1.7	-2.7	-1.9	1588.3	13.0	-1.6	-1.91667	1
45329	2024	2	7	24	3	-1.8	-2.9	-1.5	1550.8	13.0	-1.6	-2.03333	1
45330	2024	2	8	1	4	-1.9	-3.5	-0.8	1509.6	11.6	-1.7	-2.09167	1
45330	2024	2	8	2	4	-2.0	-3.7	-0.7	1475.0	11.6	-1.8	-2.09167	1
45330	2024	2	8	3	4	-2.0	-4.1	-0.4	1442.6	11.6	-2.1	-2.01667	1
45330	2024	2	8	4	4	-2.1	-4.5	-0.7	1439.6	11.6	-2.4	-1.93333	1
45330	2024	2	8	5	4	-2.3	-4.8	-1.4	1455.6	11.6	-2.7	-1.80833	1
45330	2024	2	8	6	4	-2.4	-4.9	-1.8	1516.1	11.6	-3.0	-1.7	1
45330	2024	2	8	7	4	-2.5	-4.9	-2.2	1643.8	11.6	-3.3	-1.63333	1
45330	2024	2	8	8	4	-2.6	-4.7	-2.4	1740.4	11.6	-3.6	-1.6	1
45330	2024	2	8	9	4	-2.7	-4.6	-2.5	1767.0	11.6	-3.8	-1.575	1
45330	2024	2	8	10	4	-2.8	-4.5	-2.7	1747.2	11.6	-4.0	-1.55833	1
45330	2024	2	8	11	4	-2.9	-3.4	-2.9	1673.5	11.6	-4.2	-1.55833	1
45330	2024	2	8	12	4	-2.9	-2.1	-3.5	1574.9	11.6	-4.2	-1.58333	1
45330	2024	2	8	13	4	-2.9	-1	-3.7	1519.6	11.6	-4.1	-1.66667	1
45330	2024	2	8	14	4	-2.9	0.3	-4.1	1458.0	11.6	-3.9	-1.83333	1
45330	2024	2	8	15	4	-2.8	1.5	-4.5	1419.0	11.6	-3.6	-2.075	1
45330	2024	2	8	16	4	-2.7	2.3	-4.8	1423.6	11.6	-3.1	-2.35833	1
45330	2024	2	8	17	4	-2.6	2.2	-4.9	1486.6	11.6	-2.6	-2.7	1
45330	2024	2	8	18	4	-2.5	1.5	-4.9	1613.2	11.6	-2.0	-3.04167	1
45330	2024	2	8	19	4	-2.4	-0.3	-4.7	1684.2	11.6	-1.5	-3.33333	1
45330	2024	2	8	20	4	-2.3	-1.4	-4.6	1689.2	11.6	-1.1	-3.59167	1
45330	2024	2	8	21	4	-2.3	-2.3	-4.5	1675.3	11.6	-0.8	-3.8	1
45330	2024	2	8	22	4	-2.3	-2.8	-3.4	1639.7	11.6	-0.6	-3.98333	1
45330	2024	2	8	23	4	-2.3	-3.5	-2.1	1581.2	11.6	-0.5	-4.15	1
45330	2024	2	8	24	4	-2.3	-4.2	-1	1561.4	11.6	-0.5	-4.20833	1
45331	2024	2	9	1	5	-2.4	-4.7	0.3	1542.5	6.3	-0.6	-4.14167	1
45331	2024	2	9	2	5	-2.4	-5	1.5	1522.1	6.3	-1.0	-3.93333	1
45331	2024	2	9	3	5	-2.5	-6.1	2.3	1505.0	6.3	-1.4	-3.6	1
45331	2024	2	9	4	5	-2.6	-6.5	2.2	1502.6	6.3	-2.0	-3.13333	1
45331	2024	2	9	5	5	-2.7	-6.5	1.5	1521.7	6.3	-2.8	-2.56667	1
45331	2024	2	9	6	5	-2.7	-6.1	-0.3	1583.7	6.3	-3.5	-1.98333	1
45331	2024	2	9	7	5	-2.8	-5.8	-1.4	1722.0	6.3	-4.1	-1.45	1
45331	2024	2	9	8	5	-2.8	-6.6	-2.3	1833.4	6.3	-4.6	-1.06667	1
45331	2024	2	9	9	5	-2.9	-6.8	-2.8	1850.3	6.3	-5.0	-0.79167	1
45331	2024	2	9	10	5	-3.0	-5.9	-3.5	1785.9	6.3	-5.4	-0.6	1
45331	2024	2	9	11	5	-3.1	-4.5	-4.2	1708.5	6.3	-5.6	-0.45833	1
45331	2024	2	9	12	5	-3.1	-3.2	-4.7	1604.5	6.3	-5.7	-0.46667	1
45331	2024	2	9	13	5	-3.1	-1.6	-5	1519.9	6.3	-5.6	-0.64167	1
45331	2024	2	9	14	5	-3.2	-0.4	-6.1	1455.0	6.3	-5.4	-0.95	1
45331	2024	2	9	15	5	-3.2	1.9	-6.5	1405.7	6.3	-5.0	-1.39167	1
45331	2024	2	9	16	5	-3.2	1.4	-6.5	1402.1	6.3	-4.3	-2.025	1
45331	2024	2	9	17	5	-3.2	0.5	-6.1	1465.7	6.3	-3.7	-2.75833	1
45331	2024	2	9	18	5	-3.3	-0.2	-5.8	1582.9	6.3	-3.1	-3.48333	1
45331	2024	2	9	19									

DATE	Year	Month	Day	HOUR	DOW	24hrAvgLa	g Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLa	g Weekdays	
45331	2024	2	9	24		5	-3.4	-2	-1.6	1475.5	6.3	-1.1	-5.725	1
45332	2024	2	10	1		6	-3.3	-1.7	-0.4	1441.5	7.5	-1.0	-5.64167	0
45332	2024	2	10	2		6	-3.2	-1.3	1.9	1402.6	7.5	-1.0	-5.38333	0
45332	2024	2	10	3		6	-3.0	-0.3	1.4	1373.3	7.5	-1.0	-5	0
45332	2024	2	10	4		6	-2.8	-0.8	0.5	1361.6	7.5	-1.2	-4.33333	0
45332	2024	2	10	5		6	-2.5	-1.4	-0.2	1372.8	7.5	-1.4	-3.675	0
45332	2024	2	10	6		6	-2.3	-1.7	-1.2	1416.5	7.5	-1.6	-3.09167	0
45332	2024	2	10	7		6	-2.1	-1.8	-2.8	1477.9	7.5	-1.7	-2.6	0
45332	2024	2	10	8		6	-2.0	-1.9	-3.2	1549.9	7.5	-1.7	-2.21667	0
45332	2024	2	10	9		6	-1.8	-0.1	-1.8	1593.5	7.5	-1.7	-1.9	0
45332	2024	2	10	10		6	-1.5	1	-2	1588.6	7.5	-1.4	-1.6	0
45332	2024	2	10	11		6	-1.2	1.8	-2	1557.7	7.5	-1.2	-1.25833	0
45332	2024	2	10	12		6	-1.0	2.6	-1.7	1500.6	7.5	-0.9	-1.05	0
45332	2024	2	10	13		6	-0.7	3	-1.3	1447.5	7.5	-0.5	-0.95	0
45332	2024	2	10	14		6	-0.5	3.5	-0.3	1384.8	7.5	-0.1	-0.95833	0
45332	2024	2	10	15		6	-0.4	3.9	-0.8	1334.9	7.5	0.3	-1.03333	0
45332	2024	2	10	16		6	-0.3	4	-1.4	1366.0	7.5	0.7	-1.21667	0
45332	2024	2	10	17		6	-0.2	3.7	-1.7	1434.5	7.5	1.1	-1.4	0
45332	2024	2	10	18		6	0.0	3.5	-1.8	1507.2	7.5	1.5	-1.55833	0
45332	2024	2	10	19		6	0.1	2.9	-1.9	1509.6	7.5	1.9	-1.68333	0
45332	2024	2	10	20		6	0.3	2.7	-0.1	1479.2	7.5	2.3	-1.73333	0
45332	2024	2	10	21		6	0.5	2.3	1	1432.3	7.5	2.7	-1.65833	0
45332	2024	2	10	22		6	0.8	2.5	1.8	1376.6	7.5	2.9	-1.4	0
45332	2024	2	10	23		6	0.9	2.2	2.6	1321.9	7.5	3.0	-1.16667	0
45332	2024	2	10	24		6	1.1	2.2	3	1272.1	7.5	3.1	-0.85	0
45333	2024	2	11	1		7	1.3	2	3.5	1223.9	6.2	3.0	-0.46667	0
45333	2024	2	11	2		7	1.4	1.6	3.9	1198.6	6.2	3.0	-0.075	0
45333	2024	2	11	3		7	1.6	1	4	1184.2	6.2	2.8	0.325	0
45333	2024	2	11	4		7	1.6	0.6	3.7	1182.3	6.2	2.6	0.675	0
45333	2024	2	11	5		7	1.7	0.5	3.5	1194.8	6.2	2.3	1.075	0
45333	2024	2	11	6		7	1.8	0.6	2.9	1216.6	6.2	2.0	1.5	0
45333	2024	2	11	7		7	1.8	1.4	2.7	1265.9	6.2	1.8	1.933333	0
45333	2024	2	11	8		7	2.0	1.2	2.3	1336.3	6.2	1.6	2.325	0
45333	2024	2	11	9		7	2.1	1.6	2.5	1391.7	6.2	1.5	2.708333	0
45333	2024	2	11	10		7	2.2	3.4	2.2	1416.8	6.2	1.5	2.908333	0
45333	2024	2	11	11		7	2.3	3.1	2.2	1408.2	6.2	1.5	3.033333	0
45333	2024	2	11	12		7	2.3	3.9	2	1386.7	6.2	1.6	3.066667	0
45333	2024	2	11	13		7	2.4	5.1	1.6	1349.2	6.2	1.7	3.033333	0
45333	2024	2	11	14		7	2.5	6.4	1	1300.2	6.2	2.0	2.95	0
45333	2024	2	11	15		7	2.6	6.6	0.6	1269.7	6.2	2.4	2.791667	0
45333	2024	2	11	16		7	2.7	7.4	0.5	1281.7	6.2	2.9	2.55	0
45333	2024	2	11	17		7	2.9	5.8	0.6	1358.7	6.2	3.4	2.266667	0
45333	2024	2	11	18		7	2.9	4.8	1.4	1462.5	6.2	3.9	2	0
45333	2024	2	11	19		7	3.0	3	1.2	1508.7	6.2	4.2	1.758333	0
45333	2024	2	11	20		7	3.0	2.7	1.6	1479.6	6.2	4.4	1.633333	0
45333	2024	2	11	21		7	3.0	2.6	3.4	1421.5	6.2	4.5	1.508333	0
45333	2024	2	11	22		7	3.0	2.8	3.1	1360.6	6.2	4.6	1.45	0
45333	2024	2	11	23		7	3.0	2.9	3.9	1304.0	6.2	4.5	1.525	0
45333	2024	2	11	24		7	3.1	1.5	5.1	1242.4	6.2	4.5	1.6	0
45334	2024	2	12	1		1	3.0	2	6.4	1202.8	7.2	4.3	1.741667	1
45334	2024	2	12	2		1	3.0	2.6	6.6	1167.5	7.2	4.0	2	1
45334	2024	2	12	3		1	3.1	1.8	7.4	1161.8	7.2	3.7	2.4	1
45334	2024	2	12	4		1	3.1	3	5.8	1158.8	7.2	3.3	2.866667	1
45334	2024	2	12	5		1	3.2	2.6	4.8	1176.7	7.2	3.0	3.433333	1
45334	2024	2	12	6		1	3.3	2.6	3	1239.7	7.2	2.7	3.875	1
45334	2024	2	12	7		1	3.4	2.3	2.7	1376.1	7.2	2.5	4.225	1
45334	2024	2	12	8		1	3.4	1.8	2.6	1501.0	7.2	2.5	4.358333	1
45334	2024	2	12	9		1	3.4	2.1	2.8	1496.8	7.2	2.4	4.483333	1
45334	2024	2	12	10		1	3.5	3.2	2.9	1426.3	7.2	2.3	4.566667	1
45334	2024	2	12	11		1	3.4	4.6	1.5	1369.7	7.2	2.4	4.516667	1
45334	2024	2	12	12		1	3.5	5.7	2	1331.7	7.2	2.5	4.5	1
45334	2024	2	12	13		1	3.6	7.5	2.6	1307.5	7.2	2.9	4.3	1
45334	2024	2	12	14		1	3.7	7.1	1.8	1278.1	7.2	3.3	4.041667	1
45334	2024	2	12	15		1	3.7	8.3	3	1261.9	7.2	3.7	3.725	1
45334	2024	2	12	16		1	3.8	7.8	2.6	1282.5	7.2	4.2	3.325	1
45334	2024	2	12	17		1	3.8	6.2	2.6	1358.8	7.2	4.6	2.958333	1
45334	2024	2	12	18		1	3.8	5.8	2.3	1462.6	7.2	4.9	2.691667	1
45334	2024	2	12	19		1	3.9	4.2	1.8	1522.9	7.2	5.2	2.508333	1
45334	2024	2	12	20		1	3.9	2.8	2.1	1517.0	7.2	5.4	2.45	1
45334	2024	2	12	21		1	3.9	1.7	3.2	1497.5	7.2	5.4	2.375	1
45334	2024	2	12	22		1	3.9	0.7	4.6	1453.9	7.2	5.4	2.333333	1
45334	2024	2	12	23		1	3.8	-0.1	5.7	1390.1	7.2	5.2	2.366667	1
45334	2024	2	12	24		1	3.7	0.1	7.5	1362.7	7.2	4.8	2.508333	1
45335	2024	2	13	1		2	3.6	0.3	7.1	1336.2	10.8	4.3	2.858333	1
45335	2024	2	13	2		2	3.5	-0.2	8.3	1303.7	10.8	3.7	3.316667	1
45335	2024	2	13	3		2	3.4	0.2	7.8	1277.3	10.8	3.1	3.691667	1
45335	2024	2	13	4		2	3.3	-1.9	6.2	1285.7	10.8	2.5	4.233333	1
45335	2024	2	13	5		2	3.1	-1.6	5.8	1308.8	10.8	1.7	4.633333	1
45335	2024	2	13	6		2	3.0	-1.8	4.2	1380.7	10.8	1.0	4.933333	1
45335	2024	2	13	7		2	2.8	-2.8	2.8	1521.5	10.8	0.4	5.2	1
45335	2024	2	13	8		2	2.6	-2.9	1.7	1629.9	10.8	-0.2	5.358333	1
45335	2024	2	13	9		2	2.4	-2.3	0.7	1621.7	10.8	-0.7	5.441667	1
45335	2024	2	13	10		2	2.2	1.4	-0.1	1540.6	10.8	-1.0	5.408333	1
45335	2024	2	13	11		2	2.1	2	0.1	1473.1	10.8	-1.0	5.2	1
45335	2024	2	13	12		2	2.0	2.6	0.3	1458.4	10.8	-0.8	4.808333	1
45335	2024	2	13	13		2	1.9	3.2	-0.2	1461.3	10.8	-0.6	4.341667	1
45335	2024	2	13	14		2	1.7	3.9	0.2	1435.8	10.8	-0.3	3.741667	1
45335	2024	2	13	15		2	1.6	2.3	-1.9	1463.2	10.8	0.0	3.133333	1
45335	2024	2	13	16		2	1.3	1.8	-1.6	1523.0	10.8	0.2	2.458333	1
45335	2024	2	13	17		2	1.1	1.4	-1.8	1608.6	10.8	0.5	1.65	1
45335	2024	2	13	18		2	0.9	0.1	-2.8	1705.4	10.8	0.7	1	1
45335	2024	2	13	19		2	0.6	-2	-2.9	1722.0	10.8	0.9	0.366667	1
45335	2024	2	13	20		2	0.4	-2.7	-2.3	1707.4	10.8	1.0	-0.21667	1
45335	2024	2	13	21		2	0.1	-3.2	1.4	1674.1	10.8	1.0	-0.69167	1
45335	2024	2	13	22		2	-0.1	-3.7	2	1622.8	10.8	0.9	-1.025	1
45335	2024	2	13	23		2	-0.2	-4.4	2.6	1552.0	10.8	0.5	-0.96667	1
45335	2024	2	13	24		2	-0.4	-4.9	3.2	1525.5	10.8	-0.1	-0.79167	1
45336	2024	2	14	1		3	-0.6	-4.8	3.9	1496.8	24.2	-0.7	-0.58333	1
45336	2024	2	14	2		3	-0.8	-4.4	2.3	1470.1	24.2	-1.4	-0.34167	1
45336	2024	2	14	3		3	-1.0	-4.2	1.8	1452.9	24.2	-2.0</		

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLag	Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLag	Weekdays
45336	2024	2	14	12	3	-2.4	-4.9	-4.8	1675.8	24.2	-4.7	-0.05833	1
45336	2024	2	14	13	3	-2.7	-3.6	-4.4	1652.9	24.2	-4.7	-0.68333	1
45336	2024	2	14	14	3	-3.0	-2.9	-4.2	1612.0	24.2	-4.6	-1.35	1
45336	2024	2	14	15	3	-3.3	-1.7	-4	1614.1	24.2	-4.5	-2.04167	1
45336	2024	2	14	16	3	-3.4	-1.9	-3.8	1663.1	24.2	-4.3	-2.58333	1
45336	2024	2	14	17	3	-3.6	-4.5	-3.8	1755.4	24.2	-4.1	-3.06667	1
45336	2024	2	14	18	3	-3.8	-5.3	-4.6	1833.2	24.2	-4.2	-3.5	1
45336	2024	2	14	19	3	-4.1	-5.8	-5.8	1857.9	24.2	-4.3	-3.825	1
45336	2024	2	14	20	3	-4.2	-6.2	-6	1839.5	24.2	-4.4	-4.04167	1
45336	2024	2	14	21	3	-4.4	-6.1	-5.2	1806.9	24.2	-4.5	-4.3	1
45336	2024	2	14	22	3	-4.5	-6.5	-5.4	1743.8	24.2	-4.5	-4.53333	1
45336	2024	2	14	23	3	-4.6	-6.9	-4.9	1664.5	24.2	-4.6	-4.65833	1
45336	2024	2	14	24	3	-4.7	-7	-3.6	1635.5	24.2	-4.7	-4.74167	1
45337	2024	2	15	1	4	-4.8	-6.8	-2.9	1603.3	23.4	-4.9	-4.74167	1
45337	2024	2	15	2	4	-4.9	-6.3	-1.7	1564.4	23.4	-5.1	-4.64167	1
45337	2024	2	15	3	4	-5.0	-5.7	-1.9	1530.1	23.4	-5.4	-4.51667	1
45337	2024	2	15	4	4	-5.0	-5.1	-4.5	1512.4	23.4	-5.8	-4.30833	1
45337	2024	2	15	5	4	-5.1	-4.5	-5.3	1518.7	23.4	-6.0	-4.13333	1
45337	2024	2	15	6	4	-5.1	-4.1	-5.8	1567.9	23.4	-6.0	-4.19167	1
45337	2024	2	15	7	4	-5.1	-4.2	-6.2	1690.5	23.4	-5.9	-4.31667	1
45337	2024	2	15	8	4	-5.1	-4.2	-6.1	1779.4	23.4	-5.8	-4.41667	1
45337	2024	2	15	9	4	-5.0	-3.8	-6.5	1797.1	23.4	-5.6	-4.45	1
45337	2024	2	15	10	4	-4.9	-3.2	-6.9	1770.0	23.4	-5.4	-4.45833	1
45337	2024	2	15	11	4	-4.9	-2.5	-7	1739.3	23.4	-5.2	-4.56667	1
45337	2024	2	15	12	4	-4.7	-1.9	-6.8	1705.5	23.4	-4.8	-4.69167	1
45337	2024	2	15	13	4	-4.6	-1.2	-6.3	1670.2	23.4	-4.4	-4.86667	1
45337	2024	2	15	14	4	-4.5	-0.7	-5.7	1602.2	23.4	-3.9	-5.13333	1
45337	2024	2	15	15	4	-4.4	-0.2	-5.1	1553.5	23.4	-3.4	-5.41667	1
45337	2024	2	15	16	4	-4.4	0.8	-4.5	1547.4	23.4	-3.0	-5.75	1
45337	2024	2	15	17	4	-4.2	0.7	-4.1	1607.4	23.4	-2.5	-6.01667	1
45337	2024	2	15	18	4	-4.0	0.2	-4.2	1702.7	23.4	-2.0	-6.01667	1
45337	2024	2	15	19	4	-3.8	-0.7	-4.2	1762.5	23.4	-1.7	-5.91667	1
45337	2024	2	15	20	4	-3.6	-1.4	-3.8	1756.3	23.4	-1.4	-5.78333	1
45337	2024	2	15	21	4	-3.4	-2	-3.2	1730.7	23.4	-1.2	-5.61667	1
45337	2024	2	15	22	4	-3.2	-2.3	-2.5	1673.0	23.4	-1.0	-5.425	1
45337	2024	2	15	23	4	-3.0	-2.8	-1.9	1598.9	23.4	-0.9	-5.15	1
45337	2024	2	15	24	4	-2.9	-3.2	-1.2	1574.6	23.4	-1.0	-4.78333	1
45338	2024	2	16	1	5	-2.7	-3.8	-0.7	1555.3	9.5	-1.1	-4.35833	1
45338	2024	2	16	2	5	-2.6	-4.8	-0.2	1534.5	9.5	-1.3	-3.89167	1
45338	2024	2	16	3	5	-2.5	-5.5	0.8	1535.0	9.5	-1.6	-3.425	1
45338	2024	2	16	4	5	-2.5	-6.8	0.7	1549.9	9.5	-2.1	-2.96667	1
45338	2024	2	16	5	5	-2.6	-6.8	0.2	1572.3	9.5	-2.7	-2.475	1
45338	2024	2	16	6	5	-2.7	-10.3	-0.7	1636.4	9.5	-3.3	-2.04167	1
45338	2024	2	16	7	5	-2.9	-9.2	-1.4	1759.6	9.5	-4.2	-1.68333	1
45338	2024	2	16	8	5	-3.2	-7.9	-2	1854.3	9.5	-4.9	-1.39167	1
45338	2024	2	16	9	5	-3.3	-7.1	-2.3	1870.8	9.5	-5.5	-1.15833	1
45338	2024	2	16	10	5	-3.4	-6.1	-2.8	1846.3	9.5	-5.9	-1.00833	1
45338	2024	2	16	11	5	-3.6	-5.4	-3.2	1793.6	9.5	-6.2	-0.93333	1
45338	2024	2	16	12	5	-3.7	-4.7	-3.8	1751.5	9.5	-6.4	-0.95833	1
45338	2024	2	16	13	5	-3.8	-4	-4.8	1687.3	9.5	-6.5	-1.06667	1
45338	2024	2	16	14	5	-3.9	-2.3	-5.5	1618.7	9.5	-6.6	-1.28333	1
45338	2024	2	16	15	5	-4.0	-0.7	-6.8	1586.4	9.5	-6.3	-1.625	1
45338	2024	2	16	16	5	-4.0	-1.2	-6.8	1611.7	9.5	-5.9	-2.06667	1
45338	2024	2	16	17	5	-4.1	-1.1	-10.3	1680.0	9.5	-5.5	-2.7	1
45338	2024	2	16	18	5	-4.2	-2	-9.2	1749.9	9.5	-5.0	-3.325	1
45338	2024	2	16	19	5	-4.3	-2.6	-7.9	1768.6	9.5	-4.3	-4.2	1
45338	2024	2	16	20	5	-4.3	-2.8	-7.1	1740.6	9.5	-3.8	-4.90833	1
45338	2024	2	16	21	5	-4.4	-3	-6.1	1703.1	9.5	-3.3	-5.45	1
45338	2024	2	16	22	5	-4.4	-4.2	-5.4	1658.3	9.5	-3.0	-5.875	1
45338	2024	2	16	23	5	-4.5	-4.7	-4.7	1604.5	9.5	-2.8	-6.19167	1
45338	2024	2	16	24	5	-4.6	-5.2	-4	1600.6	9.5	-2.8	-6.40833	1
45339	2024	2	17	1	6	-4.7	-5	-2.3	1579.8	10.2	-2.8	-6.53333	0
45339	2024	2	17	2	6	-4.7	-5.6	-0.7	1553.1	10.2	-2.9	-6.55	0
45339	2024	2	17	3	6	-4.8	-5.7	-1.2	1537.7	10.2	-3.2	-6.34167	0
45339	2024	2	17	4	6	-4.8	-6.3	-1.1	1535.4	10.2	-3.6	-5.94167	0
45339	2024	2	17	5	6	-4.7	-6.5	-2	1551.0	10.2	-4.0	-5.475	0
45339	2024	2	17	6	6	-4.7	-7.1	-2.6	1584.3	10.2	-4.5	-5	0
45339	2024	2	17	7	6	-4.6	-7.7	-2.8	1648.3	10.2	-4.9	-4.30833	0
45339	2024	2	17	8	6	-4.5	-7.6	-3	1720.4	10.2	-5.3	-3.75833	0
45339	2024	2	17	9	6	-4.5	-7.1	-4.2	1764.2	10.2	-5.7	-3.33333	0
45339	2024	2	17	10	6	-4.5	-5.8	-4.7	1769.7	10.2	-6.1	-2.99167	0
45339	2024	2	17	11	6	-4.5	-4.2	-5.2	1689.0	10.2	-6.2	-2.83333	0
45339	2024	2	17	12	6	-4.5	-2.9	-5	1610.4	10.2	-6.2	-2.775	0
45339	2024	2	17	13	6	-4.4	-1.8	-5.6	1537.4	10.2	-6.0	-2.81667	0
45339	2024	2	17	14	6	-4.3	-0.8	-5.7	1471.0	10.2	-5.7	-2.9	0
45339	2024	2	17	15	6	-4.2	-0.6	-6.3	1443.6	10.2	-5.3	-3.175	0
45339	2024	2	17	16	6	-4.2	-1.8	-6.5	1497.4	10.2	-4.9	-3.59167	0
45339	2024	2	17	17	6	-4.3	-2.2	-7.1	1597.9	10.2	-4.5	-4.01667	0
45339	2024	2	17	18	6	-4.3	-2.2	-7.7	1688.3	10.2	-4.1	-4.46667	0
45339	2024	2	17	19	6	-4.3	-2	-7.6	1718.7	10.2	-3.7	-4.89167	0
45339	2024	2	17	20	6	-4.3	-2.6	-7.1	1687.6	10.2	-3.3	-5.31667	0
45339	2024	2	17	21	6	-4.3	-3.3	-5.8	1654.8	10.2	-2.8	-5.71667	0
45339	2024	2	17	22	6	-4.3	-3.6	-4.2	1609.8	10.2	-2.5	-6.05833	0
45339	2024	2	17	23	6	-4.3	-5.1	-2.9	1559.0	10.2	-2.3	-6.19167	0
45339	2024	2	17	24	6	-4.3	-5.3	-1.8	1519.5	10.2	-2.4	-6.15	0
45340	2024	2	18	1	7	-4.3	-5.6	-0.8	1482.6	13.5	-2.6	-5.95833	0
45340	2024	2	18	2	7	-4.3	-4.6	-0.6	1472.9	13.5	-2.9	-5.69167	0
45340	2024	2	18	3	7	-4.3	-5	-1.8	1483.7	13.5	-3.2	-5.29167	0
45340	2024	2	18	4	7	-4.2	-5.7	-2.2	1491.4	13.5	-3.6	-4.86667	0
45340	2024	2	18	5	7	-4.2	-5.4	-2.2	1499.5	13.5	-3.9	-4.49167	0
45340	2024	2	18	6	7	-4.2	-5.6	-2	1524.4	13.5	-4.2	-4.13333	0
45340	2024	2	18	7	7	-4.1	-6.2	-2.6	1584.2	13.5	-4.5	-3.725	0
45340	2024	2	18	8	7	-4.0	-7.5	-3.3	1656.9	13.5	-4.8	-3.25	0
45340	2024	2	18	9	7	-4.0	-7.9	-3.6	1693.5	13.5	-5.2	-2.83333	0
45340	2024	2	18	10	7	-4.1	-7.3	-5.1	1711.8	13.5	-5.6	-2.51667	0
45340	2024	2	18	11	7	-4.1	-6.8	-5.3	1691.4	13.5	-5.9	-2.33333	0
45340	2024	2	18	12	7	-4.2	-6.4	-5.6	1655.9	13.5	-6.1	-2.40833	0
45340	2024	2	18	13	7	-4.4	-5.6	-4.6	1612.4	13.5	-6.2	-2.60833	0
45340	2024	2	18	14	7	-4.5	-5.3	-5	1565.6	13.5	-6.2	-2.925	0
45340	2024	2	18	15	7	-4.7	-3.9	-5.7	1533.9	13.5	-6.2	-3.24167	0
45340	2024	2	18	16	7	-4.9	-3.3	-5.4	1539.3	13.5	-6.1	-3.60833	0
45340	2024	2	18	17	7	-4.9	-2.6	-5.6	1606.4	13.5	-5.9	-3.93333	0
45340	2024	2	18	18	7	-5.0	-3.4						

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLa	gTemp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLa	gWeekdays
45340	2024	2	18	24	7	-5.2	-2.7	-5.6	1524.6	13.5	-4.3	-6.075	0
45341	2024	2	19	1	1	-5.1	-2.5	-5.3	1473.4	10.9	-4.0	-6.16667	0
45341	2024	2	19	2	1	-4.9	-3	-3.9	1442.5	10.9	-3.7	-6.16667	0
45341	2024	2	19	3	1	-4.9	-3	-3.3	1435.0	10.9	-3.5	-6.225	0
45341	2024	2	19	4	1	-4.8	-3.5	-2.6	1437.6	10.9	-3.4	-6.13333	0
45341	2024	2	19	5	1	-4.7	-3.9	-3.4	1449.8	10.9	-3.5	-5.93333	0
45341	2024	2	19	6	1	-4.6	-5.4	-3.9	1488.0	10.9	-3.6	-5.7	0
45341	2024	2	19	7	1	-4.6	-5.7	-4.6	1554.5	10.9	-3.7	-5.51667	0
45341	2024	2	19	8	1	-4.6	-4.9	-4.6	1592.4	10.9	-3.9	-5.325	0
45341	2024	2	19	9	1	-4.5	-4.5	-4.4	1616.5	10.9	-3.9	-5.08333	0
45341	2024	2	19	10	1	-4.4	-1.5	-3.2	1604.9	10.9	-3.9	-4.80833	0
45341	2024	2	19	11	1	-4.1	0	-2.7	1601.2	10.9	-3.7	-4.56667	0
45341	2024	2	19	12	1	-3.8	0.1	-2.5	1591.2	10.9	-3.4	-4.26667	0
45341	2024	2	19	13	1	-3.6	-0.1	-3	1556.9	10.9	-3.2	-3.95833	0
45341	2024	2	19	14	1	-3.3	0.5	-3	1497.4	10.9	-3.0	-3.7	0
45341	2024	2	19	15	1	-3.1	0.7	-3.5	1456.1	10.9	-2.7	-3.50833	0
45341	2024	2	19	16	1	-2.9	0.1	-3.9	1468.8	10.9	-2.4	-3.43333	0
45341	2024	2	19	17	1	-2.8	-0.8	-5.4	1530.9	10.9	-2.1	-3.45	0
45341	2024	2	19	18	1	-2.7	-1.3	-5.7	1640.8	10.9	-1.8	-3.55833	0
45341	2024	2	19	19	1	-2.6	-2.5	-4.9	1716.9	10.9	-1.5	-3.725	0
45341	2024	2	19	20	1	-2.5	-2.8	-4.5	1717.8	10.9	-1.2	-3.875	0
45341	2024	2	19	21	1	-2.5	-3.5	-1.5	1692.3	10.9	-1.0	-3.9	0
45341	2024	2	19	22	1	-2.4	-4.2	0	1641.5	10.9	-0.9	-3.89167	0
45341	2024	2	19	23	1	-2.4	-4.5	0.1	1567.8	10.9	-1.2	-3.65	0
45341	2024	2	19	24	1	-2.5	-5.4	-0.1	1550.9	10.9	-1.5	-3.38333	0
45342	2024	2	20	1	2	-2.6	-6.1	0.5	1535.0	12.5	-2.0	-3.15	1
45342	2024	2	20	2	2	-2.7	-6.4	0.7	1526.6	12.5	-2.5	-2.95	1
45342	2024	2	20	3	2	-2.9	-7.3	0.1	1529.4	12.5	-3.1	-2.65833	1
45342	2024	2	20	4	2	-3.0	-8.1	-0.8	1547.0	12.5	-3.7	-2.35	1
45342	2024	2	20	5	2	-3.2	-8.6	-1.3	1585.2	12.5	-4.4	-2.05	1
45342	2024	2	20	6	2	-3.4	-8.5	-2.5	1668.8	12.5	-5.1	-1.79167	1
45342	2024	2	20	7	2	-3.6	-8.8	-2.8	1829.9	12.5	-5.7	-1.45	1
45342	2024	2	20	8	2	-3.7	-9.2	-3.5	1946.6	12.5	-6.2	-1.18333	1
45342	2024	2	20	9	2	-3.9	-8.8	-4.2	1907.1	12.5	-6.7	-1.00833	1
45342	2024	2	20	10	2	-4.0	-8.2	-4.5	1796.1	12.5	-7.2	-0.925	1
45342	2024	2	20	11	2	-4.3	-7.6	-5.4	1730.6	12.5	-7.5	-1.15	1
45342	2024	2	20	12	2	-4.6	-6	-6.1	1677.2	12.5	-7.8	-1.525	1
45342	2024	2	20	13	2	-4.9	-5.7	-6.4	1647.0	12.5	-7.8	-1.98333	1
45342	2024	2	20	14	2	-5.1	-4.8	-7.3	1598.8	12.5	-7.8	-2.48333	1
45342	2024	2	20	15	2	-5.3	-4	-8.1	1568.9	12.5	-7.6	-3.05833	1
45342	2024	2	20	16	2	-5.5	-3.4	-8.6	1585.7	12.5	-7.4	-3.725	1
45342	2024	2	20	17	2	-5.7	-3	-8.5	1662.3	12.5	-7.0	-4.40833	1
45342	2024	2	20	18	2	-5.8	-4.1	-8.8	1774.8	12.5	-6.5	-5.05833	1
45342	2024	2	20	19	2	-5.9	-5.5	-9.2	1865.3	12.5	-6.1	-5.65833	1
45342	2024	2	20	20	2	-6.0	-6.9	-8.8	1870.3	12.5	-5.9	-6.18333	1
45342	2024	2	20	21	2	-6.2	-7.1	-8.2	1848.4	12.5	-5.7	-6.71667	1
45342	2024	2	20	22	2	-6.3	-7.4	-7.6	1798.8	12.5	-5.5	-7.15833	1
45342	2024	2	20	23	2	-6.5	-7.7	-6	1738.4	12.5	-5.5	-7.49167	1
45342	2024	2	20	24	2	-6.6	-9.2	-5.7	1731.6	12.5	-5.5	-7.75	1
45343	2024	2	21	1	3	-6.8	-9.7	-4.8	1715.1	7.4	-5.7	-7.8	1
45343	2024	2	21	2	3	-6.9	-10.8	-4	1713.9	7.4	-6.1	-7.76667	1
45343	2024	2	21	3	3	-7.1	-11.5	-3.4	1714.2	7.4	-6.6	-7.63333	1
45343	2024	2	21	4	3	-7.3	-12.9	-3	1726.6	7.4	-7.2	-7.35833	1
45343	2024	2	21	5	3	-7.5	-12.3	-4.1	1756.3	7.4	-8.0	-6.96667	1
45343	2024	2	21	6	3	-7.6	-12.3	-5.5	1831.7	7.4	-8.8	-6.5	1
45343	2024	2	21	7	3	-7.8	-13.5	-6.9	1986.5	7.4	-9.4	-6.13333	1
45343	2024	2	21	8	3	-8.0	-15.5	-7.1	2073.2	7.4	-10.1	-5.85833	1
45343	2024	2	21	9	3	-8.2	-12.8	-7.4	2026.7	7.4	-10.8	-5.66667	1
45343	2024	2	21	10	3	-8.4	-10.5	-7.7	1909.4	7.4	-11.3	-5.525	1
45343	2024	2	21	11	3	-8.5	-8.1	-9.2	1803.5	7.4	-11.6	-5.45833	1
45343	2024	2	21	12	3	-8.5	-6.9	-9.7	1724.9	7.4	-11.6	-5.46667	1
45343	2024	2	21	13	3	-8.6	-4.7	-10.8	1673.5	7.4	-11.4	-5.73333	1
45343	2024	2	21	14	3	-8.5	-4.9	-11.5	1607.0	7.4	-11.0	-6.06667	1
45343	2024	2	21	15	3	-8.5	-5	-12.9	1561.9	7.4	-10.5	-6.56667	1
45343	2024	2	21	16	3	-8.6	-4.7	-12.3	1560.4	7.4	-10.0	-7.19167	1
45343	2024	2	21	17	3	-8.6	-3.9	-12.3	1627.7	7.4	-9.3	-7.98333	1
45343	2024	2	21	18	3	-8.7	-4.4	-13.5	1745.0	7.4	-8.6	-8.75833	1
45343	2024	2	21	19	3	-8.7	-5.6	-15.5	1826.3	7.4	-7.9	-9.44167	1
45343	2024	2	21	20	3	-8.7	-6.5	-12.8	1841.2	7.4	-7.3	-10.1083	1
45343	2024	2	21	21	3	-8.7	-6.7	-10.5	1825.9	7.4	-6.5	-10.825	1
45343	2024	2	21	22	3	-8.6	-7	-8.1	1778.8	7.4	-6.0	-11.3	1
45343	2024	2	21	23	3	-8.6	-6.7	-6.9	1713.3	7.4	-5.7	-11.5583	1
45343	2024	2	21	24	3	-8.6	-6.7	-4.7	1698.7	7.4	-5.6	-11.5917	1
45344	2024	2	22	1	4	-8.5	-6.3	-4.9	1659.9	9.8	-5.6	-11.4	1
45344	2024	2	22	2	4	-8.3	-6.8	-5	1644.8	9.8	-5.7	-10.9833	1
45344	2024	2	22	3	4	-8.2	-6.7	-4.7	1623.2	9.8	-5.9	-10.4917	1
45344	2024	2	22	4	4	-8.0	-6.6	-3.9	1616.2	9.8	-6.0	-9.95	1
45344	2024	2	22	5	4	-7.7	-6.1	-4.4	1623.5	9.8	-6.2	-9.26667	1
45344	2024	2	22	6	4	-7.5	-5.9	-5.6	1685.4	9.8	-6.3	-8.56667	1
45344	2024	2	22	7	4	-7.2	-5.4	-6.5	1807.1	9.8	-6.5	-7.90833	1
45344	2024	2	22	8	4	-6.9	-4.5	-6.7	1896.5	9.8	-6.5	-7.25	1
45344	2024	2	22	9	4	-6.4	-3.4	-7	1904.9	9.8	-6.3	-6.5	1
45344	2024	2	22	10	4	-6.0	-2.8	-6.7	1859.9	9.8	-6.0	-5.99167	1
45344	2024	2	22	11	4	-5.7	-1.8	-6.7	1826.7	9.8	-5.7	-5.7	1
45344	2024	2	22	12	4	-5.4	-1.1	-6.3	1793.2	9.8	-5.3	-5.58333	1
45344	2024	2	22	13	4	-5.2	-0.7	-6.8	1775.0	9.8	-4.8	-5.56667	1
45344	2024	2	22	14	4	-5.0	-0.8	-6.7	1734.3	9.8	-4.3	-5.7	1
45344	2024	2	22	15	4	-4.8	-0.9	-6.6	1696.4	9.8	-3.8	-5.85833	1
45344	2024	2	22	16	4	-4.7	-0.5	-6.1	1690.6	9.8	-3.3	-6	1
45344	2024	2	22	17	4	-4.5	-0.2	-5.9	1723.8	9.8	-2.8	-6.15833	1
45344	2024	2	22	18	4	-4.3	-0.1	-5.4	1759.0	9.8	-2.3	-6.34167	1
45344	2024	2	22	19	4	-4.2	-0.2	-4.5	1792.0	9.8	-1.9	-6.46667	1
45344	2024	2	22	20	4	-3.9	-0.3	-3.4	1766.6	9.8	-1.4	-6.45	1
45344	2024	2	22	21	4	-3.7	-0.4	-2.8	1725.2	9.8	-1.1	-6.28333	1
45344	2024	2	22	22	4	-3.4	-0.6	-1.8	1651.8	9.8	-0.8	-6.00833	1
45344	2024	2	22	23	4	-3.1	-0.7	-1.1	1576.4	9.8	-0.6	-5.65833	1
45344	2024	2	22	24	4	-2.9	-0.9	-0.7	1548.9	9.8	-0.5	-5.25	1
45345	2024	2	23	1	5	-2.7	-1.5	-0.8	1518.7	10.4	-0.5	-4.78333	1
45345	2024	2	23	2	5	-2.5	-2.9	-0.9	1498.1	10.4	-0.6	-4.31667	1
45345	2024	2	23	3	5	-2.3	-4.8	-0.5	1465.8	10.4	-0.8	-3.81667	1
45345	2024	2	23	4	5	-2.2	-5.5	-0.2	1449.8	10.4	-1.1	-3.33333	1
45345	2024	2	23	5	5	-2.2	-5.9	-0.1	1463.4	10.4	-1.5	-2.825	1
45345	2024	2	23	6	5	-2.2	-3.7	-0.2	1535.6	10.4	-2		

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLa	g Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLa	g Weekdays	
45345	2024	2	23	12	12	5	-1.8	1.2	-1.5	1612.2	10.4	-3.0	-0.54167	1
45345	2024	2	23	13	13	5	-1.7	1.4	-2.9	1590.4	10.4	-2.8	-0.525	1
45345	2024	2	23	14	14	5	-1.6	1.4	-4.8	1564.5	10.4	-2.5	-0.59167	1
45345	2024	2	23	15	15	5	-1.5	1.7	-5.5	1539.3	10.4	-2.2	-0.76667	1
45345	2024	2	23	16	16	5	-1.4	2.3	-5.9	1550.2	10.4	-1.6	-1.09167	1
45345	2024	2	23	17	17	5	-1.3	1.6	-3.7	1578.6	10.4	-1.0	-1.50833	1
45345	2024	2	23	18	18	5	-1.2	1.4	-4	1624.8	10.4	-0.4	-1.98333	1
45345	2024	2	23	19	19	5	-1.1	2	-3.6	1623.4	10.4	0.1	-2.28333	1
45345	2024	2	23	20	20	5	-1.0	2.7	-2.7	1574.6	10.4	0.6	-2.6	1
45345	2024	2	23	21	21	5	-0.9	3.6	-1.2	1501.9	10.4	1.1	-2.875	1
45345	2024	2	23	22	22	5	-0.7	4	1.2	1431.3	10.4	1.6	-3.06667	1
45345	2024	2	23	23	23	5	-0.5	4.4	1.2	1352.8	10.4	2.0	-3.11667	1
45345	2024	2	23	24	24	5	-0.3	4.1	1.4	1303.5	10.4	2.3	-2.95833	1
45346	2024	2	24	1	1	6	-0.1	5.6	1.4	1255.1	19.8	2.6	-2.78333	0
45346	2024	2	24	2	2	6	0.2	4.3	1.7	1226.4	19.8	2.9	-2.54167	0
45346	2024	2	24	3	3	6	0.5	4.8	2.3	1186.7	19.8	3.1	-2.18333	0
45346	2024	2	24	4	4	6	0.9	5.2	1.6	1160.0	19.8	3.4	-1.64167	0
45346	2024	2	24	5	5	6	1.3	5.4	1.4	1147.7	19.8	3.6	-0.99167	0
45346	2024	2	24	6	6	6	1.8	4.8	2	1167.7	19.8	4.0	-0.36667	0
45346	2024	2	24	7	7	6	2.2	5.8	2.7	1211.5	19.8	4.2	0.058333	0
45346	2024	2	24	8	8	6	2.6	6.6	3.6	1273.2	19.8	4.6	0.558333	0
45346	2024	2	24	9	9	6	3.0	6.8	4	1363.7	19.8	4.9	1.083333	0
45346	2024	2	24	10	10	6	3.4	6.3	4.4	1452.7	19.8	5.2	1.608333	0
45346	2024	2	24	11	11	6	3.7	6	4.1	1506.5	19.8	5.3	2.041667	0
45346	2024	2	24	12	12	6	3.9	5.3	5.6	1547.3	19.8	5.5	2.308333	0
45346	2024	2	24	13	13	6	4.1	3.4	4.3	1574.4	19.8	5.6	2.55	0
45346	2024	2	24	14	14	6	4.1	2.5	4.8	1596.6	19.8	5.4	2.9	0
45346	2024	2	24	15	15	6	4.2	1.7	5.2	1596.7	19.8	5.2	3.141667	0
45346	2024	2	24	16	16	6	4.2	1.1	5.4	1609.3	19.8	5.0	3.4	0
45346	2024	2	24	17	17	6	4.1	0.5	4.8	1652.8	19.8	4.6	3.641667	0
45346	2024	2	24	18	18	6	4.1	-0.3	5.8	1699.5	19.8	4.2	3.958333	0
45346	2024	2	24	19	19	6	4.0	-0.7	6.6	1705.9	19.8	3.8	4.241667	0
45346	2024	2	24	20	20	6	3.9	-0.7	6.8	1666.0	19.8	3.3	4.558333	0
45346	2024	2	24	21	21	6	3.8	-1	6.3	1628.7	19.8	2.7	4.883333	0
45346	2024	2	24	22	22	6	3.6	-1.4	6	1579.0	19.8	2.0	5.15	0
45346	2024	2	24	23	23	6	3.4	-2.1	5.3	1537.2	19.8	1.4	5.341667	0
45346	2024	2	24	24	24	6	3.1	-4.3	3.4	1508.8	19.8	0.7	5.475	0
45347	2024	2	25	1	1	7	2.7	-5.6	2.5	1484.6	12.0	-0.1	5.575	0
45347	2024	2	25	2	2	7	2.3	-6.7	1.7	1482.6	12.0	-0.9	5.391667	0
45347	2024	2	25	3	3	7	1.8	-7.8	1.1	1496.9	12.0	-1.6	5.241667	0
45347	2024	2	25	4	4	7	1.3	-8.6	0.5	1516.5	12.0	-2.4	4.983333	0
45347	2024	2	25	5	5	7	0.7	-9.2	-0.3	1551.3	12.0	-3.2	4.641667	0
45347	2024	2	25	6	6	7	0.1	-9.4	-0.7	1599.3	12.0	-4.0	4.233333	0
45347	2024	2	25	7	7	7	-0.5	-9.5	-0.7	1670.9	12.0	-4.8	3.808333	0
45347	2024	2	25	8	8	7	-1.1	-9.5	-1	1731.7	12.0	-5.5	3.266667	0
45347	2024	2	25	9	9	7	-1.8	-9.1	-1.4	1747.1	12.0	-6.3	2.658333	0
45347	2024	2	25	10	10	7	-2.5	-7.8	-2.1	1726.4	12.0	-6.9	2.008333	0
45347	2024	2	25	11	11	7	-3.1	-6.4	-4.3	1675.2	12.0	-7.5	1.366667	0
45347	2024	2	25	12	12	7	-3.6	-4.7	-5.6	1627.8	12.0	-7.8	0.691667	0
45347	2024	2	25	13	13	7	-4.0	-3.7	-6.7	1574.5	12.0	-7.9	-0.10833	0
45347	2024	2	25	14	14	7	-4.3	-2.8	-7.8	1514.6	12.0	-7.7	-0.85833	0
45347	2024	2	25	15	15	7	-4.5	-2.1	-8.6	1474.7	12.0	-7.4	-1.625	0
45347	2024	2	25	16	16	7	-4.7	-1.1	-9.2	1473.9	12.0	-6.9	-2.41667	0
45347	2024	2	25	17	17	7	-4.8	-0.5	-9.4	1543.2	12.0	-6.3	-3.225	0
45347	2024	2	25	18	18	7	-4.8	-1.2	-9.5	1652.8	12.0	-5.6	-4.03333	0
45347	2024	2	25	19	19	7	-4.8	-2.3	-9.5	1751.5	12.0	-4.9	-4.79167	0
45347	2024	2	25	20	20	7	-4.9	-3.5	-9.1	1771.2	12.0	-4.3	-5.525	0
45347	2024	2	25	21	21	7	-5.0	-3.4	-7.8	1753.9	12.0	-3.8	-6.25833	0
45347	2024	2	25	22	22	7	-5.1	-3.5	-6.4	1704.4	12.0	-3.3	-6.93333	0
45347	2024	2	25	23	23	7	-5.2	-3.5	-4.7	1631.9	12.0	-2.9	-7.46667	0
45347	2024	2	25	24	24	7	-5.3	-4	-3.7	1586.0	12.0	-2.7	-7.825	0
45348	2024	2	26	1	1	1	-5.2	-3.5	-2.8	1553.0	12.9	-2.6	-7.85833	1
45348	2024	2	26	2	2	1	-5.2	-4.8	-2.1	1543.4	12.9	-2.6	-7.7	1
45348	2024	2	26	3	3	1	-5.1	-5.8	-1.1	1554.3	12.9	-2.8	-7.375	1
45348	2024	2	26	4	4	1	-5.0	-5.6	-0.5	1569.0	12.9	-3.1	-6.9	1
45348	2024	2	26	5	5	1	-4.9	-6.1	-1.2	1601.7	12.9	-3.5	-6.275	1
45348	2024	2	26	6	6	1	-4.7	-8.1	-2.3	1683.4	12.9	-3.9	-5.55	1
45348	2024	2	26	7	7	1	-4.7	-8.3	-3.5	1824.1	12.9	-4.5	-4.86667	1
45348	2024	2	26	8	8	1	-4.6	-8.3	-3.4	1924.2	12.9	-5.0	-4.26667	1
45348	2024	2	26	9	9	1	-4.6	-6	-3.5	1856.5	12.9	-5.4	-3.76667	1
45348	2024	2	26	10	10	1	-4.5	-1.9	-3.5	1739.7	12.9	-5.6	-3.29167	1
45348	2024	2	26	11	11	1	-4.2	-0.3	-4	1663.5	12.9	-5.5	-2.93333	1
45348	2024	2	26	12	12	1	-4.0	-0.4	-3.5	1624.6	12.9	-5.2	-2.69167	1
45348	2024	2	26	13	13	1	-3.8	0.1	-4.8	1599.9	12.9	-4.9	-2.63333	1
45348	2024	2	26	14	14	1	-3.6	0.3	-5.8	1579.8	12.9	-4.6	-2.61667	1
45348	2024	2	26	15	15	1	-3.5	0.4	-5.6	1565.8	12.9	-4.2	-2.78333	1
45348	2024	2	26	16	16	1	-3.4	0.6	-6.1	1581.8	12.9	-3.7	-3.09167	1
45348	2024	2	26	17	17	1	-3.3	1	-8.1	1635.9	12.9	-3.2	-3.46667	1
45348	2024	2	26	18	18	1	-3.3	1.2	-8.3	1692.9	12.9	-2.6	-3.93333	1
45348	2024	2	26	19	19	1	-3.2	1.3	-8.3	1699.7	12.9	-1.8	-4.50833	1
45348	2024	2	26	20	20	1	-3.0	1.6	-6	1661.0	12.9	-1.0	-5.00833	1
45348	2024	2	26	21	21	1	-2.8	1.8	-1.9	1602.6	12.9	-0.2	-5.40833	1
45348	2024	2	26	22	22	1	-2.6	2	-0.3	1520.7	12.9	0.5	-5.625	1
45348	2024	2	26	23	23	1	-2.3	1.7	-0.4	1432.9	12.9	0.8	-5.49167	1
45348	2024	2	26	24	24	1	-2.1	1.5	0.1	1394.0	12.9	1.0	-5.225	1
45349	2024	2	27	1	2	2	-1.9	1.9	0.3	1361.2	8.5	1.1	-4.925	1
45349	2024	2	27	2	2	2	-1.7	1.3	0.4	1336.8	8.5	1.3	-4.625	1
45349	2024	2	27	3	3	2	-1.4	0.9	0.6	1318.5	8.5	1.4	-4.2	1
45349	2024	2	27	4	4	2	-1.1	-0.4	1	1320.0	8.5	1.4	-3.68333	1
45349	2024	2	27	5	5	2	-0.9	0.4	1.2	1340.6	8.5	1.3	-3.16667	1
45349	2024	2	27	6	6	2	-0.7	0.1	1.3	1405.6	8.5	1.3	-2.575	1
45349	2024	2	27	7	7	2	-0.3	-0.2	1.6	1546.6	8.5	1.2	-1.8	1
45349	2024	2	27	8	8	2	0.0	-1	1.8	1642.0	8.5	1.1	-1	1
45349	2024	2	27	9	9	2	0.3	0	2	1575.3	8.5	0.8	-0.175	1
45349	2024	2	27	10	10	2	0.6	2.5	1.7	1469.7	8.5	0.7	0.475	1
45349	2024	2	27	11	11	2	0.8	4.5	1.5	1379.2	8.5	0.7	0.8	1
45349	2024	2	27	12	12	2	1.0	5	1.9	1318.2	8.5	1.0	0.966667	1

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLag	Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLag	Weekdays
45349	2024	2	27	24	2	2.4	4.4	5.1	1221.3	8.5	3.8	0.958333	1
45350	2024	2	28	1	3	2.5	5.2	5.4	1176.6	25.6	3.7	1.25	1
45350	2024	2	28	2	3	2.6	7.1	4.8	1133.2	25.6	3.7	1.516667	1
45350	2024	2	28	3	3	2.9	7	3.6	1107.6	25.6	3.9	1.858333	1
45350	2024	2	28	4	3	3.1	6.2	3.1	1092.9	25.6	4.1	2.183333	1
45350	2024	2	28	5	3	3.4	6.8	2.6	1096.5	25.6	4.3	2.516667	1
45350	2024	2	28	6	3	3.7	7.9	2.1	1140.1	25.6	4.6	2.741667	1
45350	2024	2	28	7	3	4.0	6.3	2.5	1256.3	25.6	5.0	2.95	1
45350	2024	2	28	8	3	4.3	6.8	3.1	1354.1	25.6	5.4	3.141667	1
45350	2024	2	28	9	3	4.6	6.5	3.7	1374.4	25.6	5.7	3.433333	1
45350	2024	2	28	10	3	4.9	7	4.3	1354.1	25.6	6.0	3.691667	1
45350	2024	2	28	11	3	5.0	6.6	4.4	1332.8	25.6	6.3	3.791667	1
45350	2024	2	28	12	3	5.1	7.3	5.2	1305.5	25.6	6.5	3.775	1
45350	2024	2	28	13	3	5.2	7.2	7.1	1288.9	25.6	6.7	3.725	1
45350	2024	2	28	14	3	5.3	6.9	7	1281.5	25.6	6.9	3.733333	1
45350	2024	2	28	15	3	5.4	7.4	6.2	1285.3	25.6	6.9	3.875	1
45350	2024	2	28	16	3	5.5	6.8	6.8	1325.8	25.6	6.9	4.058333	1
45350	2024	2	28	17	3	5.6	6.9	7.9	1395.2	25.6	7.0	4.275	1
45350	2024	2	28	18	3	5.8	5.4	6.3	1443.4	25.6	7.0	4.583333	1
45350	2024	2	28	19	3	5.9	6	6.8	1451.8	25.6	6.8	5.025	1
45350	2024	2	28	20	3	6.1	6.4	6.5	1427.7	25.6	6.7	5.375	1
45350	2024	2	28	21	3	6.2	6.7	7	1382.1	25.6	6.7	5.733333	1
45350	2024	2	28	22	3	6.4	7	6.6	1311.5	25.6	6.7	6.016667	1
45350	2024	2	28	23	3	6.5	6.9	7.3	1223.9	25.6	6.7	6.291667	1
45350	2024	2	28	24	3	6.6	7.5	7.2	1176.0	25.6	6.7	6.483333	1
45351	2024	2	29	1	4	6.7	7.2	6.9	1131.1	27.7	6.8	6.725	1
45351	2024	2	29	2	4	6.8	7.5	7.4	1080.7	27.7	6.8	6.891667	1
45351	2024	2	29	3	4	6.8	7.5	6.8	1054.0	27.7	6.8	6.875	1
45351	2024	2	29	4	4	6.9	8.2	6.9	1041.2	27.7	6.8	6.908333	1
45351	2024	2	29	5	4	6.9	7.7	5.4	1045.8	27.7	6.9	6.958333	1
45351	2024	2	29	6	4	7.0	8	6	1095.5	27.7	7.0	6.966667	1
45351	2024	2	29	7	4	7.0	8.3	6.4	1210.6	27.7	7.2	6.758333	1
45351	2024	2	29	8	4	7.1	8.2	6.7	1280.1	27.7	7.4	6.733333	1
45351	2024	2	29	9	4	7.1	7.9	7	1335.6	27.7	7.6	6.7	1
45351	2024	2	29	10	4	7.2	6.6	6.9	1386.9	27.7	7.7	6.716667	1
45351	2024	2	29	11	4	7.2	2.7	7.5	1450.5	27.7	7.6	6.716667	1
45351	2024	2	29	12	4	7.0	1.8	7.2	1481.6	27.7	7.3	6.741667	1
45351	2024	2	29	13	4	6.8	1.1	7.5	1496.7	27.7	6.8	6.758333	1
45351	2024	2	29	14	4	6.5	0.5	7.5	1473.8	27.7	6.3	6.758333	1
45351	2024	2	29	15	4	6.3	-0.2	8.2	1479.4	27.7	5.7	6.808333	1
45351	2024	2	29	16	4	5.9	-1.5	7.7	1538.8	27.7	5.1	6.816667	1
45351	2024	2	29	17	4	5.6	-2.5	8	1631.9	27.7	4.3	6.933333	1
45351	2024	2	29	18	4	5.2	-4.3	8.3	1734.4	27.7	3.4	7	1
45351	2024	2	29	19	4	4.8	-4.7	8.2	1793.3	27.7	2.4	7.216667	1
45351	2024	2	29	20	4	4.4	-5.5	7.9	1799.0	27.7	1.3	7.408333	1
45351	2024	2	29	21	4	3.9	-5.7	6.6	1778.3	27.7	0.2	7.558333	1
45351	2024	2	29	22	4	3.3	-6	2.7	1732.9	27.7	-1.0	7.658333	1
45351	2024	2	29	23	4	2.8	-7.2	1.8	1676.9	27.7	-2.0	7.625	1
45351	2024	2	29	24	4	2.2	-7.9	1.1	1668.7	27.7	-2.9	7.275	1
45352	2024	3	1	1	5	1.6	-8.9	0.5	1660.7	18.9	-3.7	6.8	1
45352	2024	3	1	2	5	0.9	-9.2	-0.2	1651.9	18.9	-4.5	6.291667	1
45352	2024	3	1	3	5	0.2	-9.6	-1.5	1642.4	18.9	-5.3	5.708333	1
45352	2024	3	1	4	5	-0.5	-9.9	-2.5	1643.8	18.9	-6.1	5.066667	1
45352	2024	3	1	5	5	-1.3	-10.7	-4.3	1674.6	18.9	-6.8	4.258333	1
45352	2024	3	1	6	5	-2.0	-11.3	-4.7	1756.8	18.9	-7.5	3.408333	1
45352	2024	3	1	7	5	-2.8	-11.7	-5.5	1903.1	18.9	-8.1	2.383333	1
45352	2024	3	1	8	5	-3.7	-12.1	-5.7	1991.4	18.9	-8.6	1.3	1
45352	2024	3	1	9	5	-4.5	-11.5	-6	1970.1	18.9	-9.2	0.158333	1
45352	2024	3	1	10	5	-5.3	-10.8	-7.2	1927.6	18.9	-9.7	-0.975	1
45352	2024	3	1	11	5	-6.0	-10.5	-7.9	1872.2	18.9	-10.1	-2.025	1
45352	2024	3	1	12	5	-6.6	-9.9	-8.9	1830.5	18.9	-10.3	-2.85	1
45352	2024	3	1	13	5	-7.1	-8.1	-9.2	1803.9	18.9	-10.5	-3.65833	1
45352	2024	3	1	14	5	-7.5	-7.3	-9.6	1754.1	18.9	-10.4	-4.49167	1
45352	2024	3	1	15	5	-7.8	-6.6	-9.9	1709.7	18.9	-10.3	-5.3	1
45352	2024	3	1	16	5	-8.1	-5.7	-10.7	1708.6	18.9	-10.0	-6.08333	1
45352	2024	3	1	17	5	-8.2	-5.1	-11.3	1755.0	18.9	-9.7	-6.78333	1
45352	2024	3	1	18	5	-8.3	-5.5	-11.7	1840.4	18.9	-9.2	-7.46667	1
45352	2024	3	1	19	5	-8.4	-6	-12.1	1907.2	18.9	-8.7	-8.05	1
45352	2024	3	1	20	5	-8.4	-6	-11.5	1892.7	18.9	-8.3	-8.63333	1
45352	2024	3	1	21	5	-8.5	-5.9	-10.8	1847.1	18.9	-7.8	-9.18333	1
45352	2024	3	1	22	5	-8.5	-5.7	-10.5	1775.1	18.9	-7.3	-9.66667	1
45352	2024	3	1	23	5	-8.5	-5.1	-9.9	1698.1	18.9	-6.9	-10.0667	1
45352	2024	3	1	24	5	-8.4	-5.1	-8.1	1673.6	18.9	-6.4	-10.3417	1
45353	2024	3	2	1	6	-8.3	-4.7	-7.3	1640.5	12.7	-6.0	-10.5083	0
45353	2024	3	2	2	6	-8.1	-4.1	-6.6	1602.9	12.7	-5.7	-10.4417	0
45353	2024	3	2	3	6	-7.9	-4	-5.7	1571.7	12.7	-5.5	-10.2833	0
45353	2024	3	2	4	6	-7.6	-4.5	-5.1	1556.3	12.7	-5.2	-10.0333	0
45353	2024	3	2	5	6	-7.4	-4.2	-5.5	1549.2	12.7	-5.1	-9.68333	0
45353	2024	3	2	6	6	-7.1	-3.4	-6	1565.9	12.7	-5.1	-9.21667	0
45353	2024	3	2	7	6	-6.8	-2.9	-6	1607.3	12.7	-4.9	-8.73333	0
45353	2024	3	2	8	6	-6.4	-2	-5.9	1646.8	12.7	-4.6	-8.25833	0
45353	2024	3	2	9	6	-6.0	-1	-5.7	1650.4	12.7	-4.3	-7.75	0
45353	2024	3	2	10	6	-5.6	2.1	-5.1	1594.7	12.7	-3.9	-7.28333	0
45353	2024	3	2	11	6	-5.1	3.9	-5.1	1505.4	12.7	-3.2	-6.85833	0
45353	2024	3	2	12	6	-4.5	5	-4.7	1446.3	12.7	-2.5	-6.40833	0
45353	2024	3	2	13	6	-3.8	5	-4.1	1374.8	12.7	-1.7	-6.00833	0
45353	2024	3	2	14	6	-3.3	5.7	-4	1309.4	12.7	-0.8	-5.725	0
45353	2024	3	2	15	6	-2.7	6	-4.5	1265.9	12.7	0.0	-5.45833	0
45353	2024	3	2	16	6	-2.2	5.4	-4.2	1281.1	12.7	0.8	-5.24167	0
45353	2024	3	2	17	6	-1.8	4.6	-3.4	1348.2	12.7	1.6	-5.14167	0
45353	2024	3	2	18	6	-1.4	4.7	-2.9	1439.3	12.7	2.4	-5.06667	0
45353	2024	3	2	19	6	-0.9	3.7	-2	1471.9	12.7	3.0	-4.89167	0
45353	2024	3	2	20	6	-0.5	3.5	-1	1455.5	12.7	3.6	-4.63333	0
45353	2024	3	2	21	6	-0.1	4	2.1	1419.1	12.7	4.1	-4.3	0
45353	2024	3	2	22	6	0.3	3.3	3.9	1365.8	12.7	4.5	-3.89167	0
45353	2024	3	2	23	6	0.7	2.6	5	1297.8	12.7	4.6	-3.24167	0
45353	2024	3	2	24	6	1.0	2.3	5	1241.6	12.7	4.5	-2.49167	0
45354	2024	3	3	1	7	1.3	3.6	5.7	1184.0	10.1	4.2	-1.65	0
45354	2024	3	3	2	7	1.6	5	6	1146.7	10.1	4.1	-0.84167	0
45354	2024	3	3	3	7	2.0	4	5.4	1116.4	10.1	4.1	-0.025	0
45354	2024	3	3	4	7	2.4	3.8	4.6	1114.1	10.1	3.9	0.808333	0
45354	2024	3	3	5	7	2.7	3.1	4.7	1120.0	10.1	3.8	1.633333	0
45354	2024	3	3	6	7	3.0	3.4						

DATE	Year	Month	Day	HOUR	DOW	24hrAvgLa	g Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLa	g Weekdays	
45354	2024	3	3	3	12	7	4.2	5.1	3.6	1416.7	10.1	3.9	4.458333	0
45354	2024	3	3	3	13	7	4.2	5	5	1415.8	10.1	4.1	4.233333	0
45354	2024	3	3	3	14	7	4.2	5.6	4	1388.2	10.1	4.2	4.116667	0
45354	2024	3	3	3	15	7	4.2	5.6	3.8	1369.1	10.1	4.3	4.058333	0
45354	2024	3	3	3	16	7	4.2	6.1	3.1	1366.8	10.1	4.4	3.891667	0
45354	2024	3	3	3	17	7	4.2	6.4	3.4	1417.4	10.1	4.6	3.758333	0
45354	2024	3	3	3	18	7	4.3	7	2.7	1454.4	10.1	4.9	3.633333	0
45354	2024	3	3	3	19	7	4.4	6	4.1	1464.4	10.1	5.2	3.525	0
45354	2024	3	3	3	20	7	4.4	7	5.1	1436.0	10.1	5.5	3.441667	0
45354	2024	3	3	3	21	7	4.6	7	4.6	1384.1	10.1	5.7	3.491667	0
45354	2024	3	3	3	22	7	4.7	6.6	4.8	1312.5	10.1	5.9	3.583333	0
45354	2024	3	3	3	23	7	4.9	6.7	5.1	1220.2	10.1	6.0	3.691667	0
45354	2024	3	3	3	24	7	5.0	7.2	5	1143.5	10.1	6.2	3.875	0
45355	2024	3	4	1	1	1	5.2	7.3	5.6	1088.8	15.6	6.4	4.108333	1
45355	2024	3	4	2	1	1	5.4	7.3	5.6	1052.1	15.6	6.5	4.225	1
45355	2024	3	4	3	1	1	5.5	7.2	6.1	1039.0	15.6	6.7	4.275	1
45355	2024	3	4	4	1	1	5.6	7.5	6.4	1042.5	15.6	6.8	4.408333	1
45355	2024	3	4	5	1	1	5.8	7.8	7	1068.6	15.6	6.9	4.6	1
45355	2024	3	4	6	1	1	6.0	6.5	6	1144.4	15.6	7.1	4.875	1
45355	2024	3	4	7	1	1	6.1	5	7	1298.9	15.6	7.0	5.175	1
45355	2024	3	4	8	1	1	6.2	3.9	7	1388.8	15.6	6.9	5.45	1
45355	2024	3	4	9	1	1	6.2	3.7	6.6	1365.8	15.6	6.7	5.691667	1
45355	2024	3	4	10	1	1	6.1	4.3	6.7	1315.9	15.6	6.4	5.85	1
45355	2024	3	4	11	1	1	6.1	5.3	7.2	1284.5	15.6	6.2	6.016667	1
45355	2024	3	4	12	1	1	6.1	5.8	7.3	1273.8	15.6	6.1	6.175	1
45355	2024	3	4	13	1	1	6.2	6.8	7.3	1254.8	15.6	6.0	6.35	1
45355	2024	3	4	14	1	1	6.2	7.5	7.2	1222.5	15.6	5.9	6.541667	1
45355	2024	3	4	15	1	1	6.3	7.7	7.5	1200.5	15.6	5.9	6.683333	1
45355	2024	3	4	16	1	1	6.4	6.8	7.8	1219.6	15.6	6.0	6.816667	1
45355	2024	3	4	17	1	1	6.4	6.4	6.5	1292.8	15.6	5.9	6.933333	1
45355	2024	3	4	18	1	1	6.4	5.4	5	1388.7	15.6	5.8	7.05	1
45355	2024	3	4	19	1	1	6.4	3.4	3.9	1470.1	15.6	5.7	7.008333	1
45355	2024	3	4	20	1	1	6.3	2	3.7	1490.8	15.6	5.6	6.925	1
45355	2024	3	4	21	1	1	6.0	0.5	4.3	1477.1	15.6	5.4	6.666667	1
45355	2024	3	4	22	1	1	5.8	-0.2	5.3	1434.7	15.6	5.2	6.391667	1
45355	2024	3	4	23	1	1	5.5	-0.8	5.8	1369.4	15.6	4.8	6.2	1
45355	2024	3	4	24	1	1	5.2	-1.4	6.8	1355.9	15.6	4.3	6.083333	1
45356	2024	3	5	1	2	2	4.8	-1.6	7.5	1339.3	9.4	3.7	5.966667	1
45356	2024	3	5	2	2	2	4.5	-1.8	7.7	1316.5	9.4	3.0	5.925	1
45356	2024	3	5	3	2	2	4.1	-2.3	6.8	1299.8	9.4	2.2	5.941667	1
45356	2024	3	5	4	2	2	3.7	-2.7	6.4	1298.4	9.4	1.4	5.983333	1
45356	2024	3	5	5	2	2	3.3	-2.7	5.4	1320.6	9.4	0.6	5.925	1
45356	2024	3	5	6	2	2	2.8	-3	3.4	1384.8	9.4	-0.2	5.808333	1
45356	2024	3	5	7	2	2	2.4	-2.3	2	1515.2	9.4	-0.9	5.716667	1
45356	2024	3	5	8	2	2	2.1	-0.5	0.5	1595.1	9.4	-1.4	5.583333	1
45356	2024	3	5	9	2	2	1.9	0.3	-0.2	1581.4	9.4	-1.6	5.425	1
45356	2024	3	5	10	2	2	1.8	0.8	-0.8	1532.4	9.4	-1.6	5.158333	1
45356	2024	3	5	11	2	2	1.6	1.2	-1.4	1466.8	9.4	-1.5	4.783333	1
45356	2024	3	5	12	2	2	1.5	1.7	-1.6	1416.3	9.4	-1.3	4.275	1
45356	2024	3	5	13	2	2	1.3	1.9	-1.8	1371.6	9.4	-1.1	3.675	1
45356	2024	3	5	14	2	2	1.1	1.7	-2.3	1328.9	9.4	-0.8	2.975	1
45356	2024	3	5	15	2	2	0.9	2.3	-2.7	1309.4	9.4	-0.5	2.2	1
45356	2024	3	5	16	2	2	0.6	2.1	-2.7	1336.0	9.4	-0.1	1.366667	1
45356	2024	3	5	17	2	2	0.4	1.8	-3	1407.7	9.4	0.3	0.575	1
45356	2024	3	5	18	2	2	0.2	1.3	-2.3	1486.5	9.4	0.7	-0.18333	1
45356	2024	3	5	19	2	2	0.1	1.2	-0.5	1524.6	9.4	1.0	-0.88333	1
45356	2024	3	5	20	2	2	0.0	1.5	0.3	1508.2	9.4	1.3	-1.35833	1
45356	2024	3	5	21	2	2	0.0	1.7	0.8	1466.3	9.4	1.5	-1.56667	1
45356	2024	3	5	22	2	2	0.0	1.8	1.2	1397.8	9.4	1.6	-1.58333	1
45356	2024	3	5	23	2	2	0.1	1.9	1.7	1317.4	9.4	1.7	-1.5	1
45356	2024	3	5	24	2	2	0.2	2.2	1.9	1266.7	9.4	1.7	-1.33333	1
45357	2024	3	6	1	3	3	0.4	2.9	1.7	1218.8	9.8	1.8	-1.075	1
45357	2024	3	6	2	3	3	0.5	3.1	2.3	1177.4	9.8	1.9	-0.78333	1
45357	2024	3	6	3	3	3	0.7	3.8	2.1	1134.9	9.8	2.0	-0.49167	1
45357	2024	3	6	4	3	3	1.0	4.5	1.8	1108.5	9.8	2.1	-0.10833	1
45357	2024	3	6	5	3	3	1.3	5.3	1.3	1103.2	9.8	2.3	0.291667	1
45357	2024	3	6	6	3	3	1.6	5.5	1.2	1144.0	9.8	2.6	0.666667	1
45357	2024	3	6	7	3	3	2.0	6.1	1.5	1254.4	9.8	3.0	1.025	1
45357	2024	3	6	8	3	3	2.3	6.8	1.7	1364.4	9.8	3.4	1.316667	1
45357	2024	3	6	9	3	3	2.6	7	1.8	1391.6	9.8	3.8	1.483333	1
45357	2024	3	6	10	3	3	2.9	8.1	1.9	1364.8	9.8	4.2	1.6	1
45357	2024	3	6	11	3	3	3.2	7.7	2.2	1343.9	9.8	4.8	1.683333	1
45357	2024	3	6	12	3	3	3.5	7.5	2.9	1319.6	9.8	5.3	1.741667	1
45357	2024	3	6	13	3	3	3.7	9.3	3.1	1284.0	9.8	5.7	1.783333	1
45357	2024	3	6	14	3	3	4.0	11.6	3.8	1262.5	9.8	6.2	1.866667	1
45357	2024	3	6	15	3	3	4.5	11.7	4.5	1245.9	9.8	6.9	1.983333	1
45357	2024	3	6	16	3	3	4.9	11	5.3	1265.0	9.8	7.6	2.108333	1
45357	2024	3	6	17	3	3	5.2	10.2	5.5	1316.3	9.8	8.1	2.308333	1
45357	2024	3	6	18	3	3	5.6	10.5	6.1	1370.6	9.8	8.5	2.6	1
45357	2024	3	6	19	3	3	6.0	9.2	6.8	1401.5	9.8	9.0	2.95	1
45357	2024	3	6	20	3	3	6.3	8	7	1394.1	9.8	9.2	3.358333	1
45357	2024	3	6	21	3	3	6.6	7.7	8.1	1361.0	9.8	9.3	3.8	1
45357	2024	3	6	22	3	3	6.8	7	7.7	1296.8	9.8	9.4	4.241667	1
45357	2024	3	6	23	3	3	7.0	6.1	7.5	1218.5	9.8	9.3	4.766667	1
45357	2024	3	6	24	3	3	7.2	5.9	9.3	1171.9	9.8	9.2	5.25	1
45358	2024	3	7	1	4	4	7.4	5.6	11.6	1131.1	16.9	9.0	5.691667	1
45358	2024	3	7	2	4	4	7.5	5.3	11.7	1098.8	16.9	8.7	6.225	1
45358	2024	3	7	3	4	4	7.6	5	11	1080.5	16.9	8.2	6.933333	1
45358	2024	3	7	4	4	4	7.6	4.6	10.2	1075.1	16.9	7.6	7.591667	1
45358	2024	3	7	5	4	4	7.6	4.4	10.5	1091.3	16.9	7.1	8.133333	1
45358	2024	3	7	6	4	4	7.6	4	9.2	1153.2	16.9	6.6	8.541667	1
45358	2024	3	7	7	4	4	7.5	3.5	8	1287.0	16.9	6.1	8.958333	1
45358	2024	3	7	8	4	4	7.4	3	7.7	1401.3	16.9	5.6	9.216667	1
45358	2024	3	7	9	4	4	7.2	3.2	7	1449.1	16.9	5.2	9.316667	1
45358	2024	3	7	10	4	4	7.1	3.4	6.1	1466.6	16.9	4.8	9.375	1
45358	2024	3	7	11	4	4	6.9	3.8	5.9	1477.5	16.9	4.5	9.283333	1
45358	2024	3	7	12	4	4	6.7	4.3	5.6	1493.7	16.9	4.3	9.15	1
45358	2024	3	7	13	4	4	6.6	4.7	5.3	1511.7	16.9	4.2	9.016667	1
45358	2024	3	7	14	4	4								

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLag	Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLag	Weekdays	
45358	2024	3	7	24		4	3.9	0.6	4.7	1436.0	16.9	3.4	4.308333	1
45359	2024	3	8	1		5	3.6	0.3	5.2	1413.7	28.3	3.1	4.175	1
45359	2024	3	8	2		5	3.4	0.3	6.3	1381.7	28.3	2.8	4.1	1
45359	2024	3	8	3		5	3.2	0.4	6.4	1359.0	28.3	2.3	4.091667	1
45359	2024	3	8	4		5	3.0	0.2	5	1353.1	28.3	1.9	4.2	1
45359	2024	3	8	5		5	2.8	0.1	2.8	1370.4	28.3	1.3	4.35	1
45359	2024	3	8	6		5	2.7	0.1	1.9	1425.7	28.3	0.9	4.4	1
45359	2024	3	8	7		5	2.5	0.2	1.7	1539.2	28.3	0.7	4.3	1
45359	2024	3	8	8		5	2.4	0	1.1	1631.8	28.3	0.6	4.166667	1
45359	2024	3	8	9		5	2.2	0.3	0.9	1689.4	28.3	0.4	4.058333	1
45359	2024	3	8	10		5	2.1	0.2	0.8	1701.5	28.3	0.4	3.883333	1
45359	2024	3	8	11		5	2.0	0.2	0.6	1697.0	28.3	0.3	3.675	1
45359	2024	3	8	12		5	1.8	0.6	0.3	1696.7	28.3	0.2	3.425	1
45359	2024	3	8	13		5	1.7	0.6	0.3	1695.6	28.3	0.2	3.116667	1
45359	2024	3	8	14		5	1.5	0.7	0.4	1663.8	28.3	0.3	2.75	1
45359	2024	3	8	15		5	1.3	1.1	0.2	1642.2	28.3	0.3	2.341667	1
45359	2024	3	8	16		5	1.1	1	0.1	1645.9	28.3	0.4	1.85	1
45359	2024	3	8	17		5	0.9	1	0.1	1674.8	28.3	0.4	1.333333	1
45359	2024	3	8	18		5	0.7	0.2	0.2	1714.9	28.3	0.5	0.925	1
45359	2024	3	8	19		5	0.6	-0.2	0	1729.1	28.3	0.5	0.7	1
45359	2024	3	8	20		5	0.5	-0.7	0.3	1700.5	28.3	0.5	0.558333	1
45359	2024	3	8	21		5	0.4	-1	0.2	1652.4	28.3	0.4	0.416667	1
45359	2024	3	8	22		5	0.3	-1.2	0.2	1593.7	28.3	0.3	0.35	1
45359	2024	3	8	23		5	0.2	-1.3	0.6	1524.4	28.3	0.2	0.291667	1
45359	2024	3	8	24		5	0.2	-1.5	0.6	1499.5	28.3	0.1	0.241667	1
45360	2024	3	9	1		6	0.1	-1.6	0.7	1469.3	13.8	-0.1	0.241667	0
45360	2024	3	9	2		6	0.0	-1.6	1.1	1424.0	13.8	-0.3	0.266667	0
45360	2024	3	9	3		6	-0.1	-1.6	1	1393.9	13.8	-0.5	0.3	0
45360	2024	3	9	4		6	-0.2	-1.5	1	1374.9	13.8	-0.7	0.358333	0
45360	2024	3	9	5		6	-0.2	-1.4	0.2	1373.7	13.8	-0.9	0.425	0
45360	2024	3	9	6		6	-0.3	-1.5	-0.2	1395.5	13.8	-1.1	0.5	0
45360	2024	3	9	7		6	-0.4	-1.4	-0.7	1445.9	13.8	-1.3	0.508333	0
45360	2024	3	9	8		6	-0.4	-1.5	-1	1512.4	13.8	-1.4	0.475	0
45360	2024	3	9	9		6	-0.5	-1.1	-1.2	1549.1	13.8	-1.4	0.416667	0
45360	2024	3	9	10		6	-0.6	-0.1	-1.3	1508.2	13.8	-1.4	0.308333	0
45360	2024	3	9	11		6	-0.6	1.3	-1.5	1409.0	13.8	-1.3	0.191667	0
45360	2024	3	9	12		6	-0.5	3	-1.6	1261.4	13.8	-1.1	0.066667	0
45360	2024	3	9	13		6	-0.4	5.4	-1.6	1314.1	13.8	-0.8	-0.10833	0
45360	2024	3	9	14		6	-0.2	6.9	-1.6	1259.1	13.8	-0.2	-0.29167	0
45360	2024	3	9	15		6	0.0	7.5	-1.5	1231.6	13.8	0.5	-0.48333	0
45360	2024	3	9	16		6	0.3	7.6	-1.4	1246.1	13.8	1.3	-0.70833	0
45360	2024	3	9	17		6	0.6	5.7	-1.5	1306.4	13.8	2.1	-0.91667	0
45360	2024	3	9	18		6	0.8	2.8	-1.4	1391.7	13.8	2.7	-1.11667	0
45360	2024	3	9	19		6	0.9	1.7	-1.5	1461.6	13.8	3.0	-1.25833	0
45360	2024	3	9	20		6	1.0	0.7	-1.1	1476.7	13.8	3.3	-1.35833	0
45360	2024	3	9	21		6	1.0	0.4	-0.1	1454.8	13.8	3.5	-1.425	0
45360	2024	3	9	22		6	1.1	-0.2	1.3	1404.5	13.8	3.6	-1.43333	0
45360	2024	3	9	23		6	1.1	-0.1	3	1355.0	13.8	3.6	-1.34167	0
45360	2024	3	9	24		6	1.2	0	5.4	1314.3	13.8	3.5	-1.125	0
45361	2024	3	10	1		7	1.2	0.2	6.9	1274.5	24.6	3.2	-0.75	0
45361	2024	3	10	2		7	1.3	0.1	7.5	1254.2	24.6	2.8	-0.16667	0
45361	2024	3	10	3		7	1.4	-0.1	7.6	1251.1	24.6	2.2	0.541667	0
45361	2024	3	10	4		7	1.4	-0.1	5.7	1248.0	24.6	1.6	1.3	0
45361	2024	3	10	5		7	1.5	-0.2	2.8	1259.9	24.6	0.9	2.058333	0
45361	2024	3	10	6		7	1.5	-0.2	1.7	1274.0	24.6	0.4	2.65	0
45361	2024	3	10	7		7	1.6	-0.1	0.7	1304.9	24.6	0.2	3.008333	0
45361	2024	3	10	8		7	1.7	-0.1	0.4	1353.0	24.6	0.0	3.266667	0
45361	2024	3	10	9		7	1.7	0	-0.2	1422.7	24.6	0.0	3.45	0
45361	2024	3	10	10		7	1.8	0.1	-0.1	1502.9	24.6	-0.1	3.575	0
45361	2024	3	10	11		7	1.8	0.4	0	1560.3	24.6	0.0	3.566667	0
45361	2024	3	10	12		7	1.7	0.7	0.2	1598.2	24.6	0.0	3.45	0
45361	2024	3	10	13		7	1.6	1	0.1	1624.2	24.6	0.1	3.2	0
45361	2024	3	10	14		7	1.4	1.2	-0.1	1625.7	24.6	0.1	2.766667	0
45361	2024	3	10	15		7	1.2	1.4	-0.1	1607.9	24.6	0.2	2.2	0
45361	2024	3	10	16		7	1.0	1.6	-0.2	1608.5	24.6	0.3	1.566667	0
45361	2024	3	10	17		7	0.7	1.6	-0.2	1650.6	24.6	0.5	0.925	0
45361	2024	3	10	18		7	0.5	1.8	-0.1	1668.4	24.6	0.6	0.433333	0
45361	2024	3	10	19		7	0.5	2.1	-0.1	1651.4	24.6	0.8	0.183333	0
45361	2024	3	10	20		7	0.5	2.3	0	1647.7	24.6	1.0	0.033333	0
45361	2024	3	10	21		7	0.6	2.6	0.1	1605.2	24.6	1.2	-0.03333	0
45361	2024	3	10	22		7	0.7	3	0.4	1535.1	24.6	1.4	-0.06667	0
45361	2024	3	10	23		7	0.8	3.4	0.7	1441.4	24.6	1.6	-0.04167	0
45361	2024	3	10	24		7	0.9	3.8	1	1352.0	24.6	1.9	0	0
45362	2024	3	11	1		1	1.1	4.6	1.2	1283.2	15.8	2.2	0.058333	1
45362	2024	3	11	2		1	1.3	4.8	1.4	1237.9	15.8	2.5	0.125	1
45362	2024	3	11	3		1	1.5	4.3	1.6	1207.3	15.8	2.8	0.216667	1
45362	2024	3	11	4		1	1.7	3.1	1.6	1199.5	15.8	3.0	0.341667	1
45362	2024	3	11	5		1	1.8	2.4	1.8	1201.1	15.8	3.1	0.483333	1
45362	2024	3	11	6		1	1.9	2.5	2.1	1244.2	15.8	3.2	0.633333	1
45362	2024	3	11	7		1	2.0	2	2.3	1344.7	15.8	3.2	0.8	1
45362	2024	3	11	8		1	2.1	2.1	2.6	1434.9	15.8	3.2	0.983333	1
45362	2024	3	11	9		1	2.2	2.1	3	1470.8	15.8	3.2	1.183333	1
45362	2024	3	11	10		1	2.3	2.3	3.4	1497.1	15.8	3.2	1.4	1
45362	2024	3	11	11		1	2.4	2.2	3.8	1501.4	15.8	3.1	1.641667	1
45362	2024	3	11	12		1	2.5	0.6	4.6	1502.9	15.8	3.0	1.891667	1
45362	2024	3	11	13		1	2.5	2.5	4.8	1496.6	15.8	2.8	2.15	1
45362	2024	3	11	14		1	2.5	2.4	4.3	1477.6	15.8	2.6	2.45	1
45362	2024	3	11	15		1	2.6	2.7	3.1	1446.9	15.8	2.4	2.75	1
45362	2024	3	11	16		1	2.6	2.7	2.4	1441.1	15.8	2.2	2.991667	1
45362	2024	3	11	17		1	2.7	3.4	2.5	1462.5	15.8	2.2	3.116667	1
45362	2024	3	11	18		1	2.7	3.3	2	1490.3	15.8	2.3	3.183333	1
45362	2024	3	11	19		1	2.8	3.2	2.1	1495.6	15.8	2.4	3.241667	1
45362	2024	3	11	20		1	2.8	2.6	2.1	1508.5	15.8	2.5	3.233333	1
45362	2024	3	11	21		1	2.9	2.3	2.3	1502.3	15.8	2.5	3.216667	1
45362	2024	3	11	22		1	2.8	2.4	2.2	1445.1	15.8	2.5	3.175	1
45362	2024	3	11	23		1	2.8	2.1	0.6	1368.1	15.8	2.5	3.116667	1
45362	2024	3	11	24		1	2.8	1.8	2.5	1315.9	15.8	2.5	3.016667	1
45363	2024	3	12	1		2	2.7	1.6	2.4	1300.0	21.0	2.6	2.75	1
45363	2024	3	12	2		2	2.6	1.5	2.7	1294.2	21.0	2.5	2.575	1
45363	2024	3	12	3		2	2.4							

DATE	Year	Month	Day	HOUR	DOW	24hrAvgLa	g Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLa	g Weekdays	
45363	2024	3	12	12	12	2	2.1	3	1.6	1519.3	21.0	1.6	2.516667	1
45363	2024	3	12	13	13	2	2.2	2.9	1.5	1513.7	21.0	1.7	2.616667	1
45363	2024	3	12	14	14	2	2.2	2.6	1.6	1513.2	21.0	1.8	2.541667	1
45363	2024	3	12	15	15	2	2.2	2.1	1.5	1492.6	21.0	1.9	2.466667	1
45363	2024	3	12	16	16	2	2.2	1.2	1.7	1508.6	21.0	2.0	2.375	1
45363	2024	3	12	17	17	2	2.1	2	1.5	1534.3	21.0	1.9	2.275	1
45363	2024	3	12	18	18	2	2.0	1.8	1.3	1565.2	21.0	2.0	2.133333	1
45363	2024	3	12	19	19	2	2.0	1.6	1.1	1570.6	21.0	2.0	1.983333	1
45363	2024	3	12	20	20	2	1.9	1.7	1.2	1592.6	21.0	2.0	1.825	1
45363	2024	3	12	21	21	2	1.9	1.5	2.1	1571.6	21.0	2.1	1.7	1
45363	2024	3	12	22	22	2	1.8	1.3	2.5	1513.4	21.0	2.1	1.608333	1
45363	2024	3	12	23	23	2	1.8	1.3	3	1434.4	21.0	2.0	1.583333	1
45363	2024	3	12	24	24	2	1.8	0.7	2.9	1373.7	21.0	1.9	1.616667	1
45364	2024	3	13	1	3	3	1.7	0.9	2.6	1352.2	24.1	1.7	1.716667	1
45364	2024	3	13	2	3	3	1.7	1	2.1	1331.5	24.1	1.6	1.825	1
45364	2024	3	13	3	3	3	1.7	0.9	1.2	1294.7	24.1	1.4	1.916667	1
45364	2024	3	13	4	3	3	1.6	1	2	1274.1	24.1	1.3	1.958333	1
45364	2024	3	13	5	3	3	1.6	0.9	1.8	1277.9	24.1	1.3	1.933333	1
45364	2024	3	13	6	3	3	1.6	0.9	1.6	1320.4	24.1	1.2	1.958333	1
45364	2024	3	13	7	3	3	1.6	0.7	1.7	1426.4	24.1	1.1	1.983333	1
45364	2024	3	13	8	3	3	1.5	1.1	1.5	1519.9	24.1	1.1	2.008333	1
45364	2024	3	13	9	3	3	1.5	1.2	1.3	1554.1	24.1	1.0	2.058333	1
45364	2024	3	13	10	3	3	1.5	3	1.3	1522.2	24.1	1.0	2.083333	1
45364	2024	3	13	11	3	3	1.6	3.9	0.7	1472.5	24.1	1.1	2.016667	1
45364	2024	3	13	12	3	3	1.6	3.9	0.9	1445.0	24.1	1.4	1.916667	1
45364	2024	3	13	13	3	3	1.7	5.1	1	1420.1	24.1	1.6	1.725	1
45364	2024	3	13	14	3	3	1.8	4.7	0.9	1394.1	24.1	2.0	1.558333	1
45364	2024	3	13	15	3	3	1.9	5.5	1	1357.8	24.1	2.3	1.425	1
45364	2024	3	13	16	3	3	2.0	5.3	0.9	1371.4	24.1	2.7	1.325	1
45364	2024	3	13	17	3	3	2.2	4.5	0.9	1413.4	24.1	3.0	1.308333	1
45364	2024	3	13	18	3	3	2.3	3.7	0.7	1464.2	24.1	3.3	1.216667	1
45364	2024	3	13	19	3	3	2.3	2.7	1.1	1476.9	24.1	3.6	1.141667	1
45364	2024	3	13	20	3	3	2.4	1.9	1.2	1508.7	24.1	3.7	1.066667	1
45364	2024	3	13	21	3	3	2.4	1.4	3	1504.3	24.1	3.8	1.016667	1
45364	2024	3	13	22	3	3	2.4	1.2	3.9	1451.7	24.1	3.8	0.991667	1
45364	2024	3	13	23	3	3	2.4	1.1	3.9	1373.7	24.1	3.7	1.133333	1
45364	2024	3	13	24	3	3	2.4	1	5.1	1325.1	24.1	3.4	1.35	1
45365	2024	3	14	1	4	4	2.4	1.1	4.7	1301.5	12.1	3.2	1.616667	1
45365	2024	3	14	2	4	4	2.4	1.2	5.5	1283.5	12.1	2.8	1.966667	1
45365	2024	3	14	3	4	4	2.4	0.8	5.3	1259.9	12.1	2.6	2.275	1
45365	2024	3	14	4	4	4	2.4	0.9	4.5	1254.9	12.1	2.2	2.658333	1
45365	2024	3	14	5	4	4	2.4	0.9	3.7	1261.4	12.1	1.8	3.016667	1
45365	2024	3	14	6	4	4	2.4	0.8	2.7	1310.2	12.1	1.5	3.316667	1
45365	2024	3	14	7	4	4	2.4	0.7	1.9	1419.0	12.1	1.3	3.55	1
45365	2024	3	14	8	4	4	2.4	0.5	1.4	1518.7	12.1	1.1	3.716667	1
45365	2024	3	14	9	4	4	2.4	0.9	1.2	1545.9	12.1	1.0	3.783333	1
45365	2024	3	14	10	4	4	2.4	1.8	1.1	1515.7	12.1	0.9	3.8	1
45365	2024	3	14	11	4	4	2.3	3.4	1	1444.5	12.1	1.0	3.65	1
45365	2024	3	14	12	4	4	2.3	6	1.1	1368.5	12.1	1.2	3.416667	1
45365	2024	3	14	13	4	4	2.4	7.1	1.2	1315.0	12.1	1.6	3.175	1
45365	2024	3	14	14	4	4	2.5	6.2	0.8	1260.3	12.1	2.1	2.841667	1
45365	2024	3	14	15	4	4	2.5	5.4	0.9	1220.0	12.1	2.5	2.55	1
45365	2024	3	14	16	4	4	2.5	5.1	0.9	1216.2	12.1	2.9	2.158333	1
45365	2024	3	14	17	4	4	2.5	4.7	0.8	1249.9	12.1	3.2	1.791667	1
45365	2024	3	14	18	4	4	2.5	3.1	0.7	1299.3	12.1	3.6	1.491667	1
45365	2024	3	14	19	4	4	2.5	2.1	0.5	1320.5	12.1	3.7	1.25	1
45365	2024	3	14	20	4	4	2.5	1.7	0.9	1370.4	12.1	3.9	1.083333	1
45365	2024	3	14	21	4	4	2.5	1.4	1.8	1388.1	12.1	4.0	0.966667	1
45365	2024	3	14	22	4	4	2.5	0.8	3.4	1347.1	12.1	4.0	0.925	1
45365	2024	3	14	23	4	4	2.4	0.3	6	1283.8	12.1	3.9	0.975	1
45366	2024	3	15	24	5	5	2.4	1.1	7.1	1276.3	7.9	3.7	1.166667	1
45366	2024	3	15	1	5	5	2.4	0.1	6.2	1227.7	7.9	3.3	1.583333	1
45366	2024	3	15	2	5	5	2.4	-0.2	5.4	1221.4	7.9	2.7	2.083333	1
45366	2024	3	15	3	5	5	2.3	-0.6	5.1	1201.7	7.9	2.1	2.5	1
45366	2024	3	15	4	5	5	2.3	-1	4.7	1192.9	7.9	1.6	2.883333	1
45366	2024	3	15	5	5	5	2.2	-1	3.1	1202.8	7.9	1.1	3.233333	1
45366	2024	3	15	6	5	5	2.1	-0.8	2.1	1256.0	7.9	0.7	3.55	1
45366	2024	3	15	7	5	5	2.0	-0.9	1.7	1361.1	7.9	0.3	3.741667	1
45366	2024	3	15	8	5	5	2.0	-0.7	1.4	1453.3	7.9	0.1	3.858333	1
45366	2024	3	15	9	5	5	1.9	-0.2	0.8	1504.5	7.9	-0.1	3.958333	1
45366	2024	3	15	10	5	5	1.9	0	0.3	1522.2	7.9	-0.3	4	1
45366	2024	3	15	11	5	5	1.8	0.5	1.1	1511.3	7.9	-0.3	3.916667	1
45366	2024	3	15	12	5	5	1.7	0.9	0.1	1488.5	7.9	-0.3	3.658333	1
45366	2024	3	15	13	5	5	1.5	1.6	-0.2	1467.3	7.9	-0.3	3.25	1
45366	2024	3	15	14	5	5	1.2	2.4	-0.6	1434.0	7.9	-0.2	2.666667	1
45366	2024	3	15	15	5	5	1.1	1.6	-1	1391.1	7.9	0.0	2.133333	1
45366	2024	3	15	16	5	5	0.9	1.4	-1	1389.2	7.9	0.2	1.633333	1
45366	2024	3	15	17	5	5	0.8	1.2	-0.8	1425.7	7.9	0.4	1.125	1
45366	2024	3	15	18	5	5	0.6	0.8	-0.9	1457.6	7.9	0.6	0.65	1
45366	2024	3	15	19	5	5	0.5	0.6	-0.7	1451.4	7.9	0.7	0.325	1
45366	2024	3	15	20	5	5	0.5	0.6	-0.2	1456.3	7.9	0.8	0.075	1
45366	2024	3	15	21	5	5	0.4	0.8	0	1433.3	7.9	1.0	-0.125	1
45366	2024	3	15	22	5	5	0.4	0.9	0.5	1382.5	7.9	1.0	-0.25833	1
45366	2024	3	15	23	5	5	0.4	0.9	0.9	1317.7	7.9	1.1	-0.325	1
45367	2024	3	16	24	6	6	0.4	1.5	1.6	1180.0	10.0	1.1	-0.30833	0
45367	2024	3	16	1	6	6	0.4	1.1	2.4	1251.8	10.0	1.2	-0.325	0
45367	2024	3	16	2	6	6	0.5	1.1	1.6	1231.0	10.0	1.2	-0.2	0
45367	2024	3	16	3	6	6	0.5	1.1	1.4	1205.9	10.0	1.0	0.016667	0
45367	2024	3	16	4	6	6	0.6	1.2	1.2	1188.5	10.0	1.0	0.2	0
45367	2024	3	16	5	6	6	0.7	1.3	0.8	1185.6	10.0	1.0	0.4	0
45367	2024	3	16	6	6	6	0.8	1.5	0.6	1206.3	10.0	1.0	0.583333	0
45367	2024	3	16	7	6	6	0.9	1.8	0.6	1256.9	10.0	1.1	0.716667	0
45367	2024	3	16	8	6	6	1.0	2	0.8	1321.9	10.0	1.2	0.841667	0
45367	2024	3	16	9	6	6	1.1	2.5	0.9	1382.4	10.0	1.3	0.95	0
45367	2024	3	16	10	6	6	1.2	3.7	0.9	1390.0	10.0	1.4	1.033333	0
45367	2024	3	16	11	6	6	1.4	6.1	1.5	1326.7	10.0	1.6	1.108333	0
45367	2024	3	16	12	6	6	1.6	7.6	1.1	1277.0	10.0	2.1	1.141667	0
45367	2024	3	16</											

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLag	Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLag	Weekdays	
45368	2024	3	17	24	7	7	3.8	4.2	7.8	1222.3	15.6	5.5	2.075	0
45368	2024	3	17	1	7	7	3.9	2.1	8.3	1133.2	15.6	5.2	2.583333	0
45368	2024	3	17	2	7	7	3.9	2.4	9.5	1105.0	15.6	4.7	3.141667	0
45368	2024	3	17	3	7	7	4.0	2.3	10.1	1091.4	15.6	4.2	3.741667	0
45368	2024	3	17	4	7	7	4.0	2.3	6.4	1088.2	15.6	3.6	4.441667	0
45368	2024	3	17	5	7	7	4.1	2.1	4.7	1098.6	15.6	3.0	5.183333	0
45368	2024	3	17	6	7	7	4.1	0.6	3.2	1128.0	15.6	2.6	5.608333	0
45368	2024	3	17	7	7	7	4.1	0	2.3	1176.6	15.6	2.3	5.875	0
45368	2024	3	17	8	7	7	4.0	0.3	2.1	1246.7	15.6	2.0	5.991667	0
45368	2024	3	17	9	7	7	3.9	0.7	1.9	1336.7	15.6	1.8	6.016667	0
45368	2024	3	17	10	7	7	3.8	1.4	1.6	1414.9	15.6	1.7	5.983333	0
45368	2024	3	17	11	7	7	3.8	2.4	4.2	1442.9	15.6	1.7	5.833333	0
45368	2024	3	17	12	7	7	3.6	3	2.1	1450.9	15.6	1.7	5.458333	0
45368	2024	3	17	13	7	7	3.4	2.6	2.4	1448.9	15.6	1.6	5.175	0
45368	2024	3	17	14	7	7	3.2	2.5	2.3	1421.1	15.6	1.7	4.7	0
45368	2024	3	17	15	7	7	2.9	3	2.3	1395.7	15.6	1.7	4.208333	0
45368	2024	3	17	16	7	7	2.7	3	2.1	1419.3	15.6	1.7	3.608333	0
45368	2024	3	17	17	7	7	2.4	2.8	0.6	1475.8	15.6	1.8	2.958333	0
45368	2024	3	17	18	7	7	2.2	2.6	0	1518.1	15.6	1.9	2.6	0
45368	2024	3	17	19	7	7	2.1	2.7	0.3	1511.2	15.6	2.0	2.258333	0
45368	2024	3	17	20	7	7	2.1	3	0.7	1520.8	15.6	2.3	1.991667	0
45368	2024	3	17	21	7	7	2.2	3.3	1.4	1486.2	15.6	2.5	1.825	0
45368	2024	3	17	22	7	7	2.2	3.5	2.4	1413.7	15.6	2.7	1.708333	0
45368	2024	3	17	23	7	7	2.3	3.8	3	1313.6	15.6	2.9	1.666667	0
45369	2024	3	18	24	1	1	2.4	1.6	2.6	1216.1	13.8	3.0	1.733333	1
45369	2024	3	18	1	1	1	2.3	4.2	2.5	1161.3	13.8	2.9	1.633333	1
45369	2024	3	18	2	1	1	2.3	4.1	3	1130.2	13.8	3.0	1.675	1
45369	2024	3	18	3	1	1	2.4	4.1	3	1119.3	13.8	3.1	1.683333	1
45369	2024	3	18	4	1	1	2.5	4.2	2.8	1114.6	13.8	3.2	1.741667	1
45369	2024	3	18	5	1	1	2.6	4.3	2.6	1118.2	13.8	3.3	1.8	1
45369	2024	3	18	6	1	1	2.7	4.3	2.7	1169.7	13.8	3.5	1.858333	1
45369	2024	3	18	7	1	1	2.8	3.3	3	1304.1	13.8	3.6	2.025	1
45369	2024	3	18	8	1	1	2.9	3.4	3.3	1411.3	13.8	3.6	2.25	1
45369	2024	3	18	9	1	1	3.1	4	3.5	1426.2	13.8	3.7	2.475	1
45369	2024	3	18	10	1	1	3.2	5.6	3.8	1361.4	13.8	3.7	2.691667	1
45369	2024	3	18	11	1	1	3.4	6.9	1.6	1304.9	13.8	3.9	2.866667	1
45369	2024	3	18	12	1	1	3.6	7	4.2	1273.8	13.8	4.2	2.983333	1
45369	2024	3	18	13	1	1	3.7	7.3	4.1	1251.0	13.8	4.6	2.866667	1
45369	2024	3	18	14	1	1	3.9	7	4.1	1236.1	13.8	4.9	3	1
45369	2024	3	18	15	1	1	4.1	7.9	4.2	1211.3	13.8	5.1	3.133333	1
45369	2024	3	18	16	1	1	4.3	8	4.3	1202.3	13.8	5.4	3.225	1
45369	2024	3	18	17	1	1	4.5	6.9	4.3	1228.6	13.8	5.8	3.325	1
45369	2024	3	18	18	1	1	4.7	5.7	3.3	1264.9	13.8	6.0	3.45	1
45369	2024	3	18	19	1	1	4.8	4.6	3.4	1282.5	13.8	6.1	3.591667	1
45369	2024	3	18	20	1	1	4.9	3.6	4	1339.8	13.8	6.2	3.641667	1
45369	2024	3	18	21	1	1	4.9	2.7	5.6	1374.6	13.8	6.2	3.675	1
45369	2024	3	18	22	1	1	4.9	2.4	6.9	1333.4	13.8	6.1	3.733333	1
45369	2024	3	18	23	1	1	4.9	1.8	7	1260.5	13.8	5.8	3.908333	1
45370	2024	3	19	24	2	2	4.8	1.4	7.3	1265.4	11.0	5.4	4.166667	1
45370	2024	3	19	1	2	2	4.8	1.3	7	1198.4	11.0	4.9	4.616667	1
45370	2024	3	19	2	2	2	4.7	0.8	7.9	1192.9	11.0	4.4	4.875	1
45370	2024	3	19	3	2	2	4.5	0.4	8	1178.6	11.0	3.9	5.116667	1
45370	2024	3	19	4	2	2	4.4	0.7	6.9	1176.2	11.0	3.3	5.433333	1
45370	2024	3	19	5	2	2	4.2	0.4	5.7	1195.0	11.0	2.7	5.75	1
45370	2024	3	19	6	2	2	4.1	0.2	4.6	1262.1	11.0	2.2	5.966667	1
45370	2024	3	19	7	2	2	3.9	0.6	3.6	1401.2	11.0	1.7	6.083333	1
45370	2024	3	19	8	2	2	3.8	0.6	2.7	1518.1	11.0	1.4	6.191667	1
45370	2024	3	19	9	2	2	3.7	2.2	2.4	1486.2	11.0	1.1	6.208333	1
45370	2024	3	19	10	2	2	3.6	4.3	1.8	1395.7	11.0	1.1	6.1	1
45370	2024	3	19	11	2	2	3.5	4.9	1.4	1339.1	11.0	1.2	5.833333	1
45370	2024	3	19	12	2	2	3.4	5.1	1.3	1342.8	11.0	1.5	5.408333	1
45370	2024	3	19	13	2	2	3.4	5.3	0.8	1351.8	11.0	1.8	4.941667	1
45370	2024	3	19	14	2	2	3.3	5.5	0.4	1335.1	11.0	2.1	4.441667	1
45370	2024	3	19	15	2	2	3.2	6.1	0.7	1308.9	11.0	2.5	3.925	1
45370	2024	3	19	16	2	2	3.1	5.6	0.4	1305.9	11.0	3.0	3.3	1
45370	2024	3	19	17	2	2	3.0	5.3	0.2	1356.0	11.0	3.4	2.691667	1
45370	2024	3	19	18	2	2	3.0	5.3	0.6	1405.5	11.0	3.8	2.15	1
45370	2024	3	19	19	2	2	3.0	5.1	0.6	1405.0	11.0	4.2	1.691667	1
45370	2024	3	19	20	2	2	3.0	4.1	2.2	1431.2	11.0	4.6	1.358333	1
45370	2024	3	19	21	2	2	3.0	3.8	4.3	1447.0	11.0	4.9	1.108333	1
45370	2024	3	19	22	2	2	3.1	3	4.9	1399.8	11.0	5.0	1.066667	1
45370	2024	3	19	23	2	2	3.1	2	5.1	1315.3	11.0	4.9	1.225	1
45371	2024	3	20	24	3	3	3.1	3.1	5.3	1209.3	14.5	4.7	1.483333	1
45371	2024	3	20	1	3	3	3.2	1.1	5.5	1247.9	14.5	4.5	1.791667	1
45371	2024	3	20	2	3	3	3.1	1	6.1	1237.9	14.5	4.2	2.125	1
45371	2024	3	20	3	3	3	3.2	0.8	5.6	1215.7	14.5	3.8	2.516667	1
45371	2024	3	20	4	3	3	3.2	1.2	5.3	1207.9	14.5	3.4	2.991667	1
45371	2024	3	20	5	3	3	3.2	0.4	5.3	1229.5	14.5	3.0	3.4	1
45371	2024	3	20	6	3	3	3.2	-0.2	5.1	1299.9	14.5	2.6	3.808333	1
45371	2024	3	20	7	3	3	3.2	-0.8	4.1	1447.7	14.5	2.1	4.233333	1
45371	2024	3	20	8	3	3	3.1	0.1	3.8	1568.7	14.5	1.6	4.608333	1
45371	2024	3	20	9	3	3	3.1	1.4	3	1531.6	14.5	1.3	4.9	1
45371	2024	3	20	10	3	3	3.1	2.6	2	1440.9	14.5	1.1	5.033333	1
45371	2024	3	20	11	3	3	3.0	3.9	3.1	1357.0	14.5	1.1	4.925	1
45371	2024	3	20	12	3	3	3.0	5.2	1.1	1305.6	14.5	1.2	4.683333	1
45371	2024	3	20	13	3	3	3.0	6.1	1	1266.0	14.5	1.4	4.516667	1
45371	2024	3	20	14	3	3	3.0	6	0.8	1234.1	14.5	1.8	4.166667	1
45371	2024	3	20	15	3	3	3.0	5.4	1.2	1202.6	14.5	2.2	3.791667	1
45371	2024	3	20	16	3	3	3.0	5.5	0.4	1204.7	14.5	2.6	3.35	1
45371	2024	3	20	17	3	3	3.0	4.4	-0.2	1247.8	14.5	3.0	2.983333	1
45371	2024	3	20	18	3	3	2.9	3.8	-0.8	1301.5	14.5	3.3	2.575	1
45371	2024	3	20	19	3	3	2.9	3	0.1	1328.7	14.5	3.6	2.116667	1
45371	2024	3	20	20	3	3	2.8	2.6	1.4	1382.5	14.5	4.0	1.625	1
45371	2024	3	20	21	3	3	2.7	2.8	2.6	1402.0	14.5	4.2	1.291667	1
45371	2024	3	20	22	3	3	2.7	2.9	3.9	1352.4	14.5	4.3	1.091667	1
45371	2024	3	20	23	3	3	2.7	3.2	5.2	1262.2	14.5	4.3	1.058333	1
45372	2024	3	21	24	4	4	2.7	-0.6	6.1	1399.2	28.0	4.2	1.216667	1
45372	20													

DATE	Year	Month	Day	HOUR	DOW	24hrAvgLa	g Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLa	g Weekdays	
45372	2024	3	21	12	12	4	3.5	3	3.3	1449.5	28.0	2.8	4.241667	1
45372	2024	3	21	13	13	4	3.5	3.5	2.8	1414.0	28.0	3.1	3.758333	1
45372	2024	3	21	14	14	4	3.3	1.5	3.1	1386.0	28.0	3.2	3.525	1
45372	2024	3	21	15	15	4	3.2	2.6	3.1	1376.5	28.0	3.1	3.258333	1
45372	2024	3	21	16	16	4	3.0	3.1	3.6	1389.6	28.0	3.0	3.066667	1
45372	2024	3	21	17	17	4	2.9	2.3	3.7	1419.2	28.0	3.0	2.866667	1
45372	2024	3	21	18	18	4	2.9	1.3	3.7	1467.8	28.0	2.9	2.8	1
45372	2024	3	21	19	19	4	2.7	0.4	3.4	1501.9	28.0	2.7	2.791667	1
45372	2024	3	21	20	20	4	2.6	-0.3	3.3	1550.9	28.0	2.4	2.85	1
45372	2024	3	21	21	21	4	2.5	-0.5	2.7	1569.2	28.0	2.1	2.916667	1
45372	2024	3	21	22	22	4	2.4	-0.3	2	1523.7	28.0	1.8	2.958333	1
45372	2024	3	21	23	23	4	2.2	-0.3	3	1446.4	28.0	1.6	2.941667	1
45373	2024	3	22	24	24	5	2.1	-1	3.5	1427.3	21.0	1.4	2.841667	1
45373	2024	3	22	1	1	5	2.1	-0.6	1.5	1382.2	21.0	1.0	3.141667	1
45373	2024	3	22	2	2	5	1.9	-1.3	2.6	1376.9	21.0	0.7	3.158333	1
45373	2024	3	22	3	3	5	1.8	-1.7	3.1	1353.8	21.0	0.5	3.05	1
45373	2024	3	22	4	4	5	1.6	-1.9	2.3	1348.4	21.0	0.1	3.008333	1
45373	2024	3	22	5	5	5	1.3	-2.2	1.3	1360.2	21.0	-0.3	3.008333	1
45373	2024	3	22	6	6	5	1.1	-2.4	0.4	1416.1	21.0	-0.7	2.9	1
45373	2024	3	22	7	7	5	0.8	-2.7	-0.3	1554.8	21.0	-1.0	2.7	1
45373	2024	3	22	8	8	5	0.6	-3	-0.5	1692.5	21.0	-1.3	2.425	1
45373	2024	3	22	9	9	5	0.3	-2.9	-0.3	1728.2	21.0	-1.5	2.116667	1
45373	2024	3	22	10	10	5	0.1	-2.5	-0.3	1702.5	21.0	-1.7	1.8	1
45373	2024	3	22	11	11	5	-0.2	-1.8	-1	1627.8	21.0	-1.9	1.55	1
45373	2024	3	22	12	12	5	-0.3	-0.9	-0.6	1562.4	21.0	-2.0	1.358333	1
45373	2024	3	22	13	13	5	-0.5	0	-1.3	1523.8	21.0	-2.0	1.025	1
45373	2024	3	22	14	14	5	-0.6	0.9	-1.7	1473.5	21.0	-1.9	0.683333	1
45373	2024	3	22	15	15	5	-0.7	1.7	-1.9	1422.4	21.0	-1.8	0.45	1
45373	2024	3	22	16	16	5	-0.7	2.8	-2.2	1393.5	21.0	-1.5	0.091667	1
45373	2024	3	22	17	17	5	-0.7	2.9	-2.4	1405.5	21.0	-1.1	-0.325	1
45373	2024	3	22	18	18	5	-0.7	2.3	-2.7	1429.2	21.0	-0.7	-0.7	1
45373	2024	3	22	19	19	5	-0.6	1.4	-3	1441.5	21.0	-0.3	-1.00833	1
45373	2024	3	22	20	20	5	-0.6	0.3	-2.9	1498.5	21.0	0.1	-1.26667	1
45373	2024	3	22	21	21	5	-0.6	-0.2	-2.5	1537.0	21.0	0.4	-1.49167	1
45373	2024	3	22	22	22	5	-0.6	-0.5	-1.8	1504.8	21.0	0.6	-1.69167	1
45373	2024	3	22	23	23	5	-0.6	-0.6	-0.9	1446.3	21.0	0.7	-1.875	1
45374	2024	3	23	24	24	6	-0.6	4.3	0	1300.7	13.4	0.8	-2	0
45374	2024	3	23	1	1	6	-0.4	-1.3	0.9	1411.8	13.4	1.3	-1.99167	0
45374	2024	3	23	2	2	6	-0.4	-1.7	1.7	1403.0	13.4	1.2	-1.94167	0
45374	2024	3	23	3	3	6	-0.4	-2.5	2.8	1388.7	13.4	1.0	-1.75833	0
45374	2024	3	23	4	4	6	-0.4	-2.8	2.9	1377.6	13.4	0.6	-1.475	0
45374	2024	3	23	5	5	6	-0.5	-3.4	2.3	1389.3	13.4	0.1	-1.08333	0
45374	2024	3	23	6	6	6	-0.5	-3.8	1.4	1418.3	13.4	-0.4	-0.65833	0
45374	2024	3	23	7	7	6	-0.6	-3.7	0.3	1477.1	13.4	-0.9	-0.26667	0
45374	2024	3	23	8	8	6	-0.6	-3.4	-0.2	1546.3	13.4	-1.3	0.075	0
45374	2024	3	23	9	9	6	-0.6	-2.9	-0.5	1594.8	13.4	-1.6	0.35	0
45374	2024	3	23	10	10	6	-0.6	-2.4	-0.6	1636.1	13.4	-1.9	0.575	0
45374	2024	3	23	11	11	6	-0.6	-1.3	4.3	1634.7	13.4	-2.0	0.741667	0
45374	2024	3	23	12	12	6	-0.6	0	-1.3	1613.2	13.4	-2.1	0.841667	0
45374	2024	3	23	13	13	6	-0.6	0.4	-1.7	1574.9	13.4	-2.4	1.275	0
45374	2024	3	23	14	14	6	-0.6	0.7	-2.5	1540.9	13.4	-2.3	1.166667	0
45374	2024	3	23	15	15	6	-0.6	0.5	-2.8	1502.9	13.4	-2.1	0.95	0
45374	2024	3	23	16	16	6	-0.6	0	-3.4	1504.1	13.4	-1.8	0.6	0
45374	2024	3	23	17	17	6	-0.7	0.5	-3.8	1554.8	13.4	-1.6	0.133333	0
45374	2024	3	23	18	18	6	-0.8	0.4	-3.7	1595.2	13.4	-1.3	-0.39167	0
45374	2024	3	23	19	19	6	-0.9	1	-3.4	1578.8	13.4	-0.9	-0.9	0
45374	2024	3	23	20	20	6	-0.9	1.7	-2.9	1555.6	13.4	-0.5	-1.325	0
45374	2024	3	23	21	21	6	-0.9	2.2	-2.4	1524.4	13.4	-0.1	-1.63333	0
45374	2024	3	23	22	22	6	-0.8	3	-1.3	1465.5	13.4	0.3	-1.85833	0
45374	2024	3	23	23	23	6	-0.6	3.8	0	1378.5	13.4	0.8	-2.01667	0
45375	2024	3	24	24	24	7	-0.4	0.1	0.4	1316.6	25.2	1.2	-2.075	0
45375	2024	3	24	1	1	7	-0.6	4.5	0.7	1235.3	25.2	1.2	-2.43333	0
45375	2024	3	24	2	2	7	-0.4	5.1	0.5	1186.0	25.2	1.5	-2.29167	0
45375	2024	3	24	3	3	7	-0.1	5.6	0	1154.8	25.2	1.9	-2.09167	0
45375	2024	3	24	4	4	7	0.2	6	0.5	1130.6	25.2	2.3	-1.84167	0
45375	2024	3	24	5	5	7	0.6	7.2	0.4	1124.1	25.2	2.8	-1.60833	0
45375	2024	3	24	6	6	7	1.1	7.5	1	1130.5	25.2	3.4	-1.28333	0
45375	2024	3	24	7	7	7	1.5	8	1.7	1136.1	25.2	4.0	-0.93333	0
45375	2024	3	24	8	8	7	2.0	9	2.2	1158.8	25.2	4.6	-0.54167	0
45375	2024	3	24	9	9	7	2.5	8	3	1238.1	25.2	5.2	-0.11667	0
45375	2024	3	24	10	10	7	3.0	7.7	3.8	1312.9	25.2	5.7	0.308333	0
45375	2024	3	24	11	11	7	3.4	6.3	0.1	1362.1	25.2	6.0	0.758333	0
45375	2024	3	24	12	12	7	3.7	3.3	4.5	1423.6	25.2	6.3	1.183333	0
45375	2024	3	24	13	13	7	3.9	3	5.1	1418.9	25.2	6.5	1.191667	0
45375	2024	3	24	14	14	7	4.0	3	5.6	1385.5	25.2	6.4	1.533333	0
45375	2024	3	24	15	15	7	4.1	3.4	6	1357.0	25.2	6.2	1.9	0
45375	2024	3	24	16	16	7	4.2	3.6	7.2	1356.4	25.2	6.0	2.325	0
45375	2024	3	24	17	17	7	4.3	3.2	7.5	1408.3	25.2	5.8	2.825	0
45375	2024	3	24	18	18	7	4.4	3	8	1464.4	25.2	5.5	3.383333	0
45375	2024	3	24	19	19	7	4.6	2.6	9	1490.0	25.2	5.1	3.975	0
45375	2024	3	24	20	20	7	4.6	2	8	1527.1	25.2	4.7	4.558333	0
45375	2024	3	24	21	21	7	4.6	1.4	7.7	1539.6	25.2	4.1	5.166667	0
45375	2024	3	24	22	22	7	4.6	1	6.3	1485.7	25.2	3.5	5.65	0
45375	2024	3	24	23	23	7	4.5	0.6	3.3	1394.5	25.2	3.0	6.041667	0
45376	2024	3	25	24	24	1	4.4	1.4	3	1330.5	14.6	2.5	6.25	1
45376	2024	3	25	1	1	1	4.4	-0.2	3	1264.5	14.6	2.4	6.516667	1
45376	2024	3	25	2	1	1	4.2	-0.5	3.4	1248.9	14.6	2.1	6.391667	1
45376	2024	3	25	3	1	1	4.0	-0.7	3.6	1244.4	14.6	1.8	6.216667	1
45376	2024	3	25	4	1	1	3.7	-1	3.2	1254.1	14.6	1.5	6.033333	1
45376	2024	3	25	5	1	1	3.5	-1.2	3	1273.8	14.6	1.1	5.833333	1
45376	2024	3	25	6	1	1	3.1	-1.4	2.6	1339.4	14.6	0.7	5.5	1
45376	2024	3	25	7	1	1	2.7	-1.7	2	1487.0	14.6	0.3	5.125	1
45376	2024	3	25	8	1	1	2.3	-1.6	1.4	1609.6	14.6	0.0	4.675	1
45376	2024	3	25	9	1	1	1.9	-0.9	1	1623.8	14.6	-0.3	4.091667	1
45376	2024	3	25	10	1	1	1.5	0.1	0.6	1582.6	14.6	-0.5	3.541667	1
45376	2024	3	25	11	1	1	1.2	0.9	1.4	1542.2	14.6	-0.6	2.983333	1
45376	2024	3	25	12	1	1	1.0	1.8	-0.2	1513.8	14.6	-0.6	2.508333	1
45376	2024													

DATE	Year	Month	Day	HOUR	DOW	24hrAvgLa	g Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLa	g Weekdays
45377	2024	3	26	24	2	0.8	1.8	3.1	1296.9	19.8	2.2	-0.56667	1
45377	2024	3	26	1	2	0.8	1.2	2.8	1312.1	19.8	2.2	-0.53333	1
45377	2024	3	26	2	2	0.9	1.3	2	1289.8	19.8	2.1	-0.25833	1
45377	2024	3	26	3	2	1.0	1.2	2.7	1262.2	19.8	1.9	0.016667	1
45377	2024	3	26	4	2	1.1	0.9	2.3	1243.0	19.8	1.9	0.241667	1
45377	2024	3	26	5	2	1.1	1.2	1.6	1250.8	19.8	1.7	0.55	1
45377	2024	3	26	6	2	1.2	1.4	1.7	1303.7	19.8	1.6	0.841667	1
45377	2024	3	26	7	2	1.4	1.5	2.2	1426.2	19.8	1.6	1.091667	1
45377	2024	3	26	8	2	1.5	1.8	2.6	1538.1	19.8	1.6	1.375	1
45377	2024	3	26	9	2	1.6	1.8	2.2	1565.4	19.8	1.6	1.691667	1
45377	2024	3	26	10	2	1.7	2.3	1.7	1548.1	19.8	1.5	1.983333	1
45377	2024	3	26	11	2	1.8	2.5	1.8	1522.3	19.8	1.5	2.158333	1
45377	2024	3	26	12	2	1.9	3.4	1.2	1496.9	19.8	1.6	2.225	1
45377	2024	3	26	13	2	2.0	3.5	1.3	1480.0	19.8	1.7	2.225	1
45377	2024	3	26	14	2	2.0	3.6	1.2	1447.5	19.8	1.9	2.066667	1
45377	2024	3	26	15	2	2.0	2.8	0.9	1422.3	19.8	2.1	1.941667	1
45377	2024	3	26	16	2	2.1	2.8	1.2	1453.4	19.8	2.2	1.875	1
45377	2024	3	26	17	2	2.1	2.2	1.4	1510.4	19.8	2.4	1.725	1
45377	2024	3	26	18	2	2.1	1.9	1.5	1554.8	19.8	2.5	1.633333	1
45377	2024	3	26	19	2	2.1	1.7	1.8	1557.2	19.8	2.5	1.616667	1
45377	2024	3	26	20	2	2.1	1.6	1.8	1553.9	19.8	2.5	1.6	1
45377	2024	3	26	21	2	2.0	1.7	2.3	1529.2	19.8	2.5	1.566667	1
45377	2024	3	26	22	2	2.0	1.8	2.5	1459.7	19.8	2.5	1.5	1
45377	2024	3	26	23	2	2.0	1.7	3.4	1360.3	19.8	2.5	1.508333	1
45378	2024	3	27	24	3	2.0	6	3.5	1157.2	16.9	2.4	1.575	1
45378	2024	3	27	1	3	2.2	1.8	3.6	1264.9	16.9	2.6	1.708333	1
45378	2024	3	27	2	3	2.2	2	2.8	1239.1	16.9	2.5	1.9	1
45378	2024	3	27	3	3	2.2	2.2	2.8	1205.0	16.9	2.3	2.091667	1
45378	2024	3	27	4	3	2.3	2.4	2.2	1188.4	16.9	2.3	2.225	1
45378	2024	3	27	5	3	2.3	2.7	1.9	1184.6	16.9	2.3	2.383333	1
45378	2024	3	27	6	3	2.4	3.2	1.7	1225.0	16.9	2.3	2.466667	1
45378	2024	3	27	7	3	2.5	3.4	1.6	1340.3	16.9	2.4	2.508333	1
45378	2024	3	27	8	3	2.5	3.7	1.7	1446.6	16.9	2.5	2.525	1
45378	2024	3	27	9	3	2.6	3.5	1.8	1466.5	16.9	2.7	2.508333	1
45378	2024	3	27	10	3	2.7	3.3	1.7	1450.1	16.9	2.9	2.5	1
45378	2024	3	27	11	3	2.7	3.5	6	1436.5	16.9	3.0	2.458333	1
45378	2024	3	27	12	3	2.8	4	1.8	1413.8	16.9	3.1	2.391667	1
45378	2024	3	27	13	3	2.8	3.7	2	1401.5	16.9	3.0	2.608333	1
45378	2024	3	27	14	3	2.8	4.1	2.2	1374.4	16.9	3.1	2.466667	1
45378	2024	3	27	15	3	2.8	4.7	2.4	1349.7	16.9	3.3	2.333333	1
45378	2024	3	27	16	3	2.9	4.9	2.7	1358.4	16.9	3.5	2.283333	1
45378	2024	3	27	17	3	3.0	4.7	3.2	1380.7	16.9	3.7	2.25	1
45378	2024	3	27	18	3	3.1	4.9	3.4	1398.0	16.9	3.9	2.291667	1
45378	2024	3	27	19	3	3.2	4.9	3.7	1388.6	16.9	4.0	2.4	1
45378	2024	3	27	20	3	3.4	4.8	3.5	1387.8	16.9	4.2	2.541667	1
45378	2024	3	27	21	3	3.5	5	3.3	1372.8	16.9	4.3	2.716667	1
45378	2024	3	27	22	3	3.6	5	3.5	1310.4	16.9	4.4	2.866667	1
45378	2024	3	27	23	3	3.8	5.5	4	1219.6	16.9	4.5	2.991667	1
45379	2024	3	28	24	4	3.9	8.9	3.7	1012.3	17.2	4.7	3.141667	1
45379	2024	3	28	1	4	4.0	6.7	4.1	1104.2	17.2	5.1	2.975	1
45379	2024	3	28	2	4	4.2	6	4.7	1063.4	17.2	5.3	3.133333	1
45379	2024	3	28	3	4	4.4	6.7	4.9	1020.7	17.2	5.5	3.308333	1
45379	2024	3	28	4	4	4.6	7.3	4.7	997.3	17.2	5.7	3.516667	1
45379	2024	3	28	5	4	4.8	7.3	4.9	984.3	17.2	5.9	3.725	1
45379	2024	3	28	6	4	5.0	7.3	4.9	1018.3	17.2	6.1	3.891667	1
45379	2024	3	28	7	4	5.2	8.1	4.8	1114.7	17.2	6.3	4.033333	1
45379	2024	3	28	8	4	5.4	8.1	5	1217.5	17.2	6.6	4.158333	1
45379	2024	3	28	9	4	5.5	9	5	1247.9	17.2	6.8	4.25	1
45379	2024	3	28	10	4	5.8	9.6	5.5	1237.2	17.2	7.2	4.375	1
45379	2024	3	28	11	4	6.0	9.5	8.9	1221.6	17.2	7.5	4.516667	1
45379	2024	3	28	12	4	6.3	8.1	6.7	1214.0	17.2	7.9	4.683333	1
45379	2024	3	28	13	4	6.5	8.8	6	1208.4	17.2	7.8	5.091667	1
45379	2024	3	28	14	4	6.7	8.4	6.7	1182.0	17.2	8.0	5.341667	1
45379	2024	3	28	15	4	6.8	8.9	7.3	1155.4	17.2	8.2	5.5	1
45379	2024	3	28	16	4	7.0	9	7.3	1157.6	17.2	8.4	5.666667	1
45379	2024	3	28	17	4	7.2	8.4	7.3	1186.6	17.2	8.5	5.866667	1
45379	2024	3	28	18	4	7.3	10	8.1	1212.2	17.2	8.6	6.083333	1
45379	2024	3	28	19	4	7.6	9.5	8.1	1201.6	17.2	8.8	6.283333	1
45379	2024	3	28	20	4	7.7	7.9	9	1200.5	17.2	8.9	6.55	1
45379	2024	3	28	21	4	7.9	8.4	9.6	1180.9	17.2	8.9	6.825	1
45379	2024	3	28	22	4	8.0	8.8	9.5	1128.9	17.2	8.9	7.158333	1
45379	2024	3	28	23	4	8.2	11	8.1	1064.4	17.2	8.8	7.541667	1
45380	2024	3	29	24	5	8.4	3.6	8.8	1058.4	17.2	8.9	7.875	0
45380	2024	3	29	1	5	8.2	7.2	8.4	967.7	17.2	8.6	7.808333	0
45380	2024	3	29	2	5	8.2	7.1	8.9	930.8	17.2	8.4	7.983333	0
45380	2024	3	29	3	5	8.3	7.1	9	903.7	17.2	8.3	8.183333	0
45380	2024	3	29	4	5	8.3	6.8	8.4	888.9	17.2	8.2	8.366667	0
45380	2024	3	29	5	5	8.2	6.8	10	887.7	17.2	8.0	8.508333	0
45380	2024	3	29	6	5	8.2	6.8	9.5	910.0	17.2	7.9	8.6	0
45380	2024	3	29	7	5	8.2	6.9	7.9	950.6	17.2	7.6	8.825	0
45380	2024	3	29	8	5	8.2	6.8	8.4	999.4	17.2	7.4	8.941667	0
45380	2024	3	29	9	5	8.1	7.1	8.8	1070.9	17.2	7.3	8.925	0
45380	2024	3	29	10	5	8.0	7.1	11	1136.1	17.2	7.2	8.875	0
45380	2024	3	29	11	5	7.9	7.1	3.6	1189.4	17.2	7.0	8.808333	0
45380	2024	3	29	12	5	7.8	7.5	7.2	1218.1	17.2	6.7	8.933333	0
45380	2024	3	29	13	5	7.8	8	7.1	1218.2	17.2	7.0	8.558333	0
45380	2024	3	29	14	5	7.8	7.1	7.1	1189.0	17.2	7.1	8.425	0
45380	2024	3	29	15	5	7.7	8.6	6.8	1177.6	17.2	7.1	8.316667	0
45380	2024	3	29	16	5	7.7	8.7	6.8	1180.1	17.2	7.2	8.166667	0
45380	2024	3	29	17	5	7.7	7.8	6.8	1202.1	17.2	7.4	7.983333	0
45380	2024	3	29	18	5	7.7	7.3	6.9	1211.6	17.2	7.5	7.85	0
45380	2024	3	29	19	5	7.5	8.5	6.8	1190.7	17.2	7.5	7.583333	0
45380	2024	3	29	20	5	7.5	7.6	7.1	1183.3	17.2	7.6	7.366667	0
45380	2024	3	29	21	5	7.5	6.7	7.1	1170.0	17.2	7.7	7.275	0
45380	2024	3	29	22	5	7.4	5.9	7.1	1137.7	17.2	7.7	7.166667	0
45380	2024	3	29	23	5	7.3	4.6	7.5	1086.7	17.2	7.6	7.025	0
45381	2024	3	30	24	6	7.0	2.4	8	1231.9	22.2	7.4	6.7	0
45381	2024	3	30	1	6	7.0	3.2	7.1	1042.9	22.2	6.9	7.025	0
45381	2024	3	30	2	6	6.8	3.7	8.6	1028.1	22.2	6.5	7.091667	0
45381	2024	3	30	3	6	6.7	3.2	8.7	1017.5	22.2	6.3	7.091667	0
45381	2024	3	30	4	6	6.5	4	7.8	1012.6	22.2	5.8	7.216667	0
45381	2024	3	30	5	6	6.4	3.7	7.3	1022.3	22.2	5.4	7.375	0
45381	2												

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLag	Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLag	Weekdays
45381	2024	3	30	12	6	5.3	4.2	3.2	1365.3	22.2	3.3	7.358333	0
45381	2024	3	30	13	6	5.2	4.3	3.7	1347.2	22.2	3.5	6.933333	0
45381	2024	3	30	14	6	5.1	4.1	3.2	1318.7	22.2	3.6	6.533333	0
45381	2024	3	30	15	6	4.9	4.1	4	1307.1	22.2	3.6	6.25	0
45381	2024	3	30	16	6	4.7	3.4	3.7	1318.1	22.2	3.7	5.8	0
45381	2024	3	30	17	6	4.5	3.2	3.1	1362.6	22.2	3.6	5.408333	0
45381	2024	3	30	18	6	4.3	3.4	2.8	1387.8	22.2	3.6	5.066667	0
45381	2024	3	30	19	6	4.2	2.9	3	1384.9	22.2	3.6	4.716667	0
45381	2024	3	30	20	6	3.9	3.1	3.4	1394.2	22.2	3.6	4.241667	0
45381	2024	3	30	21	6	3.7	3.1	3.5	1399.3	22.2	3.6	3.858333	0
45381	2024	3	30	22	6	3.6	2.8	3.9	1356.8	22.2	3.6	3.583333	0
45381	2024	3	30	23	6	3.5	2.5	4.2	1291.0	22.2	3.5	3.383333	0
45382	2024	3	31	24	7	3.4	1.6	4.3	1199.2	12.0	3.4	3.325	0
45382	2024	3	31	1	7	3.3	1.9	4.1	1194.2	12.0	3.2	3.475	0
45382	2024	3	31	2	7	3.3	0.9	4.1	1170.9	12.0	3.0	3.566667	0
45382	2024	3	31	3	7	3.2	0.7	3.4	1157.3	12.0	2.7	3.6	0
45382	2024	3	31	4	7	3.1	-0.4	3.2	1156.4	12.0	2.5	3.675	0
45382	2024	3	31	5	7	2.9	-0.3	3.4	1169.4	12.0	2.1	3.625	0
45382	2024	3	31	6	7	2.7	0.1	2.9	1201.4	12.0	1.9	3.583333	0
45382	2024	3	31	7	7	2.6	-0.4	3.1	1251.3	12.0	1.6	3.608333	0
45382	2024	3	31	8	7	2.5	0.4	3.1	1311.4	12.0	1.3	3.616667	0
45382	2024	3	31	9	7	2.4	0.9	2.8	1337.8	12.0	1.1	3.625	0
45382	2024	3	31	10	7	2.2	2	2.5	1347.5	12.0	0.9	3.6	0
45382	2024	3	31	11	7	2.2	3.7	1.6	1338.3	12.0	0.8	3.541667	0
45382	2024	3	31	12	7	2.2	4	1.9	1340.6	12.0	0.9	3.425	0
45382	2024	3	31	13	7	2.2	4.2	0.9	1327.0	12.0	1.1	3.208333	0
45382	2024	3	31	14	7	2.2	4.9	0.7	1294.9	12.0	1.3	3.008333	0
45382	2024	3	31	15	7	2.2	4.5	-0.4	1267.0	12.0	1.7	2.741667	0
45382	2024	3	31	16	7	2.2	5.9	-0.3	1258.7	12.0	2.0	2.458333	0
45382	2024	3	31	17	7	2.3	6.3	0.1	1232.9	12.0	2.5	2.141667	0
45382	2024	3	31	18	7	2.4	6.4	-0.4	1200.9	12.0	3.0	1.85	0
45382	2024	3	31	19	7	2.6	5.6	0.4	1203.8	12.0	3.6	1.575	0
45382	2024	3	31	20	7	2.7	4.5	0.9	1263.0	12.0	4.1	1.3	0
45382	2024	3	31	21	7	2.7	3.2	2	1324.1	12.0	4.4	1.075	0
45382	2024	3	31	22	7	2.7	3.1	3.7	1308.5	12.0	4.6	0.891667	0
45382	2024	3	31	23	7	2.8	2.7	4	1249.6	12.0	4.7	0.825	0
45597	2024	11	1	24	5	12.8	10.5	14.7	927.8	8.2	13.6	11.98333	1
45597	2024	11	1	1	5	12.7	12.1	15.2	865.3	8.2	13.3	12.16667	1
45597	2024	11	1	2	5	12.8	12	15.1	842.2	8.2	13.1	12.45	1
45597	2024	11	1	3	5	12.8	11.3	16.1	823.5	8.2	12.8	12.84167	1
45597	2024	11	1	4	5	12.9	9.6	15.3	818.8	8.2	12.5	13.225	1
45597	2024	11	1	5	5	12.8	9.9	13.4	830.8	8.2	12.0	13.64167	1
45597	2024	11	1	6	5	12.7	10.5	12.2	875.2	8.2	11.5	13.95	1
45597	2024	11	1	7	5	12.7	10.6	11.5	984.8	8.2	11.3	14.06667	1
45597	2024	11	1	8	5	12.6	10.7	11.7	1101.4	8.2	11.1	14.025	1
45597	2024	11	1	9	5	12.5	12.9	11.8	1130.8	8.2	11.1	13.90833	1
45597	2024	11	1	10	5	12.5	14.3	12.1	1116.5	8.2	11.2	13.80833	1
45597	2024	11	1	11	5	12.5	15	10.5	1121.5	8.2	11.4	13.70833	1
45597	2024	11	1	12	5	12.6	15.2	12.1	1123.3	8.2	11.6	13.6	1
45597	2024	11	1	13	5	12.7	16.5	12	1120.2	8.2	12.0	13.3	1
45597	2024	11	1	14	5	12.7	17.1	11.3	1114.6	8.2	12.4	13.08333	1
45597	2024	11	1	15	5	12.8	16.5	9.6	1104.3	8.2	12.8	12.81667	1
45597	2024	11	1	16	5	12.9	15.3	9.9	1119.6	8.2	13.2	12.5	1
45597	2024	11	1	17	5	12.8	15.4	10.5	1146.1	8.2	13.7	11.95833	1
45597	2024	11	1	18	5	12.8	15.1	10.6	1171.0	8.2	14.2	11.50833	1
45597	2024	11	1	19	5	12.9	14.3	10.7	1184.6	8.2	14.6	11.26667	1
45597	2024	11	1	20	5	13.0	14.5	12.9	1152.8	8.2	14.9	11.13333	1
45597	2024	11	1	21	5	13.1	15.3	14.3	1096.9	8.2	15.2	11.06667	1
45597	2024	11	1	22	5	13.3	14.5	15	1040.1	8.2	15.4	11.16667	1
45597	2024	11	1	23	5	13.4	12.8	15.2	971.9	8.2	15.4	11.375	1
45598	2024	11	2	24	6	13.4	2.4	16.5	1089.6	12.8	15.2	11.61667	0
45598	2024	11	2	1	6	13.1	8.5	17.1	899.7	12.8	14.1	12.00833	0
45598	2024	11	2	2	6	12.9	8.2	16.5	870.2	12.8	13.5	12.375	0
45598	2024	11	2	3	6	12.8	7.7	15.3	851.4	12.8	12.7	12.8	0
45598	2024	11	2	4	6	12.6	7.5	15.4	842.8	12.8	12.0	13.23333	0
45598	2024	11	2	5	6	12.5	7.2	15.1	849.1	12.8	11.4	13.70833	0
45598	2024	11	2	6	6	12.4	5.8	14.3	885.3	12.8	10.7	14.16667	0
45598	2024	11	2	7	6	12.2	4.7	14.5	950.6	12.8	9.9	14.55	0
45598	2024	11	2	8	6	12.0	4.5	15.3	1033.8	12.8	9.1	14.85833	0
45598	2024	11	2	9	6	11.7	6.2	14.5	1116.5	12.8	8.3	15.175	0
45598	2024	11	2	10	6	11.4	7.6	12.8	1164.8	12.8	7.5	15.375	0
45598	2024	11	2	11	6	11.2	6.7	2.4	1190.6	12.8	6.9	15.39167	0
45598	2024	11	2	12	6	10.8	6.7	8.5	1208.1	12.8	6.4	15.20833	0
45598	2024	11	2	13	6	10.5	7	8.2	1206.9	12.8	6.8	14.14167	0
45598	2024	11	2	14	6	10.1	7.5	7.7	1185.2	12.8	6.7	13.475	0
45598	2024	11	2	15	6	9.7	7.8	7.5	1157.8	12.8	6.6	12.73333	0
45598	2024	11	2	16	6	9.3	7.2	7.2	1157.9	12.8	6.6	12	0
45598	2024	11	2	17	6	9.0	7.1	5.8	1208.8	12.8	6.6	11.35	0
45598	2024	11	2	18	6	8.6	6.3	4.7	1275.7	12.8	6.6	10.66667	0
45598	2024	11	2	19	6	8.3	5.6	4.5	1310.9	12.8	6.6	9.891667	0
45598	2024	11	2	20	6	7.9	5.2	6.2	1292.5	12.8	6.7	9.091667	0
45598	2024	11	2	21	6	7.5	4.7	7.6	1255.2	12.8	6.7	8.258333	0
45598	2024	11	2	22	6	7.1	3.6	6.7	1208.1	12.8	6.6	7.5	0
45598	2024	11	2	23	6	6.6	3.4	6.7	1146.2	12.8	6.3	6.925	0
45599	2024	11	3	24	7	6.2	0.9	7	1128.3	11.7	6.0	6.416667	0
45599	2024	11	3	1	7	6.2	3.3	7.5	1031.0	11.7	5.5	6.775	0
45599	2024	11	3	2	7	5.9	3.1	7.8	1002.7	11.7	5.2	6.65	0
45599	2024	11	3	3	7	5.7	1.3	7.2	1007.8	11.7	4.9	6.591667	0
45599	2024	11	3	4	7	5.5	2.1	7.1	1007.9	11.7	4.3	6.6	0
45599	2024	11	3	5	7	5.2	2.4	6.3	1023.0	11.7	3.9	6.575	0
45599	2024	11	3	6	7	5.0	2.5	5.6	1060.5	11.7	3.5	6.566667	0
45599	2024	11	3	7	7	4.9	1.8	5.2	1119.6	11.7	3.2	6.608333	0
45599	2024	11	3	8	7	4.8	1.9	4.7	1199.2	11.7	2.9	6.683333	0
45599	2024	11	3	9	7	4.7	2.7	3.6	1261.9	11.7	2.6	6.741667	0
45599	2024	11	3	10	7	4.5	3.6	3.4	1284.1	11.7	2.4	6.616667	0
45599	2024	11	3	11	7	4.4	4.8	0.9	1260.5	11.7	2.4	6.283333	0
45599	2024	11	3	12	7	4.3	5.2	3.3	1240.7	11.7	2.5	6.008333	0
45599	2024	11	3	13	7	4.2	5.9	3.1	1219.7	11.7	2.9	5.525	0
45599	2024	11	3	14	7	4.2	6.2	1.3	1192.9	11.7	3.1	5.216667	0
45599	2024	11	3	15	7	4.1	6.8	2.1	1195.3	11.7	3.4	4.85	0
45599	2024	11	3	16	7	4.1	6.6	2.4	1247.6	11.7	3.8	4.308333	0
45599	2024												

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLag	Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLag	Weekdays
45600	2024	11	11	4	24	1	3.7	3.3	5.9	1182.5	8.5	4.8 2.533333	1
45600	2024	11	11	4	1	1	3.8	0.9	6.2	1083.6	8.5	4.6 2.891667	1
45600	2024	11	11	4	2	1	3.7	0.9	6.8	1071.8	8.5	4.2 3.108333	1
45600	2024	11	11	4	3	1	3.6	0.2	6.6	1070.4	8.5	3.8 3.366667	1
45600	2024	11	11	4	4	1	3.5	-0.3	5.4	1082.3	8.5	3.2 3.825	1
45600	2024	11	11	4	5	1	3.4	-0.5	4.4	1109.8	8.5	2.6 4.2	1
45600	2024	11	11	4	6	1	3.3	-0.7	4.1	1189.4	8.5	2.2 4.45	1
45600	2024	11	11	4	7	1	3.2	-1.1	4.2	1337.8	8.5	1.7 4.608333	1
45600	2024	11	11	4	8	1	3.0	-0.8	4	1444.2	8.5	1.3 4.8	1
45600	2024	11	11	4	9	1	2.9	1.2	3	1416.3	8.5	0.9 4.991667	1
45600	2024	11	11	4	10	1	2.9	3.9	1.6	1343.6	8.5	0.6 5.1	1
45600	2024	11	11	4	11	1	2.9	5.3	3.3	1285.9	8.5	0.7 5.05	1
45600	2024	11	11	4	12	1	2.9	6.4	0.9	1247.4	8.5	1.0 4.783333	1
45600	2024	11	11	4	13	1	3.0	6.9	0.9	1217.2	8.5	1.3 4.625	1
45600	2024	11	11	4	14	1	3.0	7.5	0.2	1193.6	8.5	1.8 4.208333	1
45600	2024	11	11	4	15	1	3.1	8.2	-0.3	1190.4	8.5	2.3 3.766667	1
45600	2024	11	11	4	16	1	3.1	8.1	-0.5	1241.0	8.5	3.0 3.216667	1
45600	2024	11	11	4	17	1	3.2	6.9	-0.7	1341.3	8.5	3.7 2.641667	1
45600	2024	11	11	4	18	1	3.2	5.5	-1.1	1457.5	8.5	4.3 2.15	1
45600	2024	11	11	4	19	1	3.3	3.4	-0.8	1445.7	8.5	4.8 1.725	1
45600	2024	11	11	4	20	1	3.3	3	1.2	1425.5	8.5	5.2 1.291667	1
45600	2024	11	11	4	21	1	3.2	2	3.9	1388.7	8.5	5.5 0.875	1
45600	2024	11	11	4	22	1	3.1	2.3	5.3	1319.8	8.5	5.6 0.641667	1
45600	2024	11	11	4	23	1	3.1	2.5	6.4	1237.8	8.5	5.5 0.716667	1
45601	2024	11	11	5	24	2	3.1	12	6.9	1003.5	12.7	5.2 1.025	1
45601	2024	11	11	5	1	2	3.5	3.6	7.5	1135.7	12.7	5.7 1.283333	1
45601	2024	11	11	5	2	2	3.6	4.1	8.2	1094.1	12.7	5.4 1.783333	1
45601	2024	11	11	5	3	2	3.7	4.4	8.1	1066.9	12.7	5.1 2.333333	1
45601	2024	11	11	5	4	2	3.9	4.2	6.9	1056.1	12.7	4.8 3	1
45601	2024	11	11	5	5	2	4.1	3.8	5.5	1072.5	12.7	4.5 3.7	1
45601	2024	11	11	5	6	2	4.3	3.9	3.4	1133.9	12.7	4.2 4.316667	1
45601	2024	11	11	5	7	2	4.5	3.8	3	1258.6	12.7	4.1 4.833333	1
45601	2024	11	11	5	8	2	4.7	4.6	2	1354.2	12.7	4.1 5.208333	1
45601	2024	11	11	5	9	2	4.9	5.6	2.3	1374.1	12.7	4.3 5.525	1
45601	2024	11	11	5	10	2	5.1	6.7	2.5	1365.0	12.7	4.6 5.591667	1
45601	2024	11	11	5	11	2	5.2	7.3	12	1350.6	12.7	4.9 5.458333	1
45601	2024	11	11	5	12	2	5.3	7.9	3.6	1346.1	12.7	5.3 5.225	1
45601	2024	11	11	5	13	2	5.3	8.5	4.1	1339.9	12.7	5.0 5.691667	1
45601	2024	11	11	5	14	2	5.4	9.1	4.4	1323.7	12.7	5.4 5.416667	1
45601	2024	11	11	5	15	2	5.5	9.7	4.2	1304.1	12.7	5.8 5.133333	1
45601	2024	11	11	5	16	2	5.5	10.3	3.8	1308.4	12.7	6.3 4.816667	1
45601	2024	11	11	5	17	2	5.6	11	3.9	1351.8	12.7	6.8 4.491667	1
45601	2024	11	11	5	18	2	5.8	11.3	3.8	1394.7	12.7	7.4 4.233333	1
45601	2024	11	11	5	19	2	6.0	11.3	4.6	1346.9	12.7	8.0 4.1	1
45601	2024	11	11	5	20	2	6.4	11.5	5.6	1292.4	12.7	8.6 4.133333	1
45601	2024	11	11	5	21	2	6.7	11.7	6.7	1233.4	12.7	9.2 4.266667	1
45601	2024	11	11	5	22	2	7.1	11.9	7.3	1163.6	12.7	9.7 4.566667	1
45601	2024	11	11	5	23	2	7.5	12	7.9	1073.2	12.7	10.1 4.933333	1
45602	2024	11	11	6	24	3	7.9	15.5	8.5	904.6	12.9	10.5 5.333333	1
45602	2024	11	11	6	1	3	8.1	11.7	9.1	936.4	12.9	11.2 4.991667	1
45602	2024	11	11	6	2	3	8.4	12.1	9.7	889.1	12.9	11.4 5.4	1
45602	2024	11	11	6	3	3	8.7	11.5	10.3	866.7	12.9	11.7 5.816667	1
45602	2024	11	11	6	4	3	9.0	11.7	11	862.7	12.9	11.8 6.258333	1
45602	2024	11	11	6	5	3	9.4	12.2	11.3	869.7	12.9	11.9 6.766667	1
45602	2024	11	11	6	6	3	9.7	12.9	11.3	923.0	12.9	12.0 7.366667	1
45602	2024	11	11	6	7	3	10.1	12.9	11.5	1035.0	12.9	12.2 7.983333	1
45602	2024	11	11	6	8	3	10.5	12.6	11.7	1128.0	12.9	12.3 8.608333	1
45602	2024	11	11	6	9	3	10.8	12.9	11.9	1121.2	12.9	12.4 9.183333	1
45602	2024	11	11	6	10	3	11.1	14.6	12	1091.7	12.9	12.5 9.691667	1
45602	2024	11	11	6	11	3	11.4	15.6	15.5	1072.9	12.9	12.7 10.125	1
45602	2024	11	11	6	12	3	11.8	16.9	11.7	1058.8	12.9	13.0 10.51667	1
45602	2024	11	11	6	13	3	12.1	17.8	12.1	1044.0	12.9	13.1 11.15	1
45602	2024	11	11	6	14	3	12.5	19.3	11.5	1021.3	12.9	13.6 11.41667	1
45602	2024	11	11	6	15	3	13.0	19.9	11.7	1019.4	12.9	14.2 11.66667	1
45602	2024	11	11	6	16	3	13.4	19.6	12.2	1053.7	12.9	14.9 11.81667	1
45602	2024	11	11	6	17	3	13.8	18.8	12.9	1128.2	12.9	15.6 11.93333	1
45602	2024	11	11	6	18	3	14.1	17	12.9	1193.9	12.9	16.2 12.03333	1
45602	2024	11	11	6	19	3	14.3	16.9	12.6	1171.1	12.9	16.5 12.16667	1
45602	2024	11	11	6	20	3	14.6	17	12.9	1138.7	12.9	16.8 12.3	1
45602	2024	11	11	6	21	3	14.8	16.3	14.6	1098.8	12.9	17.2 12.39167	1
45602	2024	11	11	6	22	3	15.0	15.8	15.6	1043.1	12.9	17.5 12.49167	1
45602	2024	11	11	6	23	3	15.1	15.8	16.9	966.4	12.9	17.6 12.71667	1
45603	2024	11	11	7	24	4	15.3	4.9	17.8	1096.9	8.4	17.6 13.01667	1
45603	2024	11	11	7	1	4	14.9	13.5	19.3	858.3	8.4	16.6 13.13333	1
45603	2024	11	11	7	2	4	14.9	11.6	19.9	830.8	8.4	16.2 13.64167	1
45603	2024	11	11	7	3	4	14.9	10.5	19.6	819.6	8.4	15.6 14.24167	1
45603	2024	11	11	7	4	4	14.9	9.6	18.8	820.3	8.4	14.8 14.94167	1
45603	2024	11	11	7	5	4	14.8	9.5	17	837.4	8.4	14.0 15.6	1
45603	2024	11	11	7	6	4	14.7	8.9	16.9	907.4	8.4	13.2 16.15	1
45603	2024	11	11	7	7	4	14.5	7.7	17	1041.7	8.4	12.5 16.49167	1
45603	2024	11	11	7	8	4	14.3	6.4	16.3	1146.8	8.4	11.8 16.825	1
45603	2024	11	11	7	9	4	14.0	8.9	15.8	1167.3	8.4	10.9 17.19167	1
45603	2024	11	11	7	10	4	13.9	9.3	15.8	1159.0	8.4	10.3 17.475	1
45603	2024	11	11	7	11	4	13.6	10.4	4.9	1152.3	8.4	9.7 17.575	1
45603	2024	11	11	7	12	4	13.4	11	13.5	1145.4	8.4	9.3 17.59167	1
45603	2024	11	11	7	13	4	13.2	10.9	11.6	1140.5	8.4	9.8 16.59167	1
45603	2024	11	11	7	14	4	12.9	10.3	10.5	1124.5	8.4	9.6 16.23333	1
45603	2024	11	11	7	15	4	12.5	10	9.6	1123.7	8.4	9.5 15.59167	1
45603	2024	11	11	7	16	4	12.1	9.7	9.5	1160.2	8.4	9.4 14.80833	1
45603	2024	11	11	7	17	4	11.7	8.9	8.9	1246.3	8.4	9.4 13.975	1
45603	2024	11	11	7	18	4	11.3	7.8	7.7	1328.6	8.4	9.4 13.2	1
45603	2024	11	11	7	19	4	10.9	7.2	6.4	1327.9	8.4	9.3 12.525	1
45603	2024	11	11	7	20	4	10.5	6.5	8.9	1305.1	8.4	9.2 11.75833	1
45603	2024	11	11	7	21	4	10.1	6.1	9.3	1267.3	8.4	9.2 10.875	1
45603	2024	11	11	7	22	4	9.6	5.9	10.4	1209.4	8.4	9.0 10.25833	1
45603	2024	11	11	7	23	4	9.2	5.1	11	1141.6	8.4	8.7 9.716667	1
45603	2024	11	11	7	24	4	8.8	4.9	10.9	1096.9	8.4	8.3 9.266667	1
45604	2024	11	11	8	1	5	8.8	4.3	10.3	1060.9	14.0	7.8 9.775	1
45604	2024	11	11	8	2	5	8.4	4.7					

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLag	Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLag	Weekdays
45604	2024	11	8	12	5	6.5	10.4	4.3	1156.1	14.0	4.7	8.283333	1
45604	2024	11	8	13	5	6.5	11.1	4.7	1153.4	14.0	5.2	7.775	1
45604	2024	11	8	14	5	6.5	11.1	4.5	1161.6	14.0	5.8	7.225	1
45604	2024	11	8	15	5	6.5	10.6	4	1165.2	14.0	6.3	6.758333	1
45604	2024	11	8	16	5	6.6	10.8	4.2	1194.5	14.0	6.8	6.3	1
45604	2024	11	8	17	5	6.6	10.5	3.4	1255.9	14.0	7.4	5.825	1
45604	2024	11	8	18	5	6.7	10.2	2.9	1312.3	14.0	7.9	5.433333	1
45604	2024	11	8	19	5	6.8	10.4	3.1	1281.8	14.0	8.5	5.066667	1
45604	2024	11	8	20	5	6.9	9.7	4.6	1243.9	14.0	9.1	4.708333	1
45604	2024	11	8	21	5	7.0	8.9	7.1	1203.1	14.0	9.6	4.425	1
45604	2024	11	8	22	5	7.2	8.5	9.2	1151.1	14.0	10.0	4.3	1
45604	2024	11	8	23	5	7.3	8.4	10.4	1095.9	14.0	10.1	4.4	1
45604	2024	11	8	24	5	7.4	7.5	11.1	1062.3	14.0	10.1	4.741667	1
45605	2024	11	9	1	6	7.5	6.7	11.1	1025.8	23.7	9.8	5.2	0
45605	2024	11	9	2	6	7.6	6	10.6	991.2	23.7	9.4	5.766667	0
45605	2024	11	9	3	6	7.7	5.3	10.8	972.5	23.7	9.0	6.3	0
45605	2024	11	9	4	6	7.7	5	10.5	965.9	23.7	8.6	6.808333	0
45605	2024	11	9	5	6	7.7	6	10.2	975.3	23.7	8.1	7.375	0
45605	2024	11	9	6	6	7.8	5.6	10.4	1010.9	23.7	7.7	7.9	0
45605	2024	11	9	7	6	7.9	5	9.7	1077.8	23.7	7.3	8.466667	0
45605	2024	11	9	8	6	8.0	4.3	8.9	1154.8	23.7	6.9	9.091667	0
45605	2024	11	9	9	6	8.0	4.5	8.5	1237.8	23.7	6.4	9.641667	0
45605	2024	11	9	10	6	8.0	4.4	8.4	1291.5	23.7	6.1	10	0
45605	2024	11	9	11	6	7.9	4.8	7.5	1297.2	23.7	5.7	10.11667	0
45605	2024	11	9	12	6	7.7	4.7	6.7	1291.7	23.7	5.4	10.05	0
45605	2024	11	9	13	6	7.5	4.1	6	1280.8	23.7	5.2	9.808333	0
45605	2024	11	9	14	6	7.2	5.7	5.3	1279.3	23.7	5.0	9.441667	0
45605	2024	11	9	15	6	7.0	1.5	5	1271.9	23.7	5.0	9.016667	0
45605	2024	11	9	16	6	6.6	4.4	6	1306.4	23.7	4.6	8.575	0
45605	2024	11	9	17	6	6.3	3	5.6	1395.5	23.7	4.6	8.091667	0
45605	2024	11	9	18	6	6.0	2.8	5	1479.7	23.7	4.3	7.716667	0
45605	2024	11	9	19	6	5.7	2.6	4.3	1453.6	23.7	4.1	7.333333	0
45605	2024	11	9	20	6	5.4	2.7	4.5	1406.1	23.7	3.9	6.883333	0
45605	2024	11	9	21	6	5.1	2.8	4.4	1353.6	23.7	3.8	6.433333	0
45605	2024	11	9	22	6	4.8	2.6	4.8	1299.0	23.7	3.6	6.066667	0
45605	2024	11	9	23	6	4.6	2.2	4.7	1236.0	23.7	3.5	5.725	0
45605	2024	11	9	24	6	4.3	1.9	4.1	1174.9	23.7	3.3	5.425	0
45606	2024	11	10	1	7	4.1	2	5.7	1124.9	10.5	3.0	5.191667	0
45606	2024	11	10	2	7	3.9	1.8	1.5	1091.9	10.5	2.9	4.975	0
45606	2024	11	10	3	7	3.7	1.5	4.4	1081.4	10.5	2.5	4.95	0
45606	2024	11	10	4	7	3.6	1.3	3	1080.2	10.5	2.5	4.633333	0
45606	2024	11	10	5	7	3.4	1.6	2.8	1088.2	10.5	2.3	4.583333	0
45606	2024	11	10	6	7	3.2	1.3	2.6	1126.6	10.5	2.2	4.333333	0
45606	2024	11	10	7	7	3.1	0.2	2.7	1186.7	10.5	2.0	4.1	0
45606	2024	11	10	8	7	2.9	0	2.8	1253.1	10.5	1.8	3.9	0
45606	2024	11	10	9	7	2.7	1	2.6	1290.3	10.5	1.6	3.766667	0
45606	2024	11	10	10	7	2.5	2.3	2.2	1310.1	10.5	1.5	3.625	0
45606	2024	11	10	11	7	2.5	2.6	1.9	1251.4	10.5	1.4	3.475	0
45606	2024	11	10	12	7	2.4	4.7	2	1202.3	10.5	1.5	3.258333	0
45606	2024	11	10	13	7	2.4	7.1	1.8	1164.6	10.5	1.7	3.025	0
45606	2024	11	10	14	7	2.5	8.2	1.5	1127.8	10.5	2.1	2.85	0
45606	2024	11	10	15	7	2.6	9.2	1.3	1110.5	10.5	2.7	2.525	0
45606	2024	11	10	16	7	2.9	9.5	1.6	1142.6	10.5	3.3	2.525	0
45606	2024	11	10	17	7	3.1	9.1	1.3	1248.1	10.5	4.0	2.266667	0
45606	2024	11	10	18	7	3.4	7.4	0.2	1351.2	10.5	4.6	2.15	0
45606	2024	11	10	19	7	3.6	6.4	0	1333.2	10.5	5.1	2.025	0
45606	2024	11	10	20	7	3.7	6.3	1	1302.8	10.5	5.6	1.825	0
45606	2024	11	10	21	7	3.9	6	2.3	1265.4	10.5	6.2	1.6	0
45606	2024	11	10	22	7	4.0	5.3	2.6	1207.6	10.5	6.6	1.45	0
45606	2024	11	10	23	7	4.1	5	4.7	1139.4	10.5	6.8	1.425	0
45606	2024	11	10	24	7	4.2	5.2	7.1	1081.2	10.5	7.0	1.458333	0
45607	2024	11	11	1	1	4.4	5.7	8.2	1028.5	13.6	7.1	1.691667	0
45607	2024	11	11	2	1	4.5	5.3	9.2	994.1	13.6	6.9	2.116667	0
45607	2024	11	11	3	1	4.7	5.8	9.5	978.2	13.6	6.7	2.65	0
45607	2024	11	11	4	1	4.9	6.1	9.1	972.9	13.6	6.4	3.291667	0
45607	2024	11	11	5	1	5.1	6.3	7.4	976.3	13.6	6.1	3.975	0
45607	2024	11	11	6	1	5.3	6.8	6.4	999.6	13.6	5.9	4.6	0
45607	2024	11	11	7	1	5.5	7.8	6.3	1039.4	13.6	5.9	5.108333	0
45607	2024	11	11	8	1	5.8	9.7	6	1089.7	13.6	6.0	5.625	0
45607	2024	11	11	9	1	6.2	9.8	5.3	1160.0	13.6	6.3	6.15	0
45607	2024	11	11	10	1	6.6	9.6	5	1222.9	13.6	6.6	6.566667	0
45607	2024	11	11	11	1	6.9	10.3	5.2	1242.7	13.6	6.9	6.816667	0
45607	2024	11	11	12	1	7.2	11.2	5.7	1256.1	13.6	7.4	7.016667	0
45607	2024	11	11	13	1	7.5	11.6	5.3	1278.2	13.6	7.9	7.058333	0
45607	2024	11	11	14	1	7.7	11.8	5.8	1258.3	13.6	8.4	6.941667	0
45607	2024	11	11	15	1	7.8	12.5	6.1	1237.8	13.6	8.9	6.7	0
45607	2024	11	11	16	1	7.9	12.4	6.3	1231.6	13.6	9.5	6.416667	0
45607	2024	11	11	17	1	8.1	12.5	6.8	1275.0	13.6	10.0	6.133333	0
45607	2024	11	11	18	1	8.2	12	7.8	1317.1	13.6	10.5	5.9	0
45607	2024	11	11	19	1	8.4	11.8	9.7	1267.6	13.6	10.9	5.85	0
45607	2024	11	11	20	1	8.6	11.2	9.8	1214.8	13.6	11.3	5.966667	0
45607	2024	11	11	21	1	8.8	10.6	9.6	1161.6	13.6	11.4	6.25	0
45607	2024	11	11	22	1	9.0	9.8	10.3	1092.4	13.6	11.5	6.566667	0
45607	2024	11	11	23	1	9.2	9.8	11.2	1017.3	13.6	11.5	6.925	0
45607	2024	11	11	24	1	9.4	9.7	11.6	955.5	13.6	11.4	7.366667	0
45608	2024	11	12	1	2	9.6	9.8	11.8	913.7	12.0	11.3	7.866667	1
45608	2024	11	12	2	2	9.8	9.6	12.5	884.8	12.0	11.2	8.358333	1
45608	2024	11	12	3	2	9.9	9.1	12.4	868.2	12.0	11.0	8.9	1
45608	2024	11	12	4	2	10.1	8.8	12.5	865.1	12.0	10.7	9.458333	1
45608	2024	11	12	5	2	10.2	8.6	12	877.6	12.0	10.4	9.983333	1
45608	2024	11	12	6	2	10.3	8.4	11.8	933.3	12.0	10.1	10.5	1
45608	2024	11	12	7	2	10.4	8.6	11.2	1051.2	12.0	9.8	10.93333	1
45608	2024	11	12	8	2	10.4	8.7	10.6	1156.5	12.0	9.5	11.26667	1
45608	2024	11	12	9	2	10.3	9	9.8	1188.5	12.0	9.3	11.39167	1
45608	2024	11	12	10	2	10.3	9.2	9.8	1184.1	12.0	9.2	11.45833	1
45608	2024	11	12	11	2	10.3	9.4	9.7	1168.9	12.0	9.1	11.475	1
45608	2024	11	12	12	2	10.3	9.8	9.8	1157.0	12.0	9.1	11.43333	1
45608	2024	11	12	13	2	10.2	11.1	9.6	1140.8	12.0	9.1	11.30833	1
45608	2024	11	12	14	2	10.2	11.6	9.1	1128.2	12.0	9.2	11.15833	1
45608	2024	11	12	15	2	10.2	10.8	8.8	1123.0	12.0	9.4	10.975	1
45608	2024	11	12	16	2	10.1	12	8.6	1165.4	12.0	9.5	10.69167	1
45608	2024	11	12	17	2	10.1							

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLag	Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLag	Weekdays	
45608	2024	11	12	12	24	2	8.9	3.5	11.1	1137.7	12.0	8.8	9.075	1
45609	2024	11	13	13	1	3	8.7	3.3	11.6	1101.3	31.9	8.2	9.083333	1
45609	2024	11	13	2	3	3	8.4	3.4	10.8	1079.5	31.9	7.6	9.191667	1
45609	2024	11	13	3	3	3	8.1	3.3	12	1064.7	31.9	6.9	9.358333	1
45609	2024	11	13	4	3	3	7.9	3	11.1	1064.8	31.9	6.3	9.5	1
45609	2024	11	13	5	3	3	7.6	2.8	11.7	1089.4	31.9	5.5	9.766667	1
45609	2024	11	13	6	3	3	7.4	2.7	8.2	1156.9	31.9	4.8	9.975	1
45609	2024	11	13	7	3	3	7.2	2.4	5.7	1292.3	31.9	4.1	10.25	1
45609	2024	11	13	8	3	3	6.9	2.1	4.6	1411.9	31.9	3.6	10.21667	1
45609	2024	11	13	9	3	3	6.6	2.1	4.3	1455.0	31.9	3.3	9.966667	1
45609	2024	11	13	10	3	3	6.3	2.1	4.1	1454.4	31.9	3.1	9.6	1
45609	2024	11	13	11	3	3	6.0	2.4	3.5	1435.0	31.9	2.9	9.191667	1
45609	2024	11	13	12	3	3	5.8	2.7	3.3	1423.1	31.9	2.8	8.75	1
45609	2024	11	13	13	3	3	5.5	2.8	3.4	1410.1	31.9	2.7	8.225	1
45609	2024	11	13	14	3	3	5.1	2.9	3.3	1402.6	31.9	2.7	7.575	1
45609	2024	11	13	15	3	3	4.8	3.1	3	1404.1	31.9	2.6	6.891667	1
45609	2024	11	13	16	3	3	4.4	2.3	2.8	1447.8	31.9	2.6	6.266667	1
45609	2024	11	13	17	3	3	4.0	1.6	2.7	1550.7	31.9	2.5	5.516667	1
45609	2024	11	13	18	3	3	3.6	0.7	2.4	1647.7	31.9	2.4	4.825	1
45609	2024	11	13	19	3	3	3.2	0.4	2.1	1624.3	31.9	2.3	4.075	1
45609	2024	11	13	20	3	3	2.8	0.3	2.1	1597.7	31.9	2.1	3.591667	1
45609	2024	11	13	21	3	3	2.6	0.5	2.1	1548.9	31.9	2.0	3.291667	1
45609	2024	11	13	22	3	3	2.5	0.6	2.4	1475.2	31.9	1.8	3.083333	1
45609	2024	11	13	23	3	3	2.3	0.8	2.7	1383.8	31.9	1.7	2.9	1
45609	2024	11	13	24	3	3	2.2	0.5	2.8	1329.1	31.9	1.6	2.758333	1
45610	2024	11	14	1	4	4	2.0	1	2.9	1276.7	27.9	1.4	2.691667	1
45610	2024	11	14	2	4	4	1.9	1.4	3.1	1236.9	27.9	1.2	2.65	1
45610	2024	11	14	3	4	4	1.9	1.2	2.3	1208.8	27.9	1.1	2.608333	1
45610	2024	11	14	4	4	4	1.8	1	1.6	1206.1	27.9	0.9	2.591667	1
45610	2024	11	14	5	4	4	1.7	1	0.7	1217.6	27.9	0.8	2.533333	1
45610	2024	11	14	6	4	4	1.6	1	0.4	1273.4	27.9	0.8	2.433333	1
45610	2024	11	14	7	4	4	1.5	0.9	0.3	1397.2	27.9	0.8	2.266667	1
45610	2024	11	14	8	4	4	1.5	1	0.5	1497.7	27.9	0.9	2.1	1
45610	2024	11	14	9	4	4	1.4	1.2	0.6	1508.1	27.9	0.9	1.95	1
45610	2024	11	14	10	4	4	1.4	2.2	0.8	1484.9	27.9	1.0	1.816667	1
45610	2024	11	14	11	4	4	1.4	2.4	0.5	1459.0	27.9	1.1	1.691667	1
45610	2024	11	14	12	4	4	1.4	3.2	1	1444.3	27.9	1.2	1.558333	1
45610	2024	11	14	13	4	4	1.4	3.2	1.4	1439.9	27.9	1.5	1.375	1
45610	2024	11	14	14	4	4	1.4	3.6	1.2	1426.1	27.9	1.6	1.225	1
45610	2024	11	14	15	4	4	1.5	3.1	1	1433.8	27.9	1.8	1.1	1
45610	2024	11	14	16	4	4	1.5	2.8	1	1465.9	27.9	2.0	0.941667	1
45610	2024	11	14	17	4	4	1.5	2.5	1	1540.4	27.9	2.1	0.833333	1
45610	2024	11	14	18	4	4	1.5	1.7	0.9	1608.1	27.9	2.3	0.783333	1
45610	2024	11	14	19	4	4	1.6	1.9	1	1581.2	27.9	2.3	0.808333	1
45610	2024	11	14	20	4	4	1.6	1.7	1.2	1545.9	27.9	2.4	0.85	1
45610	2024	11	14	21	4	4	1.7	2	2.2	1494.9	27.9	2.5	0.908333	1
45610	2024	11	14	22	4	4	1.7	2.4	2.4	1428.2	27.9	2.5	0.966667	1
45610	2024	11	14	23	4	4	1.8	2.8	3.2	1338.2	27.9	2.5	1.1	1
45610	2024	11	14	24	4	4	1.9	3.1	3.2	1277.2	27.9	2.6	1.233333	1
45611	2024	11	15	1	5	5	2.0	3.4	3.6	1227.7	21.0	2.6	1.458333	1
45611	2024	11	15	2	5	5	2.1	3.5	3.1	1185.9	21.0	2.6	1.641667	1
45611	2024	11	15	3	5	5	2.2	3.6	2.8	1153.1	21.0	2.6	1.825	1
45611	2024	11	15	4	5	5	2.3	3.4	2.5	1140.2	21.0	2.6	1.983333	1
45611	2024	11	15	5	5	5	2.4	3.3	1.7	1148.0	21.0	2.7	2.133333	1
45611	2024	11	15	6	5	5	2.5	2.4	1.9	1199.8	21.0	2.7	2.258333	1
45611	2024	11	15	7	5	5	2.6	2.2	1.7	1317.4	21.0	2.8	2.316667	1
45611	2024	11	15	8	5	5	2.6	2.8	2	1416.2	21.0	2.8	2.4	1
45611	2024	11	15	9	5	5	2.7	3.4	2.4	1444.9	21.0	2.9	2.458333	1
45611	2024	11	15	10	5	5	2.8	4.3	2.8	1444.3	21.0	3.0	2.525	1
45611	2024	11	15	11	5	5	2.9	4.3	3.1	1440.3	21.0	3.2	2.541667	1
45611	2024	11	15	12	5	5	2.9	4.5	3.4	1442.6	21.0	3.3	2.575	1
45611	2024	11	15	13	5	5	3.0	4.5	3.5	1433.2	21.0	3.4	2.566667	1
45611	2024	11	15	14	5	5	3.1	4.8	3.6	1411.0	21.0	3.5	2.583333	1
45611	2024	11	15	15	5	5	3.1	5.1	3.4	1402.6	21.0	3.6	2.575	1
45611	2024	11	15	16	5	5	3.2	5.3	3.3	1409.4	21.0	3.8	2.616667	1
45611	2024	11	15	17	5	5	3.3	5.6	2.4	1444.1	21.0	3.9	2.666667	1
45611	2024	11	15	18	5	5	3.4	5.6	2.2	1482.6	21.0	4.1	2.733333	1
45611	2024	11	15	19	5	5	3.6	5.8	2.8	1438.1	21.0	4.4	2.791667	1
45611	2024	11	15	20	5	5	3.7	5.9	3.4	1386.8	21.0	4.7	2.816667	1
45611	2024	11	15	21	5	5	3.9	6.1	4.3	1336.0	21.0	4.9	2.908333	1
45611	2024	11	15	22	5	5	4.1	6.3	4.3	1267.0	21.0	5.2	3.025	1
45611	2024	11	15	23	5	5	4.3	6.3	4.5	1194.8	21.0	5.3	3.183333	1
45611	2024	11	15	24	5	5	4.4	6.6	4.5	1151.9	21.0	5.5	3.308333	1
45612	2024	11	16	1	6	6	4.5	6.7	4.8	1094.8	7.3	5.7	3.425	0
45612	2024	11	16	2	6	6	4.7	6.7	5.1	1048.4	7.3	5.8	3.516667	0
45612	2024	11	16	3	6	6	4.8	6.7	5.3	1012.6	7.3	6.0	3.625	0
45612	2024	11	16	4	6	6	4.9	6.8	5.6	994.2	7.3	6.1	3.75	0
45612	2024	11	16	5	6	6	5.1	6.8	5.6	994.3	7.3	6.3	3.908333	0
45612	2024	11	16	6	6	6	5.2	6.8	5.8	1017.4	7.3	6.4	4.1	0
45612	2024	11	16	7	6	6	5.4	6.6	5.9	1071.5	7.3	6.5	4.366667	0
45612	2024	11	16	8	6	6	5.6	6.6	6.1	1136.8	7.3	6.5	4.666667	0
45612	2024	11	16	9	6	6	5.8	6.7	6.3	1200.1	7.3	6.6	4.925	0
45612	2024	11	16	10	6	6	5.9	7.2	6.3	1231.8	7.3	6.6	5.15	0
45612	2024	11	16	11	6	6	6.0	7.6	6.6	1249.8	7.3	6.7	5.316667	0
45612	2024	11	16	12	6	6	6.2	7.7	6.7	1252.2	7.3	6.8	5.483333	0
45612	2024	11	16	13	6	6	6.3	8.1	6.7	1242.6	7.3	6.9	5.658333	0
45612	2024	11	16	14	6	6	6.4	9.3	6.7	1233.5	7.3	7.0	5.841667	0
45612	2024	11	16	15	6	6	6.6	8.4	6.8	1231.1	7.3	7.2	6	0
45612	2024	11	16	16	6	6	6.8	8.5	6.8	1253.4	7.3	7.4	6.133333	0
45612	2024	11	16	17	6	6	6.9	8.5	6.8	1308.9	7.3	7.5	6.258333	0
45612	2024	11	16	18	6	6	7.0	8	6.6	1369.7	7.3	7.7	6.358333	0
45612	2024	11	16	19	6	6	7.1	7.9	6.6	1332.0	7.3	7.8	6.458333	0
45612	2024	11	16	20	6	6	7.2	8	6.7	1286.7	7.3	7.9	6.525	0
45612	2024	11	16	21	6	6	7.3	7.2	7.2	1248.2	7.3	8.0	6.583333	0
45612	2024	11	16	22	6	6	7.3	7.5	7.6	1195.1	7.3	8.0	6.633333	0
45612	2024	11	16	23	6	6	7.4	7.5	7.7	1134.6	7.3	8.1	6.708333	0
45612	2024	11	16	24	6	6	7.4							

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLa	gTemp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLa	gWeekdays	
45613	2024	11	17	17	12	7	7.2	6.9	7	1294.4	18.8	6.3	8.05	0
45613	2024	11	17	17	13	7	7.2	7.6	6.9	1293.5	18.8	6.3	7.991667	0
45613	2024	11	17	17	14	7	7.1	8	6.6	1284.5	18.8	6.4	7.9	0
45613	2024	11	17	17	15	7	7.1	8.4	6.3	1283.8	18.8	6.5	7.7	0
45613	2024	11	17	17	16	7	7.1	8.4	5.9	1314.9	18.8	6.6	7.55	0
45613	2024	11	17	17	17	7	7.1	7.6	6	1393.2	18.8	6.8	7.366667	0
45613	2024	11	17	17	18	7	7.0	6.7	6	1453.2	18.8	6.9	7.15	0
45613	2024	11	17	17	19	7	7.0	6	5.9	1420.6	18.8	7.0	6.983333	0
45613	2024	11	17	17	20	7	6.9	6.2	5.9	1380.9	18.8	7.0	6.825	0
45613	2024	11	17	17	21	7	6.8	6.2	6	1332.6	18.8	7.0	6.65	0
45613	2024	11	17	17	22	7	6.8	6.3	6.5	1265.0	18.8	7.0	6.541667	0
45613	2024	11	17	17	23	7	6.7	6.3	6.9	1177.1	18.8	7.1	6.416667	0
45613	2024	11	17	17	24	7	6.7	6.4	7.6	1098.7	18.8	7.1	6.333333	0
45614	2024	11	18	1	1	1	6.7	6.3	8	1040.4	24.7	7.0	6.325	1
45614	2024	11	18	2	1	1	6.6	6.3	8.4	1010.6	24.7	6.9	6.375	1
45614	2024	11	18	3	1	1	6.6	6.4	8.4	999.9	24.7	6.8	6.466667	1
45614	2024	11	18	4	1	1	6.6	6.2	7.6	996.2	24.7	6.6	6.616667	1
45614	2024	11	18	5	1	1	6.6	6	6.7	1012.3	24.7	6.4	6.791667	1
45614	2024	11	18	6	1	1	6.6	5.8	6	1071.4	24.7	6.3	6.933333	1
45614	2024	11	18	7	1	1	6.6	5.8	6.2	1197.7	24.7	6.2	6.991667	1
45614	2024	11	18	8	1	1	6.6	5.8	6.2	1318.7	24.7	6.2	6.991667	1
45614	2024	11	18	9	1	1	6.6	5.7	6.3	1357.5	24.7	6.2	7.016667	1
45614	2024	11	18	10	1	1	6.6	5.7	6.3	1341.1	24.7	6.1	7.041667	1
45614	2024	11	18	11	1	1	6.6	6.3	6.4	1311.7	24.7	6.1	7.066667	1
45614	2024	11	18	12	1	1	6.6	7.5	6.3	1305.1	24.7	6.1	7.05	1
45614	2024	11	18	13	1	1	6.6	7.2	6.3	1321.6	24.7	6.2	7.008333	1
45614	2024	11	18	14	1	1	6.6	6.5	6.4	1324.4	24.7	6.2	6.9	1
45614	2024	11	18	15	1	1	6.5	6.8	6.2	1322.0	24.7	6.2	6.758333	1
45614	2024	11	18	16	1	1	6.4	6.7	6	1350.4	24.7	6.3	6.591667	1
45614	2024	11	18	17	1	1	6.4	6.5	5.8	1433.6	24.7	6.3	6.408333	1
45614	2024	11	18	18	1	1	6.3	6	5.8	1500.8	24.7	6.4	6.275	1
45614	2024	11	18	19	1	1	6.3	5.4	5.8	1460.7	24.7	6.4	6.2	1
45614	2024	11	18	20	1	1	6.3	5.2	5.7	1416.3	24.7	6.3	6.183333	1
45614	2024	11	18	21	1	1	6.2	5	5.7	1374.8	24.7	6.3	6.15	1
45614	2024	11	18	22	1	1	6.2	4.7	6.3	1299.4	24.7	6.2	6.108333	1
45614	2024	11	18	23	1	1	6.1	4.6	7.5	1218.5	24.7	6.2	6.058333	1
45614	2024	11	18	24	1	1	6.0	5	7.2	1161.2	24.7	6.0	6.058333	1
45615	2024	11	19	1	2	2	6.0	5.2	6.5	1109.6	26.1	5.8	6.15	1
45615	2024	11	19	2	2	2	5.9	5.4	6.8	1069.0	26.1	5.6	6.225	1
45615	2024	11	19	3	2	2	5.9	5.5	6.7	1040.5	26.1	5.5	6.241667	1
45615	2024	11	19	4	2	2	5.9	5.5	6.5	1028.8	26.1	5.4	6.275	1
45615	2024	11	19	5	2	2	5.8	5.5	6	1040.3	26.1	5.3	6.316667	1
45615	2024	11	19	6	2	2	5.8	5.6	5.4	1091.4	26.1	5.3	6.358333	1
45615	2024	11	19	7	2	2	5.8	5.6	5.2	1213.0	26.1	5.2	6.375	1
45615	2024	11	19	8	2	2	5.8	5.5	5	1324.2	26.1	5.2	6.341667	1
45615	2024	11	19	9	2	2	5.8	5.6	4.7	1352.6	26.1	5.3	6.291667	1
45615	2024	11	19	10	2	2	5.8	6.1	4.6	1343.7	26.1	5.3	6.233333	1
45615	2024	11	19	11	2	2	5.8	6.7	5	1330.7	26.1	5.4	6.15	1
45615	2024	11	19	12	2	2	5.8	7.2	5.2	1328.7	26.1	5.6	6.008333	1
45615	2024	11	19	13	2	2	5.8	7.8	5.4	1329.5	26.1	5.8	5.8	1
45615	2024	11	19	14	2	2	5.8	8.5	5.5	1312.6	26.1	6.0	5.633333	1
45615	2024	11	19	15	2	2	5.9	8.9	5.5	1304.8	26.1	6.3	5.541667	1
45615	2024	11	19	16	2	2	6.0	8.9	5.5	1334.3	26.1	6.5	5.433333	1
45615	2024	11	19	17	2	2	6.1	8.9	5.6	1409.7	26.1	6.8	5.333333	1
45615	2024	11	19	18	2	2	6.2	8.9	5.6	1472.5	26.1	7.1	5.25	1
45615	2024	11	19	19	2	2	6.3	8.8	5.5	1428.8	26.1	7.4	5.216667	1
45615	2024	11	19	20	2	2	6.4	8.9	5.6	1392.6	26.1	7.7	5.233333	1
45615	2024	11	19	21	2	2	6.6	8.9	6.1	1346.5	26.1	7.9	5.258333	1
45615	2024	11	19	22	2	2	6.8	8.9	6.7	1273.1	26.1	8.2	5.308333	1
45615	2024	11	19	23	2	2	6.9	8.8	7.2	1186.1	26.1	8.4	5.425	1
45615	2024	11	19	24	2	2	7.1	8.7	7.8	1119.7	26.1	8.6	5.6	1
45616	2024	11	20	1	3	3	7.3	8.6	8.5	1060.3	25.8	8.7	5.783333	1
45616	2024	11	20	2	3	3	7.4	8.4	8.9	1019.2	25.8	8.8	6	1
45616	2024	11	20	3	3	3	7.5	8.1	8.9	987.9	25.8	8.8	6.258333	1
45616	2024	11	20	4	3	3	7.6	8	8.9	974.1	25.8	8.7	6.541667	1
45616	2024	11	20	5	3	3	7.7	7.7	8.9	980.6	25.8	8.7	6.825	1
45616	2024	11	20	6	3	3	7.8	7.6	8.8	1034.4	25.8	8.6	7.108333	1
45616	2024	11	20	7	3	3	7.9	7.5	8.9	1158.7	25.8	8.5	7.383333	1
45616	2024	11	20	8	3	3	8.0	7.3	8.9	1259.5	25.8	8.3	7.65	1
45616	2024	11	20	9	3	3	8.1	7.3	8.9	1275.7	25.8	8.2	7.933333	1
45616	2024	11	20	10	3	3	8.1	8	8.8	1257.8	25.8	8.1	8.208333	1
45616	2024	11	20	11	3	3	8.2	9.1	8.7	1233.8	25.8	8.0	8.441667	1
45616	2024	11	20	12	3	3	8.3	10.9	8.6	1237.1	25.8	8.0	8.616667	1
45616	2024	11	20	13	3	3	8.5	11	8.4	1224.4	25.8	8.2	8.741667	1
45616	2024	11	20	14	3	3	8.6	12	8.1	1216.9	25.8	8.4	8.808333	1
45616	2024	11	20	15	3	3	8.8	11	8	1226.6	25.8	8.7	8.8	1
45616	2024	11	20	16	3	3	8.8	9	7.7	1257.6	25.8	9.0	8.733333	1
45616	2024	11	20	17	3	3	8.8	8.5	7.6	1341.3	25.8	9.0	8.658333	1
45616	2024	11	20	18	3	3	8.8	7.2	7.5	1417.1	25.8	9.1	8.558333	1
45616	2024	11	20	19	3	3	8.8	7	7.3	1394.1	25.8	9.1	8.45	1
45616	2024	11	20	20	3	3	8.7	7	7.3	1355.2	25.8	9.0	8.341667	1
45616	2024	11	20	21	3	3	8.6	6.8	8	1317.1	25.8	9.0	8.208333	1
45616	2024	11	20	22	3	3	8.5	6.7	9.1	1252.8	25.8	9.0	8.075	1
45616	2024	11	20	23	3	3	8.4	6.6	10.9	1174.6	25.8	8.9	8	1
45616	2024	11	20	24	3	3	8.3	6.5	11	1121.6	25.8	8.6	8.025	1
45617	2024	11	21	1	4	4	8.2	6.6	12	1066.5	16.1	8.3	8.208333	1
45617	2024	11	21	2	4	4	8.2	6.6	11	1023.0	16.1	7.9	8.408333	1
45617	2024	11	21	3	4	4	8.1	6.7	9	990.0	16.1	7.5	8.708333	1
45617	2024	11	21	4	4	4	8.0	6.6	8.5	975.2	16.1	7.1	8.95	1
45617	2024	11	21	5	4	4	8.0	6.5	7.2	994.0	16.1	6.9	9.033333	1
45617	2024	11	21	6	4	4	7.9	6.3	7	1055.5	16.1	6.7	9.1	1
45617	2024	11	21	7	4	4	7.9	6.4	7	1184.5	16.1	6.7	9.066667	1
45617	2024	11	21	8	4	4	7.8	6.4	6.8	1286.9	16.1	6.6	9.025	1
45617	2024	11	21	9	4	4	7.8	6.6	6.7	1307.3	16.1	6.6	9	1
45617	2024	11	21	10	4	4	7.8	7	6.6	1287.7	16.1	6.5	8.958333	1
45617	2024	11	21	11	4	4	7.7	8	6.5	1253.6	16.1	6.6	8.85	1
45617	2024	11	21	12	4	4	7.7	9.6	6.6	1235.4</				

DATE	Year	Month	Day	HOUR	DOW	24hrAvgLa	g Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLa	g Weekdays	
45617	2024	11	11	21	24	4	7.6	7.3	9.9	1100.3	16.1	8.6	6.683333	1
45618	2024	11	22	1	5	5	7.7	7.2	10.4	1040.4	21.8	8.4	6.941667	1
45618	2024	11	22	2	5	5	7.7	7.3	10.2	992.6	21.8	8.2	7.216667	1
45618	2024	11	22	3	5	5	7.7	7.3	9.8	965.5	21.8	7.9	7.533333	1
45618	2024	11	22	4	5	5	7.7	7.7	8.8	958.2	21.8	7.7	7.825	1
45618	2024	11	22	5	5	5	7.8	8	7.7	966.7	21.8	7.5	8.091667	1
45618	2024	11	22	6	5	5	7.9	8.1	7.7	1017.5	21.8	7.4	8.283333	1
45618	2024	11	22	7	5	5	7.9	7.7	7.5	1132.9	21.8	7.5	8.4	1
45618	2024	11	22	8	5	5	8.0	7.6	7.1	1234.0	21.8	7.5	8.508333	1
45618	2024	11	22	9	5	5	8.0	7.2	7	1290.2	21.8	7.5	8.6	1
45618	2024	11	22	10	5	5	8.1	7.4	7.2	1287.4	21.8	7.5	8.641667	1
45618	2024	11	22	11	5	5	8.1	7.7	7.3	1289.1	21.8	7.5	8.641667	1
45618	2024	11	22	12	5	5	8.1	7.8	7.2	1298.0	21.8	7.5	8.575	1
45618	2024	11	22	13	5	5	8.0	8.1	7.3	1301.3	21.8	7.6	8.383333	1
45618	2024	11	22	14	5	5	7.9	8.2	7.3	1295.8	21.8	7.7	8.158333	1
45618	2024	11	22	15	5	5	7.8	8.1	7.7	1288.1	21.8	7.7	7.9	1
45618	2024	11	22	16	5	5	7.7	8.1	8	1307.3	21.8	7.8	7.658333	1
45618	2024	11	22	17	5	5	7.7	7.8	8.1	1362.7	21.8	7.8	7.483333	1
45618	2024	11	22	18	5	5	7.6	7.7	7.7	1399.5	21.8	7.8	7.416667	1
45618	2024	11	22	19	5	5	7.6	7.7	7.6	1361.7	21.8	7.8	7.45	1
45618	2024	11	22	20	5	5	7.6	7.6	7.2	1319.6	21.8	7.8	7.45	1
45618	2024	11	22	21	5	5	7.6	7.4	7.4	1277.3	21.8	7.8	7.458333	1
45618	2024	11	22	22	5	5	7.6	7.5	7.7	1224.2	21.8	7.8	7.466667	1
45618	2024	11	22	23	5	5	7.7	7.7	7.8	1166.6	21.8	7.8	7.5	1
45618	2024	11	22	24	5	5	7.7	8.2	8.1	1121.6	21.8	7.8	7.541667	1
45619	2024	11	23	1	6	6	7.7	8.4	8.2	1066.0	30.2	7.8	7.583333	0
45619	2024	11	23	2	6	6	7.8	8.3	8.1	1015.7	30.2	7.9	7.658333	0
45619	2024	11	23	3	6	6	7.8	8.4	8.1	977.8	30.2	7.9	7.733333	0
45619	2024	11	23	4	6	6	7.9	8.4	7.8	965.1	30.2	7.9	7.8	0
45619	2024	11	23	5	6	6	7.9	8.4	7.7	976.8	30.2	7.9	7.833333	0
45619	2024	11	23	6	6	6	7.9	8.2	7.7	1007.6	30.2	8.0	7.816667	0
45619	2024	11	23	7	6	6	7.9	8.5	7.6	1064.5	30.2	8.0	7.783333	0
45619	2024	11	23	8	6	6	7.9	8.4	7.4	1145.5	30.2	8.1	7.783333	0
45619	2024	11	23	9	6	6	8.0	8.4	7.5	1216.6	30.2	8.2	7.783333	0
45619	2024	11	23	10	6	6	8.0	8.5	7.7	1298.3	30.2	8.2	7.8	0
45619	2024	11	23	11	6	6	8.1	8.5	8.2	1340.2	30.2	8.3	7.808333	0
45619	2024	11	23	12	6	6	8.1	8.7	8.4	1363.6	30.2	8.4	7.808333	0
45619	2024	11	23	13	6	6	8.1	8.7	8.3	1361.4	30.2	8.4	7.841667	0
45619	2024	11	23	14	6	6	8.2	9.6	8.4	1330.9	30.2	8.5	7.866667	0
45619	2024	11	23	15	6	6	8.2	9.3	8.4	1310.8	30.2	8.6	7.875	0
45619	2024	11	23	16	6	6	8.3	8.5	8.4	1329.7	30.2	8.6	7.9	0
45619	2024	11	23	17	6	6	8.3	8.3	8.2	1388.2	30.2	8.6	7.925	0
45619	2024	11	23	18	6	6	8.3	8.3	8.5	1417.1	30.2	8.6	7.975	0
45619	2024	11	23	19	6	6	8.3	8.3	8.4	1366.5	30.2	8.6	8.016667	0
45619	2024	11	23	20	6	6	8.4	8.5	8.4	1316.5	30.2	8.6	8.083333	0
45619	2024	11	23	21	6	6	8.4	8.2	8.5	1276.8	30.2	8.6	8.15	0
45619	2024	11	23	22	6	6	8.4	7.9	8.5	1220.9	30.2	8.6	8.233333	0
45619	2024	11	23	23	6	6	8.4	7.3	8.7	1165.3	30.2	8.6	8.316667	0
45619	2024	11	23	24	6	6	8.4	5.8	8.7	1114.4	30.2	8.5	8.383333	0
45620	2024	11	24	1	7	7	8.3	4	9.6	1060.9	18.5	8.2	8.425	0
45620	2024	11	24	2	7	7	8.1	4	9.3	1032.3	18.5	7.8	8.45	0
45620	2024	11	24	3	7	7	8.0	3.6	8.5	1019.9	18.5	7.4	8.558333	0
45620	2024	11	24	4	7	7	7.8	4.2	8.3	1020.0	18.5	6.9	8.633333	0
45620	2024	11	24	5	7	7	7.6	4.6	8.3	1027.0	18.5	6.5	8.641667	0
45620	2024	11	24	6	7	7	7.4	4.8	8.3	1050.2	18.5	6.2	8.633333	0
45620	2024	11	24	7	7	7	7.3	4.7	8.5	1093.1	18.5	5.9	8.641667	0
45620	2024	11	24	8	7	7	7.1	4.6	8.2	1151.2	18.5	5.6	8.625	0
45620	2024	11	24	9	7	7	7.0	4.8	7.9	1227.9	18.5	5.3	8.633333	0
45620	2024	11	24	10	7	7	6.8	5.1	7.3	1299.9	18.5	5.0	8.616667	0
45620	2024	11	24	11	7	7	6.7	5.6	5.8	1324.1	18.5	4.8	8.566667	0
45620	2024	11	24	12	7	7	6.6	6	4	1340.4	18.5	4.7	8.466667	0
45620	2024	11	24	13	7	7	6.4	6.4	4	1347.6	18.5	4.7	8.225	0
45620	2024	11	24	14	7	7	6.4	7.1	3.6	1336.2	18.5	4.9	7.833333	0
45620	2024	11	24	15	7	7	6.2	7	4.2	1330.7	18.5	5.1	7.366667	0
45620	2024	11	24	16	7	7	6.2	6.8	4.6	1362.6	18.5	5.4	6.891667	0
45620	2024	11	24	17	7	7	6.1	6.3	4.8	1445.7	18.5	5.6	6.533333	0
45620	2024	11	24	18	7	7	6.0	5.9	4.7	1492.4	18.5	5.8	6.225	0
45620	2024	11	24	19	7	7	5.9	5.8	4.6	1448.3	18.5	5.9	5.933333	0
45620	2024	11	24	20	7	7	5.8	5.6	4.8	1413.5	18.5	6.0	5.633333	0
45620	2024	11	24	21	7	7	5.7	5.4	5.1	1373.7	18.5	6.0	5.308333	0
45620	2024	11	24	22	7	7	5.6	5.3	5.6	1312.4	18.5	6.1	5.025	0
45620	2024	11	24	23	7	7	5.4	5.2	6	1219.9	18.5	6.1	4.791667	0
45620	2024	11	24	24	7	7	5.4	4.9	6.4	1149.8	18.5	6.1	4.65	0
45621	2024	11	25	1	1	1	5.3	4.7	7.1	1098.6	20.5	6.0	4.666667	1
45621	2024	11	25	2	1	1	5.4	4.3	7	1065.8	20.5	5.8	4.866667	1
45621	2024	11	25	3	1	1	5.4	3.8	6.8	1057.8	20.5	5.6	5.125	1
45621	2024	11	25	4	1	1	5.4	3.4	6.3	1060.0	20.5	5.3	5.408333	1
45621	2024	11	25	5	1	1	5.3	3.4	5.9	1080.5	20.5	5.1	5.625	1
45621	2024	11	25	6	1	1	5.3	3.7	5.8	1143.5	20.5	4.8	5.766667	1
45621	2024	11	25	7	1	1	5.2	3.6	5.6	1282.1	20.5	4.6	5.858333	1
45621	2024	11	25	8	1	1	5.2	3.6	5.4	1404.6	20.5	4.4	5.95	1
45621	2024	11	25	9	1	1	5.2	3.4	5.3	1445.2	20.5	4.3	6.033333	1
45621	2024	11	25	10	1	1	5.1	3.5	5.2	1446.9	20.5	4.1	6.083333	1
45621	2024	11	25	11	1	1	5.0	4	4.9	1426.6	20.5	4.0	6.1	1
45621	2024	11	25	12	1	1	5.0	4.8	4.7	1399.1	20.5	3.9	6.066667	1
45621	2024	11	25	13	1	1	4.9	6.1	4.3	1401.3	20.5	3.9	5.975	1
45621	2024	11	25	14	1	1	4.9	5.7	3.8	1388.5	20.5	4.0	5.833333	1
45621	2024	11	25	15	1	1	4.8	5.7	3.4	1381.6	20.5	4.1	5.6	1
45621	2024	11	25	16	1	1	4.8	6.1	3.4	1402.6	20.5	4.2	5.333333	1
45621	2024	11	25	17	1	1	4.8	5.6	3.7	1478.4	20.5	4.5	5.05	1
45621	2024	11	25	18	1	1	4.7	5.7	3.6	1541.5	20.5	4.7	4.808333	1
45621	2024	11	25	19	1	1	4.7	5.9	3.6	1498.8	20.5	4.8	4.625	1
45621	2024	11	25	20	1	1	4.7	6.4	3.4	1452.4	20.5	5.0	4.441667	1
45621	2024	11	25	21	1	1	4.8	6.5	3.5	1401.4	20.5	5.2	4.275	1
45621	2024	11	25	22	1	1	4.8	6.4	4	1323.4	20.5	5.5	4.108333	1
45621	2024	11	25	23	1	1	4.9	6.3	4.8	1229.6	20.5	5.7	3.958333	1
45621	2024	11	25											

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLa	gTemp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLa	gWeekdays
45622	2024	11	26	12	2	6.0	6.9	6.6	1327.1	11.2	6.1	5.933333	1
45622	2024	11	26	13	2	6.1	6.7	6.6	1328.8	11.2	6.1	6.066667	1
45622	2024	11	26	14	2	6.1	7	6.5	1320.9	11.2	6.2	6.108333	1
45622	2024	11	26	15	2	6.2	8.3	5.9	1322.1	11.2	6.2	6.183333	1
45622	2024	11	26	16	2	6.3	7	6.1	1352.6	11.2	6.3	6.25	1
45622	2024	11	26	17	2	6.3	6.8	6	1429.1	11.2	6.4	6.233333	1
45622	2024	11	26	18	2	6.4	6.6	5.9	1483.2	11.2	6.5	6.275	1
45622	2024	11	26	19	2	6.4	6.6	5.8	1459.4	11.2	6.5	6.3	1
45622	2024	11	26	20	2	6.4	6.6	5.7	1424.5	11.2	6.6	6.3	1
45622	2024	11	26	21	2	6.5	6.1	5.6	1380.5	11.2	6.7	6.25	1
45622	2024	11	26	22	2	6.4	5.8	6.1	1308.3	11.2	6.7	6.183333	1
45622	2024	11	26	23	2	6.4	5.7	6.9	1218.5	11.2	6.7	6.116667	1
45622	2024	11	26	24	2	6.4	5.5	6.7	1168.0	11.2	6.7	6.1	1
45623	2024	11	27	1	3	6.4	5.5	7	1113.1	5.9	6.6	6.141667	1
45623	2024	11	27	2	3	6.3	5.9	8.3	1062.6	5.9	6.5	6.15	1
45623	2024	11	27	3	3	6.3	5.8	7	1027.7	5.9	6.4	6.183333	1
45623	2024	11	27	4	3	6.2	5.8	6.8	1018.3	5.9	6.2	6.333333	1
45623	2024	11	27	5	3	6.2	5.8	6.6	1026.4	5.9	6.1	6.425	1
45623	2024	11	27	6	3	6.2	5.6	6.6	1085.0	5.9	6.0	6.483333	1
45623	2024	11	27	7	3	6.2	5.6	6.6	1206.9	5.9	5.9	6.533333	1
45623	2024	11	27	8	3	6.2	5.6	6.1	1316.4	5.9	5.8	6.591667	1
45623	2024	11	27	9	3	6.2	5.7	5.8	1334.4	5.9	5.7	6.658333	1
45623	2024	11	27	10	3	6.2	6.2	5.7	1311.8	5.9	5.7	6.691667	1
45623	2024	11	27	11	3	6.2	6.5	5.5	1298.8	5.9	5.7	6.708333	1
45623	2024	11	27	12	3	6.2	6.9	5.5	1298.1	5.9	5.8	6.675	1
45623	2024	11	27	13	3	6.2	7.5	5.9	1295.9	5.9	5.9	6.558333	1
45623	2024	11	27	14	3	6.3	9.6	5.8	1286.1	5.9	6.1	6.458333	1
45623	2024	11	27	15	3	6.4	8.4	5.8	1280.5	5.9	6.4	6.366667	1
45623	2024	11	27	16	3	6.4	8.1	5.8	1292.8	5.9	6.6	6.158333	1
45623	2024	11	27	17	3	6.4	7.8	5.6	1367.3	5.9	6.8	6.058333	1
45623	2024	11	27	18	3	6.5	7.5	5.6	1438.2	5.9	7.0	5.975	1
45623	2024	11	27	19	3	6.5	6.5	5.6	1418.8	5.9	7.1	5.891667	1
45623	2024	11	27	20	3	6.5	6.5	5.7	1399.2	5.9	7.2	5.808333	1
45623	2024	11	27	21	3	6.5	6.3	6.2	1364.5	5.9	7.3	5.725	1
45623	2024	11	27	22	3	6.5	5.7	6.5	1310.0	5.9	7.3	5.691667	1
45623	2024	11	27	23	3	6.5	5.2	6.9	1230.2	5.9	7.3	5.725	1
45623	2024	11	27	24	3	6.5	4.9	7.5	1186.6	5.9	7.2	5.791667	1
45624	2024	11	28	1	4	6.5	4.8	9.6	1146.6	12.0	7.0	5.908333	1
45624	2024	11	28	2	4	6.4	3.4	8.4	1131.6	12.0	6.8	6.075	1
45624	2024	11	28	3	4	6.3	2.4	8.1	1121.7	12.0	6.3	6.383333	1
45624	2024	11	28	4	4	6.2	2.5	7.8	1126.0	12.0	5.8	6.6	1
45624	2024	11	28	5	4	6.0	2.1	7.5	1148.9	12.0	5.3	6.791667	1
45624	2024	11	28	6	4	5.9	2	6.5	1219.4	12.0	4.8	6.958333	1
45624	2024	11	28	7	4	5.7	1.2	6.5	1362.1	12.0	4.4	7.116667	1
45624	2024	11	28	8	4	5.6	1.7	6.3	1487.6	12.0	3.9	7.191667	1
45624	2024	11	28	9	4	5.4	2.2	5.7	1501.2	12.0	3.5	7.266667	1
45624	2024	11	28	10	4	5.2	3.2	5.2	1460.2	12.0	3.2	7.316667	1
45624	2024	11	28	11	4	5.1	4.5	4.9	1409.1	12.0	3.0	7.275	1
45624	2024	11	28	12	4	5.0	5.4	4.8	1385.8	12.0	2.9	7.166667	1
45624	2024	11	28	13	4	5.0	6	3.4	1364.0	12.0	3.0	7	1
45624	2024	11	28	14	4	4.9	6.6	2.4	1331.0	12.0	3.1	6.775	1
45624	2024	11	28	15	4	4.8	6.2	2.5	1329.5	12.0	3.3	6.258333	1
45624	2024	11	28	16	4	4.7	6.8	2.1	1365.6	12.0	3.6	5.758333	1
45624	2024	11	28	17	4	4.6	5.6	2	1463.5	12.0	4.0	5.291667	1
45624	2024	11	28	18	4	4.6	5.3	1.2	1529.0	12.0	4.3	4.816667	1
45624	2024	11	28	19	4	4.5	5.5	1.7	1498.1	12.0	4.6	4.358333	1
45624	2024	11	28	20	4	4.4	5.6	2.2	1471.3	12.0	4.9	3.916667	1
45624	2024	11	28	21	4	4.4	4.5	3.2	1440.3	12.0	5.2	3.516667	1
45624	2024	11	28	22	4	4.3	3.6	4.5	1394.9	12.0	5.4	3.175	1
45624	2024	11	28	23	4	4.2	3.3	5.4	1321.8	12.0	5.5	2.966667	1
45624	2024	11	28	24	4	4.1	3.9	6	1277.7	12.0	5.4	2.908333	1
45625	2024	11	29	1	5	4.1	4.1	6.6	1215.4	21.4	5.2	2.95	1
45625	2024	11	29	2	5	4.1	4.9	6.2	1171.3	21.4	5.1	3.05	1
45625	2024	11	29	3	5	4.1	6.4	6.8	1126.2	21.4	4.9	3.316667	1
45625	2024	11	29	4	5	4.3	8.6	5.6	1089.9	21.4	5.0	3.633333	1
45625	2024	11	29	5	5	4.6	10	5.3	1073.5	21.4	5.1	3.991667	1
45625	2024	11	29	6	5	4.9	9.8	5.5	1108.3	21.4	5.5	4.283333	1
45625	2024	11	29	7	5	5.2	8.2	5.6	1227.1	21.4	5.9	4.558333	1
45625	2024	11	29	8	5	5.5	7.3	4.5	1328.0	21.4	6.1	4.916667	1
45625	2024	11	29	9	5	5.7	7.3	3.6	1365.0	21.4	6.2	5.241667	1
45625	2024	11	29	10	5	5.9	8.2	3.3	1359.8	21.4	6.5	5.433333	1
45625	2024	11	29	11	5	6.2	6.5	3.9	1353.8	21.4	6.8	5.466667	1
45625	2024	11	29	12	5	6.2	5.3	4.1	1346.7	21.4	7.1	5.366667	1
45625	2024	11	29	13	5	6.2	5.8	4.9	1335.2	21.4	7.2	5.241667	1
45625	2024	11	29	14	5	6.2	5.4	6.4	1324.5	21.4	7.4	5.083333	1
45625	2024	11	29	15	5	6.2	5.1	8.6	1328.6	21.4	7.4	4.941667	1
45625	2024	11	29	16	5	6.1	5.9	10	1354.4	21.4	7.3	4.958333	1
45625	2024	11	29	17	5	6.1	5.3	9.8	1434.6	21.4	7.1	5.108333	1
45625	2024	11	29	18	5	6.1	4.3	8.2	1510.8	21.4	6.7	5.475	1
45625	2024	11	29	19	5	6.0	4.3	7.3	1478.6	21.4	6.2	5.85	1
45625	2024	11	29	20	5	6.0	3.8	7.3	1443.6	21.4	5.9	6.075	1
45625	2024	11	29	21	5	5.9	2.9	8.2	1410.1	21.4	5.6	6.216667	1
45625	2024	11	29	22	5	5.8	3	6.5	1361.5	21.4	5.2	6.45	1
45625	2024	11	29	23	5	5.8	3.5	5.3	1305.0	21.4	4.8	6.833333	1
45625	2024	11	29	24	5	5.8	3.1	5.8	1266.9	21.4	4.6	7.1	1
45626	2024	11	30	1	6	5.8	3.1	5.4	1221.5	7.3	4.4	7.216667	0
45626	2024	11	30	2	6	5.8	2.9	5.1	1187.3	7.3	4.1	7.358333	0
45626	2024	11	30	3	6	5.7	2.5	5.9	1169.4	7.3	3.9	7.4	0
45626	2024	11	30	4	6	5.5	1.8	5.3	1169.2	7.3	3.7	7.291667	0
45626	2024	11	30	5	6	5.2	-0.3	4.3	1183.1	7.3	3.4	7.066667	0
45626	2024	11	30	6	6	4.8	0.3	4.3	1217.4	7.3	2.9	6.675	0
45626	2024	11	30	7	6	4.4	-0.7	3.8	1279.8	7.3	2.6	6.216667	0
45626	2024	11	30	8	6	4.0	0.4	2.9	1362.1	7.3	2.2	5.891667	0
45626	2024	11	30	9	6	3.7	1	3	1443.7	7.3	1.9	5.6	0
45626	2024	11	30	10	6	3.5	2.1	3.5	1431.1	7.3	1.7	5.233333	0
45626	2024	11	30	11	6	3.2	4.7	3.1	1375.7	7.3	1.6	4.8	0
45626	2024	11	30	12	6	3.1	5.9	3.1	1332.3	7.3	1.7	4.55	0
45626	2024	11	30	13	6	3.2	7.1	2.9	1313.1	7.3	2.0	4.366667	0
45626	2024	11	30	14	6	3.2	7.2	2.5	1302.4	7.3	2.3	4.141667	0
45626	2024	11	30	15	6	3.3	6.5	1.8	1329.4	7.3	2.7	3.933333	0
45626	2024	11	30	16	6	3.4	3	-0.3	1362.4	7.3	3.0	3.716667	0
45626	2024	11	30										

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLag	Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLag	Weekdays	
45626	2024	12	11	30	24	6	2.5	1.6	7.1	1293.3	7.3	3.3	1.741667	0
45627	2024	12	1	1	1	7	2.4	1.2	7.2	1238.6	7.4	2.9	1.975	0
45627	2024	12	1	2	2	7	2.4	1	6.5	1211.7	7.4	2.4	2.308333	0
45627	2024	12	1	3	3	7	2.3	0.9	3	1200.7	7.4	1.9	2.666667	0
45627	2024	12	1	4	4	7	2.2	0.8	2	1196.7	7.4	1.4	3	0
45627	2024	12	1	5	5	7	2.2	1	1.2	1217.5	7.4	1.3	3.1	0
45627	2024	12	1	6	6	7	2.2	0.8	0.9	1257.9	7.4	1.2	3.291667	0
45627	2024	12	1	7	7	7	2.3	0.6	0.9	1310.9	7.4	1.1	3.366667	0
45627	2024	12	1	8	7	7	2.3	0	1.9	1384.4	7.4	1.1	3.5	0
45627	2024	12	1	9	7	7	2.3	0.1	1.2	1441.3	7.4	1.0	3.541667	0
45627	2024	12	1	10	7	7	2.3	0.7	1.4	1449.4	7.4	0.9	3.616667	0
45627	2024	12	1	11	7	7	2.2	2.8	1.6	1401.3	7.4	0.8	3.541667	0
45627	2024	12	1	12	7	7	2.1	4.4	1.2	1378.8	7.4	1.0	3.266667	0
45627	2024	12	1	13	7	7	2.1	4.1	1	1362.8	7.4	1.2	2.908333	0
45627	2024	12	1	14	7	7	1.9	5.2	0.9	1325.0	7.4	1.4	2.416667	0
45627	2024	12	1	15	7	7	1.8	5.4	0.8	1319.4	7.4	1.8	1.9	0
45627	2024	12	1	16	7	7	1.8	5.1	1	1365.6	7.4	2.2	1.433333	0
45627	2024	12	1	17	7	7	1.9	4.1	0.8	1498.6	7.4	2.5	1.25	0
45627	2024	12	1	18	7	7	2.0	2.8	0.6	1611.7	7.4	2.8	1.166667	0
45627	2024	12	1	19	7	7	2.0	2.5	0	1593.2	7.4	2.9	1.133333	0
45627	2024	12	1	20	7	7	2.1	1.6	0.1	1574.6	7.4	3.1	1.108333	0
45627	2024	12	1	21	7	7	2.1	1.8	0.7	1531.0	7.4	3.2	1.033333	0
45627	2024	12	1	22	7	7	2.1	2.5	2.8	1457.1	7.4	3.4	0.883333	0
45627	2024	12	1	23	7	7	2.2	2.7	4.4	1360.0	7.4	3.5	0.841667	0
45627	2024	12	1	24	7	7	2.2	2.8	4.1	1281.4	7.4	3.5	0.958333	0
45628	2024	12	2	1	1	1	2.3	2	5.2	1231.4	5.9	3.4	1.191667	1
45628	2024	12	2	2	1	1	2.3	1.7	5.4	1204.4	5.9	3.2	1.433333	1
45628	2024	12	2	3	1	1	2.4	2.3	5.1	1195.4	5.9	2.9	1.783333	1
45628	2024	12	2	4	1	1	2.4	2.3	4.1	1201.5	5.9	2.7	2.158333	1
45628	2024	12	2	5	1	1	2.5	1.6	2.8	1235.5	5.9	2.4	2.516667	1
45628	2024	12	2	6	1	1	2.5	0.4	2.5	1313.0	5.9	2.2	2.775	1
45628	2024	12	2	7	1	1	2.5	0.1	1.6	1456.2	5.9	2.0	2.941667	1
45628	2024	12	2	8	1	1	2.5	-0.5	1.8	1571.1	5.9	1.8	3.1	1
45628	2024	12	2	9	1	1	2.4	0.1	2.5	1593.6	5.9	1.6	3.233333	1
45628	2024	12	2	10	1	1	2.4	0.1	2.7	1547.2	5.9	1.5	3.375	1
45628	2024	12	2	11	1	1	2.4	1.3	2.8	1468.7	5.9	1.3	3.525	1
45628	2024	12	2	12	1	1	2.4	3.7	2	1410.8	5.9	1.2	3.516667	1
45628	2024	12	2	13	1	1	2.3	4	1.7	1389.6	5.9	1.3	3.383333	1
45628	2024	12	2	14	1	1	2.3	4	2.3	1360.3	5.9	1.4	3.208333	1
45628	2024	12	2	15	1	1	2.3	4.8	2.3	1367.6	5.9	1.6	2.916667	1
45628	2024	12	2	16	1	1	2.2	3.8	1.6	1425.6	5.9	1.8	2.658333	1
45628	2024	12	2	17	1	1	2.2	3.4	0.4	1541.7	5.9	2.0	2.425	1
45628	2024	12	2	18	1	1	2.2	1.5	0.1	1654.9	5.9	2.1	2.216667	1
45628	2024	12	2	19	1	1	2.1	0.6	-0.5	1651.7	5.9	2.2	2.016667	1
45628	2024	12	2	20	1	1	2.0	-0.1	0.1	1632.7	5.9	2.2	1.816667	1
45628	2024	12	2	21	1	1	2.0	-0.5	0.1	1600.4	5.9	2.3	1.641667	1
45628	2024	12	2	22	1	1	1.9	-1.2	1.3	1544.0	5.9	2.2	1.5	1
45628	2024	12	2	23	1	1	1.7	-2.6	3.7	1469.0	5.9	2.1	1.3	1
45628	2024	12	2	24	1	1	1.5	-1.8	4	1427.0	5.9	1.8	1.183333	1
45629	2024	12	3	1	2	2	1.3	-2.5	4	1395.9	9.4	1.3	1.258333	1
45629	2024	12	3	2	2	2	1.1	-2.7	4.8	1369.5	9.4	0.8	1.425	1
45629	2024	12	3	3	2	2	0.9	-2.1	3.8	1343.4	9.4	0.2	1.616667	1
45629	2024	12	3	4	2	2	0.7	-2	3.4	1332.4	9.4	-0.4	1.825	1
45629	2024	12	3	5	2	2	0.6	-2.4	1.5	1351.1	9.4	-0.8	1.95	1
45629	2024	12	3	6	2	2	0.4	-2.5	0.6	1417.1	9.4	-1.3	2.1	1
45629	2024	12	3	7	2	2	0.3	-2.7	-0.1	1552.0	9.4	-1.7	2.191667	1
45629	2024	12	3	8	2	2	0.2	-2.9	-0.5	1666.2	9.4	-1.9	2.233333	1
45629	2024	12	3	9	2	2	0.1	-2.8	-1.2	1665.6	9.4	-2.2	2.266667	1
45629	2024	12	3	10	2	2	-0.1	-1	-2.6	1587.5	9.4	-2.4	2.216667	1
45629	2024	12	3	11	2	2	-0.1	0	-1.8	1527.2	9.4	-2.3	2.108333	1
45629	2024	12	3	12	2	2	-0.2	0.9	-2.5	1505.0	9.4	-2.1	1.783333	1
45629	2024	12	3	13	2	2	-0.3	1.1	-2.7	1507.2	9.4	-1.9	1.325	1
45629	2024	12	3	14	2	2	-0.4	1.1	-2.1	1497.1	9.4	-1.6	0.783333	1
45629	2024	12	3	15	2	2	-0.5	0.8	-2	1498.2	9.4	-1.3	0.225	1
45629	2024	12	3	16	2	2	-0.7	0.1	-2.4	1551.5	9.4	-1.0	-0.35	1
45629	2024	12	3	17	2	2	-0.8	0.4	-2.5	1661.2	9.4	-0.9	-0.833333	1
45629	2024	12	3	18	2	2	-1.0	-0.6	-2.7	1754.6	9.4	-0.6	-1.31667	1
45629	2024	12	3	19	2	2	-1.1	-0.8	-2.9	1742.3	9.4	-0.5	-1.65	1
45629	2024	12	3	20	2	2	-1.1	-1.2	-2.8	1713.7	9.4	-0.3	-1.925	1
45629	2024	12	3	21	2	2	-1.2	-1.5	-1	1679.1	9.4	-0.2	-2.15833	1
45629	2024	12	3	22	2	2	-1.2	-1.3	0	1616.9	9.4	-0.1	-2.35	1
45629	2024	12	3	23	2	2	-1.2	-1.6	0.9	1530.1	9.4	-0.1	-2.33333	1
45629	2024	12	3	24	2	2	-1.2	-1.8	1.1	1491.6	9.4	-0.2	-2.11667	1
45630	2024	12	4	1	3	3	-1.2	-3	1.1	1449.2	6.9	-0.4	-1.89167	1
45630	2024	12	4	2	3	3	-1.2	-3.4	0.8	1424.7	6.9	-0.8	-1.59167	1
45630	2024	12	4	3	3	3	-1.2	-4.3	0.1	1406.9	6.9	-1.2	-1.275	1
45630	2024	12	4	4	3	3	-1.3	-3.7	0.4	1399.8	6.9	-1.6	-1.03333	1
45630	2024	12	4	5	3	3	-1.4	-3.9	-0.6	1421.6	6.9	-1.9	-0.85833	1
45630	2024	12	4	6	3	3	-1.4	-4.2	-0.8	1479.9	6.9	-2.3	-0.625	1
45630	2024	12	4	7	3	3	-1.5	-3.1	-1.2	1616.7	6.9	-2.6	-0.46667	1
45630	2024	12	4	8	3	3	-1.5	-3.4	-1.5	1717.1	6.9	-2.8	-0.30833	1
45630	2024	12	4	9	3	3	-1.6	-3.1	-1.3	1729.9	6.9	-2.9	-0.16667	1
45630	2024	12	4	10	3	3	-1.6	-2.6	-1.6	1679.4	6.9	-3.1	-0.05833	1
45630	2024	12	4	11	3	3	-1.6	-2.1	-1.8	1616.6	6.9	-3.2	-0.08333	1
45630	2024	12	4	12	3	3	-1.7	-0.7	-3	1572.2	6.9	-3.2	-0.21667	1
45630	2024	12	4	13	3	3	-1.8	0	-3.4	1541.5	6.9	-3.1	-0.44167	1
45630	2024	12	4	14	3	3	-1.8	-0.8	-4.3	1507.1	6.9	-2.9	-0.78333	1
45630	2024	12	4	15	3	3	-1.9	0.1	-3.7	1491.4	6.9	-2.7	-1.15833	1
45630	2024	12	4	16	3	3	-1.9	0.1	-3.9	1530.0	6.9	-2.3	-1.58333	1
45630	2024	12	4	17	3	3	-1.9	-0.7	-4.2	1657.2	6.9	-2.0	-1.9	1
45630	2024	12	4	18	3	3	-2.0	-2.3	-3.1	1768.6	6.9	-1.7	-2.25833	1
45630	2024	12	4	19	3	3	-2.1	-3.1	-3.4	1763.4	6.9	-1.6	-2.55833	1
45630	2024	12	4	20	3	3	-2.2	-3.7	-3.1	1755.0	6.9	-1.6	-2.75	1
45630	2024	12	4	21	3	3	-2.3	-4.3	-2.6	1737.5	6.9	-1.6	-2.93333	1
45630	2024	12	4	22	3	3	-2.4	-5.4	-2.1	1686.5	6.9	-1.7	-3.06667	1
45630	2024	12	4	23	3	3	-2.5	-5.6	-0.7	1599.3	6.9	-1.9	-3.175	1
45630	2024	12	4	24	3	3	-2.7	-5.2	0	1564.8	6.9	-2.2	-3.21667	1
45631	2024	12	5	1	4	4	-2.9	-4.4	-0.8	1510.6	22.1	-2.6	-3.125	1
4														

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLag	Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLag	Weekdays
45631	2024	12	5	12	4	-1.5	4.4	-4.4	1663.4	22.1	-0.8	-2.2	1
45631	2024	12	5	13	4	-1.3	5.3	-3.9	1671.3	22.1	0.0	-2.575	1
45631	2024	12	5	14	4	-1.1	6.6	-3.8	1649.5	22.1	0.8	-2.94167	1
45631	2024	12	5	15	4	-0.8	7.6	-3.9	1611.1	22.1	1.7	-3.2	1
45631	2024	12	5	16	4	-0.4	8.1	-3.1	1587.5	22.1	2.7	-3.525	1
45631	2024	12	5	17	4	-0.1	7.9	-1.4	1617.4	22.1	3.7	-3.85833	1
45631	2024	12	5	18	4	0.3	7.6	2.1	1637.4	22.1	4.6	-4.05833	1
45631	2024	12	5	19	4	0.7	7.1	1.9	1583.5	22.1	5.3	-3.98333	1
45631	2024	12	5	20	4	1.1	6.9	3.3	1527.1	22.1	5.7	-3.55	1
45631	2024	12	5	21	4	1.5	7.2	4.3	1467.7	22.1	6.2	-3.08333	1
45631	2024	12	5	22	4	2.0	6.3	4.7	1389.3	22.1	6.5	-2.45	1
45631	2024	12	5	23	4	2.5	5.6	4.4	1301.1	22.1	6.6	-1.64167	1
45631	2024	12	5	24	4	3.0	5.5	5.3	1253.6	22.1	6.7	-0.78333	1
45632	2024	12	6	1	5	3.4	4.5	6.6	1210.4	21.6	6.8	0.016667	1
45632	2024	12	6	2	5	3.8	3.4	7.6	1183.2	21.6	6.7	0.825	1
45632	2024	12	6	3	5	4.1	2.3	8.1	1167.1	21.6	6.5	1.7	1
45632	2024	12	6	4	5	4.3	1.6	7.9	1169.2	21.6	6.0	2.65	1
45632	2024	12	6	5	5	4.6	1.9	7.6	1199.8	21.6	5.5	3.65	1
45632	2024	12	6	6	5	4.8	1.9	7.1	1274.7	21.6	5.0	4.566667	1
45632	2024	12	6	7	5	4.9	1.9	6.9	1415.6	21.6	4.5	5.316667	1
45632	2024	12	6	8	5	4.9	1.8	7.2	1537.8	21.6	4.1	5.733333	1
45632	2024	12	6	9	5	4.9	1.1	6.3	1570.5	21.6	3.7	6.15	1
45632	2024	12	6	10	5	4.8	1.6	5.6	1570.0	21.6	3.2	6.475	1
45632	2024	12	6	11	5	4.7	1.6	5.5	1566.4	21.6	2.8	6.641667	1
45632	2024	12	6	12	5	4.6	1.9	4.5	1562.4	21.6	2.4	6.716667	1
45632	2024	12	6	13	5	4.5	1.6	3.4	1562.8	21.6	2.1	6.808333	1
45632	2024	12	6	14	5	4.3	1.4	2.3	1557.0	21.6	1.9	6.741667	1
45632	2024	12	6	15	5	4.1	1.5	1.6	1570.6	21.6	1.7	6.475	1
45632	2024	12	6	16	5	3.8	1	1.9	1614.1	21.6	1.7	6.033333	1
45632	2024	12	6	17	5	3.5	0.4	1.9	1698.2	21.6	1.6	5.491667	1
45632	2024	12	6	18	5	3.2	-0.8	1.9	1758.6	21.6	1.5	4.991667	1
45632	2024	12	6	19	5	2.9	-1.5	1.8	1730.6	21.6	1.3	4.516667	1
45632	2024	12	6	20	5	2.5	-1.9	1.1	1695.7	21.6	1.0	4.083333	1
45632	2024	12	6	21	5	2.2	-2.7	1.6	1664.8	21.6	0.7	3.658333	1
45632	2024	12	6	22	5	1.7	-2.9	1.6	1619.7	21.6	0.3	3.15	1
45632	2024	12	6	23	5	1.4	-3.5	1.9	1558.1	21.6	0.0	2.758333	1
45632	2024	12	6	24	5	1.0	-4.2	1.6	1540.4	21.6	-0.5	2.425	1
45633	2024	12	7	1	6	0.6	-4.5	1.4	1507.2	14.6	-1.0	2.125	0
45633	2024	12	7	2	6	0.2	-5	1.5	1478.5	14.6	-1.5	1.883333	0
45633	2024	12	7	3	6	-0.1	-4.8	1	1458.1	14.6	-2.0	1.716667	0
45633	2024	12	7	4	6	-0.4	-5	0.4	1451.2	14.6	-2.5	1.65	0
45633	2024	12	7	5	6	-0.7	-5.4	-0.8	1457.0	14.6	-3.0	1.6	0
45633	2024	12	7	6	6	-1.0	-5.8	-1.5	1491.6	14.6	-3.5	1.475	0
45633	2024	12	7	7	6	-1.3	-5.7	-1.9	1556.9	14.6	-3.9	1.25	0
45633	2024	12	7	8	6	-1.7	-6.1	-2.7	1638.4	14.6	-4.3	0.966667	0
45633	2024	12	7	9	6	-2.0	-6.2	-2.9	1712.0	14.6	-4.6	0.658333	0
45633	2024	12	7	10	6	-2.3	-5.1	-3.5	1714.1	14.6	-4.9	0.341667	0
45633	2024	12	7	11	6	-2.6	-4.2	-4.2	1694.8	14.6	-5.1	-0.03333	0
45633	2024	12	7	12	6	-2.8	-3.6	-4.5	1692.0	14.6	-5.2	-0.45833	0
45633	2024	12	7	13	6	-3.0	-4.5	-5	1673.4	14.6	-5.1	-0.96667	0
45633	2024	12	7	14	6	-3.3	-3.8	-4.8	1657.0	14.6	-5.1	-1.475	0
45633	2024	12	7	15	6	-3.5	-4.9	-5	1657.2	14.6	-5.0	-2.00833	0
45633	2024	12	7	16	6	-3.8	-4.3	-5.4	1704.0	14.6	-5.0	-2.53333	0
45633	2024	12	7	17	6	-4.0	-5.8	-5.8	1822.1	14.6	-5.0	-3.03333	0
45633	2024	12	7	18	6	-4.3	-6.4	-5.7	1914.1	14.6	-5.0	-3.51667	0
45633	2024	12	7	19	6	-4.5	-6.7	-6.1	1887.2	14.6	-5.1	-3.93333	0
45633	2024	12	7	20	6	-4.7	-6.9	-6.2	1867.0	14.6	-5.1	-4.28333	0
45633	2024	12	7	21	6	-4.9	-6.8	-5.1	1835.8	14.6	-5.2	-4.63333	0
45633	2024	12	7	22	6	-5.1	-6.5	-4.2	1792.3	14.6	-5.3	-4.925	0
45633	2024	12	7	23	6	-5.2	-6.5	-3.6	1729.9	14.6	-5.4	-5.10833	0
45633	2024	12	7	24	6	-5.4	-6.6	-4.5	1656.9	14.6	-5.6	-5.16667	0
45634	2024	12	8	1	7	-5.5	-6.8	-3.8	1612.3	17.0	-5.8	-5.11667	0
45634	2024	12	8	2	7	-5.6	-7.3	-4.9	1587.2	17.0	-6.0	-5.11667	0
45634	2024	12	8	3	7	-5.7	-7.6	-4.3	1585.6	17.0	-6.3	-5.01667	0
45634	2024	12	8	4	7	-5.8	-9.8	-5.8	1598.8	17.0	-6.5	-5.025	0
45634	2024	12	8	5	7	-6.0	-9.6	-6.4	1614.7	17.0	-7.0	-4.96667	0
45634	2024	12	8	6	7	-6.1	-8.4	-6.7	1635.6	17.0	-7.3	-5	0
45634	2024	12	8	7	7	-6.3	-7.1	-6.9	1672.0	17.0	-7.5	-5.05	0
45634	2024	12	8	8	7	-6.3	-6.5	-6.8	1714.1	17.0	-7.5	-5.13333	0
45634	2024	12	8	9	7	-6.3	-5.9	-6.5	1771.8	17.0	-7.5	-5.2	0
45634	2024	12	8	10	7	-6.3	-3.9	-6.5	1829.1	17.0	-7.4	-5.25	0
45634	2024	12	8	11	7	-6.3	-1.3	-6.6	1846.0	17.0	-7.2	-5.36667	0
45634	2024	12	8	12	7	-6.1	0.1	-6.8	1853.6	17.0	-6.7	-5.55833	0
45634	2024	12	8	13	7	-6.0	1.7	-7.3	1842.5	17.0	-6.2	-5.80833	0
45634	2024	12	8	14	7	-5.7	2.8	-7.6	1808.2	17.0	-5.5	-6	0
45634	2024	12	8	15	7	-5.5	3.2	-9.8	1782.9	17.0	-4.6	-6.29167	0
45634	2024	12	8	16	7	-5.1	4.1	-9.6	1760.2	17.0	-3.7	-6.51667	0
45634	2024	12	8	17	7	-4.8	5.1	-8.4	1800.4	17.0	-2.6	-6.975	0
45634	2024	12	8	18	7	-4.3	6	-7.1	1808.5	17.0	-1.3	-7.29167	0
45634	2024	12	8	19	7	-3.8	5.5	-6.5	1713.2	17.0	-0.1	-7.45833	0
45634	2024	12	8	20	7	-3.3	4.5	-5.9	1669.4	17.0	0.9	-7.49167	0
45634	2024	12	8	21	7	-2.8	4	-3.9	1613.5	17.0	1.8	-7.45833	0
45634	2024	12	8	22	7	-2.4	2.8	-1.3	1525.9	17.0	2.7	-7.38333	0
45634	2024	12	8	23	7	-2.0	2.2	0.1	1423.4	17.0	3.2	-7.16667	0
45634	2024	12	8	24	7	-1.6	2.3	1.7	1336.4	17.0	3.5	-6.73333	0
45635	2024	12	9	1	1	-1.2	2.2	2.8	1273.1	12.8	3.7	-6.175	1
45635	2024	12	9	2	1	-0.9	2.2	3.2	1250.9	12.8	3.7	-5.46667	1
45635	2024	12	9	3	1	-0.5	2.3	4.1	1245.0	12.8	3.7	-4.625	1
45635	2024	12	9	4	1	-0.1	2	5.1	1260.0	12.8	3.6	-3.725	1
45635	2024	12	9	5	1	0.4	1.3	6	1288.9	12.8	3.4	-2.56667	1
45635	2024	12	9	6	1	0.9	0.2	5.5	1374.3	12.8	3.1	-1.34167	1
45635	2024	12	9	7	1	1.2	-0.7	4.5	1524.3	12.8	2.6	-0.14167	1
45635	2024	12	9	8	1	1.5	-1.5	4	1649.3	12.8	2.1	0.908333	1
45635	2024	12	9	9	1	1.7	-1.4	2.8	1673.2	12.8	1.6	1.825	1
45635	2024	12	9	10	1	1.9	-0.6	2.2	1625.4	12.8	1.2	2.65	1
45635	2024	12	9	11	1	2.0	0	2.3	1585.4	12.8	0.9	3.208333	1
45635	2024	12	9	12	1	2.1	0.4	2.2	1556.2	12.8	0.7	3.5	1
45635	2024	12	9	13	1	2.1	0.9	2.2	1528.6	12.8	-0.5	3.683333	1
45635	2024	12	9	14	1	2.1	1.2	2.3	1497.1	12.8	0.4	3.725	1
45635	2024	12	9	15	1	2.0	1.9	2	1492.0	12.8	0.3	3.675	1
45635	2024	12	9	16	1	2.0	1.9	1.3	1541.3	12.8	0.3	3.6	1
45635	2024	12	9	17	1	1.9	0.8	0.2	1686.0	12.8	0.3	3.425	1
45635	2024	12	9	18	1</								

DATE	Year	Month	Day	HOUR	DOW	24hrAvgLa	g Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLa	g Weekdays	
45635	2024	12	12	9	24	1	0.2	-3	0.9	1508.0	12.8	-0.3	0.691667	1
45636	2024	12	12	10	1	2	0.0	-3.3	1.2	1470.5	14.4	-0.5	0.533333	1
45636	2024	12	12	10	2	2	-0.2	-3.6	1.9	1437.2	14.4	-0.9	0.425	1
45636	2024	12	12	10	3	2	-0.5	-3.5	1.9	1406.1	14.4	-1.3	0.341667	1
45636	2024	12	12	10	4	2	-0.7	-3.4	0.8	1395.2	14.4	-1.7	0.308333	1
45636	2024	12	12	10	5	2	-0.9	-3.1	-0.5	1399.3	14.4	-2.2	0.3	1
45636	2024	12	12	10	6	2	-1.1	-2.8	-1.3	1455.4	14.4	-2.5	0.258333	1
45636	2024	12	12	10	7	2	-1.2	-2.6	-1.4	1583.9	14.4	-2.7	0.2	1
45636	2024	12	12	10	8	2	-1.3	-2.5	-1.5	1688.9	14.4	-2.8	0.15	1
45636	2024	12	12	10	9	2	-1.4	-2.5	-2.5	1734.6	14.4	-2.9	0.158333	1
45636	2024	12	12	10	10	2	-1.4	-2.3	-2.9	1730.9	14.4	-3.0	0.15	1
45636	2024	12	12	10	11	2	-1.5	-1.4	-3	1724.3	14.4	-3.0	-0.00833	1
45636	2024	12	12	10	12	2	-1.5	-0.4	-3.3	1722.8	14.4	-2.8	-0.25	1
45636	2024	12	12	10	13	2	-1.6	0.2	-3.6	1718.0	14.4	-2.6	-0.53333	1
45636	2024	12	12	10	14	2	-1.6	0.6	-3.5	1699.1	14.4	-2.3	-0.88333	1
45636	2024	12	12	10	15	2	-1.6	0.8	-3.4	1688.7	14.4	-2.0	-1.28333	1
45636	2024	12	12	10	16	2	-1.7	1.4	-3.1	1701.0	14.4	-1.6	-1.73333	1
45636	2024	12	12	10	17	2	-1.7	1.7	-2.8	1759.6	14.4	-1.2	-2.175	1
45636	2024	12	12	10	18	2	-1.7	2.2	-2.6	1794.9	14.4	-0.8	-2.5	1
45636	2024	12	12	10	19	2	-1.5	3	-2.5	1747.4	14.4	-0.4	-2.69167	1
45636	2024	12	12	10	20	2	-1.4	3.7	-2.5	1696.4	14.4	0.1	-2.8	1
45636	2024	12	12	10	21	2	-1.2	4.2	-2.3	1643.0	14.4	0.6	-2.89167	1
45636	2024	12	12	10	22	2	-0.9	4.6	-1.4	1557.9	14.4	1.1	-2.975	1
45636	2024	12	12	10	23	2	-0.6	4.8	-0.4	1449.3	14.4	1.7	-2.95833	1
45636	2024	12	12	10	24	2	-0.3	5	0.2	1382.5	14.4	2.2	-2.83333	1
45637	2024	12	12	11	1	3	0.0	5.5	0.6	1308.7	12.5	2.7	-2.61667	1
45637	2024	12	12	11	2	3	0.4	5.8	0.8	1252.5	12.5	3.1	-2.325	1
45637	2024	12	12	11	3	3	0.8	6.5	1.4	1211.4	12.5	3.6	-1.975	1
45637	2024	12	12	11	4	3	1.2	6.4	1.7	1188.2	12.5	4.0	-1.61667	1
45637	2024	12	12	11	5	3	1.6	6.4	2.2	1188.9	12.5	4.5	-1.21667	1
45637	2024	12	12	11	6	3	2.0	6.3	3	1237.7	12.5	4.8	-0.81667	1
45637	2024	12	12	11	7	3	2.4	6.4	3.7	1358.7	12.5	5.2	-0.4	1
45637	2024	12	12	11	8	3	2.8	6.4	4.2	1463.9	12.5	5.5	0.06667	1
45637	2024	12	12	11	9	3	3.1	6.4	4.6	1479.3	12.5	5.7	0.583333	1
45637	2024	12	12	11	10	3	3.5	6.1	4.8	1467.9	12.5	5.9	1.141667	1
45637	2024	12	12	11	11	3	3.9	5.9	5	1461.7	12.5	6.0	1.716667	1
45637	2024	12	12	11	12	3	4.2	5.9	5.5	1463.7	12.5	6.1	2.233333	1
45637	2024	12	12	11	13	3	4.4	6.1	5.8	1457.5	12.5	6.2	2.683333	1
45637	2024	12	12	11	14	3	4.7	5.9	6.5	1435.6	12.5	6.2	3.125	1
45637	2024	12	12	11	15	3	4.9	6.4	6.4	1423.1	12.5	6.2	3.558333	1
45637	2024	12	12	11	16	3	5.1	6.9	6.4	1430.3	12.5	6.2	4.033333	1
45637	2024	12	12	11	17	3	5.4	8.1	6.3	1497.1	12.5	6.3	4.45	1
45637	2024	12	12	11	18	3	5.6	8.9	6.4	1531.4	12.5	6.4	4.841667	1
45637	2024	12	12	11	19	3	5.9	9.3	6.4	1476.0	12.5	6.6	5.183333	1
45637	2024	12	12	11	20	3	6.2	9.2	6.4	1426.8	12.5	6.9	5.466667	1
45637	2024	12	12	11	21	3	6.4	9.3	6.1	1374.1	12.5	7.1	5.691667	1
45637	2024	12	12	11	22	3	6.6	10.3	5.9	1291.5	12.5	7.3	5.875	1
45637	2024	12	12	11	23	3	6.8	11.5	5.9	1189.5	12.5	7.7	6	1
45637	2024	12	12	11	24	3	7.1	10.7	6.1	1102.3	12.5	8.2	6.091667	1
45638	2024	12	12	12	1	4	7.4	9.8	5.9	1023.9	24.7	8.6	6.166667	1
45638	2024	12	12	12	2	4	7.5	10.1	6.4	970.1	24.7	8.9	6.216667	1
45638	2024	12	12	12	3	4	7.7	10.6	6.9	946.3	24.7	9.2	6.225	1
45638	2024	12	12	12	4	4	7.9	10.4	8.1	940.5	24.7	9.6	6.216667	1
45638	2024	12	12	12	5	4	8.1	10.4	8.9	939.8	24.7	9.9	6.258333	1
45638	2024	12	12	12	6	4	8.2	10.4	9.3	992.3	24.7	10.0	6.4	1
45638	2024	12	12	12	7	4	8.4	10.8	9.2	1111.8	24.7	10.2	6.616667	1
45638	2024	12	12	12	8	4	8.6	10.9	9.3	1222.9	24.7	10.3	6.858333	1
45638	2024	12	12	12	9	4	8.8	11.1	10.3	1242.2	24.7	10.4	7.091667	1
45638	2024	12	12	12	10	4	9.0	11.7	11.5	1270.2	24.7	10.6	7.333333	1
45638	2024	12	12	12	11	4	9.2	12.1	10.7	1277.9	24.7	10.7	7.683333	1
45638	2024	12	12	12	12	4	9.5	10.5	9.8	1275.0	24.7	10.8	8.15	1
45638	2024	12	12	12	13	4	9.6	9.4	10.1	1275.4	24.7	10.7	8.55	1
45638	2024	12	12	12	14	4	9.8	8.5	10.6	1269.0	24.7	10.7	8.858333	1
45638	2024	12	12	12	15	4	9.9	8.4	10.4	1259.2	24.7	10.6	9.208333	1
45638	2024	12	12	12	16	4	10.0	7.7	10.4	1283.1	24.7	10.4	9.558333	1
45638	2024	12	12	12	17	4	10.0	7.2	10.4	1383.8	24.7	10.2	9.85	1
45638	2024	12	12	12	18	4	10.0	6	10.8	1485.2	24.7	9.9	10.04167	1
45638	2024	12	12	12	19	4	9.8	5.5	10.9	1469.2	24.7	9.5	10.16667	1
45638	2024	12	12	12	20	4	9.7	4.9	11.1	1455.8	24.7	9.1	10.29167	1
45638	2024	12	12	12	21	4	9.5	4.4	11.7	1432.4	24.7	8.6	10.43333	1
45638	2024	12	12	12	22	4	9.3	3.7	12.1	1397.7	24.7	8.0	10.58333	1
45638	2024	12	12	12	23	4	9.0	4.4	10.5	1317.8	24.7	7.4	10.7	1
45638	2024	12	12	12	24	4	8.7	4	9.4	1279.5	24.7	6.7	10.75	1
45639	2024	12	13	1	5	5	8.5	3.8	8.5	1233.8	12.3	6.2	10.73333	1
45639	2024	12	13	2	5	5	8.2	4.1	8.4	1200.9	12.3	5.7	10.7	1
45639	2024	12	13	3	5	5	8.0	3.5	7.7	1180.2	12.3	5.3	10.56667	1
45639	2024	12	13	4	5	5	7.7	4	7.2	1164.3	12.3	4.9	10.38333	1
45639	2024	12	13	5	5	5	7.4	3.9	6	1187.5	12.3	4.6	10.15833	1
45639	2024	12	13	6	5	5	7.1	2.4	5.5	1249.4	12.3	4.4	9.891667	1
45639	2024	12	13	7	5	5	6.8	1.5	4.9	1394.9	12.3	4.1	9.525	1
45639	2024	12	13	8	5	5	6.4	0.5	4.4	1520.2	12.3	3.7	9.083333	1
45639	2024	12	13	9	5	5	6.0	0.4	3.7	1541.0	12.3	3.4	8.583333	1
45639	2024	12	13	10	5	5	5.5	0.8	4.4	1492.2	12.3	3.0	8.025	1
45639	2024	12	13	11	5	5	5.1	1.4	4	1451.0	12.3	2.8	7.358333	1
45639	2024	12	13	12	5	5	4.6	1.6	3.8	1432.2	12.3	2.5	6.716667	1
45639	2024	12	13	13	5	5	4.3	0.8	4.1	1411.7	12.3	2.3	6.175	1
45639	2024	12	13	14	5	5	3.9	1	3.5	1396.0	12.3	2.1	5.708333	1
45639	2024	12	13	15	5	5	3.6	1.3	4	1399.6	12.3	1.8	5.341667	1
45639	2024	12	13	16	5	5	3.3	1.2	3.9	1458.5	12.3	1.6	4.933333	1
45639	2024	12	13	17	5	5	3.0	0.6	2.4	1593.2	12.3	1.4	4.625	1
45639	2024	12	13	18	5	5	2.7	-0.4	1.5	1705.7	12.3	1.1	4.35	1
45639	2024	12	13	19	5	5	2.5	-0.8	0.5	1690.9	12.3	0.9	4.05	1
45639	2024	12	13	20	5	5	2.2	-1	0.4	1670.4	12.3	0.7	3.716667	1
45639	2024	12	13	21	5	5	2.0	-1.1	0.8	1659.3	12.3	0.6	3.35	1
45639	2024	12	13	22	5	5	1.7	-1.6	1.4	1611.1	12.3	0.5	3.016667	1
45639	2024	12	13	23	5	5	1.5	-1.8</						

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLa	gTemp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLa	gWeekdays	
45640	2024	12	12	14	12	6	-2.0	-2	-2.3	1609.0	12.8	-3.9	-0.01667	0
45640	2024	12	12	14	13	6	-2.1	-0.7	-2.8	1556.6	12.8	-3.9	-0.33333	0
45640	2024	12	12	14	14	6	-2.2	-0.1	-3.6	1525.6	12.8	-3.8	-0.59167	0
45640	2024	12	12	14	15	6	-2.2	0.7	-3.9	1521.5	12.8	-3.6	-0.90833	0
45640	2024	12	12	14	16	6	-2.3	0.9	-4.4	1557.8	12.8	-3.2	-1.31667	0
45640	2024	12	12	14	17	6	-2.3	0.1	-4.8	1681.2	12.8	-2.8	-1.74167	0
45640	2024	12	12	14	18	6	-2.3	-1.4	-5	1793.8	12.8	-2.4	-2.15833	0
45640	2024	12	12	14	19	6	-2.3	-2.3	-5.2	1768.3	12.8	-2.1	-2.525	0
45640	2024	12	12	14	20	6	-2.4	-2.3	-5.2	1743.8	12.8	-1.9	-2.875	0
45640	2024	12	12	14	21	6	-2.4	-3.2	-4.3	1734.6	12.8	-1.7	-3.225	0
45640	2024	12	12	14	22	6	-2.5	-4.2	-3.4	1695.2	12.8	-1.5	-3.56667	0
45640	2024	12	12	14	23	6	-2.6	-5.5	-2	1638.1	12.8	-1.5	-3.79167	0
45640	2024	12	12	14	24	6	-2.8	-5.3	-0.7	1588.9	12.8	-1.7	-3.925	0
45641	2024	12	12	15	1	7	-2.9	-5	-0.1	1535.8	7.3	-1.9	-3.90833	0
45641	2024	12	12	15	2	7	-3.0	-5.7	0.7	1512.8	7.3	-2.3	-3.775	0
45641	2024	12	12	15	3	7	-3.2	-5.9	0.9	1502.2	7.3	-2.8	-3.55	0
45641	2024	12	12	15	4	7	-3.3	-7	0.1	1505.6	7.3	-3.3	-3.19167	0
45641	2024	12	12	15	5	7	-3.4	-6.9	-1.4	1522.9	7.3	-4.0	-2.79167	0
45641	2024	12	12	15	6	7	-3.5	-6.7	-2.3	1556.6	7.3	-4.6	-2.41667	0
45641	2024	12	12	15	7	7	-3.6	-7	-2.3	1614.3	7.3	-5.0	-2.13333	0
45641	2024	12	12	15	8	7	-3.7	-7.9	-3.2	1687.5	7.3	-5.4	-1.90833	0
45641	2024	12	12	15	9	7	-3.8	-7.9	-4.2	1758.4	7.3	-5.9	-1.66667	0
45641	2024	12	12	15	10	7	-3.9	-5.7	-5.5	1759.0	7.3	-6.3	-1.5	0
45641	2024	12	12	15	11	7	-3.9	-4.3	-5.3	1703.1	7.3	-6.4	-1.49167	0
45641	2024	12	12	15	12	7	-4.0	-2.4	-5	1646.5	7.3	-6.3	-1.66667	0
45641	2024	12	12	15	13	7	-4.0	-0.5	-5.7	1590.5	7.3	-6.0	-1.94167	0
45641	2024	12	12	15	14	7	-4.0	1.1	-5.9	1530.8	7.3	-5.7	-2.3	0
45641	2024	12	12	15	15	7	-3.9	1.6	-7	1510.9	7.3	-5.1	-2.76667	0
45641	2024	12	12	15	16	7	-3.9	1.5	-6.9	1556.5	7.3	-4.5	-3.31667	0
45641	2024	12	12	15	17	7	-3.9	0.9	-6.7	1683.9	7.3	-3.8	-3.975	0
45641	2024	12	12	15	18	7	-3.8	-0.7	-7	1798.3	7.3	-3.1	-4.55833	0
45641	2024	12	12	15	19	7	-3.8	-1.4	-7.9	1789.2	7.3	-2.6	-5	0
45641	2024	12	12	15	20	7	-3.8	-2.1	-7.9	1792.5	7.3	-2.1	-5.39167	0
45641	2024	12	12	15	21	7	-3.8	-2.4	-5.7	1777.8	7.3	-1.7	-5.85833	0
45641	2024	12	12	15	22	7	-3.7	-1.8	-4.3	1726.2	7.3	-1.2	-6.25	0
45641	2024	12	12	15	23	7	-3.6	-1.9	-2.4	1630.6	7.3	-0.9	-6.375	0
45641	2024	12	12	15	24	7	-3.5	-2.1	-0.5	1545.2	7.3	-0.7	-6.275	0
45642	2024	12	12	16	1	1	-3.3	-2.4	1.1	1490.9	6.0	-0.7	-6.03333	1
45642	2024	12	12	16	2	1	-3.2	-3	1.6	1477.4	6.0	-0.8	-5.65833	1
45642	2024	12	12	16	3	1	-3.1	-3.8	1.5	1483.7	6.0	-1.2	-5.09167	1
45642	2024	12	12	16	4	1	-3.0	-4	0.9	1488.5	6.0	-1.6	-4.46667	1
45642	2024	12	12	16	5	1	-2.9	-5.3	-0.7	1513.7	6.0	-2.1	-3.75833	1
45642	2024	12	12	16	6	1	-2.8	-4	-1.4	1587.0	6.0	-2.6	-3.10833	1
45642	2024	12	12	16	7	1	-2.7	-3.3	-2.1	1741.0	6.0	-2.9	-2.60833	1
45642	2024	12	12	16	8	1	-2.6	-3.6	-2.4	1871.0	6.0	-3.0	-2.14167	1
45642	2024	12	12	16	9	1	-2.4	-3.6	-1.8	1882.1	6.0	-3.1	-1.65833	1
45642	2024	12	12	16	10	1	-2.2	-1.3	-1.9	1784.8	6.0	-3.2	-1.2	1
45642	2024	12	12	16	11	1	-2.0	-0.4	-2.1	1657.3	6.0	-3.2	-0.875	1
45642	2024	12	12	16	12	1	-1.9	1.3	-2.4	1570.9	6.0	-3.1	-0.675	1
45642	2024	12	12	16	13	1	-1.7	2.7	-3	1514.3	6.0	-2.8	-0.65	1
45642	2024	12	12	16	14	1	-1.6	3.4	-3.8	1466.2	6.0	-2.4	-0.80833	1
45642	2024	12	12	16	15	1	-1.5	3.8	-4	1451.0	6.0	-1.8	-1.15	1
45642	2024	12	12	16	16	1	-1.4	3.4	-5.3	1493.8	6.0	-1.2	-1.6	1
45642	2024	12	12	16	17	1	-1.3	2.6	-4	1621.1	6.0	-0.6	-2.05833	1
45642	2024	12	12	16	18	1	-1.2	1	-3.3	1741.4	6.0	0.1	-2.575	1
45642	2024	12	12	16	19	1	-1.2	0.6	-3.6	1725.2	6.0	0.5	-2.85	1
45642	2024	12	12	16	20	1	-1.1	-0.3	-3.6	1712.1	6.0	0.8	-3.00833	1
45642	2024	12	12	16	21	1	-1.0	-1.3	-1.3	1682.4	6.0	1.1	-3.13333	1
45642	2024	12	12	16	22	1	-1.0	-1	-0.4	1619.4	6.0	1.3	-3.23333	1
45642	2024	12	12	16	23	1	-0.9	-1.4	1.3	1532.6	6.0	1.3	-3.19167	1
45642	2024	12	12	16	24	1	-0.9	-1.1	2.7	1492.1	6.0	1.2	-3.06667	1
45643	2024	12	12	17	1	2	-0.9	-0.9	3.4	1453.5	17.3	1.0	-2.78333	1
45643	2024	12	12	17	2	2	-0.8	-1.8	3.8	1422.1	17.3	0.7	-2.35833	1
45643	2024	12	12	17	3	2	-0.8	-3.2	3.4	1397.2	17.3	0.3	-1.825	1
45643	2024	12	12	17	4	2	-0.7	-2.4	2.6	1386.0	17.3	-0.3	-1.19167	1
45643	2024	12	12	17	5	2	-0.7	0.6	1	1373.3	17.3	-0.8	-0.575	1
45643	2024	12	12	17	6	2	-0.4	2.4	0.6	1413.5	17.3	-0.9	0.083333	1
45643	2024	12	12	17	7	2	-0.2	4	-0.3	1519.9	17.3	-0.8	0.5	1
45643	2024	12	12	17	8	2	0.1	4.3	-1.3	1614.2	17.3	-0.5	0.825	1
45643	2024	12	12	17	9	2	0.5	4.7	-1	1615.4	17.3	-0.2	1.1	1
45643	2024	12	12	17	10	2	0.8	5.6	-1.4	1566.1	17.3	0.4	1.291667	1
45643	2024	12	12	17	11	2	1.1	6.3	-1.1	1531.2	17.3	0.9	1.316667	1
45643	2024	12	12	17	12	2	1.4	7.1	-0.9	1508.0	17.3	1.5	1.233333	1
45643	2024	12	12	17	13	2	1.6	8	-1.8	1498.2	17.3	2.2	1.033333	1
45643	2024	12	12	17	14	2	1.9	8.5	-3.2	1471.5	17.3	3.0	0.733333	1
45643	2024	12	12	17	15	2	2.1	9.6	-2.4	1460.4	17.3	3.8	0.3	1
45643	2024	12	12	17	16	2	2.3	9	0.6	1470.5	17.3	4.9	-0.28333	1
45643	2024	12	12	17	17	2	2.5	9.6	2.4	1520.1	17.3	5.8	-0.76667	1
45643	2024	12	12	17	18	2	2.8	9.4	4	1557.6	17.3	6.6	-0.93333	1
45643	2024	12	12	17	19	2	3.2	9.2	4.3	1515.6	17.3	7.2	-0.81667	1
45643	2024	12	12	17	20	2	3.5	8.8	4.7	1480.5	17.3	7.6	-0.53333	1
45643	2024	12	12	17	21	2	3.9	8.3	5.6	1438.4	17.3	8.0	-0.15	1
45643	2024	12	12	17	22	2	4.3	7.7	6.3	1374.4	17.3	8.3	0.35	1
45643	2024	12	12	17	23	2	4.7	7.5	7.1	1276.1	17.3	8.5	0.9	1
45643	2024	12	12	17	24	2	5.1	7.8	8	1213.5	17.3	8.6	1.541667	1
45644	2024	12	12	18	1	3	5.4	7.5	8.5	1167.3	8.5	8.6	2.225	1
45644	2024	12	12	18	2	3	5.8	6.5	9.6	1131.6	8.5	8.6	2.966667	1
45644	2024	12	12	18	3	3	6.1	5.7	9	1103.1	8.5	8.4	3.825	1
45644	2024	12	12	18	4	3	6.5	5.6	9.6	1105.8	8.5	8.1	4.891667	1
45644	2024	12	12	18	5	3	6.8	5.2	9.4	1134.1	8.5	7.8	5.841667	1
45644	2024	12	12	18	6	3	7.0	4.4	9.2	1206.5	8.5	7.4	6.591667	1
45644	2024	12	12	18	7	3	7.1	3.6	8.8	1346.6	8.5	7.0	7.175	1
45644	2024	12	12	18	8	3	7.1	3.5	8.3	1477.9	8.5	6.6	7.608333	1
45644	2024	12	12	18	9	3	7.0	3.7	7.7	1495.5	8.5	6.1	7.983333	1
45644	2024	12	12	18	10	3	7.0	4.3	7.5	1421.9	8.5	5.7	8.283333	1
45644	2024	12	12	18	11	3	7.0	5.8	7.8	1354.1	8.5	5.4	8.458333	1
45644	2024	12	12	18	12	3	6.9	6.7						

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLag	Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLag	Weekdays
45644	2024	12	18	24	3	5.5	4.9	7.6	1343.8	8.5	5.8	5.3	1
45645	2024	12	19	1	4	5.4	2.8	7.9	1301.8	9.9	5.6	5.208333	1
45645	2024	12	19	2	4	5.2	1.2	7.8	1267.1	9.9	5.2	5.216667	1
45645	2024	12	19	3	4	5.0	3.4	7.5	1224.9	9.9	4.7	5.333333	1
45645	2024	12	19	4	4	4.9	4.8	6.3	1208.3	9.9	4.3	5.508333	1
45645	2024	12	19	5	4	4.9	4.8	4.7	1206.5	9.9	4.1	5.666667	1
45645	2024	12	19	6	4	4.9	4.5	4.1	1261.6	9.9	3.9	5.758333	1
45645	2024	12	19	7	4	4.9	4.2	4.3	1387.2	9.9	3.9	5.783333	1
45645	2024	12	19	8	4	4.9	4.2	4.1	1500.0	9.9	3.9	5.825	1
45645	2024	12	19	9	4	4.9	4.3	3.4	1530.9	9.9	3.9	5.891667	1
45645	2024	12	19	10	4	4.9	4.2	4.8	1533.5	9.9	3.9	5.925	1
45645	2024	12	19	11	4	4.9	4.6	4.9	1534.8	9.9	4.0	5.85	1
45645	2024	12	19	12	4	4.9	5	2.8	1532.1	9.9	4.0	5.766667	1
45645	2024	12	19	13	4	4.8	4.9	1.2	1509.5	9.9	4.0	5.616667	1
45645	2024	12	19	14	4	4.7	5.2	3.4	1481.5	9.9	4.2	5.216667	1
45645	2024	12	19	15	4	4.6	5.3	4.8	1456.0	9.9	4.5	4.658333	1
45645	2024	12	19	16	4	4.5	5.3	4.8	1455.2	9.9	4.7	4.291667	1
45645	2024	12	19	17	4	4.4	5.3	4.5	1534.3	9.9	4.7	4.066667	1
45645	2024	12	19	18	4	4.3	3.8	4.2	1633.8	9.9	4.8	3.941667	1
45645	2024	12	19	19	4	4.3	3.1	4.2	1625.6	9.9	4.7	3.925	1
45645	2024	12	19	20	4	4.3	2.4	4.3	1620.6	9.9	4.6	3.933333	1
45645	2024	12	19	21	4	4.2	2.3	4.2	1603.8	9.9	4.5	3.925	1
45645	2024	12	19	22	4	4.1	1.5	4.6	1557.1	9.9	4.3	3.941667	1
45645	2024	12	19	23	4	4.0	0.7	5	1485.8	9.9	4.1	4.008333	1
45645	2024	12	19	24	4	3.9	-0.1	4.9	1449.0	9.9	3.7	3.991667	1
45646	2024	12	20	1	5	3.7	-1.3	5.2	1413.4	11.8	3.3	4	1
45646	2024	12	20	2	5	3.5	-1.4	5.3	1379.9	11.8	2.8	4.175	1
45646	2024	12	20	3	5	3.4	-1.4	5.3	1356.9	11.8	2.2	4.508333	1
45646	2024	12	20	4	5	3.2	-1.5	5.3	1351.8	11.8	1.7	4.666667	1
45646	2024	12	20	5	5	2.9	-1.9	3.8	1368.3	11.8	1.1	4.708333	1
45646	2024	12	20	6	5	2.6	-2.2	3.1	1434.5	11.8	0.5	4.75	1
45646	2024	12	20	7	5	2.4	-2.4	2.4	1565.5	11.8	0.0	4.691667	1
45646	2024	12	20	8	5	2.1	-2.6	2.3	1651.6	11.8	-0.4	4.6	1
45646	2024	12	20	9	5	1.8	-2.7	1.5	1688.7	11.8	-0.9	4.45	1
45646	2024	12	20	10	5	1.5	-2.6	0.7	1687.4	11.8	-1.3	4.283333	1
45646	2024	12	20	11	5	1.2	-1.9	-0.1	1661.2	11.8	-1.6	4.058333	1
45646	2024	12	20	12	5	1.0	-1.1	-1.3	1646.0	11.8	-1.8	3.733333	1
45646	2024	12	20	13	5	0.7	-0.7	-1.4	1633.1	11.8	-1.9	3.308333	1
45646	2024	12	20	14	5	0.5	-0.2	-1.4	1615.3	11.8	-1.9	2.791667	1
45646	2024	12	20	15	5	0.2	0.5	-1.5	1593.2	11.8	-1.8	2.241667	1
45646	2024	12	20	16	5	0.0	0	-1.9	1618.5	11.8	-1.6	1.683333	1
45646	2024	12	20	17	5	-0.2	0.1	-2.2	1696.5	11.8	-1.5	1.116667	1
45646	2024	12	20	18	5	-0.4	-0.3	-2.4	1762.5	11.8	-1.3	0.516667	1
45646	2024	12	20	19	5	-0.6	-0.3	-2.6	1736.2	11.8	-1.2	0.016667	1
45646	2024	12	20	20	5	-0.7	0	-2.7	1708.0	11.8	-1.0	-0.44167	1
45646	2024	12	20	21	5	-0.8	0.1	-2.6	1656.8	11.8	-0.8	-0.85833	1
45646	2024	12	20	22	5	-0.9	0.5	-1.9	1588.8	11.8	-0.5	-1.275	1
45646	2024	12	20	23	5	-0.9	0.3	-1.1	1513.9	11.8	-0.3	-1.61667	1
45646	2024	12	20	24	5	-1.0	0	-0.7	1492.8	11.8	-0.1	-1.83333	1
45647	2024	12	21	1	6	-1.0	0	-0.2	1462.7	22.5	0.0	-1.91667	0
45647	2024	12	21	2	6	-0.9	-0.5	0.5	1424.4	22.5	0.1	-1.86667	0
45647	2024	12	21	3	6	-0.9	-1.3	0	1390.2	22.5	0.0	-1.76667	0
45647	2024	12	21	4	6	-0.9	-1.8	0.1	1381.2	22.5	-0.1	-1.60833	0
45647	2024	12	21	5	6	-0.9	-1.9	-0.3	1374.0	22.5	-0.3	-1.48333	0
45647	2024	12	21	6	6	-0.9	-1.6	-0.3	1388.6	22.5	-0.4	-1.31667	0
45647	2024	12	21	7	6	-0.9	-1.1	0	1436.0	22.5	-0.5	-1.15833	0
45647	2024	12	21	8	6	-0.8	-1.2	0.1	1495.0	22.5	-0.6	-0.98333	0
45647	2024	12	21	9	6	-0.7	-1.3	0.5	1560.8	22.5	-0.7	-0.76667	0
45647	2024	12	21	10	6	-0.7	-0.8	0.3	1626.2	22.5	-0.8	-0.53333	0
45647	2024	12	21	11	6	-0.6	-0.1	0	1679.6	22.5	-0.9	-0.275	0
45647	2024	12	21	12	6	-0.5	0	0	1726.9	22.5	-1.0	-0.09167	0
45647	2024	12	21	13	6	-0.5	0.1	-0.5	1745.2	22.5	-1.0	4.63E-18	0
45647	2024	12	21	14	6	-0.5	0	-1.3	1728.2	22.5	-1.0	0.058333	0
45647	2024	12	21	15	6	-0.4	-0.5	-1.8	1699.3	22.5	-0.9	0.033333	0
45647	2024	12	21	16	6	-0.5	-0.8	-1.9	1706.6	22.5	-0.9	-0.11667	0
45647	2024	12	21	17	6	-0.5	-2.2	-1.6	1793.1	22.5	-0.8	-0.26667	0
45647	2024	12	21	18	6	-0.6	-2.2	-1.1	1865.4	22.5	-0.8	-0.43333	0
45647	2024	12	21	19	6	-0.7	-2.8	-1.2	1818.3	22.5	-0.8	-0.54167	0
45647	2024	12	21	20	6	-0.8	-3.5	-1.3	1774.4	22.5	-1.0	-0.60833	0
45647	2024	12	21	21	6	-0.9	-3.7	-0.8	1738.6	22.5	-1.2	-0.70833	0
45647	2024	12	21	22	6	-1.1	-4.2	-0.1	1689.3	22.5	-1.4	-0.825	0
45647	2024	12	21	23	6	-1.3	-4.7	0	1620.1	22.5	-1.7	-0.93333	0
45647	2024	12	21	24	6	-1.5	-4.8	0.1	1548.1	22.5	-2.0	-0.96667	0
45648	2024	12	22	1	7	-1.7	-5.1	0	1490.9	14.8	-2.4	-0.96667	0
45648	2024	12	22	2	7	-1.9	-5.4	-0.5	1462.3	14.8	-2.9	-0.95833	0
45648	2024	12	22	3	7	-2.1	-5.4	-0.8	1453.6	14.8	-3.3	-0.91667	0
45648	2024	12	22	4	7	-2.3	-5.6	-2.2	1459.2	14.8	-3.7	-0.85	0
45648	2024	12	22	5	7	-2.5	-5.8	-2.2	1473.7	14.8	-4.1	-0.76667	0
45648	2024	12	22	6	7	-2.6	-5.9	-2.8	1510.3	14.8	-4.4	-0.79167	0
45648	2024	12	22	7	7	-2.8	-6.6	-3.5	1567.9	14.8	-4.7	-0.84167	0
45648	2024	12	22	8	7	-3.0	-6.5	-3.7	1651.5	14.8	-5.1	-0.98333	0
45648	2024	12	22	9	7	-3.2	-6.8	-4.2	1762.3	14.8	-5.3	-1.175	0
45648	2024	12	22	10	7	-3.5	-7	-4.7	1834.6	14.8	-5.6	-1.375	0
45648	2024	12	22	11	7	-3.7	-7.2	-4.8	1832.5	14.8	-5.8	-1.65833	0
45648	2024	12	22	12	7	-4.0	-7.7	-5.1	1849.5	14.8	-6.0	-2.04167	0
45648	2024	12	22	13	7	-4.3	-7.5	-5.4	1845.5	14.8	-6.3	-2.44167	0
45648	2024	12	22	14	7	-4.7	-7.2	-5.4	1835.9	14.8	-6.5	-2.875	0
45648	2024	12	22	15	7	-5.0	-7.9	-5.6	1851.2	14.8	-6.6	-3.325	0
45648	2024	12	22	16	7	-5.3	-8.7	-5.8	1889.6	14.8	-6.8	-3.73333	0
45648	2024	12	22	17	7	-5.6	-9.4	-5.9	1981.2	14.8	-7.1	-4.13333	0
45648	2024	12	22	18	7	-5.9	-9.8	-6.6	2057.7	14.8	-7.4	-4.43333	0
45648	2024	12	22	19	7	-6.2	-10	-6.5	2022.6	14.8	-7.7	-4.74167	0
45648	2024	12	22	20	7	-6.5	-9.6	-6.8	1979.9	14.8	-8.0	-5.05833	0
45648	2024	12	22	21	7	-6.8	-9.4	-7	1935.8	14.8	-8.2	-5.30833	0
45648	2024	12	22	22	7	-7.0	-9	-7.2	1878.8	14.8	-8.5	-5.56667	0
45648	2024	12	22	23	7	-7.2	-8.6	-7.7	1782.7	14.8	-8.6	-5.8	0
45648	2024	12	22	24	7	-7.4	-8.5	-7.5	1703.7	14.8	-8.7	-6.00833	0
45649	2024	12	23	1	1	-7.5	-8.9	-7.2	1639.5	10.6	-8.8	-6.25	1
45649	2024	12	23	2	1	-7.7	-8.7	-7.9	1605.3	10.6	-8.9	-6.45	1
45649	2024	12	23	3	1	-7.8	-8.5	-8.7	1591.6	10.6	-9.0	-6.6	1
45649	2024	12	23	4	1	-8.0	-8.7	-9.4	1594.3	10.6	-9.1	-6.80833	1
45649	2024	12	23	5									

DATE	Year	Month	Day	HOUR	DOW	24hrAvgLa	gTemp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLa	gWeekdays	
45649	2024	12	12	23	12	1	-8.9	-7.7	-8.9	1870.2	10.6	-9.0	-8.73333	1
45649	2024	12	12	23	13	1	-8.9	-7.6	-8.7	1845.1	10.6	-9.0	-8.8	1
45649	2024	12	12	23	14	1	-8.9	-6.6	-8.5	1795.3	10.6	-8.9	-8.91667	1
45649	2024	12	12	23	15	1	-8.9	-6.3	-8.7	1775.5	10.6	-8.7	-9.04167	1
45649	2024	12	12	23	16	1	-8.8	-5.9	-8.7	1802.0	10.6	-8.5	-9.09167	1
45649	2024	12	12	23	17	1	-8.7	-5.7	-9.2	1890.5	10.6	-8.3	-9.09167	1
45649	2024	12	12	23	18	1	-8.5	-7.9	-9.6	1992.6	10.6	-8.0	-9.03333	1
45649	2024	12	12	23	19	1	-8.5	-7.4	-9.7	1986.5	10.6	-7.9	-8.98333	1
45649	2024	12	12	23	20	1	-8.3	-8.8	-10.3	1966.5	10.6	-7.7	-8.95	1
45649	2024	12	12	23	21	1	-8.3	-8.5	-9.3	1951.0	10.6	-7.7	-8.95833	1
45649	2024	12	12	23	22	1	-8.3	-8.5	-8.4	1923.4	10.6	-7.5	-9.03333	1
45649	2024	12	12	23	23	1	-8.3	-10	-7.7	1884.3	10.6	-7.4	-9.05833	1
45649	2024	12	12	23	24	1	-8.3	-9.1	-7.6	1860.7	10.6	-7.6	-9.04167	1
45650	2024	12	12	24	1	2	-8.3	-9.6	-6.6	1821.3	11.5	-7.7	-8.975	1
45650	2024	12	12	24	2	2	-8.4	-8.9	-6.3	1784.2	11.5	-7.9	-8.86667	1
45650	2024	12	12	24	3	2	-8.4	-11.3	-5.9	1754.3	11.5	-8.1	-8.69167	1
45650	2024	12	12	24	4	2	-8.5	-10.5	-5.7	1734.1	11.5	-8.5	-8.50833	1
45650	2024	12	12	24	5	2	-8.6	-7.5	-7.9	1728.3	11.5	-8.9	-8.275	1
45650	2024	12	12	24	6	2	-8.5	-8.9	-7.4	1744.4	11.5	-9.0	-8.025	1
45650	2024	12	12	24	7	2	-8.5	-8.6	-8.8	1798.4	11.5	-9.1	-7.91667	1
45650	2024	12	12	24	8	2	-8.5	-8	-8.5	1835.6	11.5	-9.2	-7.73333	1
45650	2024	12	12	24	9	2	-8.4	-7.2	-8.5	1901.4	11.5	-9.1	-7.65833	1
45650	2024	12	12	24	10	2	-8.3	-5	-10	1951.4	11.5	-9.0	-7.50833	1
45650	2024	12	12	24	11	2	-8.1	-1.8	-9.1	1969.2	11.5	-8.7	-7.44167	1
45650	2024	12	12	24	12	2	-7.8	-1.6	-9.6	1969.8	11.5	-8.0	-7.575	1
45650	2024	12	12	24	13	2	-7.6	-1.3	-8.9	1959.2	11.5	-7.4	-7.69167	1
45650	2024	12	12	24	14	2	-7.3	-1	-11.3	1912.3	11.5	-6.7	-7.85833	1
45650	2024	12	12	24	15	2	-7.1	-0.6	-10.5	1867.0	11.5	-6.1	-8.05	1
45650	2024	12	12	24	16	2	-6.8	-0.6	-7.5	1843.1	11.5	-5.2	-8.46667	1
45650	2024	12	12	24	17	2	-6.6	-0.5	-8.9	1837.9	11.5	-4.3	-8.85	1
45650	2024	12	12	24	18	2	-6.4	-0.4	-8.6	1821.8	11.5	-3.8	-9	1
45650	2024	12	12	24	19	2	-6.1	-0.2	-8	1741.9	11.5	-3.1	-9.08333	1
45650	2024	12	12	24	20	2	-5.8	-0.2	-7.2	1671.4	11.5	-2.4	-9.18333	1
45650	2024	12	12	24	21	2	-5.4	0	-5	1618.8	11.5	-1.7	-9.11667	1
45650	2024	12	12	24	22	2	-5.1	0	-1.8	1566.9	11.5	-1.1	-9.00833	1
45650	2024	12	12	24	23	2	-4.7	0.1	-1.6	1510.4	11.5	-0.7	-8.71667	1
45650	2024	12	12	24	24	2	-4.3	0.1	-1.3	1480.8	11.5	-0.5	-8.03333	1
45651	2024	12	12	25	1	3	-3.9	0	-1	1436.5	19.4	-0.4	-7.40833	0
45651	2024	12	12	25	2	3	-3.5	0.3	-0.6	1386.4	19.4	-0.3	-6.71667	0
45651	2024	12	12	25	3	3	-3.1	0.5	-0.6	1346.8	19.4	-0.2	-6.05833	0
45651	2024	12	12	25	4	3	-2.6	0.4	-0.5	1328.2	19.4	-0.1	-5.16667	0
45651	2024	12	12	25	5	3	-2.2	0.6	-0.4	1326.3	19.4	0.0	-4.34167	0
45651	2024	12	12	25	6	3	-1.8	0.6	-0.2	1351.7	19.4	0.1	-3.75833	0
45651	2024	12	12	25	7	3	-1.4	0.6	-0.2	1413.4	19.4	0.2	-3.05	0
45651	2024	12	12	25	8	3	-1.1	0.1	0	1475.5	19.4	0.3	-2.35	0
45651	2024	12	12	25	9	3	-0.7	-0.8	0	1559.3	19.4	0.3	-1.7	0
45651	2024	12	12	25	10	3	-0.4	-1.3	0.1	1581.5	19.4	0.2	-1.1	0
45651	2024	12	12	25	11	3	-0.3	-0.6	0.1	1567.8	19.4	0.1	-0.68333	0
45651	2024	12	12	25	12	3	-0.2	0	0	1580.2	19.4	0.0	-0.525	0
45651	2024	12	12	25	13	3	-0.2	0.4	0.3	1596.3	19.4	0.0	-0.38333	0
45651	2024	12	12	25	14	3	-0.1	0.5	0.5	1590.3	19.4	0.1	-0.275	0
45651	2024	12	12	25	15	3	0.0	0.1	0.4	1588.3	19.4	0.1	-0.16667	0
45651	2024	12	12	25	16	3	0.0	-0.1	0.6	1597.6	19.4	0.1	-0.075	0
45651	2024	12	12	25	17	3	0.0	-0.3	0.6	1621.6	19.4	0.0	0.008333	0
45651	2024	12	12	25	18	3	0.0	-0.3	0.6	1614.1	19.4	-0.1	0.1	0
45651	2024	12	12	25	19	3	0.0	-0.7	0.1	1571.7	19.4	-0.1	0.183333	0
45651	2024	12	12	25	20	3	0.0	-1.4	-0.8	1556.7	19.4	-0.3	0.25	0
45651	2024	12	12	25	21	3	-0.1	-1.8	-1.3	1542.6	19.4	-0.4	0.275	0
45651	2024	12	12	25	22	3	-0.1	-1.6	-0.6	1505.7	19.4	-0.5	0.208333	0
45651	2024	12	12	25	23	3	-0.2	-1.2	0	1447.0	19.4	-0.5	0.1	0
45651	2024	12	12	25	24	3	-0.2	-1	0.4	1416.4	19.4	-0.5	0.041667	0
45652	2024	12	12	26	1	4	-0.3	-1.1	0.5	1380.9	20.3	-0.6	0.033333	0
45652	2024	12	12	26	2	4	-0.3	-1.1	0.1	1343.5	20.3	-0.7	0.066667	0
45652	2024	12	12	26	3	4	-0.4	-1.3	-0.1	1317.2	20.3	-0.9	0.083333	0
45652	2024	12	12	26	4	4	-0.5	-1.2	-0.3	1306.1	20.3	-1.0	0.05	0
45652	2024	12	12	26	5	4	-0.5	-1.1	-0.3	1312.5	20.3	-1.1	0.008333	0
45652	2024	12	12	26	6	4	-0.6	-1.1	-0.7	1339.0	20.3	-1.2	-0.06667	0
45652	2024	12	12	26	7	4	-0.7	-1.3	-1.4	1384.1	20.3	-1.2	-0.14167	0
45652	2024	12	12	26	8	4	-0.8	-1.3	-1.8	1421.7	20.3	-1.3	-0.25	0
45652	2024	12	12	26	9	4	-0.8	-1	-1.6	1487.4	20.3	-1.3	-0.375	0
45652	2024	12	12	26	10	4	-0.8	-0.8	-1.2	1563.1	20.3	-1.2	-0.45833	0
45652	2024	12	12	26	11	4	-0.8	-0.8	-1	1605.1	20.3	-1.1	-0.48333	0
45652	2024	12	12	26	12	4	-0.8	-0.7	-1.1	1626.1	20.3	-1.1	-0.53333	0
45652	2024	12	12	26	13	4	-0.8	-0.4	-1.1	1618.1	20.3	-1.1	-0.61667	0
45652	2024	12	12	26	14	4	-0.9	-0.3	-1.3	1561.4	20.3	-1.0	-0.74167	0
45652	2024	12	12	26	15	4	-0.9	0.6	-1.2	1515.6	20.3	-0.9	-0.875	0
45652	2024	12	12	26	16	4	-0.9	0.4	-1.1	1522.5	20.3	-0.8	-0.99167	0
45652	2024	12	12	26	17	4	-0.9	-0.7	-1.1	1599.3	20.3	-0.7	-1.08333	0
45652	2024	12	12	26	18	4	-0.9	-1.4	-1.3	1686.6	20.3	-0.6	-1.15	0
45652	2024	12	12	26	19	4	-0.9	-2	-1.3	1668.8	20.3	-0.6	-1.21667	0
45652	2024	12	12	26	20	4	-1.0	-1.8	-1	1647.6	20.3	-0.7	-1.26667	0
45652	2024	12	12	26	21	4	-1.0	-2	-0.8	1623.6	20.3	-0.7	-1.25833	0
45652	2024	12	12	26	22	4	-1.0	-2.3	-0.8	1570.6	20.3	-0.8	-1.19167	0
45652	2024	12	12	26	23	4	-1.0	-2.1	-0.7	1509.8	20.3	-1.0	-1.125	0
45652	2024	12	12	26	24	4	-1.1	-2.2	-0.4	1481.0	20.3	-1.1	-1.09167	0
45653	2024	12	12	27	1	5	-1.1	-2.4	-0.3	1446.2	8.5	-1.2	-1.06667	1
45653	2024	12	12	27	2	5	-1.2	-3	0.6	1417.7	8.5	-1.4	-1.00833	1
45653	2024	12	12	27	3	5	-1.3	-3.8	0.4	1401.7	8.5	-1.6	-0.94167	1
45653	2024	12	12	27	4	5	-1.4	-4.7	-0.7	1397.2	8.5	-1.9	-0.78333	1
45653	2024	12	12	27	5	5	-1.5	-4.2	-1.4	1412.2	8.5	-2.4	-0.65	1
45653	2024	12	12	27	6	5	-1.6	-3.9	-2	1452.8	8.5	-2.7	-0.61667	1
45653	2024	12	12	27	7	5	-1.8	-4.5	-1.8	1526.8	8.5	-2.9	-0.64167	1
45653	2024	12	12	27	8	5	-1.9	-4.4	-2	1596.7	8.5	-3.1	-0.7	1
45653	2024	12	12	27	9	5	-2.0	-3.7	-2.3	1667.8	8.5	-3.3	-0.74167	1
45653	2024	12	12	27	10	5	-2.1	-2.7	-2.1	1671.4	8.5	-3.4	-0.825	1
45653	2024	12	12	27	11	5	-2.2	-1.3	-2.2	1619.7	8.5	-3.5	-0.95	1
45653	202													

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLa	gTemp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLa	Weekdays
45653	2024	12	27	24	5	-1.8	-4.4	1.1	1538.5	8.5	-0.1	-3.4	1
45654	2024	12	28	1	6	-1.9	-3.9	1.7	1518.4	3.3	-0.5	-3.2	0
45654	2024	12	28	2	6	-1.9	-4.2	2.2	1490.1	3.3	-0.9	-2.90833	0
45654	2024	12	28	3	6	-2.0	-5.7	2.7	1472.4	3.3	-1.4	-2.51667	0
45654	2024	12	28	4	6	-2.1	-6.4	2.4	1471.4	3.3	-2.1	-2.01667	0
45654	2024	12	28	5	6	-2.1	-6.5	0.7	1479.8	3.3	-2.9	-1.4	0
45654	2024	12	28	6	6	-2.2	-6.6	-0.6	1513.8	3.3	-3.6	-0.85	0
45654	2024	12	28	7	6	-2.3	-5.6	-1.7	1571.2	3.3	-4.2	-0.46667	0
45654	2024	12	28	8	6	-2.4	-5.7	-3.5	1648.7	3.3	-4.6	-0.14167	0
45654	2024	12	28	9	6	-2.4	-6.7	-3.8	1711.3	3.3	-5.0	0.083333	0
45654	2024	12	28	10	6	-2.6	-3	-3.1	1731.0	3.3	-5.2	0.1	0
45654	2024	12	28	11	6	-2.6	-1.2	-4.4	1704.2	3.3	-5.2	0.008333	0
45654	2024	12	28	12	6	-2.6	0.2	-3.9	1627.8	3.3	-5.0	-0.14167	0
45654	2024	12	28	13	6	-2.6	2.3	-4.2	1553.0	3.3	-4.6	-0.525	0
45654	2024	12	28	14	6	-2.5	3.2	-5.7	1492.1	3.3	-4.1	-0.94167	0
45654	2024	12	28	15	6	-2.5	4.2	-6.4	1461.8	3.3	-3.5	-1.43333	0
45654	2024	12	28	16	6	-2.4	4.8	-6.5	1485.7	3.3	-2.7	-2.09167	0
45654	2024	12	28	17	6	-2.3	3.8	-6.6	1587.2	3.3	-1.7	-2.85	0
45654	2024	12	28	18	6	-2.2	2.7	-5.6	1679.8	3.3	-0.9	-3.59167	0
45654	2024	12	28	19	6	-2.1	1.9	-5.7	1661.3	3.3	-0.1	-4.2	0
45654	2024	12	28	20	6	-2.0	-0.2	-6.7	1635.2	3.3	0.5	-4.61667	0
45654	2024	12	28	21	6	-2.0	-0.2	-3	1603.6	3.3	1.0	-4.95	0
45654	2024	12	28	22	6	-1.8	-0.6	-1.2	1558.4	3.3	1.5	-5.21667	0
45654	2024	12	28	23	6	-1.7	-2.1	0.2	1490.6	3.3	1.7	-5.15	0
45654	2024	12	28	24	6	-1.7	-2.1	2.3	1441.6	3.3	1.7	-4.99167	0
45655	2024	12	29	1	7	-1.6	-3.3	3.2	1390.7	1.8	1.5	-4.60833	0
45655	2024	12	29	2	7	-1.5	-2.5	4.2	1358.1	1.8	1.0	-4.09167	0
45655	2024	12	29	3	7	-1.5	-2.9	4.8	1338.7	1.8	0.5	-3.475	0
45655	2024	12	29	4	7	-1.4	-2.2	3.8	1330.9	1.8	-0.1	-2.65	0
45655	2024	12	29	5	7	-1.2	-1.5	2.7	1333.0	1.8	-0.6	-1.71667	0
45655	2024	12	29	6	7	-1.0	-0.8	1.9	1349.3	1.8	-1.1	-0.85833	0
45655	2024	12	29	7	7	-0.7	-0.5	-0.2	1384.2	1.8	-1.4	-0.08333	0
45655	2024	12	29	8	7	-0.5	0	-0.2	1436.9	1.8	-1.6	0.541667	0
45655	2024	12	29	9	7	-0.3	0.3	-0.6	1504.2	1.8	-1.6	1	0
45655	2024	12	29	10	7	0.0	0.9	-2.1	1566.5	1.8	-1.5	1.541667	0
45655	2024	12	29	11	7	0.2	1.5	-2.1	1580.9	1.8	-1.4	1.741667	0
45655	2024	12	29	12	7	0.3	2.1	-3.3	1566.6	1.8	-1.1	1.666667	0
45655	2024	12	29	13	7	0.4	3.2	-2.5	1551.9	1.8	-0.7	1.475	0
45655	2024	12	29	14	7	0.4	3.6	-2.9	1522.1	1.8	-0.2	1.008333	0
45655	2024	12	29	15	7	0.4	4.8	-2.2	1498.5	1.8	0.3	0.533333	0
45655	2024	12	29	16	7	0.4	4.7	-1.5	1509.7	1.8	1.0	-0.05833	0
45655	2024	12	29	17	7	0.4	3.7	-0.8	1593.0	1.8	1.5	-0.64167	0
45655	2024	12	29	18	7	0.4	3	-0.5	1659.2	1.8	2.0	-1.08333	0
45655	2024	12	29	19	7	0.5	2.6	0	1620.9	1.8	2.3	-1.375	0
45655	2024	12	29	20	7	0.5	2.7	0.3	1579.0	1.8	2.5	-1.575	0
45655	2024	12	29	21	7	0.6	2.1	0.9	1529.9	1.8	2.8	-1.55833	0
45655	2024	12	29	22	7	0.7	2.4	1.5	1466.8	1.8	2.9	-1.51667	0
45655	2024	12	29	23	7	0.8	2.1	2.1	1379.5	1.8	3.0	-1.39167	0
45655	2024	12	29	24	7	1.0	2.3	3.2	1304.2	1.8	3.1	-1.09167	0
45656	2024	12	30	1	1	1.2	2.1	3.6	1235.2	10.5	3.1	-0.74167	1
45656	2024	12	30	2	1	1.4	2.4	4.8	1195.2	10.5	3.0	-0.2	1
45656	2024	12	30	3	1	1.6	3.1	4.7	1171.6	10.5	2.9	0.308333	1
45656	2024	12	30	4	1	1.9	3.2	3.7	1164.0	10.5	2.8	0.95	1
45656	2024	12	30	5	1	2.1	2.7	3	1167.5	10.5	2.6	1.525	1
45656	2024	12	30	6	1	2.3	3.3	2.6	1198.7	10.5	2.6	1.958333	1
45656	2024	12	30	7	1	2.4	3.6	2.7	1276.5	10.5	2.6	2.275	1
45656	2024	12	30	8	1	2.6	3.5	2.1	1346.9	10.5	2.7	2.533333	1
45656	2024	12	30	9	1	2.7	3.4	2.4	1401.3	10.5	2.7	2.758333	1
45656	2024	12	30	10	1	2.9	3.9	2.1	1435.6	10.5	2.8	2.908333	1
45656	2024	12	30	11	1	3.0	4.2	2.3	1455.5	10.5	3.0	3.033333	1
45656	2024	12	30	12	1	3.1	4.3	2.1	1469.8	10.5	3.1	3.083333	1
45656	2024	12	30	13	1	3.2	4.6	2.4	1475.4	10.5	3.3	3.1	1
45656	2024	12	30	14	1	3.3	4.7	3.1	1452.7	10.5	3.5	3.008333	1
45656	2024	12	30	15	1	3.3	4.9	3.2	1433.5	10.5	3.7	2.908333	1
45656	2024	12	30	16	1	3.3	5.1	2.7	1444.3	10.5	3.9	2.766667	1
45656	2024	12	30	17	1	3.3	5	3.3	1501.0	10.5	4.0	2.641667	1
45656	2024	12	30	18	1	3.4	4.9	3.6	1548.1	10.5	4.2	2.558333	1
45656	2024	12	30	19	1	3.5	5.6	3.5	1502.2	10.5	4.3	2.583333	1
45656	2024	12	30	20	1	3.6	6.2	3.4	1452.4	10.5	4.5	2.666667	1
45656	2024	12	30	21	1	3.7	6.3	3.9	1394.4	10.5	4.7	2.733333	1
45656	2024	12	30	22	1	3.9	6.6	4.2	1325.3	10.5	5.0	2.841667	1
45656	2024	12	30	23	1	4.1	7.3	4.3	1243.4	10.5	5.2	2.966667	1
45656	2024	12	30	24	1	4.3	7.2	4.6	1187.3	10.5	5.5	3.141667	1
45657	2024	12	31	1	2	4.5	7.8	4.7	1128.9	12.5	5.7	3.308333	1
45657	2024	12	31	2	2	4.7	9	4.9	1068.4	12.5	6.0	3.516667	1
45657	2024	12	31	3	2	5.0	7.6	5.1	1026.5	12.5	6.3	3.708333	1
45657	2024	12	31	4	2	5.2	6.7	5	1014.9	12.5	6.6	3.858333	1
45657	2024	12	31	5	2	5.4	7.1	4.9	1019.6	12.5	6.7	4.016667	1
45657	2024	12	31	6	2	5.5	5.8	5.6	1054.6	12.5	6.9	4.208333	1
45657	2024	12	31	7	2	5.6	5	6.2	1129.6	12.5	6.9	4.341667	1
45657	2024	12	31	8	2	5.7	4.7	6.3	1208.4	12.5	6.9	4.508333	1
45657	2024	12	31	9	2	5.7	5.4	6.6	1267.7	12.5	6.8	4.733333	1
45657	2024	12	31	10	2	5.8	5.6	7.3	1307.4	12.5	6.7	4.975	1
45657	2024	12	31	11	2	5.9	5.8	7.2	1317.3	12.5	6.6	5.2	1
45657	2024	12	31	12	2	6.0	5.4	7.8	1317.0	12.5	6.5	5.458333	1
45657	2024	12	31	13	2	6.0	5.6	9	1304.3	12.5	6.3	5.7	1
45657	2024	12	31	14	2	6.1	5	7.6	1279.3	12.5	6.1	5.966667	1
45657	2024	12	31	15	2	6.1	6.3	6.7	1265.8	12.5	5.8	6.325	1
45657	2024	12	31	16	2	6.1	5.5	7.1	1277.4	12.5	5.7	6.55	1
45657	2024	12	31	17	2	6.1	5.6	5.8	1347.8	12.5	5.6	6.683333	1
45657	2024	12	31	18	2	6.2	5.3	5	1440.5	12.5	5.5	6.858333	1
45657	2024	12	31	19	2	6.2	3.9	4.7	1414.3	12.5	5.4	6.933333	1
45657	2024	12	31	20	2	6.1	2.6	5.4	1369.1	12.5	5.3	6.883333	1
45657	2024	12	31	21	2	6.0	1.9	5.6	1329.2	12.5	5.2	6.758333	1
45657	2024	12	31	22	2	5.8	2.1	5.8	1297.4	12.5	4.9	6.683333	1
45657	2024	12	31	23	2	5.6	0.2	5.4	1270.4	12.5	4.6	6.6	1
45657	2024	12	31	24	2	5.3	-0.2	5.6	1282.5	12.5	4.1	6.475	1
45658	2025	1	1	1	3	5.0	-0.1	5	1280.9	15.7	3.7	6.325	0
45658	2025	1	1	2	3	4.7	-0.3	6.3	1262.0	15.7	3.2	6.141667	0
45658	2025	1	1	3	3	4.3	-1.1	5.5	1231.7	15.7	2.7	5.808333	0
45658	2025	1	1	4	3	3.9	-0.8	5.6	1217.0	15.7	2.1	5.7	0
45658	2025	1	1	5	3	3.6	0.1	5.3	1216.0	15.7			

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLag	Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLag	Weekdays	
45658	2025	1	1	1	12	3	2.2	3	-0.1	1443.6	15.7	0.2	4.116667	0
45658	2025	1	1	1	13	3	2.1	2.8	-0.3	1469.8	15.7	0.5	3.65	0
45658	2025	1	1	1	14	3	1.9	2.9	-1.1	1463.6	15.7	0.7	3.175	0
45658	2025	1	1	1	15	3	1.9	3	-0.8	1459.6	15.7	1.0	2.733333	0
45658	2025	1	1	1	16	3	1.7	3.2	0.1	1465.8	15.7	1.3	2.116667	0
45658	2025	1	1	1	17	3	1.6	3.4	0.4	1520.9	15.7	1.6	1.591667	0
45658	2025	1	1	1	18	3	1.5	3.9	0.5	1533.3	15.7	1.9	1.133333	0
45658	2025	1	1	1	19	3	1.5	3.8	0.2	1488.3	15.7	2.2	0.725	0
45658	2025	1	1	1	20	3	1.5	4.1	0.3	1441.0	15.7	2.5	0.441667	0
45658	2025	1	1	1	21	3	1.5	4.4	0.8	1383.5	15.7	2.8	0.241667	0
45658	2025	1	1	1	22	3	1.6	5.3	2.5	1304.5	15.7	3.2	0.108333	0
45658	2025	1	1	1	23	3	1.8	5.4	3	1216.2	15.7	3.5	0	0
45658	2025	1	1	1	24	3	2.0	6.2	2.8	1160.8	15.7	3.8	0.191667	0
45659	2025	1	2	1	4	4	2.2	5.5	2.9	1113.2	22.1	4.0	0.458333	1
45659	2025	1	2	2	4	4	2.5	5.9	3	1067.9	22.1	4.3	0.7	1
45659	2025	1	2	3	4	4	2.7	5.5	3.2	1044.9	22.1	4.5	0.966667	1
45659	2025	1	2	4	4	4	3.0	5.5	3.4	1035.0	22.1	4.7	1.308333	1
45659	2025	1	2	5	4	4	3.3	5.4	3.9	1043.1	22.1	4.9	1.641667	1
45659	2025	1	2	6	4	4	3.5	5.3	3.8	1099.6	22.1	5.1	1.916667	1
45659	2025	1	2	7	4	4	3.7	5.3	4.1	1200.1	22.1	5.2	2.208333	1
45659	2025	1	2	8	4	4	3.9	5.2	4.4	1297.4	22.1	5.3	2.483333	1
45659	2025	1	2	9	4	4	4.1	5	5.3	1366.1	22.1	5.4	2.808333	1
45659	2025	1	2	10	4	4	4.3	4.8	5.4	1403.4	22.1	5.5	3.15	1
45659	2025	1	2	11	4	4	4.5	4.8	6.2	1431.6	22.1	5.4	3.525	1
45659	2025	1	2	12	4	4	4.6	4.7	5.5	1456.3	22.1	5.4	3.766667	1
45659	2025	1	2	13	4	4	4.6	4.8	5.9	1479.1	22.1	5.2	4.033333	1
45659	2025	1	2	14	4	4	4.7	4.5	5.5	1482.7	22.1	5.2	4.258333	1
45659	2025	1	2	15	4	4	4.8	4.3	5.5	1476.1	22.1	5.1	4.508333	1
45659	2025	1	2	16	4	4	4.8	4	5.4	1492.9	22.1	5.0	4.716667	1
45659	2025	1	2	17	4	4	4.9	3.8	5.3	1566.7	22.1	4.8	4.908333	1
45659	2025	1	2	18	4	4	4.9	3.2	5.3	1641.3	22.1	4.7	5.075	1
45659	2025	1	2	19	4	4	4.9	2.9	5.2	1614.8	22.1	4.5	5.191667	1
45659	2025	1	2	20	4	4	4.8	2.5	5	1585.5	22.1	4.3	5.316667	1
45659	2025	1	2	21	4	4	4.8	2.7	4.8	1542.6	22.1	4.1	5.408333	1
45659	2025	1	2	22	4	4	4.7	2.5	4.8	1473.2	22.1	3.9	5.458333	1
45659	2025	1	2	23	4	4	4.6	2.6	4.7	1400.1	22.1	3.7	5.416667	1
45659	2025	1	2	24	4	4	4.5	2.4	4.8	1359.1	22.1	3.5	5.366667	1
45660	2025	1	3	1	5	5	4.3	2	4.5	1312.8	18.9	3.4	5.241667	1
45660	2025	1	3	2	5	5	4.2	1.7	4.3	1280.3	18.9	3.1	5.183333	1
45660	2025	1	3	3	5	5	4.0	0.7	4	1258.2	18.9	2.9	5.066667	1
45660	2025	1	3	4	5	5	3.8	0.6	3.8	1256.1	18.9	2.6	4.966667	1
45660	2025	1	3	5	5	5	3.6	0.4	3.2	1270.9	18.9	2.3	4.841667	1
45660	2025	1	3	6	5	5	3.4	0.5	2.9	1324.2	18.9	2.0	4.708333	1
45660	2025	1	3	7	5	5	3.2	0.4	2.5	1452.1	18.9	1.8	4.533333	1
45660	2025	1	3	8	5	5	3.0	-0.2	2.7	1559.5	18.9	1.6	4.333333	1
45660	2025	1	3	9	5	5	2.7	-0.6	2.5	1605.3	18.9	1.4	4.108333	1
45660	2025	1	3	10	5	5	2.5	-0.6	2.6	1627.5	18.9	1.1	3.916667	1
45660	2025	1	3	11	5	5	2.3	-0.4	2.4	1628.0	18.9	0.8	3.725	1
45660	2025	1	3	12	5	5	2.1	-0.3	2	1637.8	18.9	0.6	3.541667	1
45660	2025	1	3	13	5	5	1.9	-0.2	1.7	1647.1	18.9	0.4	3.35	1
45660	2025	1	3	14	5	5	1.6	-0.1	0.7	1646.2	18.9	0.2	3.116667	1
45660	2025	1	3	15	5	5	1.5	-0.1	0.6	1641.4	18.9	0.0	2.883333	1
45660	2025	1	3	16	5	5	1.3	0.2	0.4	1655.6	18.9	-0.1	2.583333	1
45660	2025	1	3	17	5	5	1.1	0.4	0.5	1715.1	18.9	-0.1	2.3	1
45660	2025	1	3	18	5	5	1.0	0.4	0.4	1767.6	18.9	-0.1	2.016667	1
45660	2025	1	3	19	5	5	0.9	0.3	-0.2	1724.8	18.9	-0.1	1.791667	1
45660	2025	1	3	20	5	5	0.7	0.3	-0.6	1681.9	18.9	-0.1	1.583333	1
45660	2025	1	3	21	5	5	0.7	0.3	-0.6	1635.0	18.9	-0.1	1.358333	1
45660	2025	1	3	22	5	5	0.6	0.3	-0.4	1571.2	18.9	0.0	1.083333	1
45660	2025	1	3	23	5	5	0.5	0	-0.3	1510.6	18.9	0.1	0.825	1
45660	2025	1	3	24	5	5	0.4	-0.3	-0.2	1485.3	18.9	0.1	0.575	1
45661	2025	1	4	1	6	6	0.2	-0.9	-0.1	1455.8	10.5	0.1	0.35	0
45661	2025	1	4	2	6	6	0.1	-1.1	-0.1	1420.7	10.5	0.1	0.166667	0
45661	2025	1	4	3	6	6	0.0	-1.6	0.2	1398.1	10.5	0.0	0.016667	0
45661	2025	1	4	4	6	6	-0.1	-1.8	0.4	1394.7	10.5	-0.1	-0.05	0
45661	2025	1	4	5	6	6	-0.2	-2.1	0.4	1399.4	10.5	-0.3	-0.08333	0
45661	2025	1	4	6	6	6	-0.3	-2.2	0.3	1421.2	10.5	-0.5	-0.08333	0
45661	2025	1	4	7	6	6	-0.4	-2	0.3	1469.4	10.5	-0.7	-0.09167	0
45661	2025	1	4	8	6	6	-0.5	-1.9	0.3	1546.7	10.5	-0.9	-0.1	0
45661	2025	1	4	9	6	6	-0.6	-1.7	0.3	1609.4	10.5	-1.1	-0.05833	0
45661	2025	1	4	10	6	6	-0.6	-1	0	1642.9	10.5	-1.3	0.016667	0
45661	2025	1	4	11	6	6	-0.6	-0.3	-0.3	1608.1	10.5	-1.4	0.091667	0
45661	2025	1	4	12	6	6	-0.6	0.8	-0.9	1569.6	10.5	-1.4	0.125	0
45661	2025	1	4	13	6	6	-0.6	1.1	-1.1	1526.3	10.5	-1.3	0.125	0
45661	2025	1	4	14	6	6	-0.5	1.2	-1.6	1491.5	10.5	-1.2	0.066667	0
45661	2025	1	4	15	6	6	-0.5	1.3	-1.8	1496.0	10.5	-1.0	-0.01667	0
45661	2025	1	4	16	6	6	-0.4	1	-2.1	1537.7	10.5	-0.7	-0.14167	0
45661	2025	1	4	17	6	6	-0.4	-0.1	-2.2	1653.9	10.5	-0.5	-0.30833	0
45661	2025	1	4	18	6	6	-0.4	-1.3	-2	1770.8	10.5	-0.3	-0.51667	0
45661	2025	1	4	19	6	6	-0.5	-2.6	-1.9	1763.2	10.5	-0.2	-0.73333	0
45661	2025	1	4	20	6	6	-0.6	-3.6	-1.7	1737.5	10.5	-0.3	-0.925	0
45661	2025	1	4	21	6	6	-0.8	-4.5	-1	1712.5	10.5	-0.4	-1.10833	0
45661	2025	1	4	22	6	6	-1.0	-5.2	-0.3	1674.2	10.5	-0.7	-1.275	0
45661	2025	1	4	23	6	6	-1.2	-5.7	0.8	1628.2	10.5	-1.0	-1.38333	0
45661	2025	1	4	24	6	6	-1.4	-6.3	1.1	1584.5	10.5	-1.5	-1.40833	0
45662	2025	1	5	1	7	7	-1.7	-6.9	1.2	1545.9	21.0	-2.1	-1.31667	0
45662	2025	1	5	2	7	7	-1.9	-8	1.3	1534.3	21.0	-2.7	-1.15	0
45662	2025	1	5	3	7	7	-2.2	-8.6	1	1536.9	21.0	-3.5	-0.95833	0
45662	2025	1	5	4	7	7	-2.5	-9.1	-0.1	1551.7	21.0	-4.3	-0.71667	0
45662	2025	1	5	5	7	7	-2.8	-8.6	-1.3	1576.2	21.0	-5.2	-0.48333	0
45662	2025	1	5	6	7	7	-3.1	-8.7	-2.6	1617.3	21.0	-5.9	-0.31667	0
45662	2025	1	5	7	7	7	-3.4	-9.3	-3.6	1676.1	21.0	-6.5	-0.24167	0
45662	2025	1	5	8	7	7	-3.7	-10.2	-4.5	1748.6	21.0	-7.0	-0.29167	0
45662	2025	1	5	9	7	7	-4.0	-10.3	-5.2	1828.9	21.0	-7.6	-0.43333	0
45662	2025	1	5	10	7	7	-4.4	-10.3	-5.7	1871.3	21.0	-8.1	-0.66667	0
45662	2025	1	5	11	7	7	-4.8	-9.8	-6.3	1902.9	21.0	-8.5	-1.01667	0
45662	2025	1	5	12	7	7	-5.2	-9.2	-6.9	1926.7	21.0	-8.8	-1.46667	0
45662	2025	1	5	13	7	7	-5.6	-8.3	-8	1903.3				

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLag	Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLag	Weekdays
45662	2025	1	5	24	7	-8.3	-7.6	-8.3	1725.1	21.0	-7.7	-8.84167	0
45663	2025	1	6	1	1	-8.3	-7.6	-7.8	1667.8	21.2	-7.6	-9.08333	1
45663	2025	1	6	2	1	-8.4	-7.6	-6.8	1638.7	21.2	-7.5	-9.2	1
45663	2025	1	6	3	1	-8.3	-7.4	-7.4	1629.6	21.2	-7.5	-9.18333	1
45663	2025	1	6	4	1	-8.3	-7.4	-7.7	1621.8	21.2	-7.6	-9.03333	1
45663	2025	1	6	5	1	-8.2	-7	-8.2	1645.0	21.2	-7.6	-8.89167	1
45663	2025	1	6	6	1	-8.2	-7.1	-8.2	1712.5	21.2	-7.5	-8.81667	1
45663	2025	1	6	7	1	-8.1	-7.4	-7.6	1847.5	21.2	-7.4	-8.775	1
45663	2025	1	6	8	1	-8.0	-7.3	-7.1	1947.5	21.2	-7.3	-8.68333	1
45663	2025	1	6	9	1	-7.9	-7.3	-7.1	1973.9	21.2	-7.3	-8.46667	1
45663	2025	1	6	10	1	-7.8	-6.8	-7.1	1952.4	21.2	-7.3	-8.2	1
45663	2025	1	6	11	1	-7.6	-4.9	-7.6	1888.9	21.2	-7.3	-7.93333	1
45663	2025	1	6	12	1	-7.4	-4	-7.6	1846.8	21.2	-7.1	-7.70833	1
45663	2025	1	6	13	1	-7.2	-3.1	-7.6	1825.6	21.2	-6.8	-7.575	1
45663	2025	1	6	14	1	-7.0	-2.4	-7.4	1816.3	21.2	-6.4	-7.51667	1
45663	2025	1	6	15	1	-6.8	-2.9	-7.4	1800.3	21.2	-6.0	-7.5	1
45663	2025	1	6	16	1	-6.6	-3	-7	1811.9	21.2	-5.6	-7.55	1
45663	2025	1	6	17	1	-6.4	-2.9	-7.1	1891.6	21.2	-5.3	-7.55	1
45663	2025	1	6	18	1	-6.2	-3.3	-7.4	1976.6	21.2	-4.9	-7.49167	1
45663	2025	1	6	19	1	-6.0	-3.5	-7.3	1936.6	21.2	-4.6	-7.4	1
45663	2025	1	6	20	1	-5.8	-3.6	-7.3	1903.1	21.2	-4.3	-7.33333	1
45663	2025	1	6	21	1	-5.6	-3.6	-6.8	1849.8	21.2	-4.0	-7.30833	1
45663	2025	1	6	22	1	-5.5	-3.8	-4.9	1785.3	21.2	-3.7	-7.325	1
45663	2025	1	6	23	1	-5.4	-3.8	-4	1687.8	21.2	-3.4	-7.3	1
45663	2025	1	6	24	1	-5.2	-4.2	-3.1	1649.7	21.2	-3.3	-7.11667	1
45664	2025	1	7	1	2	-5.1	-4.4	-2.4	1605.0	11.8	-3.3	-6.81667	1
45664	2025	1	7	2	2	-4.9	-5	-2.9	1566.7	11.8	-3.5	-6.44167	1
45664	2025	1	7	3	2	-4.8	-5.6	-3	1537.4	11.8	-3.7	-6.00833	1
45664	2025	1	7	4	2	-4.8	-5.7	-2.9	1525.0	11.8	-3.9	-5.63333	1
45664	2025	1	7	5	2	-4.7	-5.8	-3.3	1535.8	11.8	-4.1	-5.26667	1
45664	2025	1	7	6	2	-4.6	-5.4	-3.5	1589.1	11.8	-4.4	-4.925	1
45664	2025	1	7	7	2	-4.6	-5.1	-3.6	1710.0	11.8	-4.5	-4.60833	1
45664	2025	1	7	8	2	-4.5	-4.9	-3.6	1816.6	11.8	-4.7	-4.28333	1
45664	2025	1	7	9	2	-4.4	-4.7	-3.8	1839.3	11.8	-4.8	-3.975	1
45664	2025	1	7	10	2	-4.3	-4.2	-3.8	1817.1	11.8	-4.9	-3.66667	1
45664	2025	1	7	11	2	-4.2	-3.8	-4.2	1767.5	11.8	-4.9	-3.41667	1
45664	2025	1	7	12	2	-4.1	-2.5	-4.4	1748.8	11.8	-4.9	-3.325	1
45664	2025	1	7	13	2	-4.1	-2.4	-5	1752.4	11.8	-4.8	-3.34167	1
45664	2025	1	7	14	2	-4.0	-1.9	-5.6	1728.4	11.8	-4.6	-3.45	1
45664	2025	1	7	15	2	-4.0	-1	-5.7	1722.4	11.8	-4.3	-3.66667	1
45664	2025	1	7	16	2	-3.9	-1.9	-5.8	1749.5	11.8	-4.0	-3.89167	1
45664	2025	1	7	17	2	-3.9	-2.3	-5.4	1822.4	11.8	-3.6	-4.11667	1
45664	2025	1	7	18	2	-3.9	-2.5	-5.1	1909.4	11.8	-3.3	-4.35833	1
45664	2025	1	7	19	2	-3.8	-2.6	-4.9	1870.6	11.8	-3.1	-4.53333	1
45664	2025	1	7	20	2	-3.8	-2.7	-4.7	1836.0	11.8	-2.9	-4.66667	1
45664	2025	1	7	21	2	-3.7	-2.8	-4.2	1786.4	11.8	-2.7	-4.775	1
45664	2025	1	7	22	2	-3.7	-2.4	-3.8	1706.6	11.8	-2.6	-4.86667	1
45664	2025	1	7	23	2	-3.7	-2.2	-2.5	1605.9	11.8	-2.4	-4.9	1
45664	2025	1	7	24	2	-3.6	-2	-2.4	1548.0	11.8	-2.3	-4.9	1
45665	2025	1	8	1	3	-3.5	-1.6	-1.9	1504.7	16.0	-2.2	-4.75833	1
45665	2025	1	8	2	3	-3.4	-1	-1	1457.2	16.0	-2.2	-4.59167	1
45665	2025	1	8	3	3	-3.2	-1	-1.9	1422.0	16.0	-2.1	-4.33333	1
45665	2025	1	8	4	3	-3.0	-1	-2.3	1406.9	16.0	-2.1	-3.95	1
45665	2025	1	8	5	3	-2.8	-0.9	-2.5	1416.1	16.0	-2.0	-3.63333	1
45665	2025	1	8	6	3	-2.6	-1.1	-2.6	1473.7	16.0	-1.9	-3.34167	1
45665	2025	1	8	7	3	-2.4	-1.5	-2.7	1608.3	16.0	-1.8	-3.1	1
45665	2025	1	8	8	3	-2.3	-1.6	-2.8	1718.1	16.0	-1.7	-2.89167	1
45665	2025	1	8	9	3	-2.2	-2	-2.4	1753.2	16.0	-1.6	-2.70833	1
45665	2025	1	8	10	3	-2.0	-2.1	-2.2	1744.1	16.0	-1.5	-2.55	1
45665	2025	1	8	11	3	-2.0	-2.1	-2	1711.7	16.0	-1.5	-2.4	1
45665	2025	1	8	12	3	-1.9	-1.4	-1.6	1687.1	16.0	-1.5	-2.26667	1
45665	2025	1	8	13	3	-1.8	-1.6	-1	1706.3	16.0	-1.4	-2.225	1
45665	2025	1	8	14	3	-1.8	-1.8	-1	1715.1	16.0	-1.4	-2.15833	1
45665	2025	1	8	15	3	-1.8	-2.2	-1	1719.5	16.0	-1.5	-2.08333	1
45665	2025	1	8	16	3	-1.8	-2.8	-0.9	1764.9	16.0	-1.6	-2.08333	1
45665	2025	1	8	17	3	-1.9	-3.2	-1.1	1841.0	16.0	-1.8	-2.00833	1
45665	2025	1	8	18	3	-1.9	-3.7	-1.5	1908.9	16.0	-2.0	-1.89167	1
45665	2025	1	8	19	3	-2.0	-4	-1.6	1882.8	16.0	-2.2	-1.775	1
45665	2025	1	8	20	3	-2.0	-4.1	-2	1852.4	16.0	-2.4	-1.68333	1
45665	2025	1	8	21	3	-2.1	-4.2	-2.1	1806.6	16.0	-2.6	-1.59167	1
45665	2025	1	8	22	3	-2.1	-4.7	-2.1	1735.0	16.0	-2.8	-1.525	1
45665	2025	1	8	23	3	-2.2	-4.7	-1.4	1649.5	16.0	-3.0	-1.5	1
45665	2025	1	8	24	3	-2.3	-5	-1.6	1613.4	16.0	-3.2	-1.49167	1
45666	2025	1	9	1	4	-2.5	-5.1	-1.8	1571.5	12.4	-3.5	-1.44167	1
45666	2025	1	9	2	4	-2.6	-5	-2.2	1538.0	12.4	-3.8	-1.44167	1
45666	2025	1	9	3	4	-2.8	-5	-2.8	1507.7	12.4	-4.1	-1.50833	1
45666	2025	1	9	4	4	-3.0	-4.8	-3.2	1497.5	12.4	-4.3	-1.60833	1
45666	2025	1	9	5	4	-3.1	-4.7	-3.7	1505.4	12.4	-4.5	-1.75833	1
45666	2025	1	9	6	4	-3.3	-4.7	-4	1561.7	12.4	-4.6	-1.95	1
45666	2025	1	9	7	4	-3.4	-4.6	-4.1	1694.5	12.4	-4.7	-2.16667	1
45666	2025	1	9	8	4	-3.5	-4.6	-4.2	1797.8	12.4	-4.7	-2.375	1
45666	2025	1	9	9	4	-3.7	-4.4	-4.7	1825.6	12.4	-4.8	-2.58333	1
45666	2025	1	9	10	4	-3.8	-4.2	-4.7	1792.0	12.4	-4.8	-2.76667	1
45666	2025	1	9	11	4	-3.9	-3.5	-5	1731.2	12.4	-4.7	-2.98333	1
45666	2025	1	9	12	4	-3.9	-0.9	-5.1	1698.8	12.4	-4.6	-3.2	1
45666	2025	1	9	13	4	-3.9	0.4	-5	1685.6	12.4	-4.3	-3.5	1
45666	2025	1	9	14	4	-3.8	0.4	-5	1657.7	12.4	-3.8	-3.79167	1
45666	2025	1	9	15	4	-3.7	1.1	-4.8	1636.2	12.4	-3.4	-4.05833	1
45666	2025	1	9	16	4	-3.6	1.5	-4.7	1655.5	12.4	-2.9	-4.29167	1
45666	2025	1	9	17	4	-3.4	1.5	-4.7	1727.3	12.4	-2.4	-4.45833	1
45666	2025	1	9	18	4	-3.2	1.3	-4.6	1803.0	12.4	-1.8	-4.58333	1
45666	2025	1	9	19	4	-3.0	1.2	-4.6	1772.2	12.4	-1.3	-4.66667	1
45666	2025	1	9	20	4	-2.8	0.9	-4.4	1732.7	12.4	-0.9	-4.71667	1
45666	2025	1	9	21	4	-2.6	1	-4.2	1678.3	12.4	-0.4	-4.75833	1
45666	2025	1	9	22	4	-2.4	1.3	-3.5	1604.5	12.4	0.1	-4.775	1
45666	2025	1	9	23	4	-2.1	1.7	-0.9	1512.3	12.4	0.5	-4.73333	1
45666	2025	1	9	24	4	-1.8	1.7	0.4	1459.1	12.4	1.0	-4.63333	1
45667	2025	1	10	1	5	-1.6	1.8	0.4	1413.9	21.6	1.2	-4.29167	1
45667	2025	1	10	2	5	-1.3	1.8	1.1	1362.1	21.6	1.3	-3.83333	1
45667	2025	1	10	3	5	-1.0	1.9	1.5	1326.4	21.6	1.4	-3.38333	1
45667	2025	1	10	4	5	-0.7	1.6	1.5	1315.4	21.6	1.5	-2.875	1
45667	2025	1	10	5	5	-0.4	1.5	1.3	1330.6	21.6	1.5	-2.35	1
45667	2025	1	10	6	5	-0.2	1.3	1.2	1378.9	21.6	1.5	-1.83333	1
45667	2025	1	10	7	5	0.1	1.5	0.9					

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLag	Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLag	Weekdays
45667	2025	1	10	12	5	1.3	1.5	1.8	1646.7	21.6	1.6	0.95	1
45667	2025	1	10	13	5	1.4	2	1.8	1645.4	21.6	1.6	1.166667	1
45667	2025	1	10	14	5	1.4	2.3	1.9	1635.3	21.6	1.6	1.283333	1
45667	2025	1	10	15	5	1.5	1.9	1.6	1625.8	21.6	1.6	1.4	1
45667	2025	1	10	16	5	1.5	0.7	1.5	1645.4	21.6	1.6	1.466667	1
45667	2025	1	10	17	5	1.5	1.2	1.3	1697.4	21.6	1.5	1.475	1
45667	2025	1	10	18	5	1.5	1.3	1.5	1758.1	21.6	1.5	1.475	1
45667	2025	1	10	19	5	1.5	1.4	1.5	1719.0	21.6	1.5	1.475	1
45667	2025	1	10	20	5	1.5	1	1.4	1662.3	21.6	1.5	1.5	1
45667	2025	1	10	21	5	1.5	1.1	1.4	1615.9	21.6	1.5	1.55	1
45667	2025	1	10	22	5	1.5	0.9	1.5	1551.0	21.6	1.4	1.583333	1
45667	2025	1	10	23	5	1.5	0.6	1.5	1483.0	21.6	1.4	1.591667	1
45667	2025	1	10	24	5	1.5	0.4	2	1452.6	21.6	1.3	1.575	1
45668	2025	1	11	1	6	1.4	0.2	2.3	1420.2	8.4	1.2	1.558333	0
45668	2025	1	11	2	6	1.3	0	1.9	1387.5	8.4	1.1	1.575	0
45668	2025	1	11	3	6	1.3	-0.4	0.7	1363.3	8.4	0.9	1.616667	0
45668	2025	1	11	4	6	1.2	-1.1	1.2	1349.1	8.4	0.7	1.616667	0
45668	2025	1	11	5	6	1.0	-0.7	1.3	1353.7	8.4	0.6	1.541667	0
45668	2025	1	11	6	6	1.0	-0.7	1.4	1383.9	8.4	0.4	1.516667	0
45668	2025	1	11	7	6	0.9	-0.6	1	1434.7	8.4	0.2	1.516667	0
45668	2025	1	11	8	6	0.8	-0.6	1.1	1503.8	8.4	0.1	1.508333	0
45668	2025	1	11	9	6	0.7	-0.7	0.9	1580.1	8.4	-0.1	1.466667	0
45668	2025	1	11	10	6	0.6	-0.3	0.6	1628.4	8.4	-0.2	1.441667	0
45668	2025	1	11	11	6	0.5	0.2	0.4	1643.5	8.4	-0.3	1.4	0
45668	2025	1	11	12	6	0.5	0.3	0.2	1634.8	8.4	-0.4	1.325	0
45668	2025	1	11	13	6	0.4	0.7	0	1624.4	8.4	-0.4	1.233333	0
45668	2025	1	11	14	6	0.4	0.4	-0.4	1603.6	8.4	-0.3	1.083333	0
45668	2025	1	11	15	6	0.3	0.4	-1.1	1596.8	8.4	-0.3	0.891667	0
45668	2025	1	11	16	6	0.2	0.4	-0.7	1611.2	8.4	-0.2	0.7	0
45668	2025	1	11	17	6	0.2	0.2	-0.7	1676.2	8.4	-0.1	0.55	0
45668	2025	1	11	18	6	0.2	0	-0.6	1734.0	8.4	0.0	0.391667	0
45668	2025	1	11	19	6	0.1	-0.2	-0.6	1700.7	8.4	0.0	0.225	0
45668	2025	1	11	20	6	0.1	-0.4	-0.7	1661.1	8.4	0.1	0.058333	0
45668	2025	1	11	21	6	0.0	-0.4	-0.3	1622.4	8.4	0.1	-0.075	0
45668	2025	1	11	22	6	-0.1	-0.6	0.2	1564.5	8.4	0.1	-0.225	0
45668	2025	1	11	23	6	-0.1	-0.6	0.3	1498.7	8.4	0.1	-0.325	0
45668	2025	1	11	24	6	-0.2	-0.9	0.7	1442.0	8.4	0.0	-0.35833	0
45669	2025	1	12	1	7	-0.2	-0.8	0.4	1390.9	17.7	-0.1	-0.36667	0
45669	2025	1	12	2	7	-0.3	-0.9	0.4	1353.0	17.7	-0.2	-0.325	0
45669	2025	1	12	3	7	-0.3	-1.1	0.4	1336.7	17.7	-0.3	-0.29167	0
45669	2025	1	12	4	7	-0.3	-1.2	0.2	1337.4	17.7	-0.4	-0.225	0
45669	2025	1	12	5	7	-0.3	-1.2	0	1349.2	17.7	-0.6	-0.1	0
45669	2025	1	12	6	7	-0.4	-1.3	-0.2	1375.3	17.7	-0.7	-0.025	0
45669	2025	1	12	7	7	-0.4	-1.8	-0.4	1424.0	17.7	-0.8	0.033333	0
45669	2025	1	12	8	7	-0.4	-1.5	-0.4	1489.4	17.7	-0.9	0.066667	0
45669	2025	1	12	9	7	-0.5	-1.5	-0.6	1577.1	17.7	-1.0	0.083333	0
45669	2025	1	12	10	7	-0.5	-1.1	-0.6	1638.3	17.7	-1.1	0.108333	0
45669	2025	1	12	11	7	-0.5	-0.6	-0.9	1667.1	17.7	-1.2	0.083333	0
45669	2025	1	12	12	7	-0.6	-0.2	-0.8	1675.1	17.7	-1.2	0.016667	0
45669	2025	1	12	13	7	-0.6	0.2	-0.9	1676.0	17.7	-1.1	-0.08333	0
45669	2025	1	12	14	7	-0.6	0.3	-1.1	1664.2	17.7	-1.0	-0.20833	0
45669	2025	1	12	15	7	-0.6	0.2	-1.2	1660.0	17.7	-0.9	-0.31667	0
45669	2025	1	12	16	7	-0.6	-0.2	-1.2	1687.5	17.7	-0.8	-0.44167	0
45669	2025	1	12	17	7	-0.7	-0.6	-1.3	1759.2	17.7	-0.7	-0.575	0
45669	2025	1	12	18	7	-0.7	-1.4	-1.8	1831.3	17.7	-0.7	-0.69167	0
45669	2025	1	12	19	7	-0.7	-1.5	-1.5	1801.4	17.7	-0.7	-0.8	0
45669	2025	1	12	20	7	-0.8	-1.8	-1.5	1770.8	17.7	-0.7	-0.93333	0
45669	2025	1	12	21	7	-0.9	-2	-1.1	1725.1	17.7	-0.7	-1.025	0
45669	2025	1	12	22	7	-0.9	-2.1	-0.6	1652.8	17.7	-0.7	-1.11667	0
45669	2025	1	12	23	7	-1.0	-2.2	-0.2	1553.3	17.7	-0.8	-1.15833	0
45669	2025	1	12	24	7	-1.1	-2.4	0.2	1479.7	17.7	-0.9	-1.15833	0
45670	2025	1	13	1	1	-1.1	-2.6	0.3	1426.3	7.3	-1.1	-1.1	1
45670	2025	1	13	2	1	-1.2	-2.9	0.2	1400.2	7.3	-1.4	-1.01667	1
45670	2025	1	13	3	1	-1.3	-3	-0.2	1389.0	7.3	-1.6	-0.91667	1
45670	2025	1	13	4	1	-1.4	-3	-0.6	1389.8	7.3	-1.9	-0.80833	1
45670	2025	1	13	5	1	-1.4	-3	-1.4	1410.8	7.3	-2.1	-0.725	1
45670	2025	1	13	6	1	-1.5	-3.2	-1.5	1472.6	7.3	-2.3	-0.675	1
45670	2025	1	13	7	1	-1.6	-3.2	-1.8	1609.6	7.3	-2.5	-0.68333	1
45670	2025	1	13	8	1	-1.6	-3.3	-2	1732.4	7.3	-2.6	-0.65833	1
45670	2025	1	13	9	1	-1.7	-3.5	-2.1	1764.5	7.3	-2.7	-0.68333	1
45670	2025	1	13	10	1	-1.8	-3.2	-2.2	1758.6	7.3	-2.9	-0.725	1
45670	2025	1	13	11	1	-1.9	-3.2	-2.4	1762.9	7.3	-3.0	-0.80833	1
45670	2025	1	13	12	1	-2.0	-3.1	-2.6	1764.3	7.3	-3.0	-0.94167	1
45670	2025	1	13	13	1	-2.1	-3	-2.9	1764.3	7.3	-3.1	-1.125	1
45670	2025	1	13	14	1	-2.2	-2.8	-3	1727.8	7.3	-3.1	-1.35833	1
45670	2025	1	13	15	1	-2.4	-2.3	-3	1702.8	7.3	-3.1	-1.625	1
45670	2025	1	13	16	1	-2.5	-2.2	-3	1716.8	7.3	-3.1	-1.89167	1
45670	2025	1	13	17	1	-2.6	-2.4	-3.2	1787.0	7.3	-3.0	-2.125	1
45670	2025	1	13	18	1	-2.6	-2.5	-3.2	1860.2	7.3	-3.0	-2.325	1
45670	2025	1	13	19	1	-2.7	-2.6	-3.3	1824.4	7.3	-2.9	-2.475	1
45670	2025	1	13	20	1	-2.7	-2.8	-3.5	1770.1	7.3	-2.8	-2.61667	1
45670	2025	1	13	21	1	-2.8	-2.8	-3.2	1713.5	7.3	-2.8	-2.74167	1
45670	2025	1	13	22	1	-2.8	-2.9	-3.2	1652.1	7.3	-2.7	-2.86667	1
45670	2025	1	13	23	1	-2.8	-2.9	-3.1	1560.7	7.3	-2.7	-2.95833	1
45670	2025	1	13	24	1	-2.9	-2.7	-3	1530.5	7.3	-2.7	-3.04167	1
45671	2025	1	14	1	2	-2.9	-2.5	-2.8	1496.0	6.0	-2.7	-3.1	1
45671	2025	1	14	2	2	-2.9	-2.8	-2.3	1464.4	6.0	-2.6	-3.13333	1
45671	2025	1	14	3	2	-2.9	-3	-2.2	1434.1	6.0	-2.6	-3.125	1
45671	2025	1	14	4	2	-2.9	-2.9	-2.4	1421.3	6.0	-2.7	-3.06667	1
45671	2025	1	14	5	2	-2.9	-3	-2.5	1435.4	6.0	-2.7	-3	1
45671	2025	1	14	6	2	-2.9	-3.1	-2.6	1490.6	6.0	-2.8	-2.95	1
45671	2025	1	14	7	2	-2.9	-3.4	-2.8	1632.0	6.0	-2.8	-2.89167	1
45671	2025	1	14	8	2	-2.9	-3.7	-2.8	1742.4	6.0	-2.9	-2.84167	1
45671	2025	1	14	9	2	-2.9	-3.6	-2.9	1770.4	6.0	-3.0	-2.8	1
45671	2025	1	14	10	2	-2.9	-3.4	-2.9	1756.8	6.0	-3.0	-2.74167	1
45671	2025	1	14	11	2	-2.9	-2.6	-2.7	1734.8	6.0	-3.1	-2.71667	1
45671	2025	1	14	12	2	-2.9	-1.7	-2.5	1687.9	6.0	-3.1	-2.69167	1
45671	2025	1	14	13	2	-2.8	-1.1	-2.8	1653.8	6.0	-3.0	-2.65833	1
45671	2025	1	14	14	2	-2.7	-0.6	-3	1625.8	6.0	-2.9	-2.61667	1
45671	2025	1	14	15	2	-2.6	-0.4	-2.9	1605.0	6.0	-2.7	-2.61667	1
45671	2025	1	14	16	2	-2.6	0.3	-3	1625.3	6.0	-2.5	-2.675	1
45671	2025	1	14	17	2	-2.5	0	-3.1	1727.1	6.0	-2.2	-2.73333	1
45671	2025	1	14	18	2	-2.4	-0.3	-3.4	1821.8	6.0	-1.9	-2.78333	1

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLag	Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLag	Weekdays	
45671	2025		1	14	24	2	-2.0	-2.6	-1.1	1542.0	6.0	-0.9	-3.05833	1
45672	2025		1	15	1	3	-2.0	-3.1	-0.6	1497.7	15.1	-1.0	-2.975	1
45672	2025		1	15	2	3	-2.0	-3.4	-0.4	1465.9	15.1	-1.1	-2.85833	1
45672	2025		1	15	3	3	-2.0	-4.2	0.3	1442.7	15.1	-1.4	-2.675	1
45672	2025		1	15	4	3	-2.1	-4.6	0	1435.3	15.1	-1.7	-2.45833	1
45672	2025		1	15	5	3	-2.1	-4.5	-0.3	1448.5	15.1	-2.1	-2.19167	1
45672	2025		1	15	6	3	-2.2	-4.6	-0.9	1519.3	15.1	-2.5	-1.94167	1
45672	2025		1	15	7	3	-2.3	-4.6	-1.2	1655.2	15.1	-2.8	-1.70833	1
45672	2025		1	15	8	3	-2.3	-4.6	-1.3	1770.3	15.1	-3.1	-1.5	1
45672	2025		1	15	9	3	-2.4	-4.7	-1.5	1784.8	15.1	-3.4	-1.29167	1
45672	2025		1	15	10	3	-2.4	-3.9	-2	1735.9	15.1	-3.7	-1.1	1
45672	2025		1	15	11	3	-2.4	-2.9	-2.6	1694.0	15.1	-3.9	-0.94167	1
45672	2025		1	15	12	3	-2.4	-2	-3.1	1676.3	15.1	-4.0	-0.89167	1
45672	2025		1	15	13	3	-2.4	-1.8	-3.4	1695.8	15.1	-3.9	-0.96667	1
45672	2025		1	15	14	3	-2.5	-1.6	-4.2	1670.3	15.1	-3.8	-1.13333	1
45672	2025		1	15	15	3	-2.5	-1.3	-4.6	1662.4	15.1	-3.7	-1.36667	1
45672	2025		1	15	16	3	-2.6	-1.3	-4.5	1696.3	15.1	-3.4	-1.68333	1
45672	2025		1	15	17	3	-2.6	-1.7	-4.6	1773.6	15.1	-3.2	-2.09167	1
45672	2025		1	15	18	3	-2.7	-2.2	-4.6	1867.5	15.1	-2.9	-2.46667	1
45672	2025		1	15	19	3	-2.8	-2.9	-4.6	1850.2	15.1	-2.7	-2.825	1
45672	2025		1	15	20	3	-2.9	-2.9	-4.7	1818.4	15.1	-2.6	-3.13333	1
45672	2025		1	15	21	3	-2.9	-2.4	-3.9	1780.5	15.1	-2.4	-3.41667	1
45672	2025		1	15	22	3	-3.0	-3.6	-2.9	1710.0	15.1	-2.2	-3.7	1
45672	2025		1	15	23	3	-3.1	-3.9	-2	1629.7	15.1	-2.2	-3.9	1
45672	2025		1	15	24	3	-3.1	-4.4	-1.8	1600.2	15.1	-2.3	-3.975	1
45673	2025		1	16	1	4	-3.2	-4.8	-1.6	1572.0	8.6	-2.5	-3.925	1
45673	2025		1	16	2	4	-3.3	-5.2	-1.3	1547.7	8.6	-2.8	-3.81667	1
45673	2025		1	16	3	4	-3.4	-5.7	-1.3	1525.6	8.6	-3.1	-3.66667	1
45673	2025		1	16	4	4	-3.4	-6.2	-1.7	1527.8	8.6	-3.4	-3.425	1
45673	2025		1	16	5	4	-3.5	-6.4	-2.2	1536.5	8.6	-3.8	-3.15	1
45673	2025		1	16	6	4	-3.6	-6.1	-2.9	1597.4	8.6	-4.2	-2.91667	1
45673	2025		1	16	7	4	-3.6	-6	-2.9	1731.5	8.6	-4.5	-2.71667	1
45673	2025		1	16	8	4	-3.7	-5.8	-2.4	1847.2	8.6	-4.8	-2.575	1
45673	2025		1	16	9	4	-3.7	-5.6	-3.6	1874.6	8.6	-5.0	-2.43333	1
45673	2025		1	16	10	4	-3.8	-5.4	-3.9	1852.3	8.6	-5.3	-2.24167	1
45673	2025		1	16	11	4	-3.8	-4.9	-4.4	1829.4	8.6	-5.5	-2.21667	1
45673	2025		1	16	12	4	-3.9	-5	-4.8	1815.9	8.6	-5.5	-2.3	1
45673	2025		1	16	13	4	-4.0	-4.8	-5.2	1821.1	8.6	-5.6	-2.5	1
45673	2025		1	16	14	4	-4.2	-4.5	-5.7	1802.0	8.6	-5.6	-2.75	1
45673	2025		1	16	15	4	-4.3	-4.6	-6.2	1795.0	8.6	-5.5	-3.05	1
45673	2025		1	16	16	4	-4.4	-4.8	-6.4	1816.4	8.6	-5.4	-3.41667	1
45673	2025		1	16	17	4	-4.6	-4.9	-6.1	1881.0	8.6	-5.3	-3.825	1
45673	2025		1	16	18	4	-4.7	-5	-6	1948.1	8.6	-5.2	-4.21667	1
45673	2025		1	16	19	4	-4.8	-5.2	-5.8	1916.1	8.6	-5.1	-4.54167	1
45673	2025		1	16	20	4	-4.9	-5.4	-5.6	1899.1	8.6	-5.0	-4.8	1
45673	2025		1	16	21	4	-5.0	-5.4	-5.4	1855.8	8.6	-5.0	-5.04167	1
45673	2025		1	16	22	4	-5.2	-5.5	-4.9	1787.6	8.6	-5.0	-5.30833	1
45673	2025		1	16	23	4	-5.2	-5.7	-5	1702.3	8.6	-5.0	-5.45833	1
45673	2025		1	16	24	4	-5.3	-5.9	-4.8	1667.2	8.6	-5.1	-5.54167	1
45674	2025		1	17	1	5	-5.4	-5.8	-4.5	1625.9	6.8	-5.1	-5.59167	1
45674	2025		1	17	2	5	-5.4	-6.1	-4.6	1593.4	6.8	-5.2	-5.59167	1
45674	2025		1	17	3	5	-5.4	-5.7	-4.8	1572.4	6.8	-5.4	-5.53333	1
45674	2025		1	17	4	5	-5.4	-5.8	-4.9	1566.9	6.8	-5.5	-5.44167	1
45674	2025		1	17	5	5	-5.4	-7.4	-5	1585.9	6.8	-5.5	-5.325	1
45674	2025		1	17	6	5	-5.5	-7.7	-5.2	1660.5	6.8	-5.7	-5.2	1
45674	2025		1	17	7	5	-5.5	-7.9	-5.4	1804.5	6.8	-6.0	-5.10833	1
45674	2025		1	17	8	5	-5.6	-8.7	-5.4	1923.9	6.8	-6.2	-5.04167	1
45674	2025		1	17	9	5	-5.7	-8.2	-5.5	1960.2	6.8	-6.5	-5.00833	1
45674	2025		1	17	10	5	-5.8	-6.4	-5.7	1910.7	6.8	-6.7	-4.99167	1
45674	2025		1	17	11	5	-5.9	-5.6	-5.9	1825.7	6.8	-6.8	-5	1
45674	2025		1	17	12	5	-5.9	-4.1	-5.8	1766.6	6.8	-6.8	-5.06667	1
45674	2025		1	17	13	5	-5.9	-3.3	-6.1	1709.7	6.8	-6.6	-5.14167	1
45674	2025		1	17	14	5	-5.8	-2.6	-5.7	1670.1	6.8	-6.4	-5.225	1
45674	2025		1	17	15	5	-5.7	-2.6	-5.8	1678.0	6.8	-6.1	-5.35833	1
45674	2025		1	17	16	5	-5.7	-3.4	-7.4	1718.7	6.8	-5.9	-5.45	1
45674	2025		1	17	17	5	-5.6	-3.8	-7.7	1792.9	6.8	-5.7	-5.53333	1
45674	2025		1	17	18	5	-5.6	-4.1	-7.9	1883.5	6.8	-5.4	-5.74167	1
45674	2025		1	17	19	5	-5.5	-4.3	-8.7	1881.8	6.8	-5.1	-5.96667	1
45674	2025		1	17	20	5	-5.5	-5.4	-8.2	1865.6	6.8	-4.8	-6.19167	1
45674	2025		1	17	21	5	-5.5	-6.1	-6.4	1838.8	6.8	-4.5	-6.46667	1
45674	2025		1	17	22	5	-5.5	-7.3	-5.6	1807.3	6.8	-4.3	-6.7	1
45674	2025		1	17	23	5	-5.6	-7.5	-4.1	1757.9	6.8	-4.4	-6.775	1
45674	2025		1	17	24	5	-5.7	-9	-3.3	1750.8	6.8	-4.5	-6.76667	1
45675	2025		1	18	1	6	-5.8	-9.2	-2.6	1728.0	13.0	-5.0	-6.61667	0
45675	2025		1	18	2	6	-5.9	-9.2	-2.6	1705.4	13.0	-5.4	-6.40833	0
45675	2025		1	18	3	6	-6.1	-9.3	-3.4	1685.4	13.0	-6.0	-6.11667	0
45675	2025		1	18	4	6	-6.2	-8.3	-3.8	1670.3	13.0	-6.6	-5.85833	0
45675	2025		1	18	5	6	-6.3	-6.9	-4.1	1674.0	13.0	-7.0	-5.65833	0
45675	2025		1	18	6	6	-6.3	-9.3	-4.3	1693.0	13.0	-7.2	-5.35833	0
45675	2025		1	18	7	6	-6.4	-7.7	-5.4	1747.0	13.0	-7.7	-5.05833	0
45675	2025		1	18	8	6	-6.3	-7.6	-6.1	1806.2	13.0	-7.9	-4.75833	0
45675	2025		1	18	9	6	-6.3	-7.8	-7.3	1858.9	13.0	-8.1	-4.48333	0
45675	2025		1	18	10	6	-6.3	-3.4	-7.5	1835.8	13.0	-8.3	-4.30833	0
45675	2025		1	18	11	6	-6.2	-0.2	-9	1760.8	13.0	-7.9	-4.38333	0
45675	2025		1	18	12	6	-5.9	0.6	-9.2	1718.5	13.0	-7.3	-4.54167	0
45675	2025		1	18	13	6	-5.7	1	-9.2	1698.0	13.0	-6.5	-4.95	0
45675	2025		1	18	14	6	-5.6	0.5	-9.3	1675.4	13.0	-5.7	-5.44167	0
45675	2025		1	18	15	6	-5.4	0.6	-8.3	1654.2	13.0	-4.9	-5.99167	0
45675	2025		1	18	16	6	-5.3	0.8	-6.9	1653.1	13.0	-4.0	-6.55	0
45675	2025		1	18	17	6	-5.1	1	-9.3	1705.1	13.0	-3.3	-6.95833	0
45675	2025		1	18	18	6	-4.9	1.1	-7.7	1768.4	13.0	-2.6	-7.21667	0
45675	2025		1	18	19	6	-4.7	1.5	-7.6	1725.1	13.0	-1.8	-7.65	0
45675	2025		1	18	20	6	-4.5	2	-7.8	1659.2	13.0	-1.0	-7.93333	0
45675	2025		1	18	21	6	-4.2	2.2	-3.4	1604.7	13.0	-0.2	-8.11667	0
45675	2025		1	18	22	6	-3.8	2.4	-0.2	1533.8	13.0	0.6	-8.25833	0
45675	2025		1	18	23	6	-3.4	2.6	0.6	1451.0	13.0	1.1	-7.93333	0
45675	2025		1	18	24	6	-3.0	2.9	1	1374.3	13.0	1.4	-7.325	0
45676	2025		1	19	1	7	-2.5	2.9	0.5	1304.1	13.1	1.6	-6.525	0
45676	2025		1	19	2	7	-2.0	3	0.6	1259.4	13.1	1.7	-5.675	0
45676	2025		1	19	3	7	-1.5	3.1	0.8					

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLag	Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLag	Weekdays
45676	2025	1	19	12	7	2.7	6.2	2.9	1482.1	13.1	4.1	1.358333	0
45676	2025	1	19	13	7	3.0	7.4	3	1479.4	13.1	4.4	1.55	0
45676	2025	1	19	14	7	3.2	7.2	3.1	1452.2	13.1	4.8	1.708333	0
45676	2025	1	19	15	7	3.5	7.1	3.5	1428.3	13.1	5.1	1.916667	0
45676	2025	1	19	16	7	3.8	6.7	3.7	1435.6	13.1	5.5	2.125	0
45676	2025	1	19	17	7	4.0	6.8	4.5	1500.6	13.1	5.7	2.35	0
45676	2025	1	19	18	7	4.3	5.9	4.6	1567.0	13.1	6.0	2.575	0
45676	2025	1	19	19	7	4.5	4.6	4.7	1533.7	13.1	6.1	2.858333	0
45676	2025	1	19	20	7	4.6	4.7	5.4	1501.7	13.1	6.1	3.116667	0
45676	2025	1	19	21	7	4.7	5.2	5.4	1467.9	13.1	6.1	3.341667	0
45676	2025	1	19	22	7	4.8	5.1	5.7	1408.2	13.1	6.1	3.608333	0
45676	2025	1	19	23	7	5.0	3.9	6.2	1324.4	13.1	6.1	3.858333	0
45676	2025	1	19	24	7	5.0	3.5	7.4	1257.9	13.1	5.9	4.116667	0
45677	2025	1	20	1	1	5.0	3.3	7.2	1213.1	18.4	5.7	4.391667	1
45677	2025	1	20	2	1	5.1	2.5	7.1	1194.3	18.4	5.3	4.766667	1
45677	2025	1	20	3	1	5.0	2.2	6.7	1194.5	18.4	4.9	5.116667	1
45677	2025	1	20	4	1	5.0	2.1	6.8	1195.5	18.4	4.5	5.45	1
45677	2025	1	20	5	1	4.9	1.8	5.9	1217.1	18.4	4.2	5.716667	1
45677	2025	1	20	6	1	4.9	2.1	4.6	1276.0	18.4	3.7	5.975	1
45677	2025	1	20	7	1	4.8	3.7	4.7	1397.4	18.4	3.4	6.091667	1
45677	2025	1	20	8	1	4.7	5.9	5.2	1521.1	18.4	3.3	6.091667	1
45677	2025	1	20	9	1	4.8	1.7	5.1	1581.4	18.4	3.4	6.091667	1
45677	2025	1	20	10	1	4.6	1.4	3.9	1593.0	18.4	3.2	6.075	1
45677	2025	1	20	11	1	4.4	0.5	3.5	1612.5	18.4	2.8	6.05	1
45677	2025	1	20	12	1	4.2	0	3.3	1652.8	18.4	2.6	5.9	1
45677	2025	1	20	13	1	4.0	-0.8	2.5	1672.4	18.4	2.3	5.675	1
45677	2025	1	20	14	1	3.6	-0.4	2.2	1669.9	18.4	1.9	5.333333	1
45677	2025	1	20	15	1	3.3	-0.2	2.1	1684.7	18.4	1.7	4.941667	1
45677	2025	1	20	16	1	3.0	-1	1.8	1724.1	18.4	1.5	4.533333	1
45677	2025	1	20	17	1	2.7	-2	2.1	1794.5	18.4	1.2	4.15	1
45677	2025	1	20	18	1	2.3	-2.7	3.7	1878.5	18.4	0.9	3.733333	1
45677	2025	1	20	19	1	2.0	-4.2	5.9	1874.5	18.4	0.5	3.416667	1
45677	2025	1	20	20	1	1.6	-5	1.7	1862.8	18.4	-0.2	3.341667	1
45677	2025	1	20	21	1	1.2	-5.7	1.4	1849.4	18.4	-1.1	3.441667	1
45677	2025	1	20	22	1	0.7	-6.5	0.5	1802.5	18.4	-1.7	3.15	1
45677	2025	1	20	23	1	0.3	-7.1	0	1733.2	18.4	-2.3	2.841667	1
45677	2025	1	20	24	1	-0.2	-7.4	-0.8	1727.6	18.4	-3.0	2.558333	1
45678	2025	1	21	1	2	-0.7	-8.3	-0.4	1718.0	13.1	-3.6	2.266667	1
45678	2025	1	21	2	2	-1.1	-9.3	-0.2	1720.1	13.1	-4.2	1.925	1
45678	2025	1	21	3	2	-1.6	-11.2	-1	1728.2	13.1	-5.0	1.683333	1
45678	2025	1	21	4	2	-2.2	-11.7	-2	1744.5	13.1	-5.9	1.483333	1
45678	2025	1	21	5	2	-2.8	-12.2	-2.7	1775.1	13.1	-6.8	1.225	1
45678	2025	1	21	6	2	-3.4	-12.7	-4.2	1848.6	13.1	-7.6	0.908333	1
45678	2025	1	21	7	2	-4.0	-13.2	-5	2000.9	13.1	-8.4	0.508333	1
45678	2025	1	21	8	2	-4.7	-13.4	-5.7	2121.1	13.1	-9.2	-0.15	1
45678	2025	1	21	9	2	-5.5	-13.4	-6.5	2140.2	13.1	-9.9	-1.05833	1
45678	2025	1	21	10	2	-6.1	-12.4	-7.1	2063.6	13.1	-10.5	-1.675	1
45678	2025	1	21	11	2	-6.7	-11.3	-7.4	1980.1	13.1	-11.0	-2.33333	1
45678	2025	1	21	12	2	-7.2	-9.6	-8.3	1928.1	13.1	-11.4	-2.96667	1
45678	2025	1	21	13	2	-7.6	-8.1	-9.3	1890.8	13.1	-11.6	-3.58333	1
45678	2025	1	21	14	2	-7.9	-7.1	-11.2	1868.3	13.1	-11.5	-4.20833	1
45678	2025	1	21	15	2	-8.2	-6.7	-11.7	1850.9	13.1	-11.4	-4.95	1
45678	2025	1	21	16	2	-8.4	-7.5	-12.2	1897.2	13.1	-11.0	-5.86667	1
45678	2025	1	21	17	2	-8.7	-7.8	-12.7	1982.0	13.1	-10.6	-6.75833	1
45678	2025	1	21	18	2	-8.9	-8.1	-13.2	2084.8	13.1	-10.3	-7.60833	1
45678	2025	1	21	19	2	-9.2	-8.3	-13.4	2083.3	13.1	-9.9	-8.44167	1
45678	2025	1	21	20	2	-9.3	-9.3	-13.4	2046.4	13.1	-9.5	-9.19167	1
45678	2025	1	21	21	2	-9.5	-9.3	-12.4	2005.4	13.1	-9.1	-9.89167	1
45678	2025	1	21	22	2	-9.7	-7.7	-11.3	1938.9	13.1	-8.8	-10.5333	1
45678	2025	1	21	23	2	-9.7	-8.3	-9.6	1854.8	13.1	-8.4	-11.025	1
45678	2025	1	21	24	2	-9.8	-9.2	-8.1	1825.5	13.1	-8.2	-11.375	1
45679	2025	1	22	1	3	-9.8	-9.7	-7.1	1796.3	15.7	-8.1	-11.5583	1
45679	2025	1	22	2	3	-9.9	-9.9	-6.7	1770.4	15.7	-8.3	-11.5417	1
45679	2025	1	22	3	3	-9.9	-10	-7.5	1743.0	15.7	-8.5	-11.3583	1
45679	2025	1	22	4	3	-9.9	-10.2	-7.8	1739.9	15.7	-8.8	-10.9833	1
45679	2025	1	22	5	3	-9.8	-10.5	-8.1	1769.3	15.7	-9.0	-10.6333	1
45679	2025	1	22	6	3	-9.7	-11	-8.3	1838.4	15.7	-9.2	-10.2667	1
45679	2025	1	22	7	3	-9.7	-11.6	-9.3	1989.5	15.7	-9.5	-9.88333	1
45679	2025	1	22	8	3	-9.6	-12.1	-9.3	2103.8	15.7	-9.7	-9.475	1
45679	2025	1	22	9	3	-9.5	-13.2	-7.7	2145.3	15.7	-10.0	-9.13333	1
45679	2025	1	22	10	3	-9.5	-13.6	-8.3	2071.5	15.7	-10.3	-8.79167	1
45679	2025	1	22	11	3	-9.6	-12	-9.2	1995.7	15.7	-10.8	-8.4	1
45679	2025	1	22	12	3	-9.6	-10.8	-9.7	1955.4	15.7	-11.1	-8.15	1
45679	2025	1	22	13	3	-9.7	-10.2	-9.9	1935.2	15.7	-11.2	-8.11667	1
45679	2025	1	22	14	3	-9.8	-9.8	-10	1901.1	15.7	-11.3	-8.25	1
45679	2025	1	22	15	3	-9.9	-9.3	-10.2	1884.7	15.7	-11.3	-8.48333	1
45679	2025	1	22	16	3	-10.0	-9.6	-10.5	1914.7	15.7	-11.2	-8.75833	1
45679	2025	1	22	17	3	-10.1	-9.7	-11	2020.8	15.7	-11.1	-8.98333	1
45679	2025	1	22	18	3	-10.1	-10.6	-11.6	2164.5	15.7	-11.1	-9.20833	1
45679	2025	1	22	19	3	-10.2	-11.3	-12.1	2181.0	15.7	-11.0	-9.45	1
45679	2025	1	22	20	3	-10.4	-11.5	-13.2	2172.6	15.7	-11.0	-9.725	1
45679	2025	1	22	21	3	-10.5	-11.6	-13.6	2148.7	15.7	-11.0	-9.95833	1
45679	2025	1	22	22	3	-10.6	-12.4	-12	2083.7	15.7	-10.8	-10.2833	1
45679	2025	1	22	23	3	-10.8	-12.4	-10.8	1995.9	15.7	-10.7	-10.775	1
45679	2025	1	22	24	3	-10.9	-12.5	-10.2	1973.1	15.7	-10.8	-11.0833	1
45680	2025	1	23	1	4	-11.1	-12.6	-9.8	1957.5	12.1	-10.9	-11.2167	1
45680	2025	1	23	2	4	-11.2	-12.8	-9.3	1936.1	12.1	-11.1	-11.2583	1
45680	2025	1	23	3	4	-11.3	-12.1	-9.6	1906.7	12.1	-11.4	-11.125	1
45680	2025	1	23	4	4	-11.4	-12	-9.7	1891.2	12.1	-11.6	-11.1917	1
45680	2025	1	23	5	4	-11.5	-12.1	-10.6	1896.1	12.1	-11.8	-11.1417	1
45680	2025	1	23	6	4	-11.5	-12.2	-11.3	1950.0	12.1	-12.0	-11.075	1
45680	2025	1	23	7	4	-11.6	-11.8	-11.5	2070.4	12.1	-12.1	-11.0417	1
45680	2025	1	23	8	4	-11.6	-11.4	-11.6	2168.7	12.1	-12.2	-11.0167	1
45680	2025	1	23	9	4	-11.6	-11.7	-12.4	2170.9	12.1	-12.2	-10.9667	1
45680	2025	1	23	10	4	-11.5	-9	-12.4	2115.4	12.1	-12.2	-10.8333	1
45680	2025	1	23	11	4	-11.3	-7.7	-12.5	1999.4	12.1	-11.9	-10.7333	1
45680	2025	1	23	12	4	-11.1	-6.5	-12.6	1934.8	12.1	-11.5	-10.7667	1
45680	2025	1	23	13	4	-11.0	-5.1	-12.8	1910.2	12.1	-11.0	-10.9083	1
45680	2025	1	23	14	4	-10.7	-5.3	-12.1	1905.9	12.1	-10.4	-11.1083	1
45680	2025	1	23	15	4	-10.6	-5	-12	1902.1	12.1	-9.7	-11.3583	1
45680	2025	1	23	16	4	-10.4	-4.4	-12.1	1920.8	12.1	-9.2	-11.5917	

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLa	gTemp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLa	Weekdays	
45680	2025	1	23	24		4	-7.8	-1.9	-5.1	1670.6	12.1	-4.2	-11.4917	1
45681	2025	1	24	1		5	-7.4	-1.5	-5.3	1612.7	15.0	-3.8	-10.9917	1
45681	2025	1	24	2		5	-6.9	-1.2	-5	1565.3	15.0	-3.5	-10.3667	1
45681	2025	1	24	3		5	-6.4	-0.8	-4.4	1531.1	15.0	-3.1	-9.74167	1
45681	2025	1	24	4		5	-6.0	-0.3	-4.2	1514.3	15.0	-2.8	-9.15	1
45681	2025	1	24	5		5	-5.5	0.1	-3.8	1515.8	15.0	-2.4	-8.51667	1
45681	2025	1	24	6		5	-5.0	0.2	-3.8	1576.1	15.0	-2.1	-7.85833	1
45681	2025	1	24	7		5	-4.5	-0.1	-3.5	1719.8	15.0	-1.7	-7.15833	1
45681	2025	1	24	8		5	-4.0	-2.2	-3.1	1839.7	15.0	-1.4	-6.49167	1
45681	2025	1	24	9		5	-3.6	-3.2	-2.7	1871.9	15.0	-1.3	-5.83333	1
45681	2025	1	24	10		5	-3.2	-3.4	-2.4	1834.5	15.0	-1.3	-5.11667	1
45681	2025	1	24	11		5	-3.0	-3.9	-1.9	1770.8	15.0	-1.4	-4.59167	1
45681	2025	1	24	12		5	-2.8	-3.4	-1.5	1719.3	15.0	-1.5	-4.15	1
45681	2025	1	24	13		5	-2.7	-2.8	-1.2	1692.4	15.0	-1.6	-3.76667	1
45681	2025	1	24	14		5	-2.6	-2.3	-0.8	1670.6	15.0	-1.8	-3.46667	1
45681	2025	1	24	15		5	-2.5	-2.3	-0.3	1677.8	15.0	-1.8	-3.125	1
45681	2025	1	24	16		5	-2.4	-3.3	0.1	1724.6	15.0	-2.0	-2.775	1
45681	2025	1	24	17		5	-2.3	-4.4	0.2	1824.2	15.0	-2.2	-2.43333	1
45681	2025	1	24	18		5	-2.3	-5.6	-0.1	1931.3	15.0	-2.6	-2.075	1
45681	2025	1	24	19		5	-2.4	-6.2	-2.2	1947.7	15.0	-3.1	-1.74167	1
45681	2025	1	24	20		5	-2.5	-6.4	-3.2	1921.0	15.0	-3.6	-1.43333	1
45681	2025	1	24	21		5	-2.6	-7.1	-3.4	1885.1	15.0	-3.9	-1.325	1
45681	2025	1	24	22		5	-2.8	-7.3	-3.9	1839.2	15.0	-4.3	-1.33333	1
45681	2025	1	24	23		5	-3.0	-7.6	-3.4	1779.2	15.0	-4.6	-1.39167	1
45681	2025	1	24	24		5	-3.2	-7.6	-2.8	1775.7	15.0	-4.9	-1.51667	1
45682	2025	1	25	1		6	-3.4	-8	-2.3	1755.7	12.3	-5.2	-1.64167	0
45682	2025	1	25	2		6	-3.7	-8.7	-2.3	1736.3	12.3	-5.7	-1.75	0
45682	2025	1	25	3		6	-4.0	-9.2	-3.3	1713.7	12.3	-6.2	-1.84167	0
45682	2025	1	25	4		6	-4.4	-8.9	-4.4	1706.0	12.3	-6.8	-1.96667	0
45682	2025	1	25	5		6	-4.7	-8.7	-5.6	1718.7	12.3	-7.3	-2.21667	0
45682	2025	1	25	6		6	-5.1	-9	-6.2	1748.1	12.3	-7.6	-2.59167	0
45682	2025	1	25	7		6	-5.5	-9.1	-6.4	1812.8	12.3	-7.9	-3.075	0
45682	2025	1	25	8		6	-5.9	-9.4	-7.1	1903.5	12.3	-8.1	-3.58333	0
45682	2025	1	25	9		6	-6.2	-9.7	-7.3	1975.9	12.3	-8.4	-3.93333	0
45682	2025	1	25	10		6	-6.4	-8.5	-7.6	1945.0	12.3	-8.6	-4.25833	0
45682	2025	1	25	11		6	-6.6	-7.3	-7.6	1880.9	12.3	-8.7	-4.58333	0
45682	2025	1	25	12		6	-6.8	-6.3	-8	1838.1	12.3	-8.7	-4.89167	0
45682	2025	1	25	13		6	-6.9	-4.9	-8.7	1773.4	12.3	-8.6	-5.24167	0
45682	2025	1	25	14		6	-7.0	-3.8	-9.2	1706.1	12.3	-8.3	-5.675	0
45682	2025	1	25	15		6	-7.1	-2.9	-8.9	1669.9	12.3	-7.9	-6.20833	0
45682	2025	1	25	16		6	-7.1	-2.6	-8.7	1688.0	12.3	-7.4	-6.78333	0
45682	2025	1	25	17		6	-7.1	-3	-9	1789.4	12.3	-6.9	-7.25	0
45682	2025	1	25	18		6	-7.0	-4.3	-9.1	1918.7	12.3	-6.4	-7.60833	0
45682	2025	1	25	19		6	-6.9	-5.1	-9.4	1943.3	12.3	-6.0	-7.89167	0
45682	2025	1	25	20		6	-6.9	-5.9	-9.7	1924.1	12.3	-5.7	-8.13333	0
45682	2025	1	25	21		6	-6.9	-6.3	-8.5	1893.5	12.3	-5.4	-8.38333	0
45682	2025	1	25	22		6	-6.8	-6.7	-7.3	1843.2	12.3	-5.1	-8.6	0
45682	2025	1	25	23		6	-6.8	-6.6	-6.3	1785.1	12.3	-4.9	-8.7	0
45682	2025	1	25	24		6	-6.8	-6.9	-4.9	1741.1	12.3	-4.9	-8.675	0
45683	2025	1	26	1		7	-6.7	-7.2	-3.8	1698.7	12.1	-4.9	-8.56667	0
45683	2025	1	26	2		7	-6.7	-7.5	-2.9	1686.2	12.1	-5.1	-8.30833	0
45683	2025	1	26	3		7	-6.7	-7.7	-2.6	1687.3	12.1	-5.4	-7.9	0
45683	2025	1	26	4		7	-6.6	-7.8	-3	1689.8	12.1	-5.8	-7.375	0
45683	2025	1	26	5		7	-6.6	-7.9	-4.3	1709.9	12.1	-6.3	-6.85	0
45683	2025	1	26	6		7	-6.5	-7.6	-5.1	1745.0	12.1	-6.7	-6.375	0
45683	2025	1	26	7		7	-6.5	-7.9	-5.9	1789.7	12.1	-6.9	-5.98333	0
45683	2025	1	26	8		7	-6.4	-6.6	-6.3	1837.5	12.1	-7.2	-5.65	0
45683	2025	1	26	9		7	-6.3	-6.1	-6.7	1900.7	12.1	-7.2	-5.35833	0
45683	2025	1	26	10		7	-6.1	-4.8	-6.6	1927.9	12.1	-7.2	-5.075	0
45683	2025	1	26	11		7	-6.0	-3.4	-6.9	1910.1	12.1	-7.1	-4.925	0
45683	2025	1	26	12		7	-5.8	-2.5	-7.2	1898.0	12.1	-6.8	-4.86667	0
45683	2025	1	26	13		7	-5.7	-0.6	-7.5	1861.6	12.1	-6.4	-4.91667	0
45683	2025	1	26	14		7	-5.5	1	-7.7	1793.7	12.1	-5.9	-5.10833	0
45683	2025	1	26	15		7	-5.3	1.7	-7.8	1777.1	12.1	-5.2	-5.41667	0
45683	2025	1	26	16		7	-5.1	0.6	-7.9	1793.0	12.1	-4.4	-5.81667	0
45683	2025	1	26	17		7	-5.0	0.1	-7.6	1842.1	12.1	-3.7	-6.25	0
45683	2025	1	26	18		7	-4.8	1	-7.9	1887.6	12.1	-3.0	-6.65833	0
45683	2025	1	26	19		7	-4.6	0.6	-6.6	1877.7	12.1	-2.3	-6.93333	0
45683	2025	1	26	20		7	-4.4	0.5	-6.1	1844.2	12.1	-1.6	-7.16667	0
45683	2025	1	26	21		7	-4.1	0.3	-4.8	1792.6	12.1	-1.0	-7.225	0
45683	2025	1	26	22		7	-3.8	-0.6	-3.4	1712.8	12.1	-0.5	-7.20833	0
45683	2025	1	26	23		7	-3.6	-1.2	-2.5	1618.4	12.1	-0.1	-7.05	0
45683	2025	1	26	24		7	-3.4	-1.3	-0.6	1533.5	12.1	0.1	-6.78333	0
45684	2025	1	27	1		1	-3.1	-1.7	1	1478.7	16.6	0.2	-6.41667	1
45684	2025	1	27	2		1	-2.9	-1.1	1.7	1455.0	16.6	0.1	-5.86667	1
45684	2025	1	27	3		1	-2.6	-1.8	0.6	1454.3	16.6	-0.1	-5.15833	1
45684	2025	1	27	4		1	-2.4	-2.7	0.1	1472.3	16.6	-0.4	-4.375	1
45684	2025	1	27	5		1	-2.2	-3.6	1	1509.9	16.6	-0.7	-3.675	1
45684	2025	1	27	6		1	-2.0	-4.5	0.6	1601.6	16.6	-1.0	-3.00833	1
45684	2025	1	27	7		1	-1.9	-5.4	0.5	1762.8	16.6	-1.4	-2.29167	1
45684	2025	1	27	8		1	-1.8	-5.8	0.3	1893.0	16.6	-1.9	-1.58333	1
45684	2025	1	27	9		1	-1.7	-5.5	-0.6	1915.4	16.6	-2.5	-0.99167	1
45684	2025	1	27	10		1	-1.7	-4.4	-1.2	1859.4	16.6	-2.9	-0.45833	1
45684	2025	1	27	11		1	-1.7	-3.4	-1.3	1780.7	16.6	-3.3	-0.10833	1
45684	2025	1	27	12		1	-1.7	-2.3	-1.7	1738.0	16.6	-3.4	0.075	1
45684	2025	1	27	13		1	-1.7	-1.3	-1.1	1710.6	16.6	-3.5	0.175	1
45684	2025	1	27	14		1	-1.7	-1.4	-1.8	1684.6	16.6	-3.5	0.083333	1
45684	2025	1	27	15		1	-1.8	-1.5	-2.7	1652.9	16.6	-3.5	-0.09167	1
45684	2025	1	27	16		1	-1.9	-0.8	-3.6	1663.2	16.6	-3.5	-0.38333	1
45684	2025	1	27	17		1	-2.0	1	-4.5	1726.2	16.6	-3.3	-0.65833	1
45684	2025	1	27	18		1	-2.0	1	-5.4	1831.1	16.6	-2.9	-0.96667	1
45684	2025	1	27	19		1	-2.0	0.8	-5.8	1829.1	16.6	-2.5	-1.425	1
45684	2025	1	27	20		1	-1.9	1.2	-5.5	1793.6	16.6	-2.0	-1.925	1
45684	2025	1	27	21		1	-1.9	1	-4.4	1744.6	16.6	-1.4	-2.45	1
45684	2025	1	27	22		1	-1.9	0.1	-3.4	1667.7	16.6	-0.8	-2.93333	1
45684	2025	1	27	23		1	-1.9	0.5	-2.3	1575.5	16.6	-0.5	-3.25	1
45684	2025	1	27	24		1	-1.8	1	-1.3	1523.6	16.6	-0.1	-3.43333	1
45685	2025	1	28	1		2	-1.7	1.2	-1.4	1474.2	24.4	0.1	-3.51667	1
45685	2025	1	28	2		2	-1.6	1.6	-1.5	1431.3	24.4	0.3	-3.48333	1
4														

DATE	Year	Month	Day	HOUR	DOW	24hrAvgLag	Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLag	Weekdays	
45685	2025	1	28	12	12	2	1.1	3.1	1.2	1641.0	24.4	2.4	-0.14167	1
45685	2025	1	28	13	13	2	1.3	3.8	1.6	1652.7	24.4	2.6	0.133333	1
45685	2025	1	28	14	14	2	1.6	1.9	1.8	1640.0	24.4	2.8	0.341667	1
45685	2025	1	28	15	15	2	1.7	1.4	2.3	1630.9	24.4	2.8	0.591667	1
45685	2025	1	28	16	16	2	1.8	1	2.6	1646.5	24.4	2.8	0.866667	1
45685	2025	1	28	17	17	2	1.9	0.8	2.7	1731.9	24.4	2.7	1.125	1
45685	2025	1	28	18	18	2	1.9	-0.3	2.7	1834.8	24.4	2.5	1.258333	1
45685	2025	1	28	19	19	2	1.8	-3.2	2.8	1861.1	24.4	2.3	1.4	1
45685	2025	1	28	20	20	2	1.7	-4.3	3.2	1866.5	24.4	1.8	1.558333	1
45685	2025	1	28	21	21	2	1.4	-6.3	3.2	1851.0	24.4	1.2	1.691667	1
45685	2025	1	28	22	22	2	1.1	-7.4	3.5	1806.1	24.4	0.4	1.875	1
45685	2025	1	28	23	23	2	0.8	-7.8	3.1	1739.4	24.4	-0.5	2.133333	1
45685	2025	1	28	24	24	2	0.5	-8.2	3.8	1720.0	24.4	-1.4	2.383333	1
45686	2025	1	29	1	1	3	0.1	-8.5	1.9	1708.3	13.4	-2.4	2.558333	1
45686	2025	1	29	2	2	3	-0.3	-8.7	1.4	1701.8	13.4	-3.4	2.775	1
45686	2025	1	29	3	3	3	-0.7	-9.1	1	1693.7	13.4	-4.3	2.8	1
45686	2025	1	29	4	3	3	-1.2	-9.3	0.8	1696.7	13.4	-5.2	2.766667	1
45686	2025	1	29	5	3	3	-1.7	-9.6	-0.3	1726.3	13.4	-6.0	2.658333	1
45686	2025	1	29	6	3	3	-2.2	-10.1	-3.2	1797.3	13.4	-6.9	2.508333	1
45686	2025	1	29	7	3	3	-2.7	-10.4	-4.3	1922.5	13.4	-7.7	2.258333	1
45686	2025	1	29	8	3	3	-3.3	-10.2	-6.3	2008.7	13.4	-8.3	1.766667	1
45686	2025	1	29	9	3	3	-3.8	-10.3	-7.4	2036.5	13.4	-8.8	1.175	1
45686	2025	1	29	10	3	3	-4.4	-9.7	-7.8	2016.7	13.4	-9.1	0.383333	1
45686	2025	1	29	11	3	3	-4.9	-8.7	-8.2	1996.0	13.4	-9.3	-0.5	1
45686	2025	1	29	12	3	3	-5.4	-8	-8.5	1996.8	13.4	-9.4	-1.44167	1
45686	2025	1	29	13	3	3	-5.9	-4.1	-8.7	2009.4	13.4	-9.4	-2.38333	1
45686	2025	1	29	14	3	3	-6.2	-1.8	-9.1	1988.6	13.4	-9.0	-3.40833	1
45686	2025	1	29	15	3	3	-6.4	-1	-9.3	1945.7	13.4	-8.4	-4.29167	1
45686	2025	1	29	16	3	3	-6.5	-0.1	-9.6	1925.4	13.4	-7.8	-5.16667	1
45686	2025	1	29	17	3	3	-6.5	3.3	-10.1	1918.5	13.4	-7.0	-6.025	1
45686	2025	1	29	18	3	3	-6.4	3.1	-10.4	1955.7	13.4	-5.9	-6.89167	1
45686	2025	1	29	19	3	3	-6.3	3	-10.2	1913.6	13.4	-4.8	-7.70833	1
45686	2025	1	29	20	3	3	-6.0	2.5	-10.3	1847.4	13.4	-3.7	-8.30833	1
45686	2025	1	29	21	3	3	-5.7	1.4	-9.7	1793.3	13.4	-2.7	-8.8	1
45686	2025	1	29	22	3	3	-5.4	-1.7	-8.7	1727.8	13.4	-1.7	-9.13333	1
45686	2025	1	29	23	3	3	-5.2	-3.6	-8	1654.4	13.4	-1.0	-9.325	1
45686	2025	1	29	24	3	3	-5.0	-5.1	-4.1	1634.2	13.4	-0.6	-9.4	1
45687	2025	1	30	1	4	4	-4.9	-5.7	-1.8	1613.2	20.5	-0.3	-9.38333	1
45687	2025	1	30	2	4	4	-4.7	-6.4	-1	1602.7	20.5	-0.5	-9.01667	1
45687	2025	1	30	3	4	4	-4.7	-6.6	-0.1	1590.8	20.5	-0.9	-8.44167	1
45687	2025	1	30	4	4	4	-4.5	-6.6	3.3	1603.0	20.5	-1.3	-7.76667	1
45687	2025	1	30	5	4	4	-4.4	-8.1	3.1	1643.8	20.5	-1.9	-7	1
45687	2025	1	30	6	4	4	-4.4	-9.2	3	1722.2	20.5	-2.8	-5.925	1
45687	2025	1	30	7	4	4	-4.3	-10.2	2.5	1881.2	20.5	-3.8	-4.825	1
45687	2025	1	30	8	4	4	-4.3	-11.2	1.4	2002.9	20.5	-4.9	-3.70833	1
45687	2025	1	30	9	4	4	-4.4	-11.8	-1.7	2053.2	20.5	-6.1	-2.65	1
45687	2025	1	30	10	4	4	-4.4	-11.9	-3.6	2045.8	20.5	-7.2	-1.675	1
45687	2025	1	30	11	4	4	-4.5	-11.9	-5.1	2028.3	20.5	-8.0	-1.00833	1
45687	2025	1	30	12	4	4	-4.7	-12.1	-5.7	2011.9	20.5	-8.7	-0.58333	1
45687	2025	1	30	13	4	4	-4.8	-10.7	-6.4	1998.3	20.5	-9.3	-0.34167	1
45687	2025	1	30	14	4	4	-5.1	-10.6	-6.6	1975.7	20.5	-9.7	-0.475	1
45687	2025	1	30	15	4	4	-5.5	-10.8	-6.6	1979.6	20.5	-10.1	-0.85833	1
45687	2025	1	30	16	4	4	-5.9	-11.3	-8.1	2010.9	20.5	-10.4	-1.325	1
45687	2025	1	30	17	4	4	-6.3	-10.5	-9.2	2078.7	20.5	-10.8	-1.86667	1
45687	2025	1	30	18	4	4	-6.9	-11.7	-10.2	2197.4	20.5	-11.0	-2.81667	1
45687	2025	1	30	19	4	4	-7.5	-11.8	-11.2	2224.3	20.5	-11.2	-3.84167	1
45687	2025	1	30	20	4	4	-8.2	-11.7	-11.8	2197.2	20.5	-11.4	-4.94167	1
45687	2025	1	30	21	4	4	-8.7	-11.3	-11.9	2158.4	20.5	-11.4	-6.08333	1
45687	2025	1	30	22	4	4	-9.3	-11.3	-11.9	2090.7	20.5	-11.4	-7.18333	1
45687	2025	1	30	23	4	4	-9.7	-11.4	-12.1	2004.5	20.5	-11.3	-8.03333	1
45687	2025	1	30	24	4	4	-10.0	-11.2	-10.7	1962.0	20.5	-11.3	-8.725	1
45688	2025	1	31	1	5	5	-10.3	-11.3	-10.6	1938.0	14.7	-11.2	-9.30833	1
45688	2025	1	31	2	5	5	-10.5	-11.4	-10.8	1917.7	14.7	-11.2	-9.725	1
45688	2025	1	31	3	5	5	-10.7	-11.6	-11.3	1899.6	14.7	-11.3	-10.075	1
45688	2025	1	31	4	5	5	-10.9	-11.5	-10.5	1893.4	14.7	-11.4	-10.425	1
45688	2025	1	31	5	5	5	-11.1	-11.5	-11.7	1907.3	14.7	-11.4	-10.8167	1
45688	2025	1	31	6	5	5	-11.2	-11.5	-11.8	1963.3	14.7	-11.5	-11.0167	1
45688	2025	1	31	7	5	5	-11.3	-11.2	-11.7	2086.0	14.7	-11.5	-11.225	1
45688	2025	1	31	8	5	5	-11.4	-11.4	-11.3	2173.9	14.7	-11.4	-11.3583	1
45688	2025	1	31	9	5	5	-11.4	-10.8	-11.3	2180.2	14.7	-11.4	-11.4	1
45688	2025	1	31	10	5	5	-11.4	-9.4	-11.4	2134.8	14.7	-11.3	-11.3583	1
45688	2025	1	31	11	5	5	-11.2	-7.1	-11.2	2078.2	14.7	-11.2	-11.3083	1
45688	2025	1	31	12	5	5	-11.0	-3.9	-11.3	2050.0	14.7	-10.8	-11.2667	1
45688	2025	1	31	13	5	5	-10.7	-1.6	-11.4	2014.9	14.7	-10.2	-11.1917	1
45688	2025	1	31	14	5	5	-10.3	0.7	-11.6	1967.6	14.7	-9.4	-11.2417	1
45688	2025	1	31	15	5	5	-9.9	1.1	-11.5	1919.5	14.7	-8.4	-11.3083	1
45688	2025	1	31	16	5	5	-9.4	1	-11.5	1890.3	14.7	-7.3	-11.375	1
45688	2025	1	31	17	5	5	-8.8	1.3	-11.5	1899.3	14.7	-6.3	-11.3917	1
45688	2025	1	31	18	5	5	-8.4	1.5	-11.2	1920.4	14.7	-5.2	-11.475	1
45688	2025	1	31	19	5	5	-7.8	2	-11.4	1874.1	14.7	-4.2	-11.4583	1
45688	2025	1	31	20	5	5	-7.2	2.2	-10.8	1810.8	14.7	-3.1	-11.4083	1
45688	2025	1	31	21	5	5	-6.7	2.2	-9.4	1747.0	14.7	-1.9	-11.3833	1
45688	2025	1	31	22	5	5	-6.1	0.7	-7.1	1689.6	14.7	-0.8	-11.3417	1
45688	2025	1	31	23	5	5	-5.6	0.3	-3.9	1633.4	14.7	0.0	-11.1833	1
45688	2025	1	31	24	5	5	-5.1	-0.9	-1.6	1624.8	14.7	0.6	-10.825	1
45689	2025	2	1	1	6	6	-4.7	-2.5	0.7	1608.0	14.4	0.9	-10.2167	0
45689	2025	2	1	2	6	6	-4.3	-4.2	1.1	1585.6	14.4	0.8	-9.40833	0
45689	2025	2	1	3	6	6	-4.0	-5.3	1	1577.7	14.4	0.4	-8.4	0
45689	2025	2	1	4	6	6	-3.7	-7.1	1.3	1576.7	14.4	-0.1	-7.34167	0
45689	2025	2	1	5	6	6	-3.6	-7.7	1.5	1587.6	14.4	-0.8	-6.3	0
45689	2025	2	1	6	6	6	-3.4	-7.9	2	1624.4	14.4	-1.6	-5.23333	0
45689	2025	2	1	7	6	6	-3.3	-8.1	2.2	1697.4	14.4	-2.4	-4.15	0
45689	2025	2	1	8	6	6	-3.1	-8	2.2	1777.9	14.4	-3.2	-3.05	0
45689	2025	2	1	9	6	6	-3.0	-8.1	0.7	1863.3	14.4	-4.0	-1.91667	0
45689	2025	2	1	10	6	6	-2.9	-8.2	0.3	1927.5	14.4	-4.9	-0.83333	0
45689	2025	2	1	11	6	6	-2.8	-8	-0.9	1954.7	14.4	-5.6	0.008333	0
45689	2025	2	1	12	6	6	-2.9	-7						

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLag	Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLag	Weekdays	
45689	2025	2	2	1	24	6	-7.6	-12.5	-7	1862.7	14.4	-8.9	-6.33333	0
45690	2025	2	2	2	1	7	-8.1	-12.5	-6.7	1829.1	11.3	-9.3	-6.88333	0
45690	2025	2	2	2	2	7	-8.5	-13	-6.6	1815.9	11.3	-9.8	-7.25833	0
45690	2025	2	2	2	3	7	-8.9	-14.1	-7	1812.9	11.3	-10.3	-7.46667	0
45690	2025	2	2	2	4	7	-9.2	-14.9	-7.3	1833.1	11.3	-10.9	-7.575	0
45690	2025	2	2	2	5	7	-9.6	-15.7	-8	1855.8	11.3	-11.6	-7.56667	0
45690	2025	2	2	2	6	7	-9.9	-15.5	-9.2	1887.1	11.3	-12.3	-7.53333	0
45690	2025	2	2	2	7	7	-10.2	-15.7	-10.3	1944.9	11.3	-12.9	-7.54167	0
45690	2025	2	2	2	8	7	-10.5	-15.8	-11.5	2012.8	11.3	-13.4	-7.63333	0
45690	2025	2	2	2	9	7	-10.9	-15.7	-13	2086.3	11.3	-13.9	-7.825	0
45690	2025	2	2	2	10	7	-11.2	-14.4	-12.4	2090.7	11.3	-14.2	-8.10833	0
45690	2025	2	2	2	11	7	-11.4	-13	-12.5	2049.7	11.3	-14.4	-8.50833	0
45690	2025	2	2	2	12	7	-11.6	-10.7	-12.5	2007.8	11.3	-14.4	-8.875	0
45690	2025	2	2	2	13	7	-11.8	-9.6	-13	1963.3	11.3	-14.3	-9.29167	0
45690	2025	2	2	2	14	7	-11.9	-9	-14.1	1905.7	11.3	-14.0	-9.75	0
45690	2025	2	2	2	15	7	-12.0	-8.2	-14.9	1867.6	11.3	-13.7	-10.275	0
45690	2025	2	2	2	16	7	-12.0	-8.2	-15.7	1878.9	11.3	-13.2	-10.9	0
45690	2025	2	2	2	17	7	-12.1	-8.4	-15.5	1975.6	11.3	-12.6	-11.5583	0
45690	2025	2	2	2	18	7	-12.1	-8.8	-15.7	2089.9	11.3	-12.0	-12.2583	0
45690	2025	2	2	2	19	7	-12.2	-8.8	-15.8	2129.0	11.3	-11.5	-12.8833	0
45690	2025	2	2	2	20	7	-12.2	-8.9	-15.7	2118.5	11.3	-10.9	-13.425	0
45690	2025	2	2	2	21	7	-12.1	-9.3	-14.4	2080.0	11.3	-10.3	-13.8833	0
45690	2025	2	2	2	22	7	-12.0	-10.6	-13	2012.9	11.3	-9.8	-14.2333	0
45690	2025	2	2	2	23	7	-11.9	-9.5	-10.7	1911.2	11.3	-9.5	-14.35	0
45690	2025	2	2	2	24	7	-11.8	-9.6	-9.6	1828.8	11.3	-9.2	-14.4	0
45691	2025	2	3	1	1	1	-11.7	-8.7	-9	1771.0	9.4	-9.1	-14.25	1
45691	2025	2	3	2	1	1	-11.5	-8.3	-8.2	1744.4	9.4	-9.0	-14.0083	1
45691	2025	2	3	3	1	1	-11.3	-8.2	-8.2	1731.9	9.4	-8.9	-13.675	1
45691	2025	2	3	4	1	1	-11.1	-8.9	-8.4	1732.7	9.4	-8.9	-13.1833	1
45691	2025	2	3	5	1	1	-10.8	-8.5	-8.8	1749.9	9.4	-9.0	-12.625	1
45691	2025	2	3	6	1	1	-10.5	-8.1	-8.8	1807.6	9.4	-9.0	-12.0167	1
45691	2025	2	3	7	1	1	-10.2	-8.4	-8.9	1937.1	9.4	-9.0	-11.4583	1
45691	2025	2	3	8	1	1	-9.9	-7.8	-9.3	2036.7	9.4	-8.9	-10.8833	1
45691	2025	2	3	9	1	1	-9.6	-7.7	-10.6	2052.4	9.4	-8.8	-10.3083	1
45691	2025	2	3	10	1	1	-9.2	-7.3	-9.5	2018.9	9.4	-8.7	-9.775	1
45691	2025	2	3	11	1	1	-8.9	-5.9	-9.6	1969.1	9.4	-8.4	-9.45833	1
45691	2025	2	3	12	1	1	-8.6	-2.7	-8.7	1914.3	9.4	-8.1	-9.16667	1
45691	2025	2	3	13	1	1	-8.3	-1.9	-8.3	1885.6	9.4	-7.5	-9.075	1
45691	2025	2	3	14	1	1	-8.0	-1.9	-8.2	1858.3	9.4	-7.0	-9	1
45691	2025	2	3	15	1	1	-7.7	-1.7	-8.9	1830.6	9.4	-6.4	-8.94167	1
45691	2025	2	3	16	1	1	-7.4	-1.4	-8.5	1812.7	9.4	-5.9	-8.94167	1
45691	2025	2	3	17	1	1	-7.1	-0.6	-8.1	1853.9	9.4	-5.3	-9	1
45691	2025	2	3	18	1	1	-6.8	-0.5	-8.4	1917.1	9.4	-4.6	-9.00833	1
45691	2025	2	3	19	1	1	-6.5	-0.2	-7.8	1899.6	9.4	-4.0	-8.95	1
45691	2025	2	3	20	1	1	-6.1	0.4	-7.7	1850.9	9.4	-3.3	-8.91667	1
45691	2025	2	3	21	1	1	-5.7	0.6	-7.3	1780.8	9.4	-2.6	-8.825	1
45691	2025	2	3	22	1	1	-5.3	0.7	-5.9	1707.4	9.4	-1.9	-8.69167	1
45691	2025	2	3	23	1	1	-4.8	0.9	-2.7	1594.8	9.4	-1.3	-8.41667	1
45691	2025	2	3	24	1	1	-4.4	0.8	-1.9	1539.2	9.4	-0.7	-8.11667	1
45692	2025	2	4	1	2	2	-4.0	1.2	-1.9	1471.5	17.5	-0.4	-7.54167	1
45692	2025	2	4	2	2	2	-3.6	1.9	-1.7	1428.6	17.5	-0.1	-6.975	1
45692	2025	2	4	3	2	2	-3.1	1.9	-1.4	1403.5	17.5	0.2	-6.44167	1
45692	2025	2	4	4	2	2	-2.7	1.7	-0.6	1383.9	17.5	0.5	-5.9	1
45692	2025	2	4	5	2	2	-2.3	2.1	-0.5	1397.1	17.5	0.7	-5.275	1
45692	2025	2	4	6	2	2	-1.8	1.3	-0.2	1449.9	17.5	1.0	-4.61667	1
45692	2025	2	4	7	2	2	-1.4	1.1	0.4	1560.0	17.5	1.1	-3.98333	1
45692	2025	2	4	8	2	2	-1.0	1	0.6	1654.5	17.5	1.2	-3.3	1
45692	2025	2	4	9	2	2	-0.7	0.9	0.7	1693.4	17.5	1.3	-2.61667	1
45692	2025	2	4	10	2	2	-0.3	0.9	0.9	1668.4	17.5	1.3	-1.925	1
45692	2025	2	4	11	2	2	0.0	0.5	0.8	1604.3	17.5	1.3	-1.25833	1
45692	2025	2	4	12	2	2	0.3	0.1	1.2	1571.3	17.5	1.3	-0.69167	1
45692	2025	2	4	13	2	2	0.4	-0.1	1.9	1553.3	17.5	1.2	-0.4	1
45692	2025	2	4	14	2	2	0.5	-0.2	1.9	1525.8	17.5	1.1	-0.14167	1
45692	2025	2	4	15	2	2	0.6	0.3	1.7	1526.8	17.5	0.9	0.175	1
45692	2025	2	4	16	2	2	0.6	-0.1	2.1	1588.7	17.5	0.8	0.475	1
45692	2025	2	4	17	2	2	0.7	-0.9	1.3	1714.9	17.5	0.7	0.733333	1
45692	2025	2	4	18	2	2	0.7	-1.7	1.1	1823.3	17.5	0.4	0.958333	1
45692	2025	2	4	19	2	2	0.6	-2.4	1	1846.2	17.5	0.2	1.108333	1
45692	2025	2	4	20	2	2	0.5	-3.3	0.9	1832.2	17.5	-0.1	1.216667	1
45692	2025	2	4	21	2	2	0.4	-3.8	0.9	1805.7	17.5	-0.5	1.266667	1
45692	2025	2	4	22	2	2	0.2	-4.4	0.5	1764.1	17.5	-0.9	1.291667	1
45692	2025	2	4	23	2	2	0.0	-5.4	0.1	1706.8	17.5	-1.3	1.308333	1
45692	2025	2	4	24	2	2	-0.3	-6.8	-0.1	1696.2	17.5	-1.8	1.275	1
45693	2025	2	5	1	3	3	-0.6	-7.6	-0.2	1674.6	17.6	-2.4	1.216667	1
45693	2025	2	5	2	3	3	-1.0	-8.2	0.3	1662.7	17.6	-3.0	1.108333	1
45693	2025	2	5	3	3	3	-1.4	-8.9	-0.1	1651.8	17.6	-3.7	0.933333	1
45693	2025	2	5	4	3	3	-1.8	-9.1	-0.9	1656.6	17.6	-4.5	0.8	1
45693	2025	2	5	5	3	3	-2.3	-9.3	-1.7	1687.9	17.6	-5.2	0.65	1
45693	2025	2	5	6	3	3	-2.8	-9.8	-2.4	1759.9	17.6	-5.9	0.4	1
45693	2025	2	5	7	3	3	-3.2	-10.3	-3.3	1906.1	17.6	-6.6	0.15	1
45693	2025	2	5	8	3	3	-3.7	-10.4	-3.8	2028.4	17.6	-7.2	-0.14167	1
45693	2025	2	5	9	3	3	-4.2	-10.4	-4.4	2047.4	17.6	-7.8	-0.5	1
45693	2025	2	5	10	3	3	-4.6	-10.4	-5.4	2028.1	17.6	-8.4	-0.89167	1
45693	2025	2	5	11	3	3	-5.1	-10.7	-6.8	2006.8	17.6	-8.9	-1.33333	1
45693	2025	2	5	12	3	3	-5.6	-11.2	-7.6	1991.0	17.6	-9.3	-1.825	1
45693	2025	2	5	13	3	3	-6.0	-11.1	-8.2	1981.1	17.6	-9.7	-2.4	1
45693	2025	2	5	14	3	3	-6.5	-10.7	-8.9	1933.8	17.6	-10.0	-3.025	1
45693	2025	2	5	15	3	3	-6.9	-11.3	-9.1	1915.1	17.6	-10.2	-3.69167	1
45693	2025	2	5	16	3	3	-7.4	-11.2	-9.3	1946.4	17.6	-10.4	-4.45833	1
45693	2025	2	5	17	3	3	-7.9	-11.5	-9.8	2038.9	17.6	-10.6	-5.20833	1
45693	2025	2	5	18	3	3	-8.3	-12.2	-10.3	2164.3	17.6	-10.8	-5.90833	1
45693	2025	2	5	19	3	3	-8.8	-12.1	-10.4	2201.5	17.6	-11.0	-6.58333	1
45693	2025	2	5	20	3	3	-9.2	-11.8	-10.4	2179.0	17.6	-11.1	-7.24167	1
45693	2025	2	5	21	3	3	-9.5	-11.7	-10.4	2140.0	17.6	-11.2	-7.83333	1
45693	2025	2	5	22	3	3	-9.9	-11.7	-10.7	2081.7	17.6	-11.3	-8.38333	1
45693	2025	2	5	23	3	3	-10.2	-11.9	-11.2	2013.0	17.6	-11.4	-8.88333	1
45693	2025	2	5	24	3	3	-10.4	-12.4	-11.1	1995.5	17.6	-11.5	-9.325	1
45694	2025	2	6	1	4	4	-10.7	-13						

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLag	Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLag	Weekdays
45694	2025	2	6	12	4	-11.5	-5.1	-13	1889.8	14.1	-11.4	-11.5333	1
45694	2025	2	6	13	4	-11.2	-3.1	-12.6	1841.6	14.1	-10.8	-11.6333	1
45694	2025	2	6	14	4	-10.9	-1.8	-12.7	1785.2	14.1	-10.0	-11.7917	1
45694	2025	2	6	15	4	-10.5	-2.1	-12.7	1803.6	14.1	-9.1	-11.95	1
45694	2025	2	6	16	4	-10.1	-2	-12	1838.7	14.1	-8.2	-12.0667	1
45694	2025	2	6	17	4	-9.7	-2.4	-11.7	1909.2	14.1	-7.3	-12.1917	1
45694	2025	2	6	18	4	-9.4	-2.3	-11.5	1975.8	14.1	-6.5	-12.2333	1
45694	2025	2	6	19	4	-9.0	-1.6	-11.5	1962.9	14.1	-5.7	-12.1917	1
45694	2025	2	6	20	4	-8.5	-1.8	-10.8	1936.9	14.1	-4.9	-12.1417	1
45694	2025	2	6	21	4	-8.1	-1	-9.1	1881.3	14.1	-4.1	-12.1167	1
45694	2025	2	6	22	4	-7.7	-0.7	-6.8	1780.7	14.1	-3.3	-12.0417	1
45694	2025	2	6	23	4	-7.2	0	-5.1	1685.0	14.1	-2.6	-11.825	1
45694	2025	2	6	24	4	-6.7	0	-3.1	1637.8	14.1	-2.0	-11.4	1
45695	2025	2	7	1	5	-6.2	0.4	-1.8	1570.1	13.6	-1.6	-10.7917	1
45695	2025	2	7	2	5	-5.6	1.1	-2.1	1502.8	13.6	-1.3	-9.96667	1
45695	2025	2	7	3	5	-5.1	2.1	-2	1448.8	13.6	-1.0	-9.06667	1
45695	2025	2	7	4	5	-4.4	3.1	-2.4	1403.2	13.6	-0.7	-8.18333	1
45695	2025	2	7	5	5	-3.8	2.9	-2.3	1390.7	13.6	-0.3	-7.29167	1
45695	2025	2	7	6	5	-3.2	2.5	-1.6	1427.6	13.6	0.2	-6.49167	1
45695	2025	2	7	7	5	-2.6	2.1	-1.8	1523.8	13.6	0.6	-5.70833	1
45695	2025	2	7	8	5	-2.0	2	-1	1605.2	13.6	0.9	-4.88333	1
45695	2025	2	7	9	5	-1.4	2.3	-0.7	1628.2	13.6	1.2	-4.075	1
45695	2025	2	7	10	5	-0.9	2.4	0	1615.5	13.6	1.5	-3.25833	1
45695	2025	2	7	11	5	-0.4	2.6	0	1572.3	13.6	1.7	-2.55833	1
45695	2025	2	7	12	5	0.0	4.4	0.4	1523.9	13.6	2.0	-1.99167	1
45695	2025	2	7	13	5	0.4	4.2	1.1	1500.7	13.6	2.3	-1.56667	1
45695	2025	2	7	14	5	0.7	3.9	2.1	1489.3	13.6	2.6	-1.275	1
45695	2025	2	7	15	5	0.9	2.5	3.1	1482.1	13.6	2.9	-1.03333	1
45695	2025	2	7	16	5	1.1	2.8	2.9	1480.6	13.6	2.9	-0.68333	1
45695	2025	2	7	17	5	1.3	3.3	2.5	1538.2	13.6	2.9	-0.25833	1
45695	2025	2	7	18	5	1.6	1.1	2.1	1639.3	13.6	2.9	0.183333	1
45695	2025	2	7	19	5	1.7	1	2	1684.8	13.6	2.8	0.583333	1
45695	2025	2	7	20	5	1.8	0.5	2.3	1661.4	13.6	2.7	0.891667	1
45695	2025	2	7	21	5	1.9	0.1	2.4	1627.5	13.6	2.6	1.208333	1
45695	2025	2	7	22	5	1.9	0.1	2.6	1587.6	13.6	2.4	1.483333	1
45695	2025	2	7	23	5	2.0	-0.3	4.4	1538.0	13.6	2.2	1.741667	1
45695	2025	2	7	24	5	2.0	-1.1	4.2	1541.4	13.6	2.0	1.958333	1
45696	2025	2	8	1	6	1.9	-1.9	3.9	1518.3	14.2	1.5	2.325	0
45696	2025	2	8	2	6	1.8	-2.5	2.5	1492.6	14.2	1.0	2.641667	0
45696	2025	2	8	3	6	1.7	-2.7	2.8	1480.4	14.2	0.5	2.875	0
45696	2025	2	8	4	6	1.5	-3.1	3.3	1475.3	14.2	0.0	2.908333	0
45696	2025	2	8	5	6	1.2	-3.3	1.1	1487.9	14.2	-0.5	2.883333	0
45696	2025	2	8	6	6	1.0	-4.1	1	1528.6	14.2	-1.0	2.916667	0
45696	2025	2	8	7	6	0.7	-4.5	0.5	1601.9	14.2	-1.4	2.8	0
45696	2025	2	8	8	6	0.4	-5.1	0.1	1683.8	14.2	-1.9	2.708333	0
45696	2025	2	8	9	6	0.1	-4.6	0.1	1726.8	14.2	-2.4	2.583333	0
45696	2025	2	8	10	6	-0.2	-4.2	-0.3	1709.1	14.2	-2.8	2.4	0
45696	2025	2	8	11	6	-0.5	-3.4	-1.1	1697.9	14.2	-3.1	2.208333	0
45696	2025	2	8	12	6	-0.7	-3.1	-1.9	1675.8	14.2	-3.4	1.966667	0
45696	2025	2	8	13	6	-1.0	-3.7	-2.5	1632.8	14.2	-3.5	1.508333	0
45696	2025	2	8	14	6	-1.3	-2.2	-2.7	1574.0	14.2	-3.7	1	0
45696	2025	2	8	15	6	-1.6	-1.5	-3.1	1541.3	14.2	-3.7	0.466667	0
45696	2025	2	8	16	6	-1.8	-1.7	-3.3	1574.3	14.2	-3.6	0.033333	0
45696	2025	2	8	17	6	-2.0	-1.3	-4.1	1653.9	14.2	-3.5	-0.45833	0
45696	2025	2	8	18	6	-2.1	-2.1	-4.5	1783.6	14.2	-3.3	-1.00833	0
45696	2025	2	8	19	6	-2.3	-2.8	-5.1	1828.1	14.2	-3.1	-1.44167	0
45696	2025	2	8	20	6	-2.4	-3.5	-4.6	1802.9	14.2	-3.0	-1.9	0
45696	2025	2	8	21	6	-2.6	-3.9	-4.2	1782.5	14.2	-2.8	-2.36667	0
45696	2025	2	8	22	6	-2.8	-4.6	-3.4	1749.1	14.2	-2.8	-2.75833	0
45696	2025	2	8	23	6	-3.0	-4.8	-3.1	1715.5	14.2	-2.8	-3.11667	0
45696	2025	2	8	24	6	-3.2	-6.6	-3.7	1683.4	14.2	-2.9	-3.375	0
45697	2025	2	9	1	7	-3.4	-7.2	-2.2	1642.1	13.2	-3.2	-3.54167	0
45697	2025	2	9	2	7	-3.6	-6.5	-1.5	1622.0	13.2	-3.5	-3.69167	0
45697	2025	2	9	3	7	-3.8	-6.2	-1.7	1604.0	13.2	-3.9	-3.66667	0
45697	2025	2	9	4	7	-3.9	-6.2	-1.3	1594.5	13.2	-4.3	-3.56667	0
45697	2025	2	9	5	7	-4.0	-6	-2.1	1594.8	13.2	-4.6	-3.45	0
45697	2025	2	9	6	7	-4.2	-5.2	-2.8	1616.5	13.2	-5.0	-3.28333	0
45697	2025	2	9	7	7	-4.2	-5.1	-3.5	1655.5	13.2	-5.3	-3.11667	0
45697	2025	2	9	8	7	-4.2	-6	-3.9	1725.6	13.2	-5.5	-2.975	0
45697	2025	2	9	9	7	-4.3	-5.9	-4.6	1810.7	13.2	-5.7	-2.84167	0
45697	2025	2	9	10	7	-4.3	-5.4	-4.8	1869.9	13.2	-5.9	-2.78333	0
45697	2025	2	9	11	7	-4.4	-4.8	-6.6	1897.7	13.2	-5.9	-2.81667	0
45697	2025	2	9	12	7	-4.4	-4.4	-7.2	1916.2	13.2	-5.9	-2.93333	0
45697	2025	2	9	13	7	-4.5	-4.2	-6.5	1928.5	13.2	-5.7	-3.225	0
45697	2025	2	9	14	7	-4.5	-4.1	-6.2	1916.8	13.2	-5.5	-3.51667	0
45697	2025	2	9	15	7	-4.6	-4.4	-6.2	1904.4	13.2	-5.3	-3.875	0
45697	2025	2	9	16	7	-4.7	-4.9	-6	1917.6	13.2	-5.1	-4.26667	0
45697	2025	2	9	17	7	-4.8	-5.9	-5.2	1976.9	13.2	-5.0	-4.64167	0
45697	2025	2	9	18	7	-5.0	-7	-5.1	2054.7	13.2	-5.0	-5.03333	0
45697	2025	2	9	19	7	-5.2	-8.3	-6	2083.8	13.2	-5.2	-5.29167	0
45697	2025	2	9	20	7	-5.5	-9.3	-5.9	2060.0	13.2	-5.4	-5.48333	0
45697	2025	2	9	21	7	-5.7	-10.2	-5.4	2006.0	13.2	-5.7	-5.69167	0
45697	2025	2	9	22	7	-6.0	-10.5	-4.8	1946.3	13.2	-6.1	-5.85833	0
45697	2025	2	9	23	7	-6.2	-11.2	-4.4	1877.1	13.2	-6.5	-5.925	0
45697	2025	2	9	24	7	-6.5	-11.5	-4.2	1815.2	13.2	-7.0	-5.925	0
45698	2025	2	10	1	1	-6.7	-11.5	-4.1	1779.2	7.7	-7.6	-5.74167	1
45698	2025	2	10	2	1	-6.9	-12.1	-4.4	1763.1	7.7	-8.2	-5.49167	1
45698	2025	2	10	3	1	-7.1	-12.1	-4.9	1772.8	7.7	-8.9	-5.29167	1
45698	2025	2	10	4	1	-7.3	-12.5	-5.9	1796.4	7.7	-9.5	-5.14167	1
45698	2025	2	10	5	1	-7.6	-12.8	-7	1832.6	7.7	-10.2	-5.03333	1
45698	2025	2	10	6	1	-7.9	-13	-8.3	1906.6	7.7	-10.8	-5.025	1
45698	2025	2	10	7	1	-8.2	-13.3	-9.3	2045.1	7.7	-11.3	-5.175	1
45698	2025	2	10	8	1	-8.6	-13.5	-10.2	2151.8	7.7	-11.7	-5.44167	1
45698	2025	2	10	9	1	-8.9	-13	-10.5	2149.1	7.7	-12.0	-5.71667	1
45698	2025	2	10	10	1	-9.2	-10.1	-11.2	2054.9	7.7	-12.3	-6.075	1
45698	2025	2	10	11	1	-9.4	-7.6	-11.5	1961.3	7.7	-12.2	-6.5	1
45698	2025	2	10	12	1	-9.5	-6.4	-11.5	1916.2	7.7	-11.9	-7.03333	1
45698	2025	2	10	13	1	-9.6	-5.1	-12.1	1899.9	7.7	-11.5	-7.625	1
45698	2025	2	10	14	1	-9.6	-4.2	-12.1	1867.5	7.7	-11.0	-8.23333	1
45698	2025	2	10	15	1	-9.6	-4.5	-12.5	1847.7	7.7	-10.3	-8.9	1
45698	2025	2	10	16	1	-9.6	-3.9	-12.8	1853.2	7.7	-9.7	-9.54167	1
45698	2025	2	10	17	1	-9.6	-4	-13	1910.1	7.7	-9.0	-10.175	1
45698	2025	2	10	18	1	-9.5	-4	-13.3	198				

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLag	Temp	LagTemp12	Load	Wind	12hrAvg	12hrAvgLag	Weekdays	
45698	2025	2	10	24		1	-8.7	-11.7	-5.1	1862.5	7.7	-5.4	-11.9167	1
45699	2025	2	11	1		2	-8.7	-12.3	-4.2	1843.7	12.1	-5.8	-11.4917	1
45699	2025	2	11	2		2	-8.7	-12.6	-4.5	1828.4	12.1	-6.4	-10.9583	1
45699	2025	2	11	3		2	-8.7	-11.1	-3.9	1821.6	12.1	-7.1	-10.3	1
45699	2025	2	11	4		2	-8.7	-11.7	-4	1822.9	12.1	-7.7	-9.66667	1
45699	2025	2	11	5		2	-8.6	-12.5	-4	1853.1	12.1	-8.3	-8.95	1
45699	2025	2	11	6		2	-8.6	-13.2	-4.9	1918.7	12.1	-9.0	-8.21667	1
45699	2025	2	11	7		2	-8.6	-13.9	-4.3	2065.5	12.1	-9.8	-7.46667	1
45699	2025	2	11	8		2	-8.7	-14.7	-6	2182.7	12.1	-10.6	-6.76667	1
45699	2025	2	11	9		2	-8.7	-14	-7.7	2171.2	12.1	-11.4	-6	1
45699	2025	2	11	10		2	-8.8	-11.9	-9.7	2064.0	12.1	-12.1	-5.41667	1
45699	2025	2	11	11		2	-8.8	-10.5	-11.7	1982.8	12.1	-12.4	-5.21667	1
45699	2025	2	11	12		2	-9.0	-10.5	-12.3	1924.1	12.1	-12.5	-5.39167	1
45699	2025	2	11	13		2	-9.1	-9.8	-12.6	1891.5	12.1	-12.4	-5.83333	1
45699	2025	2	11	14		2	-9.3	-8.8	-11.1	1827.3	12.1	-12.2	-6.43333	1
45699	2025	2	11	15		2	-9.5	-7	-11.7	1778.9	12.1	-11.9	-7.13333	1
45699	2025	2	11	16		2	-9.6	-5.7	-12.5	1787.6	12.1	-11.5	-7.68333	1
45699	2025	2	11	17		2	-9.7	-5.5	-13.2	1865.9	12.1	-11.0	-8.33333	1
45699	2025	2	11	18		2	-9.8	-5.9	-13.9	1983.8	12.1	-10.5	-9.04167	1
45699	2025	2	11	19		2	-9.8	-5.7	-14.7	2026.1	12.1	-9.9	-9.80833	1
45699	2025	2	11	20		2	-9.9	-5.9	-14	2001.6	12.1	-9.2	-10.5583	1
45699	2025	2	11	21		2	-9.9	-5.4	-11.9	1953.2	12.1	-8.4	-11.425	1
45699	2025	2	11	22		2	-9.9	-4.8	-10.5	1875.6	12.1	-7.7	-12.0917	1
45699	2025	2	11	23		2	-9.8	-3	-10.5	1784.7	12.1	-7.1	-12.4417	1
45699	2025	2	11	24		2	-9.5	-3.2	-9.8	1748.1	12.1	-6.5	-12.5083	1
45700	2025	2	12	1		3	-9.2	-3.7	-8.8	1713.4	11.0	-5.9	-12.4083	1
45700	2025	2	12	2		3	-8.8	-3.7	-7	1681.9	11.0	-5.4	-12.2	1
45700	2025	2	12	3		3	-8.4	-4.5	-5.7	1666.9	11.0	-5.0	-11.8833	1
45700	2025	2	12	4		3	-8.1	-5.3	-5.5	1664.7	11.0	-4.8	-11.5417	1
45700	2025	2	12	5		3	-7.9	-6	-5.9	1693.9	11.0	-4.7	-11.0417	1
45700	2025	2	12	6		3	-7.6	-7.7	-5.7	1785.5	11.0	-4.8	-10.4583	1
45700	2025	2	12	7		3	-7.4	-9	-5.9	1942.4	11.0	-4.9	-9.85	1
45700	2025	2	12	8		3	-7.2	-9.7	-5.4	2054.2	11.0	-5.2	-9.16667	1
45700	2025	2	12	9		3	-7.0	-10.3	-4.8	2020.7	11.0	-5.5	-8.43333	1
45700	2025	2	12	10		3	-6.8	-9.3	-3	1913.8	11.0	-5.9	-7.71667	1
45700	2025	2	12	11		3	-6.7	-8.2	-3.2	1822.1	11.0	-6.3	-7.125	1
45700	2025	2	12	12		3	-6.6	-7.4	-3.7	1772.8	11.0	-6.7	-6.5	1
45700	2025	2	12	13		3	-6.5	-6.3	-3.7	1741.1	11.0	-7.1	-5.89167	1
45700	2025	2	12	14		3	-6.3	-5.3	-4.5	1694.6	11.0	-7.3	-5.38333	1
45700	2025	2	12	15		3	-6.2	-4.4	-5.3	1663.3	11.0	-7.4	-4.95833	1
45700	2025	2	12	16		3	-6.1	-3.9	-6	1676.4	11.0	-7.4	-4.75	1
45700	2025	2	12	17		3	-6.0	-4.6	-7.7	1763.7	11.0	-7.3	-4.71667	1
45700	2025	2	12	18		3	-6.0	-5.6	-9	1904.1	11.0	-7.2	-4.75833	1
45700	2025	2	12	19		3	-6.0	-7.4	-9.7	1990.6	11.0	-7.0	-4.90833	1
45700	2025	2	12	20		3	-6.0	-8.5	-10.3	2006.5	11.0	-6.9	-5.18333	1
45700	2025	2	12	21		3	-6.1	-9	-9.3	2001.0	11.0	-6.8	-5.5	1
45700	2025	2	12	22		3	-6.3	-10.1	-8.2	1956.7	11.0	-6.7	-5.90833	1
45700	2025	2	12	23		3	-6.5	-10.3	-7.4	1906.6	11.0	-6.7	-6.28333	1
45700	2025	2	12	24		3	-6.8	-11.2	-6.3	1903.7	11.0	-6.9	-6.71667	1
45701	2025	2	13	1		4	-7.1	-11.7	-5.3	1890.8	17.7	-7.2	-7.06667	1
45701	2025	2	13	2		4	-7.5	-12.3	-4.4	1878.4	17.7	-7.7	-7.28333	1
45701	2025	2	13	3		4	-7.8	-12.1	-3.9	1873.9	17.7	-8.3	-7.41667	1
45701	2025	2	13	4		4	-8.2	-12.3	-4.6	1886.5	17.7	-8.9	-7.40833	1
45701	2025	2	13	5		4	-8.4	-13.6	-5.6	1906.8	17.7	-9.6	-7.29167	1
45701	2025	2	13	6		4	-8.8	-12.9	-7.4	1942.9	17.7	-10.3	-7.175	1
45701	2025	2	13	7		4	-9.0	-11.5	-8.5	2045.7	17.7	-11.0	-7	1
45701	2025	2	13	8		4	-9.1	-11.2	-9	2103.3	17.7	-11.3	-6.86667	1
45701	2025	2	13	9		4	-9.1	-10.3	-10.1	2122.6	17.7	-11.5	-6.76667	1
45701	2025	2	13	10		4	-9.1	-9.1	-10.3	2102.0	17.7	-11.6	-6.65833	1
45701	2025	2	13	11		4	-9.1	-7.4	-11.2	2060.4	17.7	-11.5	-6.725	1
45701	2025	2	13	12		4	-9.1	-4.7	-11.7	2030.9	17.7	-11.3	-6.9	1
45701	2025	2	13	13		4	-9.0	-4.1	-12.3	2049.0	17.7	-10.8	-7.21667	1
45701	2025	2	13	14		4	-8.9	-3.4	-12.1	2043.0	17.7	-10.1	-7.66667	1
45701	2025	2	13	15		4	-8.8	-3.2	-12.3	2022.1	17.7	-9.4	-8.25	1
45701	2025	2	13	16		4	-8.8	-2.8	-13.6	2016.4	17.7	-8.6	-8.89167	1
45701	2025	2	13	17		4	-8.7	-2.4	-12.9	2023.1	17.7	-7.9	-9.59167	1
45701	2025	2	13	18		4	-8.6	-1.5	-11.5	2046.8	17.7	-6.9	-10.3417	1
45701	2025	2	13	19		4	-8.5	-0.2	-11.2	2021.1	17.7	-6.0	-10.95	1
45701	2025	2	13	20		4	-8.2	0.4	-10.3	1934.3	17.7	-5.0	-11.2917	1
45701	2025	2	13	21		4	-7.8	1.1	-9.1	1834.7	17.7	-4.1	-11.5167	1
45701	2025	2	13	22		4	-7.4	1.7	-7.4	1709.5	17.7	-3.1	-11.625	1
45701	2025	2	13	23		4	-6.9	3.1	-4.7	1587.6	17.7	-2.2	-11.5417	1
45701	2025	2	13	24		4	-6.3	4.3	-4.1	1519.3	17.7	-1.3	-11.3	1
45702	2025	2	14	1		5	-5.7	4	-3.4	1463.3	25.4	-0.6	-10.7583	1
45702	2025	2	14	2		5	-5.0	4.1	-3.2	1435.0	25.4	0.1	-10.125	1
45702	2025	2	14	3		5	-4.3	3.5	-2.8	1422.1	25.4	0.7	-9.38333	1
45702	2025	2	14	4		5	-3.7	2.3	-2.4	1443.9	25.4	1.3	-8.64167	1
45702	2025	2	14	5		5	-3.1	0.6	-1.5	1480.7	25.4	1.7	-7.85	1
45702	2025	2	14	6		5	-2.5	-1.1	-0.2	1563.2	25.4	2.0	-6.91667	1
45702	2025	2	14	7		5	-2.0	-2.5	0.4	1692.7	25.4	2.0	-5.96667	1
45702	2025	2	14	8		5	-1.6	-3.3	1.1	1792.9	25.4	1.8	-5.025	1
45702	2025	2	14	9		5	-1.3	-3.9	1.7	1849.3	25.4	1.5	-4.05833	1
45702	2025	2	14	10		5	-1.0	-4.1	3.1	1859.1	25.4	1.1	-3.10833	1
45702	2025	2	14	11		5	-0.8	-4	4.3	1851.3	25.4	0.6	-2.20833	1
45702	2025	2	14	12		5	-0.7	-4.2	4	1860.7	25.4	0.0	-1.33333	1
45702	2025	2	14	13		5	-0.7	-4.8	4.1	1844.7	25.4	-0.7	-0.58333	1
45702	2025	2	14	14		5	-0.7	-4.1	3.5	1814.9	25.4	-1.5	0.091667	1
45702	2025	2	14	15		5	-0.7	-4	2.3	1805.3	25.4	-2.1	0.716667	1
45702	2025	2	14	16		5	-0.7	-4	0.6	1828.7	25.4	-2.8	1.275	1
45702	2025	2	14	17		5	-0.8	-3.9	-1.1	1912.0	25.4	-3.3	1.7	1
45702	2025	2	14	18		5	-0.9	-4.8	-2.5	2006.5	25.4	-3.7	1.95	1
45702	2025	2	14	19		5	-1.0	-5.8	-3.3	2052.0	25.4	-4.0	1.983333	1
45702	2025	2	14	20		5	-1.2	-6.3	-3.9	2041.2	25.4	-4.2	1.791667	1
45702	2025	2	14	21		5	-1.5	-7	-4.1	2019.5	25.4	-4.5	1.483333	1
45702	2025	2	14	22		5	-1.8	-7.5	-4	1974.2	25.4	-4.8	1.066667	1
45702	2025	2	14	23		5	-2.2	-8	-4.2	1923.3	25.4	-5.0	0.583333	1
45702	2025	2	14	24		5	-2.7	-8.3	-4.8	1912.9	25.4	-5.4	-0.00833	1
45703	2025	2	15	1		6	-3.2	-8.5	-4.1	1887.2	24.4	-5.7	-0.71667	0
45703	2025	2	15	2		6	-3.7							

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLag	Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLag	Weekdays
45703	2025	2	15	12	6	-7.4	-7.1	-8.5	1902.3	24.4	-9.5	-5.36667	0
45703	2025	2	15	13	6	-7.6	-6.1	-8.8	1845.2	24.4	-9.4	-5.70833	0
45703	2025	2	15	14	6	-7.6	-4.7	-9.4	1784.6	24.4	-9.2	-6.01667	0
45703	2025	2	15	15	6	-7.6	-3.9	-9.8	1739.3	24.4	-8.9	-6.40833	0
45703	2025	2	15	16	6	-7.6	-3.8	-10.1	1752.0	24.4	-8.4	-6.85833	0
45703	2025	2	15	17	6	-7.6	-4.3	-10.4	1832.6	24.4	-7.9	-7.34167	0
45703	2025	2	15	18	6	-7.6	-5.2	-10.4	1960.8	24.4	-7.4	-7.85833	0
45703	2025	2	15	19	6	-7.7	-6.1	-10.7	2028.2	24.4	-7.0	-8.325	0
45703	2025	2	15	20	6	-7.7	-6.5	-10.2	2004.7	24.4	-6.6	-8.70833	0
45703	2025	2	15	21	6	-7.7	-6.8	-9.3	1969.4	24.4	-6.3	-9.075	0
45703	2025	2	15	22	6	-7.7	-6.9	-8.1	1903.9	24.4	-6.0	-9.34167	0
45703	2025	2	15	23	6	-7.6	-7	-7.1	1832.9	24.4	-5.8	-9.49167	0
45703	2025	2	15	24	6	-7.6	-6.8	-6.1	1778.8	24.4	-5.7	-9.5	0
45704	2025	2	16	1	7	-7.5	-6.5	-4.7	1718.7	13.8	-5.7	-9.4	0
45704	2025	2	16	2	7	-7.5	-6.2	-3.9	1682.2	13.8	-5.7	-9.2	0
45704	2025	2	16	3	7	-7.3	-6.1	-3.8	1663.2	13.8	-5.8	-8.85833	0
45704	2025	2	16	4	7	-7.2	-6.2	-4.3	1661.2	13.8	-6.0	-8.4	0
45704	2025	2	16	5	7	-7.1	-6.3	-5.2	1670.0	13.8	-6.2	-7.9	0
45704	2025	2	16	6	7	-6.9	-6.4	-6.1	1690.4	13.8	-6.4	-7.41667	0
45704	2025	2	16	7	7	-6.7	-6.6	-6.5	1734.2	13.8	-6.5	-6.98333	0
45704	2025	2	16	8	7	-6.6	-6.7	-6.8	1783.2	13.8	-6.5	-6.625	0
45704	2025	2	16	9	7	-6.4	-6.4	-6.9	1812.8	13.8	-6.5	-6.275	0
45704	2025	2	16	10	7	-6.3	-5.9	-7	1804.0	13.8	-6.5	-5.99167	0
45704	2025	2	16	11	7	-6.1	-4.8	-6.8	1779.0	13.8	-6.4	-5.79167	0
45704	2025	2	16	12	7	-6.0	-4.1	-6.5	1778.4	13.8	-6.2	-5.7	0
45704	2025	2	16	13	7	-5.8	-3.5	-6.2	1790.3	13.8	-6.0	-5.675	0
45704	2025	2	16	14	7	-5.7	-2.8	-6.1	1793.5	13.8	-5.8	-5.70833	0
45704	2025	2	16	15	7	-5.7	-3.1	-6.2	1795.3	13.8	-5.5	-5.83333	0
45704	2025	2	16	16	7	-5.6	-4.8	-6.3	1849.0	13.8	-5.2	-6.01667	0
45704	2025	2	16	17	7	-5.7	-5.9	-6.4	1929.4	13.8	-5.1	-6.21667	0
45704	2025	2	16	18	7	-5.7	-5.4	-6.6	1979.0	13.8	-5.1	-6.38333	0
45704	2025	2	16	19	7	-5.7	-5.1	-6.7	1950.3	13.8	-5.0	-6.48333	0
45704	2025	2	16	20	7	-5.7	-3.4	-6.4	1873.5	13.8	-4.9	-6.525	0
45704	2025	2	16	21	7	-5.6	-2.1	-5.9	1807.5	13.8	-4.6	-6.54167	0
45704	2025	2	16	22	7	-5.4	-1.5	-4.8	1723.3	13.8	-4.2	-6.50833	0
45704	2025	2	16	23	7	-5.2	-0.7	-4.1	1625.8	13.8	-3.9	-6.425	0
45704	2025	2	16	24	7	-4.9	-0.3	-3.5	1550.1	13.8	-3.5	-6.24167	0
45705	2025	2	17	1	1	-4.6	0.6	-2.8	1468.0	29.4	-3.2	-6.01667	0
45705	2025	2	17	2	1	-4.3	1.7	-3.1	1397.8	29.4	-2.9	-5.76667	0
45705	2025	2	17	3	1	-4.0	4.8	-4.8	1330.0	29.4	-2.5	-5.48333	0
45705	2025	2	17	4	1	-3.5	6.5	-5.9	1298.8	29.4	-1.8	-5.23333	0
45705	2025	2	17	5	1	-3.0	5.6	-5.4	1291.2	29.4	-0.9	-5.11667	0
45705	2025	2	17	6	1	-2.5	4.6	-5.1	1322.7	29.4	0.1	-5.08333	0
45705	2025	2	17	7	1	-2.1	3.4	-3.4	1399.4	29.4	0.9	-5	0
45705	2025	2	17	8	1	-1.6	0.9	-2.1	1463.9	29.4	1.6	-4.875	0
45705	2025	2	17	9	1	-1.3	0.3	-1.5	1544.9	29.4	2.0	-4.6	0
45705	2025	2	17	10	1	-1.0	-0.9	-0.7	1631.2	29.4	2.2	-4.24167	0
45705	2025	2	17	11	1	-0.8	-1	-0.3	1683.7	29.4	2.2	-3.875	0
45705	2025	2	17	12	1	-0.7	-1.6	0.6	1722.7	29.4	2.2	-3.53333	0
45705	2025	2	17	13	1	-0.6	-2	1.7	1772.2	29.4	2.1	-3.21667	0
45705	2025	2	17	14	1	-0.5	-3	4.8	1782.0	29.4	1.9	-2.875	0
45705	2025	2	17	15	1	-0.5	-3.6	6.5	1794.8	29.4	1.5	-2.5	0
45705	2025	2	17	16	1	-0.5	-3.6	5.6	1831.5	29.4	0.8	-1.84167	0
45705	2025	2	17	17	1	-0.5	-4.9	4.6	1907.7	29.4	-0.1	-0.9	0
45705	2025	2	17	18	1	-0.4	-5.1	3.4	1972.1	29.4	-1.0	0.058333	0
45705	2025	2	17	19	1	-0.4	-5.6	0.9	2005.0	29.4	-1.8	0.891667	0
45705	2025	2	17	20	1	-0.5	-5.4	0.3	1983.2	29.4	-2.5	1.6	0
45705	2025	2	17	21	1	-0.5	-5.4	-0.9	1947.3	29.4	-3.0	1.958333	0
45705	2025	2	17	22	1	-0.7	-5.7	-1	1887.8	29.4	-3.5	2.158333	0
45705	2025	2	17	23	1	-0.9	-6.3	-1.6	1822.5	29.4	-3.9	2.208333	0
45705	2025	2	17	24	1	-1.1	-7.6	-2	1806.0	29.4	-4.4	2.183333	0
45706	2025	2	18	1	2	-1.4	-8.3	-3	1787.4	23.5	-4.9	2.075	1
45706	2025	2	18	2	2	-1.8	-7.9	-3.6	1760.6	23.5	-5.4	1.858333	1
45706	2025	2	18	3	2	-2.2	-7.9	-3.6	1747.1	23.5	-5.8	1.466667	1
45706	2025	2	18	4	2	-2.7	-7.8	-4.9	1751.5	23.5	-6.1	0.766667	1
45706	2025	2	18	5	2	-3.3	-7.7	-5.1	1770.5	23.5	-6.5	-0.075	1
45706	2025	2	18	6	2	-3.8	-7.9	-5.6	1833.4	23.5	-6.7	-0.95	1
45706	2025	2	18	7	2	-4.4	-7.8	-5.4	1963.7	23.5	-7.0	-1.75833	1
45706	2025	2	18	8	2	-4.8	-7.9	-5.4	2051.4	23.5	-7.1	-2.50833	1
45706	2025	2	18	9	2	-5.2	-8.3	-5.7	2084.5	23.5	-7.4	-3.03333	1
45706	2025	2	18	10	2	-5.6	-8.3	-6.3	2066.4	23.5	-7.6	-3.50833	1
45706	2025	2	18	11	2	-5.9	-8.2	-7.6	2031.8	23.5	-7.8	-3.90833	1
45706	2025	2	18	12	2	-6.2	-8.4	-8.3	1978.3	23.5	-8.0	-4.35	1
45706	2025	2	18	13	2	-6.4	-7.7	-7.9	1958.2	23.5	-8.0	-4.85	1
45706	2025	2	18	14	2	-6.7	-7	-7.9	1943.4	23.5	-8.0	-5.375	1
45706	2025	2	18	15	2	-6.8	-6.5	-7.8	1933.0	23.5	-7.9	-5.78333	1
45706	2025	2	18	16	2	-7.0	-6.6	-7.7	1942.6	23.5	-7.8	-6.14167	1
45706	2025	2	18	17	2	-7.1	-6.5	-7.9	1999.2	23.5	-7.7	-6.49167	1
45706	2025	2	18	18	2	-7.2	-6.9	-7.8	2071.1	23.5	-7.6	-6.725	1
45706	2025	2	18	19	2	-7.2	-7	-7.9	2097.5	23.5	-7.5	-6.95833	1
45706	2025	2	18	20	2	-7.3	-7	-8.3	2064.7	23.5	-7.4	-7.14167	1
45706	2025	2	18	21	2	-7.4	-7	-8.3	2009.3	23.5	-7.4	-7.35	1
45706	2025	2	18	22	2	-7.4	-7	-8.2	1924.1	23.5	-7.3	-7.59167	1
45706	2025	2	18	23	2	-7.5	-6.9	-8.4	1829.3	23.5	-7.2	-7.80833	1
45706	2025	2	18	24	2	-7.5	-7.3	-7.7	1801.0	23.5	-7.0	-7.96667	1
45707	2025	2	19	1	3	-7.5	-7.5	-7	1771.8	12.8	-7.0	-8.03333	1
45707	2025	2	19	2	3	-7.5	-8	-6.5	1756.5	12.8	-6.9	-7.98333	1
45707	2025	2	19	3	3	-7.5	-8.2	-6.6	1741.4	12.8	-7.0	-7.90833	1
45707	2025	2	19	4	3	-7.5	-8.6	-6.5	1734.8	12.8	-7.2	-7.79167	1
45707	2025	2	19	5	3	-7.5	-8.7	-6.9	1745.5	12.8	-7.3	-7.69167	1
45707	2025	2	19	6	3	-7.6	-8.8	-7	1800.2	12.8	-7.5	-7.59167	1
45707	2025	2	19	7	3	-7.6	-9	-7	1919.4	12.8	-7.7	-7.50833	1
45707	2025	2	19	8	3	-7.6	-8.9	-7	2008.0	12.8	-7.8	-7.44167	1
45707	2025	2	19	9	3	-7.7	-8.5	-7	2011.0	12.8	-8.0	-7.36667	1
45707	2025	2	19	10	3	-7.7	-7.9	-6.9	1933.7	12.8	-8.1	-7.25833	1
45707	2025	2	19	11	3	-7.7	-5.9	-7.3	1842.2	12.8	-8.2	-7.15	1
45707	2025	2	19	12	3	-7.6	-4.4	-7.5	1762.9	12.8	-8.1	-7.04167	1
45707	2025	2	19	13	3	-7.4	-2.6	-8	1710.1	12.8	-7.9	-6.95	1
45707	2025	2	19	14	3	-7.2	-1.2	-8.2	1643.3	12.8	-7.5	-6.93333	1
45707	2025	2	19	15	3	-7.0	-0.5	-8.6	1601.0	12.8	-6.9	-7.01667	1
45707	2025	2	19	16	3	-6.7	0.8	-8.7	1602.0	12.8	-6.3	-7.15833	1
45707	2025	2	19	17	3	-6.4	1.1	-8.8	1660.8	12.8	-5.5	-7.325	1
45707	2025	2	19	18	3	-6.1</							

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLa	gTemp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLa	gWeekdays
45707	2025	2	19	24	3	-4.9	-5.3	-2.6	1660.6	12.8	-1.7	-8.10833	1
45708	2025	2	20	1	4	-4.8	-5.3	-1.2	1638.0	6.6	-1.8	-7.86667	1
45708	2025	2	20	2	4	-4.7	-5.8	-0.5	1629.3	6.6	-2.0	-7.45833	1
45708	2025	2	20	3	4	-4.6	-6.1	0.8	1617.3	6.6	-2.4	-6.89167	1
45708	2025	2	20	4	4	-4.5	-5.9	1.1	1628.7	6.6	-2.8	-6.25	1
45708	2025	2	20	5	4	-4.4	-5.9	1	1653.5	6.6	-3.4	-5.46667	1
45708	2025	2	20	6	4	-4.3	-6	-0.5	1720.3	6.6	-4.0	-4.65	1
45708	2025	2	20	7	4	-4.2	-6.4	-1.7	1854.8	6.6	-4.6	-3.83333	1
45708	2025	2	20	8	4	-4.1	-6.4	-2.7	1940.0	6.6	-5.0	-3.125	1
45708	2025	2	20	9	4	-4.0	-5.5	-4.3	1911.1	6.6	-5.4	-2.525	1
45708	2025	2	20	10	4	-3.9	-4.7	-5.1	1830.9	6.6	-5.7	-2.04167	1
45708	2025	2	20	11	4	-3.7	-3.5	-5.3	1768.7	6.6	-5.7	-1.74167	1
45708	2025	2	20	12	4	-3.6	-3.5	-5.3	1711.7	6.6	-5.6	-1.675	1
45708	2025	2	20	13	4	-3.6	-2.4	-5.8	1661.0	6.6	-5.4	-1.75	1
45708	2025	2	20	14	4	-3.6	-1.8	-6.1	1619.1	6.6	-5.2	-1.975	1
45708	2025	2	20	15	4	-3.6	-0.2	-5.9	1600.5	6.6	-4.8	-2.35833	1
45708	2025	2	20	16	4	-3.6	-2	-5.9	1632.0	6.6	-4.4	-2.825	1
45708	2025	2	20	17	4	-3.7	-1.9	-6	1706.8	6.6	-4.0	-3.38333	1
45708	2025	2	20	18	4	-3.8	-2.4	-6.4	1792.7	6.6	-3.7	-3.96667	1
45708	2025	2	20	19	4	-4.0	-2.6	-6.4	1831.7	6.6	-3.4	-4.55	1
45708	2025	2	20	20	4	-4.1	-2.9	-5.5	1811.2	6.6	-3.1	-5.04167	1
45708	2025	2	20	21	4	-4.1	-2.9	-4.7	1768.2	6.6	-2.8	-5.43333	1
45708	2025	2	20	22	4	-4.1	-3	-3.5	1694.5	6.6	-2.6	-5.66667	1
45708	2025	2	20	23	4	-4.1	-2.9	-3.5	1616.3	6.6	-2.4	-5.7	1
45708	2025	2	20	24	4	-4.0	-2.5	-2.4	1581.9	6.6	-2.4	-5.56667	1
45709	2025	2	21	1	5	-3.9	-2.4	-1.8	1547.8	15.5	-2.3	-5.41667	1
45709	2025	2	21	2	5	-3.7	-2.8	-0.2	1509.9	15.5	-2.3	-5.175	1
45709	2025	2	21	3	5	-3.6	-3.1	-2	1472.7	15.5	-2.4	-4.84167	1
45709	2025	2	21	4	5	-3.5	-3.1	-1.9	1463.6	15.5	-2.6	-4.35	1
45709	2025	2	21	5	5	-3.4	-2.8	-2.4	1473.8	15.5	-2.7	-4.025	1
45709	2025	2	21	6	5	-3.2	-2.8	-2.6	1535.7	15.5	-2.8	-3.69167	1
45709	2025	2	21	7	5	-3.1	-3	-2.9	1668.4	15.5	-2.8	-3.39167	1
45709	2025	2	21	8	5	-3.0	-3.1	-2.9	1776.7	15.5	-2.9	-3.075	1
45709	2025	2	21	9	5	-2.8	-3.1	-3	1813.6	15.5	-2.9	-2.78333	1
45709	2025	2	21	10	5	-2.7	-2.6	-2.9	1799.0	15.5	-2.9	-2.56667	1
45709	2025	2	21	11	5	-2.6	-1.9	-2.5	1784.5	15.5	-2.9	-2.425	1
45709	2025	2	21	12	5	-2.6	-1.4	-2.4	1761.4	15.5	-2.8	-2.375	1
45709	2025	2	21	13	5	-2.5	-1.5	-2.8	1736.3	15.5	-2.7	-2.29167	1
45709	2025	2	21	14	5	-2.4	-1.5	-3.1	1681.9	15.5	-2.6	-2.29167	1
45709	2025	2	21	15	5	-2.4	-1.6	-3.1	1647.2	15.5	-2.5	-2.375	1
45709	2025	2	21	16	5	-2.5	-1.3	-2.8	1649.4	15.5	-2.4	-2.61667	1
45709	2025	2	21	17	5	-2.5	-1.9	-2.8	1708.9	15.5	-2.2	-2.70833	1
45709	2025	2	21	18	5	-2.5	-1.7	-3	1788.4	15.5	-2.1	-2.78333	1
45709	2025	2	21	19	5	-2.4	-2.3	-3.1	1843.3	15.5	-2.1	-2.81667	1
45709	2025	2	21	20	5	-2.4	-3	-3.1	1820.0	15.5	-2.0	-2.85	1
45709	2025	2	21	21	5	-2.4	-4.3	-2.6	1775.5	15.5	-2.0	-2.86667	1
45709	2025	2	21	22	5	-2.5	-3.2	-1.9	1718.2	15.5	-2.1	-2.88333	1
45709	2025	2	21	23	5	-2.5	-3.4	-1.4	1661.4	15.5	-2.1	-2.85	1
45709	2025	2	21	24	5	-2.5	-4	-1.5	1648.1	15.5	-2.3	-2.76667	1
45710	2025	2	22	1	6	-2.6	-4.4	-1.5	1615.8	11.8	-2.5	-2.675	0
45710	2025	2	22	2	6	-2.7	-4.7	-1.6	1584.3	11.8	-2.7	-2.6	0
45710	2025	2	22	3	6	-2.7	-4.9	-1.3	1571.5	11.8	-3.0	-2.49167	0
45710	2025	2	22	4	6	-2.8	-4.7	-1.9	1570.7	11.8	-3.3	-2.36667	0
45710	2025	2	22	5	6	-2.9	-5.7	-1.7	1582.2	11.8	-3.5	-2.21667	0
45710	2025	2	22	6	6	-3.0	-6	-2.3	1620.5	11.8	-3.9	-2.14167	0
45710	2025	2	22	7	6	-3.1	-6.5	-3	1690.3	11.8	-4.2	-2.05	0
45710	2025	2	22	8	6	-3.3	-7.1	-4.3	1765.7	11.8	-4.6	-1.99167	0
45710	2025	2	22	9	6	-3.4	-6.8	-3.2	1789.1	11.8	-4.9	-1.98333	0
45710	2025	2	22	10	6	-3.6	-5.7	-3.4	1765.4	11.8	-5.1	-2.08333	0
45710	2025	2	22	11	6	-3.7	-4.7	-4	1742.0	11.8	-5.3	-2.13333	0
45710	2025	2	22	12	6	-3.8	-4	-4.4	1703.9	11.8	-5.4	-2.25833	0
45710	2025	2	22	13	6	-4.0	-4.1	-4.7	1644.8	11.8	-5.4	-2.475	0
45710	2025	2	22	14	6	-4.1	-3	-4.9	1564.8	11.8	-5.4	-2.71667	0
45710	2025	2	22	15	6	-4.1	-2.4	-4.7	1519.2	11.8	-5.3	-2.98333	0
45710	2025	2	22	16	6	-4.2	-2.1	-5.7	1534.5	11.8	-5.1	-3.25833	0
45710	2025	2	22	17	6	-4.2	-1.7	-6	1613.6	11.8	-4.8	-3.54167	0
45710	2025	2	22	18	6	-4.2	-2.6	-6.5	1741.0	11.8	-4.5	-3.85833	0
45710	2025	2	22	19	6	-4.2	-4.2	-7.1	1823.0	11.8	-4.2	-4.21667	0
45710	2025	2	22	20	6	-4.3	-5.2	-6.8	1827.1	11.8	-4.0	-4.56667	0
45710	2025	2	22	21	6	-4.4	-5.6	-5.7	1811.7	11.8	-3.9	-4.90833	0
45710	2025	2	22	22	6	-4.4	-6	-4.7	1774.8	11.8	-3.8	-5.11667	0
45710	2025	2	22	23	6	-4.6	-5.7	-4	1725.5	11.8	-3.8	-5.325	0
45710	2025	2	22	24	6	-4.7	-5.7	-4.1	1692.7	11.8	-3.9	-5.43333	0
45711	2025	2	23	1	7	-4.7	-5.9	-3	1664.7	12.7	-4.0	-5.43333	0
45711	2025	2	23	2	7	-4.8	-6.2	-2.4	1657.4	12.7	-4.2	-5.40833	0
45711	2025	2	23	3	7	-4.9	-6.9	-2.1	1665.5	12.7	-4.4	-5.26667	0
45711	2025	2	23	4	7	-4.9	-7.1	-1.7	1684.7	12.7	-4.8	-5.05833	0
45711	2025	2	23	5	7	-5.0	-6.7	-2.6	1716.9	12.7	-5.2	-4.84167	0
45711	2025	2	23	6	7	-5.1	-7.2	-4.2	1749.1	12.7	-5.7	-4.50833	0
45711	2025	2	23	7	7	-5.1	-8	-5.2	1797.0	12.7	-6.0	-4.225	0
45711	2025	2	23	8	7	-5.2	-7.4	-5.6	1822.7	12.7	-6.4	-4.03333	0
45711	2025	2	23	9	7	-5.2	-4.7	-6	1857.7	12.7	-6.5	-3.875	0
45711	2025	2	23	10	7	-5.1	-2.7	-5.7	1863.4	12.7	-6.5	-3.775	0
45711	2025	2	23	11	7	-5.0	-0.5	-5.7	1806.5	12.7	-6.2	-3.8	0
45711	2025	2	23	12	7	-4.8	0.3	-5.9	1752.4	12.7	-5.8	-3.88333	0
45711	2025	2	23	13	7	-4.6	1	-6.2	1730.4	12.7	-5.3	-4.025	0
45711	2025	2	23	14	7	-4.4	1	-6.9	1698.2	12.7	-4.7	-4.175	0
45711	2025	2	23	15	7	-4.3	1.6	-7.1	1667.6	12.7	-4.1	-4.44167	0
45711	2025	2	23	16	7	-4.1	2	-6.7	1670.8	12.7	-3.4	-4.81667	0
45711	2025	2	23	17	7	-3.9	1.8	-7.2	1738.9	12.7	-2.6	-5.23333	0
45711	2025	2	23	18	7	-3.8	1.4	-8	1802.7	12.7	-1.9	-5.65	0
45711	2025	2	23	19	7	-3.6	0	-7.4	1828.4	12.7	-1.2	-6.03333	0
45711	2025	2	23	20	7	-3.4	0.1	-4.7	1802.1	12.7	-0.5	-6.35	0
45711	2025	2	23	21	7	-3.2	0.3	-2.7	1762.7	12.7	0.1	-6.53333	0
45711	2025	2	23	22	7	-3.0	-1.6	-0.5	1686.6	12.7	0.5	-6.45833	0
45711	2025	2	23	23	7	-2.8	-1.5	0.3	1593.0	12.7	0.6	-6.18333	0
45711	2025	2	23	24	7	-2.6	-1.5	1	1517.5	12.7	0.5	-5.75	0
45712	2025	2	24	1	1	-2.4	-2.3	1	1473.0	10.6	0.4	-5.25	1
45712	2025	2	24	2	1	-2.3	-3	1.6	1460.1	10.6	0.1	-4.675	1
45712	2025	2	24	3	1	-2.2	-3	2	1456.4	10.6	-0.2	-4.075	1
45712	2025	2	24	4	1	-2.0	-3	1.8	1479.8	10.6	-0.6	-3.36667	1
45712	2025	2	24	5	1	-1.8	-5.2	1.4	1520.8	10.6	-1.0	-2.60833	1
45712	2025	2	24	6	1	-1.8	-5.6	0	1609.8	10.6	-1.6	-1.9	1

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLag	Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLag	Weekdays
45712	2025	2	24	12	1	-1.5	0.1	-2.3	1519.1	10.6	-3.6	0.533333	1
45712	2025	2	24	13	1	-1.6	1.2	-3	1473.2	10.6	-3.5	0.383333	1
45712	2025	2	24	14	1	-1.5	2.3	-3	1431.8	10.6	-3.2	0.108333	1
45712	2025	2	24	15	1	-1.5	1.2	-3	1400.6	10.6	-2.8	-0.225	1
45712	2025	2	24	16	1	-1.5	2	-5.2	1414.0	10.6	-2.4	-0.60833	1
45712	2025	2	24	17	1	-1.5	1.3	-5.6	1491.9	10.6	-2.0	-1.025	1
45712	2025	2	24	18	1	-1.5	0.4	-5.8	1617.4	10.6	-1.5	-1.60833	1
45712	2025	2	24	19	1	-1.6	-1.1	-5.6	1705.0	10.6	-1.0	-2.19167	1
45712	2025	2	24	20	1	-1.6	-1.4	-5	1703.2	10.6	-0.6	-2.675	1
45712	2025	2	24	21	1	-1.7	-1.2	-2.7	1671.4	10.6	-0.2	-3.15	1
45712	2025	2	24	22	1	-1.7	-0.9	-0.8	1608.0	10.6	0.1	-3.59167	1
45712	2025	2	24	23	1	-1.7	-0.8	0.1	1528.2	10.6	0.3	-3.68333	1
45712	2025	2	24	24	1	-1.7	-0.7	1.2	1504.8	10.6	0.3	-3.625	1
45713	2025	2	25	1	2	-1.7	-0.6	2.3	1465.5	13.7	0.2	-3.49167	1
45713	2025	2	25	2	2	-1.6	-0.3	1.2	1427.7	13.7	0.0	-3.2	1
45713	2025	2	25	3	2	-1.5	-0.1	2	1393.5	13.7	-0.2	-2.75833	1
45713	2025	2	25	4	2	-1.3	0.3	1.3	1379.4	13.7	-0.3	-2.40833	1
45713	2025	2	25	5	2	-1.2	0.6	0.4	1383.6	13.7	-0.4	-1.99167	1
45713	2025	2	25	6	2	-1.0	0.9	-1.1	1428.5	13.7	-0.5	-1.45	1
45713	2025	2	25	7	2	-0.7	1	-1.4	1545.8	13.7	-0.4	-0.95	1
45713	2025	2	25	8	2	-0.4	1.4	-1.2	1631.9	13.7	-0.3	-0.55833	1
45713	2025	2	25	9	2	-0.1	1.7	-0.9	1609.8	13.7	0.0	-0.20833	1
45713	2025	2	25	10	2	0.2	2	-0.8	1520.3	13.7	0.2	0.108333	1
45713	2025	2	25	11	2	0.4	5.1	-0.7	1421.6	13.7	0.5	0.258333	1
45713	2025	2	25	12	2	0.6	5.7	-0.6	1367.0	13.7	0.9	0.258333	1
45713	2025	2	25	13	2	0.8	6.4	-0.3	1318.0	13.7	1.5	0.191667	1
45713	2025	2	25	14	2	1.1	7.3	-0.1	1275.2	13.7	2.1	0.041667	1
45713	2025	2	25	15	2	1.3	7	0.3	1249.9	13.7	2.7	-0.175	1
45713	2025	2	25	16	2	1.5	7.2	0.6	1280.5	13.7	3.3	-0.28333	1
45713	2025	2	25	17	2	1.7	5	0.9	1363.5	13.7	3.9	-0.425	1
45713	2025	2	25	18	2	1.9	3.4	1	1463.4	13.7	4.2	-0.48333	1
45713	2025	2	25	19	2	2.0	3.1	1.4	1530.1	13.7	4.4	-0.44167	1
45713	2025	2	25	20	2	2.2	2.2	1.7	1520.3	13.7	4.6	-0.26667	1
45713	2025	2	25	21	2	2.3	2.3	2	1485.6	13.7	4.7	-0.03333	1
45713	2025	2	25	22	2	2.5	2.5	5.1	1430.6	13.7	4.7	0.208333	1
45713	2025	2	25	23	2	2.6	2.5	5.7	1352.4	13.7	4.8	0.45	1
45713	2025	2	25	24	2	2.7	3.3	6.4	1313.6	13.7	4.6	0.941667	1
45714	2025	2	26	1	3	2.9	2.5	7.3	1267.2	10.8	4.4	1.475	1
45714	2025	2	26	2	3	3.0	2.6	7	1221.2	10.8	4.0	2.058333	1
45714	2025	2	26	3	3	3.2	1.9	7.2	1193.8	10.8	3.6	2.691667	1
45714	2025	2	26	4	3	3.2	1.8	5	1196.9	10.8	3.2	3.283333	1
45714	2025	2	26	5	3	3.3	1.9	3.4	1213.4	10.8	2.8	3.858333	1
45714	2025	2	26	6	3	3.4	2	3.1	1280.2	10.8	2.5	4.225	1
45714	2025	2	26	7	3	3.4	1.7	2.2	1412.6	10.8	2.4	4.433333	1
45714	2025	2	26	8	3	3.4	1.4	2.3	1516.0	10.8	2.3	4.608333	1
45714	2025	2	26	9	3	3.4	1.5	2.5	1540.0	10.8	2.2	4.675	1
45714	2025	2	26	10	3	3.4	1.5	2.5	1512.7	10.8	2.1	4.725	1
45714	2025	2	26	11	3	3.4	2.3	3.3	1488.3	10.8	2.1	4.766667	1
45714	2025	2	26	12	3	3.3	2.9	2.5	1456.7	10.8	2.0	4.55	1
45714	2025	2	26	13	3	3.2	3.7	2.6	1416.7	10.8	2.0	4.35	1
45714	2025	2	26	14	3	3.1	6.5	1.9	1409.5	10.8	2.1	4.025	1
45714	2025	2	26	15	3	3.0	5.5	1.8	1425.1	10.8	2.4	3.633333	1
45714	2025	2	26	16	3	3.0	5.1	1.9	1469.1	10.8	2.7	3.208333	1
45714	2025	2	26	17	3	2.9	4.4	2	1540.5	10.8	3.0	2.758333	1
45714	2025	2	26	18	3	2.9	4	1.7	1595.0	10.8	3.2	2.5	1
45714	2025	2	26	19	3	2.9	3.6	1.4	1616.5	10.8	3.4	2.383333	1
45714	2025	2	26	20	3	2.9	3.8	1.5	1594.1	10.8	3.5	2.266667	1
45714	2025	2	26	21	3	3.0	3.2	1.5	1561.9	10.8	3.7	2.2	1
45714	2025	2	26	22	3	3.0	2.5	2.3	1509.5	10.8	3.9	2.133333	1
45714	2025	2	26	23	3	3.0	2.2	2.9	1439.3	10.8	4.0	2.05	1
45714	2025	2	26	24	3	3.0	1.8	3.7	1411.7	10.8	4.0	2.033333	1
45715	2025	2	27	1	4	2.9	1.3	6.5	1381.6	16.1	3.9	2	1
45715	2025	2	27	2	4	2.9	0.8	5.5	1355.9	16.1	3.7	2.1	1
45715	2025	2	27	3	4	2.8	0.5	5.1	1332.8	16.1	3.2	2.425	1
45715	2025	2	27	4	4	2.7	0.1	4.4	1330.2	16.1	2.8	2.725	1
45715	2025	2	27	5	4	2.7	-0.7	4	1357.5	16.1	2.4	3	1
45715	2025	2	27	6	4	2.6	-1.8	3.6	1435.6	16.1	1.9	3.208333	1
45715	2025	2	27	7	4	2.4	-2.6	3.8	1590.5	16.1	1.4	3.375	1
45715	2025	2	27	8	4	2.2	-3	3.2	1666.5	16.1	0.9	3.533333	1
45715	2025	2	27	9	4	2.0	-2	2.5	1598.2	16.1	0.4	3.733333	1
45715	2025	2	27	10	4	1.9	-0.5	2.2	1497.9	16.1	-0.1	3.875	1
45715	2025	2	27	11	4	1.8	0.8	1.8	1422.5	16.1	-0.3	3.958333	1
45715	2025	2	27	12	4	1.8	1.7	1.3	1375.9	16.1	-0.4	3.95	1
45715	2025	2	27	13	4	1.7	2.3	0.8	1345.0	16.1	-0.5	3.858333	1
45715	2025	2	27	14	4	1.6	1.4	0.5	1356.8	16.1	-0.4	3.658333	1
45715	2025	2	27	15	4	1.4	0	0.1	1405.9	16.1	-0.3	3.183333	1
45715	2025	2	27	16	4	1.2	0.1	-0.7	1476.3	16.1	-0.4	2.766667	1
45715	2025	2	27	17	4	1.0	0.1	-1.8	1573.5	16.1	-0.4	2.35	1
45715	2025	2	27	18	4	0.8	-1.1	-2.6	1651.7	16.1	-0.3	1.925	1
45715	2025	2	27	19	4	0.6	-0.3	-3	1681.2	16.1	-0.2	1.441667	1
45715	2025	2	27	20	4	0.4	1.2	-2	1657.9	16.1	0.0	0.925	1
45715	2025	2	27	21	4	0.3	2.4	-0.5	1601.9	16.1	0.3	0.358333	1
45715	2025	2	27	22	4	0.3	3.8	0.8	1512.6	16.1	0.7	-0.075	1
45715	2025	2	27	23	4	0.4	5.1	1.7	1405.5	16.1	1.0	-0.325	1
45715	2025	2	27	24	4	0.5	5.9	2.3	1334.8	16.1	1.4	-0.44167	1
45716	2025	2	28	1	5	0.6	6.4	1.4	1274.0	17.8	1.7	-0.45	1
45716	2025	2	28	2	5	0.9	6.5	0	1217.0	17.8	2.1	-0.36667	1
45716	2025	2	28	3	5	1.1	6.4	0.1	1177.3	17.8	2.5	-0.31667	1
45716	2025	2	28	4	5	1.3	5.6	0.1	1164.1	17.8	3.0	-0.35833	1
45716	2025	2	28	5	5	1.6	4.7	-1.1	1179.5	17.8	3.5	-0.35833	1
45716	2025	2	28	6	5	1.8	4.4	-0.3	1229.7	17.8	3.9	-0.29167	1
45716	2025	2	28	7	5	2.1	4.4	1.2	1339.7	17.8	4.3	-0.23333	1
45716	2025	2	28	8	5	2.3	4.2	2.4	1450.5	17.8	4.7	-0.04167	1
45716	2025	2	28	9	5	2.6	3.4	3.8	1489.7	17.8	5.0	0.308333	1
45716	2025	2	28	10	5	2.9	3.7	5.1	1487.4	17.8	5.1	0.675	1
45716	2025	2	28	11	5	3.0	3.9	5.9	1455.7	17.8	5.1	1.033333	1
45716	2025	2	28	12	5	3.2	4.8	6.4	1413.0	17.8	5.0	1.391667	1
45716	2025	2	28	13	5	3.3	6	6.5	1374.6	17.8	4.9	1.741667	1
45716	2025	2	28	14	5	3.5	6.1	6.4	1311.2	17.8	4.8	2.083333	1
45716	2025	2	28	15	5	3.7	7.2	5.6	1282.4	17.8	4.8	2.508333	1
45716	2025	2	28	16	5	4.0	7.6	4.7	1294.5	17.8	4.9	3.041667	1
45716	2025	2	28	17	5	4.3	7.8	4.4	1349.8	17.8	5.0	3.5	1
45716	2025	2	28	18									

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLag	Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLag	Weekdays	
45716	2025	2	28	24		5	4.7	-2.3	6	1484.6	17.8	4.5	4.958333	1
45717	2025	3	1	1	1	6	4.4	-2.7	6.1	1474.1	19.4	3.9	4.866667	0
45717	2025	3	1	2	6	6	4.0	-3.3	7.2	1449.9	19.4	3.2	4.833333	0
45717	2025	3	1	3	6	6	3.6	-3.7	7.6	1438.6	19.4	2.4	4.8	0
45717	2025	3	1	4	6	6	3.2	-4.2	7.8	1440.6	19.4	1.5	4.866667	0
45717	2025	3	1	5	6	6	2.8	-4.4	6.5	1452.8	19.4	0.5	5.033333	0
45717	2025	3	1	6	6	6	2.4	-4.9	5	1485.1	19.4	-0.5	5.291667	0
45717	2025	3	1	7	6	6	2.0	-5.1	3.6	1539.7	19.4	-1.5	5.466667	0
45717	2025	3	1	8	6	6	1.6	-5	1	1604.1	19.4	-2.3	5.516667	0
45717	2025	3	1	9	6	6	1.2	-2.4	-0.4	1631.5	19.4	-3.0	5.466667	0
45717	2025	3	1	10	6	6	1.0	-0.9	-1.5	1571.0	19.4	-3.3	5.266667	0
45717	2025	3	1	11	6	6	0.8	0.3	-2.3	1519.8	19.4	-3.4	4.925	0
45717	2025	3	1	12	6	6	0.6	0.6	-2.7	1491.1	19.4	-3.2	4.475	0
45717	2025	3	1	13	6	6	0.5	2	-3.3	1462.6	19.4	-3.0	3.883333	0
45717	2025	3	1	14	6	6	0.3	2	-3.7	1423.3	19.4	-2.6	3.158333	0
45717	2025	3	1	15	6	6	0.1	2.1	-4.2	1368.5	19.4	-2.1	2.375	0
45717	2025	3	1	16	6	6	-0.1	2.7	-4.4	1362.3	19.4	-1.7	1.466667	0
45717	2025	3	1	17	6	6	-0.3	2.7	-4.9	1424.0	19.4	-1.1	0.483333	0
45717	2025	3	1	18	6	6	-0.5	2.1	-5.1	1522.0	19.4	-0.5	-0.53333	0
45717	2025	3	1	19	6	6	-0.7	2.1	-5	1557.2	19.4	0.1	-1.48333	0
45717	2025	3	1	20	6	6	-0.8	2.4	-2.4	1528.0	19.4	0.7	-2.325	0
45717	2025	3	1	21	6	6	-0.9	2.7	-0.9	1475.3	19.4	1.3	-3.04167	0
45717	2025	3	1	22	6	6	-0.8	3.4	0.3	1405.8	19.4	1.7	-3.325	0
45717	2025	3	1	23	6	6	-0.6	4.4	0.6	1326.5	19.4	2.1	-3.36667	0
45717	2025	3	1	24	6	6	-0.4	3.6	2	1253.7	19.4	2.4	-3.21667	0
45718	2025	3	2	1	7	7	-0.1	3.7	2	1189.4	27.7	2.7	-2.975	0
45718	2025	3	2	2	7	7	0.1	5.6	2.1	1147.3	27.7	2.8	-2.58333	0
45718	2025	3	2	3	7	7	0.5	5.2	2.7	1128.3	27.7	3.1	-2.14167	0
45718	2025	3	2	4	7	7	0.9	4.1	2.7	1134.5	27.7	3.4	-1.65833	0
45718	2025	3	2	5	7	7	1.2	3.8	2.1	1154.8	27.7	3.5	-1.08333	0
45718	2025	3	2	6	7	7	1.6	2.7	2.1	1191.6	27.7	3.6	-0.49167	0
45718	2025	3	2	7	7	7	1.9	2.8	2.4	1252.4	27.7	3.6	0.091667	0
45718	2025	3	2	8	7	7	2.2	2.8	2.7	1333.6	27.7	3.7	0.691667	0
45718	2025	3	2	9	7	7	2.5	1.5	3.4	1442.8	27.7	3.7	1.308333	0
45718	2025	3	2	10	7	7	2.7	0.8	4.4	1516.3	27.7	3.6	1.733333	0
45718	2025	3	2	11	7	7	2.8	1	3.6	1540.0	27.7	3.4	2.091667	0
45718	2025	3	2	12	7	7	2.8	0.2	3.7	1543.1	27.7	3.1	2.433333	0
45718	2025	3	2	13	7	7	2.8	0	5.6	1519.8	27.7	2.9	2.683333	0
45718	2025	3	2	14	7	7	2.7	0.9	5.2	1476.1	27.7	2.5	2.825	0
45718	2025	3	2	15	7	7	2.6	-0.1	4.1	1481.6	27.7	2.2	3.125	0
45718	2025	3	2	16	7	7	2.5	-1.6	3.8	1518.4	27.7	1.7	3.383333	0
45718	2025	3	2	17	7	7	2.4	-2.4	2.7	1625.1	27.7	1.2	3.5	0
45718	2025	3	2	18	7	7	2.2	-3.7	2.8	1730.8	27.7	0.7	3.591667	0
45718	2025	3	2	19	7	7	1.9	-4.4	2.8	1800.9	27.7	0.2	3.641667	0
45718	2025	3	2	20	7	7	1.6	-4.7	1.5	1815.4	27.7	-0.4	3.7	0
45718	2025	3	2	21	7	7	1.3	-5.3	0.8	1796.4	27.7	-1.0	3.733333	0
45718	2025	3	2	22	7	7	1.0	-5.8	1	1740.5	27.7	-1.6	3.633333	0
45718	2025	3	2	23	7	7	0.6	-5.9	0.2	1659.7	27.7	-2.2	3.416667	0
45718	2025	3	2	24	7	7	0.2	-6.1	0	1601.6	27.7	-2.7	3.133333	0
45719	2025	3	3	1	1	1	-0.2	-7.1	0.9	1564.5	22.5	-3.3	2.85	1
45719	2025	3	3	2	1	1	-0.7	-7.5	-0.1	1558.6	22.5	-3.9	2.541667	1
45719	2025	3	3	3	1	1	-1.2	-8.3	-1.6	1571.6	22.5	-4.6	2.15	1
45719	2025	3	3	4	1	1	-1.8	-9	-2.4	1600.8	22.5	-5.2	1.708333	1
45719	2025	3	3	5	1	1	-2.3	-9.4	-3.7	1635.2	22.5	-5.9	1.233333	1
45719	2025	3	3	6	1	1	-2.9	-9.8	-4.4	1720.6	22.5	-6.4	0.716667	1
45719	2025	3	3	7	1	1	-3.4	-10.3	-4.7	1873.0	22.5	-6.9	0.183333	1
45719	2025	3	3	8	1	1	-3.9	-10.7	-5.3	1967.9	22.5	-7.4	-0.41667	1
45719	2025	3	3	9	1	1	-4.5	-10.5	-5.8	1936.5	22.5	-7.9	-1.04167	1
45719	2025	3	3	10	1	1	-5.0	-9.3	-5.9	1842.2	22.5	-8.4	-1.60833	1
45719	2025	3	3	11	1	1	-5.4	-8.7	-6.1	1769.4	22.5	-8.7	-2.15833	1
45719	2025	3	3	12	1	1	-5.8	-7	-7.1	1719.9	22.5	-8.9	-2.73333	1
45719	2025	3	3	13	1	1	-6.1	-5.5	-7.5	1687.8	22.5	-9.0	-3.25833	1
45719	2025	3	3	14	1	1	-6.3	-5.5	-8.3	1625.9	22.5	-8.8	-3.85	1
45719	2025	3	3	15	1	1	-6.6	-4.1	-9	1584.9	22.5	-8.7	-4.55	1
45719	2025	3	3	16	1	1	-6.8	-3.6	-9.4	1595.0	22.5	-8.3	-5.23333	1
45719	2025	3	3	17	1	1	-6.9	-4.1	-9.8	1675.0	22.5	-7.9	-5.85	1
45719	2025	3	3	18	1	1	-6.9	-4.2	-10.3	1793.1	22.5	-7.4	-6.43333	1
45719	2025	3	3	19	1	1	-7.0	-5.9	-10.7	1885.5	22.5	-7.0	-6.94167	1
45719	2025	3	3	20	1	1	-7.0	-7.4	-10.5	1922.0	22.5	-6.6	-7.43333	1
45719	2025	3	3	21	1	1	-7.1	-8.1	-9.3	1901.7	22.5	-6.3	-7.93333	1
45719	2025	3	3	22	1	1	-7.2	-8.4	-8.7	1850.3	22.5	-6.1	-8.36667	1
45719	2025	3	3	23	1	1	-7.4	-8.5	-7	1785.3	22.5	-6.0	-8.65833	1
45719	2025	3	3	24	1	1	-7.5	-8.7	-5.5	1770.5	22.5	-6.0	-8.89167	1
45720	2025	3	4	1	2	2	-7.6	-9.2	-5.5	1756.2	17.4	-6.2	-8.96667	1
45720	2025	3	4	2	2	2	-7.7	-9.5	-4.1	1744.7	17.4	-6.5	-8.83333	1
45720	2025	3	4	3	2	2	-7.7	-10.1	-3.6	1736.2	17.4	-6.8	-8.66667	1
45720	2025	3	4	4	2	2	-7.8	-9.7	-4.1	1739.8	17.4	-7.3	-8.31667	1
45720	2025	3	4	5	2	2	-7.8	-9.6	-4.2	1764.8	17.4	-7.8	-7.86667	1
45720	2025	3	4	6	2	2	-7.9	-10	-5.9	1841.6	17.4	-8.3	-7.425	1
45720	2025	3	4	7	2	2	-7.9	-10.1	-7.4	1982.1	17.4	-8.8	-6.95833	1
45720	2025	3	4	8	2	2	-7.9	-11.7	-8.1	2049.0	17.4	-9.1	-6.59167	1
45720	2025	3	4	9	2	2	-7.9	-7.9	-8.4	1948.8	17.4	-9.5	-6.31667	1
45720	2025	3	4	10	2	2	-7.8	-5.9	-8.5	1804.4	17.4	-9.5	-6.11667	1
45720	2025	3	4	11	2	2	-7.6	-4.6	-8.7	1700.6	17.4	-9.2	-6.04167	1
45720	2025	3	4	12	2	2	-7.5	-3.2	-9.2	1646.2	17.4	-8.9	-6.025	1
45720	2025	3	4	13	2	2	-7.3	-1.9	-9.5	1622.4	17.4	-8.5	-6.16667	1
45720	2025	3	4	14	2	2	-7.2	-1.1	-10.1	1572.8	17.4	-7.9	-6.475	1
45720	2025	3	4	15	2	2	-7.0	-0.3	-9.7	1509.1	17.4	-7.2	-6.80833	1
45720	2025	3	4	16	2	2	-6.8	-0.2	-9.6	1518.1	17.4	-6.3	-7.30833	1
45720	2025	3	4	17	2	2	-6.7	0.4	-10	1606.3	17.4	-5.5	-7.81667	1
45720	2025	3	4	18	2	2	-6.5	-0.1	-10.1	1708.6	17.4	-4.7	-8.275	1
45720	2025	3	4	19	2	2	-6.3	0.1	-11.7	1749.4	17.4	-3.9	-8.75833	1
45720	2025	3	4	20	2	2	-6.1	0.1	-7.9	1734.7	17.4	-3.0	-9.10833	1
45720	2025	3	4	21	2	2	-5.8	0.3	-5.9	1684.3	17.4	-2.1	-9.46667	1
45720	2025	3	4	22	2	2	-5.4	0.8	-4.6	1605.2	17.4	-1.4	-9.45	1
45720	2025	3	4	23	2	2	-5.0	1.5	-3.2	1514.5	17.4	-0.8	-9.24167	1
45720	2025	3	4	24	2	2	-4.6	1	-1.9	1471.4	17.4	-0.3	-8.91667	1
45721	2025	3	5	1	3	3	-4.2	1	-1.1	1429.3	9.7			

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLag	Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLag	Weekdays
45721	2025	3	5	12	3	0.6	3.5	1	1518.0	9.7	1.5	-0.3	1
45721	2025	3	5	13	3	0.9	4.8	1	1484.8	9.7	1.7	0.05	1
45721	2025	3	5	14	3	1.2	5.6	1.1	1467.5	9.7	2.0	0.291667	1
45721	2025	3	5	15	3	1.4	4.9	1.1	1458.1	9.7	2.4	0.466667	1
45721	2025	3	5	16	3	1.7	5.1	1.4	1480.9	9.7	2.7	0.583333	1
45721	2025	3	5	17	3	1.9	3.1	1.5	1540.4	9.7	3.1	0.691667	1
45721	2025	3	5	18	3	2.0	2.5	1.5	1598.6	9.7	3.2	0.775	1
45721	2025	3	5	19	3	2.1	3	1.5	1607.7	9.7	3.3	0.908333	1
45721	2025	3	5	20	3	2.2	3.8	1.9	1573.9	9.7	3.4	1.025	1
45721	2025	3	5	21	3	2.4	3.6	2.2	1520.3	9.7	3.6	1.141667	1
45721	2025	3	5	22	3	2.5	2.8	2.7	1448.9	9.7	3.7	1.275	1
45721	2025	3	5	23	3	2.6	2.7	3.5	1354.4	9.7	3.8	1.391667	1
45721	2025	3	5	24	3	2.6	2.2	4.8	1306.0	9.7	3.8	1.491667	1
45722	2025	3	6	1	4	2.7	2.4	5.6	1254.8	25.8	3.7	1.7	1
45722	2025	3	6	2	4	2.7	4.3	4.9	1205.9	25.8	3.5	2.016667	1
45722	2025	3	6	3	4	2.9	4.9	5.1	1167.3	25.8	3.4	2.4	1
45722	2025	3	6	4	4	3.0	4.5	3.1	1149.5	25.8	3.4	2.716667	1
45722	2025	3	6	5	4	3.2	4.9	2.5	1150.6	25.8	3.3	3.05	1
45722	2025	3	6	6	4	3.3	4.5	3	1189.7	25.8	3.5	3.191667	1
45722	2025	3	6	7	4	3.5	5.8	3.8	1289.1	25.8	3.6	3.275	1
45722	2025	3	6	8	4	3.6	5.1	3.6	1381.3	25.8	3.9	3.4	1
45722	2025	3	6	9	4	3.8	4.7	2.8	1399.4	25.8	4.0	3.591667	1
45722	2025	3	6	10	4	3.9	5.7	2.7	1375.2	25.8	4.1	3.733333	1
45722	2025	3	6	11	4	4.0	5.3	2.2	1341.9	25.8	4.3	3.783333	1
45722	2025	3	6	12	4	4.2	5.2	2.4	1325.5	25.8	4.5	3.783333	1
45722	2025	3	6	13	4	4.2	6.4	4.3	1329.1	25.8	4.8	3.675	1
45722	2025	3	6	14	4	4.3	6.1	4.9	1328.3	25.8	5.1	3.475	1
45722	2025	3	6	15	4	4.3	6.4	4.5	1327.4	25.8	5.3	3.366667	1
45722	2025	3	6	16	4	4.4	6.5	4.9	1341.2	25.8	5.4	3.366667	1
45722	2025	3	6	17	4	4.4	6.3	4.5	1390.3	25.8	5.6	3.316667	1
45722	2025	3	6	18	4	4.6	6.2	5.8	1439.1	25.8	5.7	3.466667	1
45722	2025	3	6	19	4	4.7	6	5.1	1446.4	25.8	5.8	3.633333	1
45722	2025	3	6	20	4	4.8	6.3	4.7	1413.8	25.8	5.8	3.866667	1
45722	2025	3	6	21	4	5.0	5.9	5.7	1368.5	25.8	5.9	3.975	1
45722	2025	3	6	22	4	5.0	5.8	5.3	1300.9	25.8	6.0	4.066667	1
45722	2025	3	6	23	4	5.2	6.3	5.2	1222.4	25.8	6.0	4.308333	1
45722	2025	3	6	24	4	5.3	5.9	6.4	1174.0	25.8	6.1	4.525	1
45723	2025	3	7	1	5	5.5	6.4	6.1	1122.8	23.5	6.2	4.775	1
45723	2025	3	7	2	5	5.6	4.8	6.4	1081.3	23.5	6.2	5.108333	1
45723	2025	3	7	3	5	5.7	3.8	6.5	1054.2	23.5	6.1	5.258333	1
45723	2025	3	7	4	5	5.6	3.8	6.3	1043.7	23.5	5.9	5.383333	1
45723	2025	3	7	5	5	5.6	5.4	6.2	1046.7	23.5	5.6	5.55	1
45723	2025	3	7	6	5	5.6	4.9	6	1091.1	23.5	5.6	5.666667	1
45723	2025	3	7	7	5	5.6	5	6.3	1201.3	23.5	5.4	5.808333	1
45723	2025	3	7	8	5	5.6	4.7	5.9	1288.0	23.5	5.4	5.825	1
45723	2025	3	7	9	5	5.6	4.6	5.8	1339.8	23.5	5.2	5.925	1
45723	2025	3	7	10	5	5.6	3.7	6.3	1349.5	23.5	5.1	6.025	1
45723	2025	3	7	11	5	5.5	4.8	5.9	1354.6	23.5	4.9	6.033333	1
45723	2025	3	7	12	5	5.5	4	6.4	1378.6	23.5	4.8	6.116667	1
45723	2025	3	7	13	5	5.4	3.1	4.8	1375.0	23.5	4.7	6.175	1
45723	2025	3	7	14	5	5.3	5.1	3.8	1352.8	23.5	4.4	6.175	1
45723	2025	3	7	15	5	5.2	4.9	3.8	1348.5	23.5	4.4	6.066667	1
45723	2025	3	7	16	5	5.2	4.1	5.4	1382.8	23.5	4.5	5.85	1
45723	2025	3	7	17	5	5.1	3	4.9	1470.3	23.5	4.5	5.625	1
45723	2025	3	7	18	5	4.9	1.5	5	1545.0	23.5	4.3	5.55	1
45723	2025	3	7	19	5	4.7	0.3	4.7	1576.8	23.5	4.0	5.441667	1
45723	2025	3	7	20	5	4.5	-0.6	4.6	1576.9	23.5	3.7	5.358333	1
45723	2025	3	7	21	5	4.2	-1.5	3.7	1564.1	23.5	3.2	5.225	1
45723	2025	3	7	22	5	3.9	-1.9	4.8	1538.2	23.5	2.7	5.116667	1
45723	2025	3	7	23	5	3.6	-2.1	4	1490.8	23.5	2.2	4.941667	1
45723	2025	3	7	24	5	3.2	-1.8	3.1	1478.7	23.5	1.7	4.816667	1
45724	2025	3	8	1	6	2.9	-1.7	5.1	1450.5	36.3	1.2	4.658333	0
45724	2025	3	8	2	6	2.6	-1.6	4.9	1425.5	36.3	0.8	4.383333	0
45724	2025	3	8	3	6	2.3	-1.7	4.1	1411.0	36.3	0.2	4.408333	0
45724	2025	3	8	4	6	2.1	-1.7	3	1402.5	36.3	-0.3	4.5	0
45724	2025	3	8	5	6	1.9	-1.3	1.5	1409.3	36.3	-0.8	4.525	0
45724	2025	3	8	6	6	1.6	-1.2	0.3	1443.3	36.3	-1.2	4.325	0
45724	2025	3	8	7	6	1.3	-1.2	-0.6	1495.1	36.3	-1.4	4.041667	0
45724	2025	3	8	8	6	1.1	-1.3	-1.5	1562.3	36.3	-1.5	3.65	0
45724	2025	3	8	9	6	0.8	-1.2	-1.9	1599.3	36.3	-1.6	3.208333	0
45724	2025	3	8	10	6	0.6	-0.5	-2.1	1600.4	36.3	-1.6	2.7	0
45724	2025	3	8	11	6	0.4	0.5	-1.8	1615.5	36.3	-1.4	2.233333	0
45724	2025	3	8	12	6	0.2	1.4	-1.7	1594.3	36.3	-1.2	1.658333	0
45724	2025	3	8	13	6	0.1	1.3	-1.6	1566.2	36.3	-1.0	1.175	0
45724	2025	3	8	14	6	0.0	1.8	-1.7	1528.2	36.3	-0.7	0.775	0
45724	2025	3	8	15	6	-0.1	1.8	-1.7	1497.4	36.3	-0.4	0.216667	0
45724	2025	3	8	16	6	-0.2	1.7	-1.3	1490.6	36.3	-0.1	-0.333333	0
45724	2025	3	8	17	6	-0.3	2.4	-1.2	1535.4	36.3	0.2	-0.81667	0
45724	2025	3	8	18	6	-0.4	1.5	-1.2	1612.8	36.3	0.5	-1.175	0
45724	2025	3	8	19	6	-0.4	0.7	-1.3	1657.0	36.3	0.7	-1.4	0
45724	2025	3	8	20	6	-0.3	0	-1.2	1646.1	36.3	0.8	-1.525	0
45724	2025	3	8	21	6	-0.3	-0.8	-0.5	1615.4	36.3	1.0	-1.58333	0
45724	2025	3	8	22	6	-0.3	-1.5	0.5	1585.5	36.3	1.0	-1.55833	0
45724	2025	3	8	23	6	-0.3	-1.9	1.4	1524.9	36.3	0.9	-1.44167	0
45724	2025	3	8	24	6	-0.3	-3	1.3	1495.0	36.3	0.7	-1.225	0
45725	2025	3	9	1	7	-0.3	-4.1	1.8	1467.8	26.0	0.3	-0.95833	0
45725	2025	3	9	2	7	-0.4	-4.9	1.8	1447.9	26.0	-0.1	-0.70833	0
45725	2025	3	9	3	7	-0.6	-5.2	1.7	1448.2	26.0	-0.7	-0.425	0
45725	2025	3	9	4	7	-0.7	-5.7	2.4	1448.6	26.0	-1.3	-0.13333	0
45725	2025	3	9	5	7	-0.9	-5.9	1.5	1460.0	26.0	-1.9	0.15	0
45725	2025	3	9	6	7	-1.1	-6	0.7	1488.5	26.0	-2.6	0.458333	0
45725	2025	3	9	7	7	-1.3	-5.9	0	1533.5	26.0	-3.2	0.683333	0
45725	2025	3	9	8	7	-1.5	-5.6	-0.8	1589.7	26.0	-3.7	0.841667	0
45725	2025	3	9	9	7	-1.6	-5.3	-1.5	1642.0	26.0	-4.2	0.95	0
45725	2025	3	9	10	7	-1.8	-4.6	-1.9	1678.2	26.0	-4.6	0.983333	0
45725	2025	3	9	11	7	-2.0	-4	-3	1679.7	26.0	-4.8	0.9	0
45725	2025	3	9	12	7	-2.2	-2.6	-4.1	1647.3	26.0	-5.0	0.7	0
45725	2025	3	9	13	7	-2.3	-1.5	-4.9	1592.6	26.0	-5.0	0.333333	0
45725	2025	3	9	14	7	-2.4	-0.2	-5.2	1532.9	26.0	-4.8	-0.11667	0
45725	2025	3	9	15	7	-2.5	0.6	-5.7	1469.6	26.0	-4.4	-0.675	0
45725	2025	3	9	16	7	-2.6	1.4	-5.9	1438.8	26.0	-3.9	-1.25833	0
45725	2025	3	9	17	7	-2.6	1.8	-6	1456.5	26.0	-3.3	-1.875	0
45725	2025	3	9	18	7	-2.6	1.7	-5.9	1501.7	26.0	-2.7	-2.56667	0
45725	2025	3											

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLag	Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLag	Weekdays
45725	2025	3	9	24	7	-2.4	0	-1.5	1433.1	26.0	0.2	-5.01667	0
45726	2025	3	10	1	1	-2.3	-0.2	-0.2	1378.0	15.2	0.4	-4.98333	1
45726	2025	3	10	2	1	-2.1	-0.4	0.6	1349.8	15.2	0.5	-4.76667	1
45726	2025	3	10	3	1	-1.9	-1.4	1.4	1340.2	15.2	0.5	-4.375	1
45726	2025	3	10	4	1	-1.8	-1.3	1.8	1348.5	15.2	0.3	-3.89167	1
45726	2025	3	10	5	1	-1.6	-2	1.7	1371.6	15.2	0.1	-3.3	1
45726	2025	3	10	6	1	-1.4	-2.1	0.4	1443.0	15.2	-0.2	-2.65833	1
45726	2025	3	10	7	1	-1.3	-2.4	0.4	1572.6	15.2	-0.5	-2.01667	1
45726	2025	3	10	8	1	-1.1	-2.7	0.3	1684.2	15.2	-0.8	-1.49167	1
45726	2025	3	10	9	1	-1.0	-1	0.1	1688.4	15.2	-1.0	-0.99167	1
45726	2025	3	10	10	1	-0.8	0.1	0	1600.2	15.2	-1.1	-0.525	1
45726	2025	3	10	11	1	-0.6	1.2	0	1524.8	15.2	-1.1	-0.13333	1
45726	2025	3	10	12	1	-0.4	1.8	-0.2	1502.1	15.2	-1.0	0.2	1
45726	2025	3	10	13	1	-0.2	2	-0.4	1474.2	15.2	-0.9	0.416667	1
45726	2025	3	10	14	1	-0.1	3.3	-1.4	1459.6	15.2	-0.7	0.525	1
45726	2025	3	10	15	1	0.1	2.2	-1.3	1447.0	15.2	-0.4	0.508333	1
45726	2025	3	10	16	1	0.1	2.1	-2	1473.4	15.2	-0.1	0.341667	1
45726	2025	3	10	17	1	0.2	1.2	-2.1	1529.0	15.2	0.2	0.116667	1
45726	2025	3	10	18	1	0.1	0.8	-2.4	1578.7	15.2	0.5	-0.2	1
45726	2025	3	10	19	1	0.1	0.7	-2.7	1570.8	15.2	0.7	-0.51667	1
45726	2025	3	10	20	1	0.1	-0.3	-1	1607.4	15.2	1.0	-0.75	1
45726	2025	3	10	21	1	0.1	-0.7	0.1	1616.0	15.2	1.2	-1.00833	1
45726	2025	3	10	22	1	0.0	-0.9	1.2	1575.8	15.2	1.2	-1.11667	1
45726	2025	3	10	23	1	0.0	-1.2	1.8	1513.1	15.2	1.1	-1.11667	1
45726	2025	3	10	24	1	-0.1	-1.5	2	1475.9	15.2	0.9	-1.01667	1
45727	2025	3	11	1	2	-0.1	-2.9	3.3	1471.7	15.0	0.6	-0.86667	1
45727	2025	3	11	2	2	-0.2	-2.1	2.2	1464.8	15.0	0.2	-0.68333	1
45727	2025	3	11	3	2	-0.3	-3	2.1	1456.4	15.0	-0.2	-0.375	1
45727	2025	3	11	4	2	-0.4	-3.4	1.2	1460.5	15.0	-0.7	-0.075	1
45727	2025	3	11	5	2	-0.5	-4.4	0.8	1488.3	15.0	-1.1	0.208333	1
45727	2025	3	11	6	2	-0.6	-4.5	0.7	1557.6	15.0	-1.6	0.475	1
45727	2025	3	11	7	2	-0.7	-5.1	-0.3	1668.7	15.0	-2.0	0.716667	1
45727	2025	3	11	8	2	-0.8	-5.5	-0.7	1770.4	15.0	-2.5	0.975	1
45727	2025	3	11	9	2	-0.9	-2.1	-0.9	1760.3	15.0	-2.9	1.175	1
45727	2025	3	11	10	2	-0.9	-0.5	-1.2	1661.3	15.0	-3.1	1.2	1
45727	2025	3	11	11	2	-1.0	-0.1	-1.5	1559.7	15.0	-3.0	1.116667	1
45727	2025	3	11	12	2	-1.0	1.5	-2.9	1481.3	15.0	-2.9	0.916667	1
45727	2025	3	11	13	2	-1.0	1.5	-2.1	1420.8	15.0	-2.7	0.641667	1
45727	2025	3	11	14	2	-1.0	1.6	-3	1404.2	15.0	-2.3	0.233333	1
45727	2025	3	11	15	2	-1.1	2.6	-3.4	1335.6	15.0	-2.0	-0.21667	1
45727	2025	3	11	16	2	-1.1	2.8	-4.4	1298.5	15.0	-1.5	-0.65	1
45727	2025	3	11	17	2	-1.1	2.6	-4.5	1329.2	15.0	-1.0	-1.10833	1
45727	2025	3	11	18	2	-1.0	1.5	-5.1	1385.7	15.0	-0.4	-1.575	1
45727	2025	3	11	19	2	-1.0	1.2	-5.5	1437.1	15.0	0.1	-2.01667	1
45727	2025	3	11	20	2	-1.0	1.2	-2.1	1493.3	15.0	0.6	-2.5	1
45727	2025	3	11	21	2	-0.9	1.2	-0.5	1505.9	15.0	1.2	-2.93333	1
45727	2025	3	11	22	2	-0.8	1.5	-0.1	1451.5	15.0	1.4	-3.05	1
45727	2025	3	11	23	2	-0.7	1.3	1.5	1367.2	15.0	1.6	-3.01667	1
45727	2025	3	11	24	2	-0.6	1.6	1.5	1314.4	15.0	1.7	-2.925	1
45728	2025	3	12	1	3	-0.5	2.5	1.6	1282.0	15.0	1.7	-2.675	1
45728	2025	3	12	2	3	-0.3	3	2.6	1250.8	15.0	1.8	-2.30833	1
45728	2025	3	12	3	3	0.0	3.2	2.8	1206.8	15.0	1.9	-2	1
45728	2025	3	12	4	3	0.2	3.9	2.6	1177.5	15.0	2.0	-1.53333	1
45728	2025	3	12	5	3	0.5	3.9	1.5	1169.1	15.0	2.1	-1.01667	1
45728	2025	3	12	6	3	0.9	4.4	1.2	1211.9	15.0	2.2	-0.43333	1
45728	2025	3	12	7	3	1.2	4.4	1.2	1313.6	15.0	2.4	0.066667	1
45728	2025	3	12	8	3	1.6	4.6	1.2	1390.2	15.0	2.7	0.591667	1
45728	2025	3	12	9	3	2.1	4.5	1.5	1415.6	15.0	3.0	1.15	1
45728	2025	3	12	10	3	2.3	7.1	1.3	1403.5	15.0	3.2	1.425	1
45728	2025	3	12	11	3	2.6	7.3	1.6	1367.7	15.0	3.7	1.591667	1
45728	2025	3	12	12	3	3.0	7.1	2.5	1366.5	15.0	4.2	1.708333	1
45728	2025	3	12	13	3	3.2	5.9	3	1348.6	15.0	4.7	1.716667	1
45728	2025	3	12	14	3	3.4	6.6	3.2	1307.8	15.0	4.9	1.8	1
45728	2025	3	12	15	3	3.6	7.2	3.9	1257.3	15.0	5.2	1.916667	1
45728	2025	3	12	16	3	3.8	7.1	3.9	1244.3	15.0	5.6	1.966667	1
45728	2025	3	12	17	3	4.0	6.7	4.4	1280.8	15.0	5.8	2.058333	1
45728	2025	3	12	18	3	4.1	5.1	4.4	1332.5	15.0	6.1	2.166667	1
45728	2025	3	12	19	3	4.3	3.5	4.6	1375.6	15.0	6.1	2.408333	1
45728	2025	3	12	20	3	4.4	1.9	4.5	1462.5	15.0	6.1	2.675	1
45728	2025	3	12	21	3	4.4	0	7.1	1505.2	15.0	5.8	2.958333	1
45728	2025	3	12	22	3	4.3	-1.4	7.3	1489.0	15.0	5.5	3.233333	1
45728	2025	3	12	23	3	4.2	-2	7.1	1430.3	15.0	4.8	3.7	1
45728	2025	3	12	24	3	4.1	-2.1	5.9	1398.6	15.0	4.0	4.2	1
45729	2025	3	13	1	4	3.9	-2.6	6.6	1386.7	11.7	3.2	4.658333	1
45729	2025	3	13	2	4	3.7	-3.3	7.2	1379.8	11.7	2.5	4.941667	1
45729	2025	3	13	3	4	3.5	-3.7	7.1	1370.9	11.7	1.7	5.241667	1
45729	2025	3	13	4	4	3.2	-4.6	6.7	1373.7	11.7	0.8	5.575	1
45729	2025	3	13	5	4	2.8	-5.1	5.1	1404.9	11.7	-0.2	5.841667	1
45729	2025	3	13	6	4	2.4	-5.8	3.5	1474.9	11.7	-1.2	6.075	1
45729	2025	3	13	7	4	2.0	-6.6	1.9	1604.3	11.7	-2.1	6.133333	1
45729	2025	3	13	8	4	1.6	-7.1	0	1716.0	11.7	-2.9	6.058333	1
45729	2025	3	13	9	4	1.1	-6.2	-1.4	1728.5	11.7	-3.7	5.833333	1
45729	2025	3	13	10	4	0.6	-4.5	-2	1670.5	11.7	-4.2	5.458333	1
45729	2025	3	13	11	4	0.1	-3.3	-2.1	1590.6	11.7	-4.5	4.75	1
45729	2025	3	13	12	4	-0.3	-1.4	-2.6	1525.9	11.7	-4.6	3.975	1
45729	2025	3	13	13	4	-0.7	0	-3.3	1469.6	11.7	-4.5	3.208333	1
45729	2025	3	13	14	4	-0.9	0.9	-3.7	1414.6	11.7	-4.3	2.5	1
45729	2025	3	13	15	4	-1.1	2.3	-4.6	1354.2	11.7	-4.0	1.675	1
45729	2025	3	13	16	4	-1.3	0.2	-5.1	1326.4	11.7	-3.5	0.766667	1
45729	2025	3	13	17	4	-1.6	0.2	-5.8	1356.1	11.7	-3.1	-0.20833	1
45729	2025	3	13	18	4	-1.9	-0.2	-6.6	1410.9	11.7	-2.6	-1.19167	1
45729	2025	3	13	19	4	-2.1	-1.1	-7.1	1467.4	11.7	-2.1	-2.1	1
45729	2025	3	13	20	4	-2.3	-2.3	-6.2	1557.6	11.7	-1.7	-2.94167	1
45729	2025	3	13	21	4	-2.5	-2.7	-4.5	1591.3	11.7	-1.3	-3.69167	1
45729	2025	3	13	22	4	-2.6	-2.7	-3.3	1560.8	11.7	-1.0	-4.20833	1
45729	2025	3	13	23	4	-2.7	-2.7	-1.4	1507.5	11.7	-0.8	-4.46667	1
45729	2025	3	13	24	4	-2.7	-3.6	0	1467.4	11.7	-0.8	-4.575	1
45730	2025	3	14	1	5	-2.7	-3.8	0.9	1461.9	9.8	-1.0	-4.51667	1
45730	2025	3	14	2	5	-2.8	-4.2	2.3	1462.2	9.8	-1.3	-4.3	1
45730	2025	3	14	3	5	-2.8	-4.5	0.2	1456.1	9.8	-1.7	-3.95	1
45730	2025	3	14	4	5	-2.9	-2.7	0.2	1457.1	9.8	-2.3	-3.45	1
45730	2025	3	14	5	5	-2.8	-3.7	-0.2	1472.3	9.8	-2.5	-3.05	1
45730	2025	3	14	6	5	-2.7	-4.						

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLag	Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLag	Weekdays
45730	2025	3	14	12	5	-1.7	2.4	-3.8	1431.7	9.8	-2.6	-0.79167	1
45730	2025	3	14	13	5	-1.6	2.9	-4.2	1359.7	9.8	-2.1	-0.975	1
45730	2025	3	14	14	5	-1.4	3.1	-4.5	1306.6	9.8	-1.6	-1.29167	1
45730	2025	3	14	15	5	-1.3	3.1	-2.7	1246.1	9.8	-1.0	-1.71667	1
45730	2025	3	14	16	5	-1.3	2.8	-3.7	1220.3	9.8	-0.3	-2.28333	1
45730	2025	3	14	17	5	-1.2	2.6	-4.2	1239.4	9.8	0.1	-2.525	1
45730	2025	3	14	18	5	-1.1	2.2	-4	1278.6	9.8	0.7	-2.85	1
45730	2025	3	14	19	5	-1.0	1.3	-3.2	1305.5	9.8	1.2	-3.18333	1
45730	2025	3	14	20	5	-0.9	0.4	-0.2	1370.9	9.8	1.6	-3.425	1
45730	2025	3	14	21	5	-0.8	0	0.8	1399.8	9.8	1.9	-3.5	1
45730	2025	3	14	22	5	-0.7	-0.4	1.7	1378.0	9.8	1.9	-3.29167	1
45730	2025	3	14	23	5	-0.6	-0.4	2.4	1329.6	9.8	1.8	-3	1
45731	2025	3	15	24	6	-0.5	1.9	2.9	1173.0	8.0	1.7	-2.63333	0
45731	2025	3	15	1	6	-0.3	-0.5	3.1	1298.7	8.0	1.6	-2.13333	0
45731	2025	3	15	2	6	-0.1	0	3.1	1290.6	8.0	1.3	-1.575	0
45731	2025	3	15	3	6	0.1	-1.6	2.8	1277.0	8.0	1.1	-0.96667	0
45731	2025	3	15	4	6	0.2	-1.6	2.6	1273.8	8.0	0.7	-0.33333	0
45731	2025	3	15	5	6	0.2	-2.2	2.2	1283.2	8.0	0.3	0.125	0
45731	2025	3	15	6	6	0.3	-2.4	1.3	1322.1	8.0	-0.1	0.65	0
45731	2025	3	15	7	6	0.4	-2	0.4	1381.2	8.0	-0.5	1.183333	0
45731	2025	3	15	8	6	0.4	-2.4	0	1458.4	8.0	-0.7	1.625	0
45731	2025	3	15	9	6	0.5	0.7	-0.4	1495.1	8.0	-1.0	1.925	0
45731	2025	3	15	10	6	0.5	3.4	-0.4	1471.3	8.0	-0.9	1.941667	0
45731	2025	3	15	11	6	0.6	6.1	1.9	1399.0	8.0	-0.6	1.841667	0
45731	2025	3	15	12	6	0.8	6.3	-0.5	1320.9	8.0	-0.1	1.666667	0
45731	2025	3	15	13	6	1.0	5	0	1254.5	8.0	0.3	1.625	0
45731	2025	3	15	14	6	1.1	6.6	-1.6	1177.7	8.0	0.8	1.341667	0
45731	2025	3	15	15	6	1.2	5.7	-1.6	1128.9	8.0	1.3	1.083333	0
45731	2025	3	15	16	6	1.3	7.7	-2.2	1108.8	8.0	1.9	0.691667	0
45731	2025	3	15	17	6	1.5	6.9	-2.4	1145.1	8.0	2.7	0.325	0
45731	2025	3	15	18	6	1.7	4	-2	1207.6	8.0	3.5	-0.075	0
45731	2025	3	15	19	6	1.8	2.5	-2.4	1222.5	8.0	4.0	-0.45833	0
45731	2025	3	15	20	6	1.8	2.6	0.7	1313.9	8.0	4.4	-0.73333	0
45731	2025	3	15	21	6	1.9	2.2	3.4	1320.2	8.0	4.8	-0.96667	0
45731	2025	3	15	22	6	2.0	2.4	6.1	1282.6	8.0	4.9	-0.90833	0
45731	2025	3	15	23	6	2.1	2.4	6.3	1215.0	8.0	4.8	-0.59167	0
45732	2025	3	16	24	7	2.2	5.5	5	1054.3	10.1	4.5	-0.05	0
45732	2025	3	16	1	7	2.4	1.9	6.6	1131.1	10.1	4.5	0.316667	0
45732	2025	3	16	2	7	2.5	2.4	5.7	1106.6	10.1	4.2	0.775	0
45732	2025	3	16	3	7	2.6	2.2	7.7	1092.5	10.1	3.9	1.325	0
45732	2025	3	16	4	7	2.7	1.9	6.9	1089.9	10.1	3.6	1.933333	0
45732	2025	3	16	5	7	2.9	1.9	4	1099.9	10.1	3.1	2.708333	0
45732	2025	3	16	6	7	3.1	2.7	2.5	1120.5	10.1	2.7	3.466667	0
45732	2025	3	16	7	7	3.3	2.5	2.6	1158.8	10.1	2.6	4	0
45732	2025	3	16	8	7	3.5	2.5	2.2	1216.9	10.1	2.6	4.375	0
45732	2025	3	16	9	7	3.7	2.8	2.4	1290.4	10.1	2.5	4.791667	0
45732	2025	3	16	10	7	3.8	3.5	2.4	1342.3	10.1	2.6	4.916667	0
45732	2025	3	16	11	7	3.8	4.7	5.5	1350.8	10.1	2.7	4.833333	0
45732	2025	3	16	12	7	3.7	5.6	1.9	1340.9	10.1	2.9	4.525	0
45732	2025	3	16	13	7	3.7	7.7	2.4	1314.8	10.1	2.9	4.458333	0
45732	2025	3	16	14	7	3.8	9	2.2	1259.5	10.1	3.4	4.2	0
45732	2025	3	16	15	7	3.9	8.7	1.9	1202.7	10.1	3.9	3.85	0
45732	2025	3	16	16	7	4.0	7.9	1.9	1184.0	10.1	4.5	3.558333	0
45732	2025	3	16	17	7	4.0	7.2	2.7	1224.1	10.1	5.0	3.075	0
45732	2025	3	16	18	7	4.0	6.2	2.5	1254.1	10.1	5.4	2.658333	0
45732	2025	3	16	19	7	4.1	5	2.5	1273.9	10.1	5.7	2.55	0
45732	2025	3	16	20	7	4.2	4.6	2.8	1315.7	10.1	5.9	2.55	0
45732	2025	3	16	21	7	4.3	5.4	3.5	1305.9	10.1	6.1	2.541667	0
45732	2025	3	16	22	7	4.4	5.6	4.7	1233.3	10.1	6.3	2.591667	0
45732	2025	3	16	23	7	4.6	5.3	5.6	1143.0	10.1	6.5	2.683333	0
45733	2025	3	17	24	1	4.7	9.1	7.7	1008.8	19.0	6.5	2.875	1
45733	2025	3	17	1	1	4.8	5.6	9	997.6	19.0	6.8	2.883333	1
45733	2025	3	17	2	1	5.0	5.7	8.7	963.6	19.0	6.6	3.366667	1
45733	2025	3	17	3	1	5.1	6.6	7.9	947.2	19.0	6.4	3.916667	1
45733	2025	3	17	4	1	5.3	7.4	7.2	940.6	19.0	6.2	4.458333	1
45733	2025	3	17	5	1	5.6	7.4	6.2	945.8	19.0	6.1	4.958333	1
45733	2025	3	17	6	1	5.8	5.5	5	1000.7	19.0	6.2	5.4	1
45733	2025	3	17	7	1	5.9	5	4.6	1121.5	19.0	6.1	5.691667	1
45733	2025	3	17	8	1	6.0	5.1	5.4	1232.2	19.0	6.1	5.9	1
45733	2025	3	17	9	1	6.1	6.4	5.6	1259.0	19.0	6.1	6.075	1
45733	2025	3	17	10	1	6.3	8	5.3	1236.4	19.0	6.2	6.291667	1
45733	2025	3	17	11	1	6.4	9.8	9.1	1218.6	19.0	6.4	6.466667	1
45733	2025	3	17	12	1	6.7	10.2	5.6	1203.9	19.0	6.8	6.516667	1
45733	2025	3	17	13	1	6.9	10	5.7	1180.8	19.0	6.9	6.808333	1
45733	2025	3	17	14	1	6.9	10.5	6.6	1152.1	19.0	7.3	6.633333	1
45733	2025	3	17	15	1	7.0	10.8	7.4	1124.9	19.0	7.7	6.358333	1
45733	2025	3	17	16	1	7.1	10.6	7.4	1123.8	19.0	8.0	6.183333	1
45733	2025	3	17	17	1	7.2	9.9	5.5	1160.1	19.0	8.3	6.141667	1
45733	2025	3	17	18	1	7.3	9.3	5	1199.0	19.0	8.5	6.158333	1
45733	2025	3	17	19	1	7.5	10.3	5.1	1199.8	19.0	8.8	6.1	1
45733	2025	3	17	20	1	7.7	10.4	6.4	1226.4	19.0	9.2	6.1	1
45733	2025	3	17	21	1	7.9	11.4	8	1218.3	19.0	9.7	6.141667	1
45733	2025	3	17	22	1	8.2	9.2	9.8	1155.5	19.0	10.1	6.225	1
45733	2025	3	17	23	1	8.3	9.2	10.2	1072.7	19.0	10.2	6.425	1
45734	2025	3	18	24	2	8.5	1.9	10	1268.5	13.6	10.2	6.8	1
45734	2025	3	18	1	2	8.2	8.3	10.5	958.9	13.6	9.5	6.891667	1
45734	2025	3	18	2	2	8.3	7.3	10.8	925.3	13.6	9.3	7.258333	1
45734	2025	3	18	3	2	8.4	7.4	10.6	906.7	13.6	9.1	7.658333	1
45734	2025	3	18	4	2	8.4	9.7	9.9	896.7	13.6	8.8	8.008333	1
45734	2025	3	18	5	2	8.5	8.3	9.3	906.7	13.6	8.7	8.275	1
45734	2025	3	18	6	2	8.5	8.1	10.3	956.3	13.6	8.6	8.483333	1
45734	2025	3	18	7	2	8.6	8.3	10.4	1064.0	13.6	8.5	8.8	1
45734	2025	3	18	8	2	8.8	8.7	11.4	1187.9	13.6	8.3	9.241667	1
45734	2025	3	18	9	2	8.9	8.6	9.2	1243.1	13.6	8.2	9.683333	1
45734	2025	3	18	10	2	9.0	8.6	9.2	1267.6	13.6	7.9	10.1	1
45734	2025	3	18	11	2	9.0	8.2	1.9	1279.1	13.6	7.9	10.2	1
45734	2025	3	18	12	2	9.0	7.8	8.3	1303.2	13.6	7.8	10.15	1
45734	2025	3	18	13	2	8.9	6.3	7.3	1326.0	13.6	8.3	9.458333	1
45734	2025	3	18	14	2	8.7	4.6	7.4	1328.2	13.6	8.1	9.316667	1
45734	2025	3	18	15	2	8.5	3.8	9.7	1332.3	13.6	7.9	9.05	1
45734	2025	3	18	16	2	8.2	3.8	8.3	1371.5	13.6	7.6	8.766667	1
45734	2025	3	18	17	2	7.9	3.7	8.1	1433.6	13.6	7.1	8.691667	1
45734	2025	3	18	18	2	7.6	3.5	8.					

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLag	Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLag	Weekdays
45735	2025	3	19	24	3	5.8	0.3	6.3	1234.8	9.9	3.9	7.783333	1
45735	2025	3	19	1	3	5.8	1.6	4.6	1245.8	9.9	3.3	8.275	1
45735	2025	3	19	2	3	5.5	1.5	3.8	1230.8	9.9	2.9	8.108333	1
45735	2025	3	19	3	3	5.2	1.7	3.8	1211.6	9.9	2.6	7.883333	1
45735	2025	3	19	4	3	5.0	1.5	3.7	1203.5	9.9	2.4	7.583333	1
45735	2025	3	19	5	3	4.7	1.2	3.5	1210.7	9.9	2.2	7.091667	1
45735	2025	3	19	6	3	4.4	1	2.9	1268.7	9.9	2.0	6.708333	1
45735	2025	3	19	7	3	4.1	1.1	2.4	1398.4	9.9	1.8	6.325	1
45735	2025	3	19	8	3	3.8	1.1	2.6	1513.7	9.9	1.7	5.875	1
45735	2025	3	19	9	3	3.5	2.1	3	1527.9	9.9	1.6	5.35	1
45735	2025	3	19	10	3	3.2	3.2	2.1	1497.4	9.9	1.5	4.85	1
45735	2025	3	19	11	3	3.0	3.5	0.3	1457.9	9.9	1.5	4.383333	1
45735	2025	3	19	12	3	2.8	4.8	1.6	1405.8	9.9	1.7	3.875	1
45735	2025	3	19	13	3	2.6	7.4	1.5	1337.8	9.9	2.0	3.25	1
45735	2025	3	19	14	3	2.7	9.5	1.7	1269.6	9.9	2.5	2.858333	1
45735	2025	3	19	15	3	2.9	11.1	1.5	1211.4	9.9	3.2	2.6	1
45735	2025	3	19	16	3	3.2	11.6	1.2	1194.5	9.9	4.0	2.425	1
45735	2025	3	19	17	3	3.5	11	1	1228.0	9.9	4.8	2.233333	1
45735	2025	3	19	18	3	3.8	9	1.1	1272.9	9.9	5.6	2.025	1
45735	2025	3	19	19	3	4.1	7.3	1.1	1298.2	9.9	6.3	1.816667	1
45735	2025	3	19	20	3	4.2	5.1	2.1	1359.4	9.9	6.8	1.666667	1
45735	2025	3	19	21	3	4.3	3.4	3.2	1395.4	9.9	7.1	1.558333	1
45735	2025	3	19	22	3	4.4	1.8	3.5	1360.4	9.9	7.2	1.516667	1
45735	2025	3	19	23	3	4.3	1.2	4.8	1285.3	9.9	7.1	1.533333	1
45736	2025	3	20	24	4	4.3	3.2	7.4	1186.7	13.3	6.9	1.65	1
45736	2025	3	20	1	4	4.4	0.1	9.5	1214.6	13.3	6.8	2.025	1
45736	2025	3	20	2	4	4.4	-0.2	11.1	1207.1	13.3	6.2	2.508333	1
45736	2025	3	20	3	4	4.3	0.3	11.6	1196.3	13.3	5.4	3.175	1
45736	2025	3	20	4	4	4.2	-0.3	11	1199.4	13.3	4.5	3.958333	1
45736	2025	3	20	5	4	4.1	-0.3	9	1219.3	13.3	3.5	4.8	1
45736	2025	3	20	6	4	4.1	-0.3	7.3	1277.0	13.3	2.6	5.616667	1
45736	2025	3	20	7	4	4.0	-0.3	5.1	1409.3	13.3	1.8	6.283333	1
45736	2025	3	20	8	4	4.0	0	3.4	1524.3	13.3	1.1	6.8	1
45736	2025	3	20	9	4	3.9	0.1	1.8	1544.8	13.3	0.7	7.133333	1
45736	2025	3	20	10	4	3.8	0.7	1.2	1501.5	13.3	0.4	7.241667	1
45736	2025	3	20	11	4	3.7	1.6	3.2	1435.4	13.3	0.4	7.125	1
45736	2025	3	20	12	4	3.7	2.1	0.1	1378.3	13.3	0.4	6.933333	1
45736	2025	3	20	13	4	3.5	2.6	-0.2	1333.9	13.3	0.3	6.8	1
45736	2025	3	20	14	4	3.3	2.7	0.3	1288.0	13.3	0.5	6.191667	1
45736	2025	3	20	15	4	3.1	2.7	-0.3	1260.5	13.3	0.7	5.383333	1
45736	2025	3	20	16	4	2.7	2.9	-0.3	1270.9	13.3	0.9	4.483333	1
45736	2025	3	20	17	4	2.4	3.8	-0.3	1308.6	13.3	1.2	3.491667	1
45736	2025	3	20	18	4	2.1	3.6	-0.3	1351.7	13.3	1.6	2.55	1
45736	2025	3	20	19	4	1.8	2.8	0	1364.4	13.3	1.9	1.775	1
45736	2025	3	20	20	4	1.6	3.2	0.1	1394.4	13.3	2.1	1.141667	1
45736	2025	3	20	21	4	1.6	2.7	0.7	1392.1	13.3	2.4	0.716667	1
45736	2025	3	20	22	4	1.5	3.2	1.6	1337.1	13.3	2.6	0.441667	1
45736	2025	3	20	23	4	1.6	3.4	2.1	1253.4	13.3	2.8	0.35	1
45737	2025	3	21	24	5	1.7	4.7	2.6	1085.4	10.7	3.0	0.383333	1
45737	2025	3	21	1	5	1.7	2.8	2.7	1153.0	10.7	3.2	0.291667	1
45737	2025	3	21	2	5	1.9	3	2.7	1127.8	10.7	3.2	0.5	1
45737	2025	3	21	3	5	2.0	2.9	2.9	1101.9	10.7	3.2	0.741667	1
45737	2025	3	21	4	5	2.1	2.9	3.8	1082.6	10.7	3.3	0.941667	1
45737	2025	3	21	5	5	2.2	3.1	3.6	1091.5	10.7	3.3	1.208333	1
45737	2025	3	21	6	5	2.4	3.3	2.8	1145.7	10.7	3.2	1.55	1
45737	2025	3	21	7	5	2.5	2.9	3.2	1263.2	10.7	3.2	1.875	1
45737	2025	3	21	8	5	2.7	2.9	2.7	1379.3	10.7	3.2	2.133333	1
45737	2025	3	21	9	5	2.8	3.1	3.2	1412.3	10.7	3.2	2.4	1
45737	2025	3	21	10	5	2.9	4.2	3.4	1393.5	10.7	3.2	2.616667	1
45737	2025	3	21	11	5	3.0	5.2	4.7	1346.0	10.7	3.3	2.825	1
45737	2025	3	21	12	5	3.2	5.5	2.8	1318.0	10.7	3.4	2.975	1
45737	2025	3	21	13	5	3.3	5.6	3	1293.6	10.7	3.5	3.191667	1
45737	2025	3	21	14	5	3.5	5.4	2.9	1270.7	10.7	3.7	3.208333	1
45737	2025	3	21	15	5	3.6	7.2	2.9	1222.1	10.7	3.9	3.233333	1
45737	2025	3	21	16	5	3.8	7.7	3.1	1196.5	10.7	4.3	3.25	1
45737	2025	3	21	17	5	4.0	7.8	3.3	1233.3	10.7	4.7	3.25	1
45737	2025	3	21	18	5	4.1	5.8	2.9	1279.1	10.7	5.1	3.191667	1
45737	2025	3	21	19	5	4.2	5.2	2.9	1275.6	10.7	5.3	3.166667	1
45737	2025	3	21	20	5	4.3	5.2	3.1	1276.6	10.7	5.5	3.175	1
45737	2025	3	21	21	5	4.4	5.3	4.2	1258.4	10.7	5.7	3.15	1
45737	2025	3	21	22	5	4.5	5.3	5.2	1210.0	10.7	5.8	3.183333	1
45737	2025	3	21	23	5	4.6	5.6	5.5	1133.4	10.7	5.9	3.266667	1
45738	2025	3	22	24	6	4.7	3.1	5.6	1133.8	22.8	6.0	3.416667	0
45738	2025	3	22	1	6	4.6	4	5.4	1055.6	22.8	5.8	3.483333	0
45738	2025	3	22	2	6	4.7	3.2	7.2	1027.0	22.8	5.6	3.716667	0
45738	2025	3	22	3	6	4.7	2.5	7.7	1012.3	22.8	5.5	3.916667	0
45738	2025	3	22	4	6	4.7	2.4	7.8	1009.7	22.8	5.1	4.275	0
45738	2025	3	22	5	6	4.6	2.7	5.8	1023.2	22.8	4.6	4.675	0
45738	2025	3	22	6	6	4.6	2.9	5.2	1051.5	22.8	4.2	5.066667	0
45738	2025	3	22	7	6	4.6	4	5.2	1096.4	22.8	4.0	5.275	0
45738	2025	3	22	8	6	4.7	4.9	5.3	1170.5	22.8	3.9	5.466667	0
45738	2025	3	22	9	6	4.7	4.3	5.3	1250.5	22.8	3.8	5.658333	0
45738	2025	3	22	10	6	4.8	4.8	5.6	1292.9	22.8	3.7	5.841667	0
45738	2025	3	22	11	6	4.8	5.3	3.1	1323.2	22.8	3.7	5.933333	0
45738	2025	3	22	12	6	4.8	5.5	4	1325.3	22.8	3.7	5.966667	0
45738	2025	3	22	13	6	4.8	6.1	3.2	1285.6	22.8	3.9	5.766667	0
45738	2025	3	22	14	6	4.8	6.9	2.5	1213.1	22.8	4.1	5.633333	0
45738	2025	3	22	15	6	4.9	9.4	2.4	1145.2	22.8	4.4	5.45	0
45738	2025	3	22	16	6	5.0	11.1	2.7	1113.8	22.8	4.9	5.058333	0
45738	2025	3	22	17	6	5.1	11.8	2.9	1129.5	22.8	5.7	4.616667	0
45738	2025	3	22	18	6	5.3	11.3	4	1164.5	22.8	6.4	4.191667	0
45738	2025	3	22	19	6	5.5	10.2	4.9	1188.8	22.8	7.1	3.95	0
45738	2025	3	22	20	6	5.7	8.5	4.3	1246.2	22.8	7.6	3.85	0
45738	2025	3	22	21	6	5.9	7.6	4.8	1269.8	22.8	7.9	3.825	0
45738	2025	3	22	22	6	6.0	4.5	5.3	1232.0	22.8	8.2	3.741667	0
45738	2025	3	22	23	6	5.9	4.1	5.5	1179.4	22.8	8.2	3.7	0
45739	2025	3	23	24	7	5.9	-1.4	6.1	1324.8	21.3	8.1	3.675	0
45739	2025	3	23	1	7	5.7	2.4	6.9	1101.3	21.3	7.5	3.875	0
45739	2025	3	23	2	7	5.6	2.2	9.4	1087.7	21.3	7.2	4.05	0
45739	2025	3	23	3	7	5.6	2.2	11.1	1083.3	21.3	6.8	4.358333	0
45739	2025	3	23	4	7	5.6	2.4	11.8	1096.8	21.3	6.2	4.933333	0
45739	2025	3	23	5	7	5.6	2.2	11.3	1111.0	21.3	5.5	5.658333	0
45739	2025	3											

DATE	Year	Month	Day	HOUR	DOW	24hrAvgLa	g Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLa	g Weekdays	
45739	2025	3	23	12	12	7	5.2	7.6	2.4	1308.6	21.3	2.4	8.083333	0
45739	2025	3	23	13	13	7	5.3	8.6	2.2	1293.9	21.3	3.1	7.508333	0
45739	2025	3	23	14	14	7	5.4	6.1	2.2	1299.1	21.3	3.6	7.2	0
45739	2025	3	23	15	15	7	5.4	3.3	2.4	1326.2	21.3	3.9	6.808333	0
45739	2025	3	23	16	16	7	5.1	2.8	2.2	1352.1	21.3	4.0	6.208333	0
45739	2025	3	23	17	17	7	4.8	1.3	2	1426.4	21.3	4.1	5.483333	0
45739	2025	3	23	18	18	7	4.3	0.4	0.9	1483.5	21.3	4.0	4.683333	0
45739	2025	3	23	19	19	7	3.9	-0.3	1.7	1508.0	21.3	3.9	3.908333	0
45739	2025	3	23	20	20	7	3.4	-0.8	3.7	1541.3	21.3	3.8	3.133333	0
45739	2025	3	23	21	21	7	3.1	-0.8	4.3	1554.5	21.3	3.6	2.566667	0
45739	2025	3	23	22	22	7	2.7	-0.9	5.6	1493.5	21.3	3.2	2.241667	0
45739	2025	3	23	23	23	7	2.5	-0.9	7.6	1401.2	21.3	2.7	2.225	0
45740	2025	3	24	24	1	1	2.3	0.9	8.6	1336.8	18.1	2.2	2.35	1
45740	2025	3	24	1	1	1	2.4	-2.1	6.1	1288.5	18.1	1.6	3.1	1
45740	2025	3	24	2	1	1	2.2	-2.8	3.3	1281.4	18.1	0.8	3.616667	1
45740	2025	3	24	3	1	1	2.0	-3.5	2.8	1289.2	18.1	0.0	3.941667	1
45740	2025	3	24	4	1	1	1.7	-4.2	1.3	1309.6	18.1	-0.6	4.033333	1
45740	2025	3	24	5	1	1	1.5	-4.6	0.4	1351.7	18.1	-1.1	4.066667	1
45740	2025	3	24	6	1	1	1.2	-5.1	-0.3	1436.7	18.1	-1.6	3.991667	1
45740	2025	3	24	7	1	1	0.9	-6	-0.8	1603.0	18.1	-2.1	3.858333	1
45740	2025	3	24	8	1	1	0.6	-4.9	-0.8	1719.7	18.1	-2.6	3.758333	1
45740	2025	3	24	9	1	1	0.3	-2.7	-0.9	1669.9	18.1	-2.9	3.55	1
45740	2025	3	24	10	1	1	0.1	-1.9	-0.9	1563.9	18.1	-3.1	3.175	1
45740	2025	3	24	11	1	1	-0.2	-0.5	0.9	1469.3	18.1	-3.2	2.741667	1
45740	2025	3	24	12	1	1	-0.5	0.6	-2.1	1412.6	18.1	-3.1	2.2	1
45740	2025	3	24	13	1	1	-0.8	0.7	-2.8	1391.2	18.1	-3.1	1.641667	1
45740	2025	3	24	14	1	1	-1.1	0.2	-3.5	1391.1	18.1	-2.9	0.75	1
45740	2025	3	24	15	1	1	-1.3	0	-4.2	1386.0	18.1	-2.7	0.008333	1
45740	2025	3	24	16	1	1	-1.5	0.4	-4.6	1414.4	18.1	-2.4	-0.55833	1
45740	2025	3	24	17	1	1	-1.6	0.5	-5.1	1461.6	18.1	-2.0	-1.14167	1
45740	2025	3	24	18	1	1	-1.6	0.5	-6	1514.1	18.1	-1.6	-1.63333	1
45740	2025	3	24	19	1	1	-1.6	0.1	-4.9	1533.3	18.1	-1.1	-2.09167	1
45740	2025	3	24	20	1	1	-1.6	0.5	-2.7	1573.4	18.1	-0.6	-2.56667	1
45740	2025	3	24	21	1	1	-1.5	0.8	-1.9	1558.8	18.1	-0.1	-2.90833	1
45740	2025	3	24	22	1	1	-1.5	0.3	-0.5	1496.1	18.1	0.2	-3.06667	1
45740	2025	3	24	23	1	1	-1.4	0.5	0.6	1391.2	18.1	0.3	-3.15	1
45741	2025	3	25	24	2	2	-1.3	4	0.7	1212.8	15.0	0.4	-3.11667	1
45741	2025	3	25	1	2	2	-1.2	1.6	0.2	1303.5	15.0	0.7	-3.14167	1
45741	2025	3	25	2	2	2	-1.1	3.1	0	1273.8	15.0	0.8	-2.90833	1
45741	2025	3	25	3	2	2	-0.8	5.1	0.4	1218.9	15.0	1.0	-2.65833	1
45741	2025	3	25	4	2	2	-0.5	7.5	0.5	1179.1	15.0	1.5	-2.36667	1
45741	2025	3	25	5	2	2	0.0	6.4	0.5	1158.8	15.0	2.0	-1.98333	1
45741	2025	3	25	6	2	2	0.5	5.8	0.1	1193.4	15.0	2.5	-1.55833	1
45741	2025	3	25	7	2	2	0.9	5.5	0.5	1304.8	15.0	3.0	-1.09167	1
45741	2025	3	25	8	2	2	1.4	4.3	0.8	1411.3	15.0	3.4	-0.58333	1
45741	2025	3	25	9	2	2	1.8	5.3	0.3	1418.3	15.0	3.7	-0.13333	1
45741	2025	3	25	10	2	2	2.1	6.7	0.5	1404.1	15.0	4.1	0.158333	1
45741	2025	3	25	11	2	2	2.5	7.5	4	1378.5	15.0	4.7	0.341667	1
45741	2025	3	25	12	2	2	2.8	9.1	1.6	1340.7	15.0	5.2	0.425	1
45741	2025	3	25	13	2	2	3.2	9.8	3.1	1307.5	15.0	5.7	0.708333	1
45741	2025	3	25	14	2	2	3.6	10.4	5.1	1263.4	15.0	6.3	0.783333	1
45741	2025	3	25	15	2	2	4.0	10.5	7.5	1224.0	15.0	7.0	1.025	1
45741	2025	3	25	16	2	2	4.4	11.9	6.4	1219.8	15.0	7.4	1.45	1
45741	2025	3	25	17	2	2	4.9	10.7	5.8	1236.9	15.0	7.8	2.041667	1
45741	2025	3	25	18	2	2	5.3	10.8	5.5	1284.9	15.0	8.1	2.533333	1
45741	2025	3	25	19	2	2	5.8	8.7	4.3	1301.8	15.0	8.5	2.975	1
45741	2025	3	25	20	2	2	6.1	5.1	5.3	1346.4	15.0	8.8	3.425	1
45741	2025	3	25	21	2	2	6.3	4	6.7	1376.7	15.0	8.9	3.741667	1
45741	2025	3	25	22	2	2	6.4	2.9	7.5	1337.1	15.0	8.8	4.116667	1
45741	2025	3	25	23	2	2	6.6	1.9	9.1	1264.7	15.0	8.5	4.65	1
45742	2025	3	26	24	3	3	6.6	0.3	9.8	1232.2	13.3	8.0	5.233333	1
45742	2025	3	26	1	3	3	6.5	3.2	10.4	1196.7	13.3	7.3	5.658333	1
45742	2025	3	26	2	3	3	6.5	2.5	10.5	1184.5	13.3	6.7	6.341667	1
45742	2025	3	26	3	3	3	6.5	1.9	11.9	1170.8	13.3	6.0	6.95	1
45742	2025	3	26	4	3	3	6.4	1.6	10.7	1162.5	13.3	5.3	7.4	1
45742	2025	3	26	5	3	3	6.1	1.8	10.8	1169.9	13.3	4.5	7.766667	1
45742	2025	3	26	6	3	3	5.9	1.7	8.7	1236.1	13.3	3.7	8.125	1
45742	2025	3	26	7	3	3	5.8	2.1	5.1	1371.0	13.3	3.0	8.541667	1
45742	2025	3	26	8	3	3	5.6	1.9	4	1489.7	13.3	2.4	8.808333	1
45742	2025	3	26	9	3	3	5.5	2.1	2.9	1488.1	13.3	2.2	8.875	1
45742	2025	3	26	10	3	3	5.4	2.9	1.9	1436.2	13.3	2.0	8.766667	1
45742	2025	3	26	11	3	3	5.2	4.8	0.3	1340.6	13.3	2.0	8.45	1
45742	2025	3	26	12	3	3	5.1	4.4	3.2	1265.9	13.3	2.2	7.983333	1
45742	2025	3	26	13	3	3	4.9	3.6	2.5	1220.3	13.3	2.6	7.25	1
45742	2025	3	26	14	3	3	4.7	3.4	1.9	1187.5	13.3	2.6	6.7	1
45742	2025	3	26	15	3	3	4.4	3.1	1.6	1177.4	13.3	2.7	6.041667	1
45742	2025	3	26	16	3	3	4.1	3.2	1.8	1194.7	13.3	2.8	5.325	1
45742	2025	3	26	17	3	3	3.7	2.3	1.7	1248.3	13.3	2.9	4.466667	1
45742	2025	3	26	18	3	3	3.3	1.6	2.1	1318.6	13.3	3.0	3.725	1
45742	2025	3	26	19	3	3	3.0	0.8	1.9	1349.5	13.3	3.0	2.966667	1
45742	2025	3	26	20	3	3	2.6	0.7	2.1	1399.2	13.3	2.8	2.416667	1
45742	2025	3	26	21	3	3	2.4	0.8	2.9	1401.2	13.3	2.7	2.15	1
45742	2025	3	26	22	3	3	2.3	1	4.8	1348.3	13.3	2.6	1.991667	1
45742	2025	3	26	23	3	3	2.2	0.6	4.4	1270.8	13.3	2.5	1.991667	1
45743	2025	3	27	24	4	4	2.2	1.2	3.6	1307.1	15.0	2.1	2.233333	1
45743	2025	3	27	1	4	4	2.2	0.7	3.4	1226.8	15.0	1.9	2.575	1
45743	2025	3	27	2	4	4	2.1	0.6	3.1	1217.8	15.0	1.6	2.608333	1
45743	2025	3	27	3	4	4	2.0	0.5	3.2	1194.4	15.0	1.4	2.683333	1
45743	2025	3	27	4	4	4	2.0	0.4	2.3	1195.1	15.0	1.2	2.783333	1
45743	2025	3	27	5	4	4	1.9	0.3	1.6	1222.1	15.0	0.9	2.916667	1
45743	2025	3	27	6	4	4	1.9	0.5	0.8	1285.2	15.0	0.8	2.958333	1
45743	2025	3	27	7	4	4	1.8	0.6	0.7	1411.7	15.0	0.7	2.95	1
45743	2025	3	27	8	4	4	1.8	0.8	0.8	1526.4	15.0	0.7	2.841667	1
45743	2025	3	27	9	4	4	1.7	1.4	1	1550.8	15.0	0.7	2.741667	1
45743	2025	3	27	10	4	4	1.7	2.1	0.6	1519.6	15.0	0.7	2.633333	1
45743	2025	3	27	11	4	4	1.6	2.2	1.2	1493.4	15.0	0.8	2.475	1
45743	2025	3	27	12	4	4	1.5	2.6	0.7	1475.8	15.0	0.9		

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLag	Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLag	Weekdays
45744	2025	3	28	24	5	2.3	1	5.2	1279.7	16.5	3.6	0.941667	1
45744	2025	3	28	1	5	2.3	1	4.8	1291.4	16.5	3.5	1.058333	1
45744	2025	3	28	2	5	2.3	0.6	6	1273.4	16.5	3.2	1.433333	1
45744	2025	3	28	3	5	2.3	0.6	3.8	1252.6	16.5	2.8	1.783333	1
45744	2025	3	28	4	5	2.3	0.6	4.5	1241.0	16.5	2.4	2.241667	1
45744	2025	3	28	5	5	2.3	0.8	3.8	1245.7	16.5	2.1	2.525	1
45744	2025	3	28	6	5	2.3	1.3	3	1303.1	16.5	1.8	2.875	1
45744	2025	3	28	7	5	2.4	1.2	2.8	1431.6	16.5	1.6	3.15	1
45744	2025	3	28	8	5	2.4	1.3	2.7	1537.1	16.5	1.4	3.35	1
45744	2025	3	28	9	5	2.4	1.4	2.5	1516.8	16.5	1.3	3.516667	1
45744	2025	3	28	10	5	2.4	2.1	2	1452.2	16.5	1.2	3.625	1
45744	2025	3	28	11	5	2.4	2.2	1	1369.6	16.5	1.2	3.658333	1
45744	2025	3	28	12	5	2.4	3.2	1	1315.1	16.5	1.2	3.641667	1
45744	2025	3	28	13	5	2.4	3.6	0.6	1284.1	16.5	1.4	3.508333	1
45744	2025	3	28	14	5	2.4	2.5	0.6	1272.5	16.5	1.6	3.158333	1
45744	2025	3	28	15	5	2.3	4.7	0.6	1247.6	16.5	1.7	2.808333	1
45744	2025	3	28	16	5	2.2	5.2	0.8	1268.3	16.5	2.1	2.358333	1
45744	2025	3	28	17	5	2.3	5.1	1.3	1303.5	16.5	2.5	2.091667	1
45744	2025	3	28	18	5	2.3	4.3	1.2	1340.2	16.5	2.8	1.783333	1
45744	2025	3	28	19	5	2.3	3.9	1.3	1335.2	16.5	3.1	1.575	1
45744	2025	3	28	20	5	2.4	3.6	1.4	1361.4	16.5	3.3	1.425	1
45744	2025	3	28	21	5	2.4	3	2.1	1388.4	16.5	3.5	1.3	1
45744	2025	3	28	22	5	2.4	2	2.2	1362.1	16.5	3.6	1.191667	1
45744	2025	3	28	23	5	2.4	1.5	3.2	1307.0	16.5	3.6	1.158333	1
45745	2025	3	29	24	6	2.4	-2.3	3.6	1379.1	15.7	3.6	1.175	0
45745	2025	3	29	1	6	2.2	1.4	2.5	1267.3	15.7	3.1	1.358333	0
45745	2025	3	29	2	6	2.2	0.9	4.7	1256.2	15.7	2.9	1.575	0
45745	2025	3	29	3	6	2.3	-0.6	5.2	1247.8	15.7	2.8	1.733333	0
45745	2025	3	29	4	6	2.2	-1.5	5.1	1247.1	15.7	2.3	2.075	0
45745	2025	3	29	5	6	2.1	-2	4.3	1266.4	15.7	1.8	2.458333	0
45745	2025	3	29	6	6	2.0	-2.5	3.9	1320.9	15.7	1.2	2.816667	0
45745	2025	3	29	7	6	1.8	-2.5	3.6	1385.3	15.7	0.6	3.066667	0
45745	2025	3	29	8	6	1.7	-2.5	3	1474.6	15.7	0.1	3.291667	0
45745	2025	3	29	9	6	1.5	-2.1	2	1546.3	15.7	-0.4	3.483333	0
45745	2025	3	29	10	6	1.4	-1.3	1.5	1563.3	15.7	-0.9	3.616667	0
45745	2025	3	29	11	6	1.2	-0.7	-2.3	1536.2	15.7	-1.1	3.608333	0
45745	2025	3	29	12	6	1.1	0.3	1.4	1490.3	15.7	-1.3	3.55	0
45745	2025	3	29	13	6	1.0	1.5	0.9	1399.0	15.7	-1.1	3.091667	0
45745	2025	3	29	14	6	0.9	3.5	-0.6	1328.9	15.7	-1.1	2.908333	0
45745	2025	3	29	15	6	1.0	3.6	-1.5	1288.8	15.7	-0.9	2.775	0
45745	2025	3	29	16	6	0.9	4	-2	1273.4	15.7	-0.5	2.333333	0
45745	2025	3	29	17	6	0.9	4.2	-2.5	1303.1	15.7	-0.1	1.775	0
45745	2025	3	29	18	6	0.8	4	-2.5	1339.9	15.7	0.5	1.183333	0
45745	2025	3	29	19	6	0.8	3	-2.5	1371.3	15.7	1.0	0.616667	0
45745	2025	3	29	20	6	0.8	1.4	-2.1	1433.6	15.7	1.5	0.083333	0
45745	2025	3	29	21	6	0.7	0.2	-1.3	1489.9	15.7	1.8	-0.425	0
45745	2025	3	29	22	6	0.6	-0.7	-0.7	1466.2	15.7	2.0	-0.85	0
45745	2025	3	29	23	6	0.5	-1.7	0.3	1422.1	15.7	2.0	-1.125	0
45746	2025	3	30	24	7	0.3	0.3	1.5	1304.3	10.3	1.9	-1.30833	0
45746	2025	3	30	1	7	0.4	-3.8	3.5	1352.0	10.3	1.9	-1.09167	0
45746	2025	3	30	2	7	0.2	-4.2	3.6	1339.9	10.3	1.5	-1.08333	0
45746	2025	3	30	3	7	0.0	-4.3	4	1344.7	10.3	0.9	-0.86667	0
45746	2025	3	30	4	7	-0.2	-4.8	4.2	1357.5	10.3	0.2	-0.51667	0
45746	2025	3	30	5	7	-0.3	-4.5	4	1376.8	10.3	-0.5	-0.05833	0
45746	2025	3	30	6	7	-0.4	-4.9	3	1416.0	10.3	-1.3	0.458333	0
45746	2025	3	30	7	7	-0.5	-4.6	1.4	1468.9	10.3	-2.0	1	0
45746	2025	3	30	8	7	-0.6	-3.5	0.2	1532.2	10.3	-2.6	1.458333	0
45746	2025	3	30	9	7	-0.6	-0.3	-0.7	1556.6	10.3	-3.0	1.783333	0
45746	2025	3	30	10	7	-0.6	0.9	-1.7	1507.9	10.3	-3.1	1.975	0
45746	2025	3	30	11	7	-0.5	1.9	0.3	1438.6	10.3	-3.0	2.025	0
45746	2025	3	30	12	7	-0.4	2.5	-3.8	1389.8	10.3	-2.7	1.941667	0
45746	2025	3	30	13	7	-0.3	2.3	-4.2	1347.2	10.3	-2.5	1.941667	0
45746	2025	3	30	14	7	-0.2	2.1	-4.3	1297.5	10.3	-2.0	1.5	0
45746	2025	3	30	15	7	-0.3	1.8	-4.8	1288.2	10.3	-1.4	0.858333	0
45746	2025	3	30	16	7	-0.4	2.4	-4.5	1306.2	10.3	-0.9	0.2	0
45746	2025	3	30	17	7	-0.4	2.1	-4.9	1388.3	10.3	-0.3	-0.53333	0
45746	2025	3	30	18	7	-0.5	1.7	-4.6	1454.7	10.3	0.2	-1.25833	0
45746	2025	3	30	19	7	-0.6	1.4	-3.5	1471.7	10.3	0.8	-2	0
45746	2025	3	30	20	7	-0.7	1	-0.3	1506.3	10.3	1.3	-2.63333	0
45746	2025	3	30	21	7	-0.7	0.5	0.9	1524.2	10.3	1.7	-3.04167	0
45746	2025	3	30	22	7	-0.7	0.1	1.9	1467.1	10.3	1.7	-3.08333	0
45746	2025	3	30	23	7	-0.7	0.1	2.5	1378.0	10.3	1.7	-2.95	0
45747	2025	3	31	24	1	-0.6	8.3	2.3	1082.0	20.5	1.5	-2.65	1
45747	2025	3	31	1	1	-0.2	-0.4	2.1	1264.7	20.5	2.0	-2.46667	1
45747	2025	3	31	2	1	-0.1	-0.5	1.8	1245.8	20.5	1.8	-1.95833	1
45747	2025	3	31	3	1	0.1	-0.3	2.4	1242.1	20.5	1.5	-1.43333	1
45747	2025	3	31	4	1	0.2	-0.1	2.1	1247.2	20.5	1.4	-0.925	1
45747	2025	3	31	5	1	0.4	0	1.7	1262.0	20.5	1.2	-0.325	1
45747	2025	3	31	6	1	0.6	0.2	1.4	1328.4	20.5	1.0	0.225	1
45747	2025	3	31	7	1	0.8	0.5	1	1468.2	20.5	0.9	0.775	1
45747	2025	3	31	8	1	1.0	1	0.5	1581.5	20.5	0.8	1.275	1
45747	2025	3	31	9	1	1.2	1.6	0.1	1608.4	20.5	0.8	1.65	1
45747	2025	3	31	10	1	1.3	2.1	0.1	1595.2	20.5	0.9	1.716667	1
45747	2025	3	31	11	1	1.3	3.3	8.3	1568.1	20.5	1.0	1.65	1
45747	2025	3	31	12	1	1.4	3.5	-0.4	1547.8	20.5	1.3	1.5	1
45747	2025	3	31	13	1	1.4	4.4	-0.5	1516.2	20.5	0.9	1.983333	1
45747	2025	3	31	14	1	1.5	4.9	-0.3	1463.8	20.5	1.3	1.758333	1
45747	2025	3	31	15	1	1.7	7.8	-0.1	1404.8	20.5	1.8	1.541667	1
45747	2025	3	31	16	1	1.9	7.9	0	1369.2	20.5	2.4	1.366667	1
45747	2025	3	31	17	1	2.1	9.3	0.2	1372.9	20.5	3.1	1.158333	1
45747	2025	3	31	18	1	2.4	8.4	0.5	1380.0	20.5	3.9	0.983333	1
45747	2025	3	31	19	1	2.7	8.4	1	1355.3	20.5	4.6	0.858333	1
45747	2025	3	31	20	1	3.0	7.8	1.6	1350.1	20.5	5.2	0.783333	1
45747	2025	3	31	21	1	3.3	8	2.1	1330.1	20.5	5.8	0.783333	1
45747	2025	3	31	22	1	3.6	8	3.3	1258.1	20.5	6.3	0.875	1
45747	2025	3	31	23	1	3.9	8	3.5	1147.7	20.5	6.8	1.041667	1
45962	2025	11	1	24	6	14.0	8.9	15.6	979.5	24.5	14.2	13.76667	0
45962	2025	11	1	1	6	13.9	11.9	16.1	859.6	24.5	13.8	13.95833	0
45962	2025	11	1	2	6	13.8	10.8	15.7	827.5	24.5	13.5	14.15833	0
45962	2025	11	1	3	6	13.7	10.8	15.3	804.1	24.5	13.0	14.39167	0
45962	2025	11	1	4	6	13.6	10.8	15.2	791.3	24.5	12.6	14.58333	0
45962	2025	11	1	5	6	13.5	10.9	13.5	807.9	24.5	12.2	14.73333	0
45962													

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLa	gTemp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLa	gWeekdays	
45962	2025	11	1	1	12	6	12.3	10.7	11.9	1132.5	24.5	10.4	14.24167	0
45962	2025	11	1	1	13	6	12.1	11	10.8	1127.0	24.5	10.5	13.75833	0
45962	2025	11	1	1	14	6	11.9	11.5	10.8	1105.2	24.5	10.4	13.45	0
45962	2025	11	1	1	15	6	11.8	12.1	10.8	1078.3	24.5	10.5	13.00833	0
45962	2025	11	1	1	16	6	11.6	12.2	10.9	1090.4	24.5	10.6	12.6	0
45962	2025	11	1	1	17	6	11.5	11.3	10.4	1140.4	24.5	10.7	12.225	0
45962	2025	11	1	1	18	6	11.3	11.5	9.1	1190.7	24.5	10.8	11.86667	0
45962	2025	11	1	1	19	6	11.2	11.1	10	1211.0	24.5	10.9	11.60833	0
45962	2025	11	1	1	20	6	11.1	10.9	10	1190.7	24.5	11.0	11.26667	0
45962	2025	11	1	1	21	6	11.0	10.1	10.1	1157.7	24.5	11.1	11	0
45962	2025	11	1	1	22	6	10.9	9.3	10.7	1101.9	24.5	11.1	10.74167	0
45962	2025	11	1	1	23	6	10.8	9.3	10.7	1028.6	24.5	11.0	10.525	0
45963	2025	11	2	24	7	10.6	5.2	11	1057.5	12.5	10.9	10.36667	0	
45963	2025	11	2	1	7	10.5	8.6	11.5	929.9	12.5	10.5	10.51667	0	
45963	2025	11	2	2	7	10.4	8.2	12.1	947.8	12.5	10.3	10.44167	0	
45963	2025	11	2	3	7	10.2	7.9	12.2	894.1	12.5	10.0	10.5	0	
45963	2025	11	2	4	7	10.1	7.6	11.3	886.6	12.5	9.6	10.60833	0	
45963	2025	11	2	5	7	10.0	7	11.5	881.7	12.5	9.3	10.725	0	
45963	2025	11	2	6	7	9.8	6.6	11.1	889.5	12.5	8.9	10.75833	0	
45963	2025	11	2	7	7	9.7	5.9	10.9	919.2	12.5	8.5	10.85	0	
45963	2025	11	2	8	7	9.5	5.5	10.1	975.1	12.5	8.1	11.01667	0	
45963	2025	11	2	9	7	9.3	6.3	9.3	1051.1	12.5	7.6	11.09167	0	
45963	2025	11	2	10	7	9.2	7.4	9.3	1096.0	12.5	7.3	11.1	0	
45963	2025	11	2	11	7	9.1	8.3	5.2	1116.5	12.5	7.1	11.03333	0	
45963	2025	11	2	12	7	9.0	9	8.6	1112.0	12.5	7.0	10.91667	0	
45963	2025	11	2	13	7	8.9	9.6	8.2	1091.2	12.5	7.4	10.45833	0	
45963	2025	11	2	14	7	8.9	10.4	7.9	1064.8	12.5	7.4	10.25833	0	
45963	2025	11	2	15	7	8.8	10.6	7.6	1038.7	12.5	7.6	9.983333	0	
45963	2025	11	2	16	7	8.7	11	7	1030.6	12.5	7.9	9.633333	0	
45963	2025	11	2	17	7	8.7	10.3	6.6	1107.5	12.5	8.1	9.25	0	
45963	2025	11	2	18	7	8.7	8.8	5.9	1242.0	12.5	8.4	8.891667	0	
45963	2025	11	2	19	7	8.5	7.3	5.5	1322.8	12.5	8.6	8.483333	0	
45963	2025	11	2	20	7	8.4	6.3	6.3	1280.6	12.5	8.7	8.05	0	
45963	2025	11	2	21	7	8.2	6.1	7.4	1234.1	12.5	8.8	7.6	0	
45963	2025	11	2	22	7	8.0	5.8	8.3	1217.7	12.5	8.8	7.283333	0	
45963	2025	11	2	23	7	7.9	6	9	1149.2	12.5	8.6	7.125	0	
45964	2025	11	3	24	1	7.7	8.4	9.6	1094.4	7.3	8.4	7.041667	1	
45964	2025	11	3	1	1	7.9	4.6	10.4	1017.9	7.3	8.4	7.358333	1	
45964	2025	11	3	2	1	7.7	3.4	10.6	986.1	7.3	8.0	7.441667	1	
45964	2025	11	3	3	1	7.5	3.3	11	970.0	7.3	7.4	7.625	1	
45964	2025	11	3	4	1	7.3	4	10.3	969.7	7.3	6.8	7.85	1	
45964	2025	11	3	5	1	7.2	3.5	8.8	1001.8	7.3	6.2	8.133333	1	
45964	2025	11	3	6	1	7.0	3	7.3	1049.0	7.3	5.6	8.408333	1	
45964	2025	11	3	7	1	6.9	2.6	6.3	1150.7	7.3	5.1	8.591667	1	
45964	2025	11	3	8	1	6.7	2.2	6.1	1257.3	7.3	4.8	8.708333	1	
45964	2025	11	3	9	1	6.6	3.8	5.8	1361.7	7.3	4.4	8.775	1	
45964	2025	11	3	10	1	6.5	5.4	6	1328.7	7.3	4.2	8.758333	1	
45964	2025	11	3	11	1	6.4	6.4	8.4	1247.9	7.3	4.2	8.625	1	
45964	2025	11	3	12	1	6.3	6.9	4.6	1178.3	7.3	4.2	8.433333	1	
45964	2025	11	3	13	1	6.2	8.3	3.4	1139.3	7.3	4.1	8.383333	1	
45964	2025	11	3	14	1	6.2	9.6	3.3	1110.5	7.3	4.4	7.966667	1	
45964	2025	11	3	15	1	6.2	9.6	4	1103.2	7.3	4.9	7.383333	1	
45964	2025	11	3	16	1	6.1	8.6	3.5	1127.7	7.3	5.4	6.775	1	
45964	2025	11	3	17	1	6.0	7.6	3	1186.1	7.3	5.8	6.191667	1	
45964	2025	11	3	18	1	5.9	7.2	2.6	1283.1	7.3	6.2	5.625	1	
45964	2025	11	3	19	1	5.8	7.3	2.2	1365.7	7.3	6.5	5.141667	1	
45964	2025	11	3	20	1	5.8	8.3	3.8	1334.6	7.3	6.9	4.75	1	
45964	2025	11	3	21	1	5.9	8.5	5.4	1296.1	7.3	7.4	4.408333	1	
45964	2025	11	3	22	1	6.0	8.7	6.4	1197.9	7.3	7.8	4.216667	1	
45964	2025	11	3	23	1	6.1	8.7	6.9	1129.8	7.3	8.1	4.183333	1	
45965	2025	11	4	24	2	6.2	6.5	8.3	1142.9	14.7	8.3	4.216667	1	
45965	2025	11	4	1	2	6.2	7.9	9.6	1037.9	14.7	8.2	4.091667	1	
45965	2025	11	4	2	2	6.3	7.6	9.6	990.2	14.7	8.2	4.4	1	
45965	2025	11	4	3	2	6.5	7.4	8.6	959.2	14.7	8.0	4.916667	1	
45965	2025	11	4	4	2	6.7	7.3	7.6	939.2	14.7	7.9	5.441667	1	
45965	2025	11	4	5	2	6.8	7.1	7.2	934.2	14.7	7.8	5.825	1	
45965	2025	11	4	6	2	6.9	7.1	7.3	945.1	14.7	7.7	6.166667	1	
45965	2025	11	4	7	2	7.1	6.9	8.3	992.2	14.7	7.7	6.516667	1	
45965	2025	11	4	8	2	7.3	6.8	8.5	1183.3	14.7	7.7	6.908333	1	
45965	2025	11	4	9	2	7.5	6.5	8.7	1238.3	14.7	7.5	7.416667	1	
45965	2025	11	4	10	2	7.6	6.1	8.7	1263.2	14.7	7.4	7.808333	1	
45965	2025	11	4	11	2	7.6	7.2	6.5	1262.0	14.7	7.2	8.083333	1	
45965	2025	11	4	12	2	7.7	7.7	7.9	1225.0	14.7	7.0	8.275	1	
45965	2025	11	4	13	2	7.7	8.2	7.6	1209.7	14.7	7.1	8.241667	1	
45965	2025	11	4	14	2	7.7	8.1	7.4	1244.0	14.7	7.2	8.208333	1	
45965	2025	11	4	15	2	7.6	8.5	7.3	1273.6	14.7	7.2	8.041667	1	
45965	2025	11	4	16	2	7.6	8.1	7.1	1232.8	14.7	7.3	7.858333	1	
45965	2025	11	4	17	2	7.6	7.5	7.1	1239.6	14.7	7.4	7.75	1	
45965	2025	11	4	18	2	7.6	7.1	6.9	1334.4	14.7	7.4	7.708333	1	
45965	2025	11	4	19	2	7.5	7.2	6.8	1408.1	14.7	7.4	7.7	1	
45965	2025	11	4	20	2	7.5	7.5	6.5	1379.6	14.7	7.4	7.666667	1	
45965	2025	11	4	21	2	7.5	7.1	6.1	1334.7	14.7	7.5	7.541667	1	
45965	2025	11	4	22	2	7.5	6.7	7.2	1289.9	14.7	7.5	7.375	1	
45965	2025	11	4	23	2	7.4	6.7	7.7	1220.2	14.7	7.6	7.158333	1	
45966	2025	11	5	24	3	7.3	6.1	8.2	1089.2	16.8	7.5	7.033333	1	
45966	2025	11	5	1	3	7.3	6.2	8.1	1086.8	16.8	7.4	7.133333	1	
45966	2025	11	5	2	3	7.2	6.1	8.5	1032.1	16.8	7.2	7.158333	1	
45966	2025	11	5	3	3	7.1	6	8.1	1000.2	16.8	7.1	7.2	1	
45966	2025	11	5	4	3	7.1	6	7.5	977.6	16.8	6.9	7.291667	1	
45966	2025	11	5	5	3	7.0	5.8	7.1	973.4	16.8	6.7	7.358333	1	
45966	2025	11	5	6	3	7.0	5.6	7.2	989.0	16.8	6.5	7.391667	1	
45966	2025	11	5	7	3	6.9	5.5	7.5	1053.4	16.8	6.4	7.391667	1	
45966	2025	11	5	8	3	6.8	5.2	7.1	1251.8	16.8	6.3	7.416667	1	
45966	2025	11	5	9	3	6.8	5.8	6.7	1286.8	16.8	6.1	7.475	1	
45966	2025	11	5	10	3	6.8	7	6.7	1223.3	16.8	6.0	7.525	1	
45966	2025	11	5	11	3	6.8	7.9	6.1	1183.2	16.8	6.0	7.575	1	
45966	2025	11	5	12	3	6.8	8.7	6.2	1154.5	16.8	6.1	7.533333	1	
45966	2025	11	5	13	3	6.9	9.3	6.1	1097.9	16.8	6.3	7.4	1	
45966	2025	11	5	14	3	6.9	10.5	6	1052.3	16.8	6.6	7.233333	1	
45966	2025	11	5	15	3	7.0	10.5	6	1057.8	16.8	6.9	7.066667	1	
45966	2025	11	5	16	3	7.1	10.1	5.8	1141.7	16.8	7.3	6.858333	1	

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLag	Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLag	Weekdays	
45967	2025	11	11	6	24	4	7.5	3.4	9.3	1218.6	18.5	8.8	6.1	1
45967	2025	11	11	6	1	4	7.4	6.2	10.5	1070.5	18.5	8.4	6.316667	1
45967	2025	11	11	6	2	4	7.4	5.6	10.5	1032.4	18.5	8.1	6.575	1
45967	2025	11	11	6	3	4	7.3	5.4	10.1	992.8	18.5	7.7	6.941667	1
45967	2025	11	11	6	4	4	7.3	4.9	9.7	961.9	18.5	7.3	7.316667	1
45967	2025	11	11	6	5	4	7.3	4.8	8.6	956.9	18.5	6.9	7.658333	1
45967	2025	11	11	6	6	4	7.2	4.9	8	975.7	18.5	6.5	7.983333	1
45967	2025	11	11	6	7	4	7.2	4.9	7.4	1043.4	18.5	6.1	8.233333	1
45967	2025	11	11	6	8	4	7.2	4.8	7.5	1217.2	18.5	5.9	8.441667	1
45967	2025	11	11	6	9	4	7.1	3.4	7.9	1282.2	18.5	5.7	8.625	1
45967	2025	11	11	6	10	4	7.0	2.7	7.7	1332.7	18.5	5.3	8.766667	1
45967	2025	11	11	6	11	4	6.9	2.9	3.4	1367.7	18.5	4.9	8.841667	1
45967	2025	11	11	6	12	4	6.7	2.7	6.2	1372.7	18.5	4.5	8.825	1
45967	2025	11	11	6	13	4	6.4	3.3	5.6	1360.4	18.5	4.4	8.383333	1
45967	2025	11	11	6	14	4	6.2	4.6	5.4	1336.2	18.5	4.2	8.125	1
45967	2025	11	11	6	15	4	5.9	4.8	4.9	1341.5	18.5	4.1	7.716667	1
45967	2025	11	11	6	16	4	5.7	4.8	4.8	1331.2	18.5	4.1	7.291667	1
45967	2025	11	11	6	17	4	5.5	4	4.9	1349.0	18.5	4.1	6.858333	1
45967	2025	11	11	6	18	4	5.2	3.8	4.9	1429.2	18.5	4.0	6.45	1
45967	2025	11	11	6	19	4	5.0	4.5	4.8	1456.8	18.5	3.9	6.141667	1
45967	2025	11	11	6	20	4	4.9	4.3	3.4	1378.0	18.5	3.9	5.883333	1
45967	2025	11	11	6	21	4	4.7	4.5	2.7	1405.5	18.5	3.8	5.666667	1
45967	2025	11	11	6	22	4	4.6	3.7	2.9	1369.0	18.5	3.9	5.325	1
45967	2025	11	11	6	23	4	4.4	3.7	2.7	1299.9	18.5	4.0	4.891667	1
45968	2025	11	11	7	24	5	4.3	3.6	3.3	1214.1	13.1	4.1	4.491667	1
45968	2025	11	11	7	1	5	4.3	3.3	4.6	1177.2	13.1	4.1	4.433333	1
45968	2025	11	11	7	2	5	4.2	2.9	4.8	1133.0	13.1	4.1	4.191667	1
45968	2025	11	11	7	3	5	4.1	2.8	4.8	1094.4	13.1	4.0	4.108333	1
45968	2025	11	11	7	4	5	3.9	2.5	4	1074.2	13.1	3.8	4.058333	1
45968	2025	11	11	7	5	5	3.8	2.3	3.8	1068.0	13.1	3.6	4.05	1
45968	2025	11	11	7	6	5	3.7	2.3	4.5	1084.4	13.1	3.5	3.983333	1
45968	2025	11	11	7	7	5	3.6	2.3	4.3	1180.5	13.1	3.4	3.891667	1
45968	2025	11	11	7	8	5	3.5	2.4	4.5	1302.9	13.1	3.2	3.858333	1
45968	2025	11	11	7	9	5	3.4	3.5	3.7	1386.9	13.1	3.0	3.816667	1
45968	2025	11	11	7	10	5	3.4	3.7	3.7	1392.1	13.1	2.9	3.908333	1
45968	2025	11	11	7	11	5	3.5	4.4	3.6	1325.9	13.1	2.9	3.991667	1
45968	2025	11	11	7	12	5	3.5	5.1	3.3	1264.7	13.1	3.0	4.058333	1
45968	2025	11	11	7	13	5	3.6	5.8	2.9	1230.2	13.1	3.1	4.133333	1
45968	2025	11	11	7	14	5	3.7	6.7	2.8	1203.9	13.1	3.3	4.133333	1
45968	2025	11	11	7	15	5	3.8	7.2	2.5	1167.5	13.1	3.7	3.991667	1
45968	2025	11	11	7	16	5	3.9	7.3	2.3	1179.2	13.1	4.0	3.825	1
45968	2025	11	11	7	17	5	4.0	6.8	2.3	1243.7	13.1	4.4	3.633333	1
45968	2025	11	11	7	18	5	4.1	6.1	2.3	1365.9	13.1	4.8	3.491667	1
45968	2025	11	11	7	19	5	4.2	5.1	2.4	1433.6	13.1	5.1	3.366667	1
45968	2025	11	11	7	20	5	4.3	5.2	3.5	1416.2	13.1	5.3	3.183333	1
45968	2025	11	11	7	21	5	4.3	4.9	3.7	1330.9	13.1	5.6	3.025	1
45968	2025	11	11	7	22	5	4.3	4.3	4.4	1323.8	13.1	5.7	2.941667	1
45968	2025	11	11	7	23	5	4.3	3.8	5.1	1270.8	13.1	5.7	2.941667	1
45968	2025	11	11	7	24	5	4.3	3.6	5.8	1214.1	13.1	5.7	3	1
45969	2025	11	11	8	1	6	4.3	3.3	6.7	1178.7	12.2	5.6	3.125	0
45969	2025	11	11	8	2	6	4.3	3.4	7.2	1137.1	12.2	5.4	3.333333	0
45969	2025	11	11	8	3	6	4.4	3.7	7.3	1089.7	12.2	5.1	3.65	0
45969	2025	11	11	8	4	6	4.4	3.5	6.8	1048.4	12.2	4.8	4.016667	0
45969	2025	11	11	8	5	6	4.4	4.1	6.1	1027.3	12.2	4.5	4.416667	0
45969	2025	11	11	8	6	6	4.5	5.5	5.1	1020.3	12.2	4.3	4.791667	0
45969	2025	11	11	8	7	6	4.7	7.5	5.2	1023.7	12.2	4.2	5.108333	0
45969	2025	11	11	8	8	6	4.9	9.2	4.9	1062.1	12.2	4.4	5.341667	0
45969	2025	11	11	8	9	6	5.2	10.6	4.3	1117.9	12.2	4.7	5.575	0
45969	2025	11	11	8	10	6	5.5	12.6	3.8	1179.5	12.2	5.2	5.691667	0
45969	2025	11	11	8	11	6	5.8	12.6	3.6	1230.7	12.2	5.9	5.741667	0
45969	2025	11	11	8	12	6	6.2	12.9	3.3	1247.7	12.2	6.6	5.691667	0
45969	2025	11	11	8	13	6	6.5	13.3	3.4	1250.6	12.2	7.4	5.566667	0
45969	2025	11	11	8	14	6	6.8	13.3	3.7	1230.1	12.2	8.2	5.358333	0
45969	2025	11	11	8	15	6	7.1	13.9	3.5	1259.9	12.2	9.1	5.083333	0
45969	2025	11	11	8	16	6	7.4	13.4	4.1	1213.2	12.2	9.9	4.791667	0
45969	2025	11	11	8	17	6	7.6	13.6	5.5	1223.4	12.2	10.7	4.475	0
45969	2025	11	11	8	18	6	7.9	13.3	7.5	1254.3	12.2	11.5	4.25	0
45969	2025	11	11	8	19	6	8.2	12.8	9.2	1307.3	12.2	12.2	4.2	0
45969	2025	11	11	8	20	6	8.5	12.2	10.6	1255.5	12.2	12.6	4.4	0
45969	2025	11	11	8	21	6	8.8	11.2	12.6	1194.8	12.2	12.9	4.733333	0
45969	2025	11	11	8	22	6	9.1	10.6	12.6	1144.5	12.2	12.9	5.208333	0
45969	2025	11	11	8	23	6	9.3	10	12.9	1092.9	12.2	12.8	5.9	0
45969	2025	11	11	8	24	6	9.6	9.7	13.3	1034.9	12.2	12.5	6.633333	0
45970	2025	11	11	9	1	7	9.8	9	13.3	972.7	8.1	12.3	7.408333	0
45970	2025	11	11	9	2	7	10.1	7.5	13.9	943.7	8.1	11.9	8.241667	0
45970	2025	11	11	9	3	7	10.3	6.4	13.4	923.5	8.1	11.4	9.066667	0
45970	2025	11	11	9	4	7	10.4	5	13.6	921.3	8.1	10.8	9.916667	0
45970	2025	11	11	9	5	7	10.4	4	13.3	931.3	8.1	10.1	10.74167	0
45970	2025	11	11	9	6	7	10.4	3.8	12.8	948.3	8.1	9.3	11.53333	0
45970	2025	11	11	9	7	7	10.4	3.2	12.2	990.8	8.1	8.5	12.18333	0
45970	2025	11	11	9	8	7	10.2	2.7	11.2	1052.8	8.1	7.7	12.625	0
45970	2025	11	11	9	9	7	9.9	3.4	10.6	1131.1	8.1	6.9	12.875	0
45970	2025	11	11	9	10	7	9.6	4.3	10	1239.3	8.1	6.3	12.925	0
45970	2025	11	11	9	11	7	9.3	5.5	9.7	1207.0	8.1	5.8	12.75833	0
45970	2025	11	11	9	12	7	9.0	6.4	9	1167.5	8.1	5.4	12.54167	0
45970	2025	11	11	9	13	7	8.7	7.6	7.5	1140.4	8.1	5.1	12.275	0
45970	2025	11	11	9	14	7	8.5	7.4	6.4	1071.2	8.1	5.0	11.91667	0
45970	2025	11	11	9	15	7	8.2	8.4	5	1086.9	8.1	5.0	11.43333	0
45970	2025	11	11	9	16	7	8.0	8.5	4	1099.6	8.1	5.1	10.80833	0
45970	2025	11	11	9	17	7	7.8	7.7	3.8	1161.8	8.1	5.4	10.10833	0
45970	2025	11	11	9	18	7	7.5	6.4	3.2	1307.8	8.1	5.7	9.308333	0
45970	2025	11	11	9	19	7	7.2	6.2	2.7	1382.4	8.1	6.0	8.516667	0
45970	2025	11	11	9	20	7	7.0	5.6	3.4	1372.1	8.1	6.2	7.716667	0
45970	2025	11	11	9	21	7	6.7	4.8	4.3	1348.9	8.1	6.5	6.925	0
45970	2025	11	11	9	22	7	6.4	4.1	5.5	1315.0	8.1	6.6	6.275	0
45970	2025	11	11	9	23	7	6.2	3.9	6.4	1250.7	8.1	6		

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLa	gTemp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLa	Weekdays	
45971	2025	11	10	10	12	1	6.2	8.3	4	1350.5	22.1	6.0	6.416667	1
45971	2025	11	10	10	13	1	6.3	9	4.4	1354.4	22.1	6.4	6.2	1
45971	2025	11	10	10	14	1	6.3	10	4.9	1322.1	22.1	6.8	5.9	1
45971	2025	11	10	10	15	1	6.4	10.8	4.8	1265.0	22.1	7.2	5.65	1
45971	2025	11	10	10	16	1	6.5	11.2	5.6	1270.0	22.1	7.7	5.358333	1
45971	2025	11	10	10	17	1	6.7	11.9	6.6	1273.5	22.1	8.3	5.05	1
45971	2025	11	10	10	18	1	6.8	13.9	6.4	1317.0	22.1	8.8	4.875	1
45971	2025	11	10	10	19	1	7.1	13.8	7.1	1336.7	22.1	9.4	4.891667	1
45971	2025	11	10	10	20	1	7.5	13.8	7.9	1268.6	22.1	10.0	4.908333	1
45971	2025	11	10	10	21	1	7.8	14.7	8.2	1213.8	22.1	10.6	5.033333	1
45971	2025	11	10	10	22	1	8.2	13.5	8.1	1165.2	22.1	11.1	5.291667	1
45971	2025	11	10	10	23	1	8.6	13.6	8.3	1087.5	22.1	11.6	5.633333	1
45971	2025	11	10	10	24	1	9.0	13.6	9	1004.2	22.1	12.0	5.983333	1
45972	2025	11	11	1	2	2	9.4	13.7	10	935.9	14.0	12.5	6.358333	0
45972	2025	11	11	2	2	2	9.8	13.5	10.8	864.6	14.0	12.9	6.775	0
45972	2025	11	11	3	2	2	10.2	14.3	11.2	819.6	14.0	13.2	7.241667	0
45972	2025	11	11	4	2	2	10.6	13.9	11.9	787.9	14.0	13.5	7.733333	0
45972	2025	11	11	5	2	2	11.0	14.4	13.9	786.3	14.0	13.7	8.266667	0
45972	2025	11	11	6	2	2	11.3	14.8	13.8	768.3	14.0	13.9	8.791667	0
45972	2025	11	11	7	2	2	11.7	14.4	13.8	796.5	14.0	14.0	9.4	0
45972	2025	11	11	8	2	2	12.0	13.2	14.7	853.5	14.0	14.0	10.01667	0
45972	2025	11	11	9	2	2	12.3	12.6	13.5	929.7	14.0	14.0	10.575	0
45972	2025	11	11	10	2	2	12.5	11.7	13.6	988.1	14.0	13.8	11.14167	0
45972	2025	11	11	11	2	2	12.6	11.2	13.6	1055.2	14.0	13.6	11.58333	0
45972	2025	11	11	12	2	2	12.7	10.7	13.7	1080.3	14.0	13.4	12.04167	0
45972	2025	11	11	13	2	2	12.8	10.2	13.5	1084.6	14.0	13.2	12.48333	0
45972	2025	11	11	14	2	2	12.9	10.4	14.3	1111.3	14.0	12.9	12.875	0
45972	2025	11	11	15	2	2	12.9	10.4	13.9	1165.0	14.0	12.7	13.16667	0
45972	2025	11	11	16	2	2	12.9	10.3	14.4	1138.9	14.0	12.3	13.45833	0
45972	2025	11	11	17	2	2	12.9	9.3	14.8	1172.1	14.0	12.0	13.68333	0
45972	2025	11	11	18	2	2	12.7	8.9	14.4	1250.3	14.0	11.6	13.89167	0
45972	2025	11	11	19	2	2	12.5	5.7	13.2	1310.3	14.0	11.1	13.96667	0
45972	2025	11	11	20	2	2	12.2	4.2	12.6	1279.3	14.0	10.4	14.01667	0
45972	2025	11	11	21	2	2	11.8	3.7	11.7	1193.4	14.0	9.6	13.96667	0
45972	2025	11	11	22	2	2	11.3	4	11.2	1190.5	14.0	8.9	13.79167	0
45972	2025	11	11	23	2	2	10.9	4.5	10.7	1158.1	14.0	8.3	13.64167	0
45972	2025	11	11	24	2	2	10.6	3.9	10.2	1089.7	14.0	7.7	13.44167	0
45973	2025	11	12	1	3	3	10.2	3.3	10.4	1056.8	18.1	7.1	13.2	1
45973	2025	11	12	2	3	3	9.7	2.8	10.4	1035.1	18.1	6.6	12.90833	1
45973	2025	11	12	3	3	3	9.3	2.4	10.3	1027.7	18.1	5.9	12.65	1
45973	2025	11	12	4	3	3	8.8	1.9	9.3	1015.6	18.1	5.3	12.325	1
45973	2025	11	12	5	3	3	8.3	1.5	8.9	1021.6	18.1	4.6	12.025	1
45973	2025	11	12	6	3	3	7.8	1.6	5.7	1051.3	18.1	3.9	11.6	1
45973	2025	11	12	7	3	3	7.2	1.5	4.2	1181.2	18.1	3.3	11.10833	1
45973	2025	11	12	8	3	3	6.7	0.2	3.7	1293.6	18.1	2.9	10.38333	1
45973	2025	11	12	9	3	3	6.1	1.2	4	1388.8	18.1	2.6	9.633333	1
45973	2025	11	12	10	3	3	5.6	1.8	4.5	1426.6	18.1	2.4	8.891667	1
45973	2025	11	12	11	3	3	5.2	2.3	3.9	1413.8	18.1	2.2	8.25	1
45973	2025	11	12	12	3	3	4.9	3.2	3.3	1359.8	18.1	2.0	7.691667	1
45973	2025	11	12	13	3	3	4.6	4.5	2.8	1338.6	18.1	2.0	7.125	1
45973	2025	11	12	14	3	3	4.3	6	2.4	1306.2	18.1	2.1	6.55	1
45973	2025	11	12	15	3	3	4.1	6.5	1.9	1291.1	18.1	2.3	5.916667	1
45973	2025	11	12	16	3	3	4.0	6.5	1.5	1285.2	18.1	2.7	5.25	1
45973	2025	11	12	17	3	3	3.8	6.1	1.6	1278.7	18.1	3.1	4.55	1
45973	2025	11	12	18	3	3	3.7	5.4	1.5	1375.9	18.1	3.5	3.9	1
45973	2025	11	12	19	3	3	3.5	5.6	0.2	1462.5	18.1	3.8	3.291667	1
45973	2025	11	12	20	3	3	3.5	5.5	1.2	1455.7	18.1	4.1	2.941667	1
45973	2025	11	12	21	3	3	3.6	5.3	1.8	1435.1	18.1	4.6	2.608333	1
45973	2025	11	12	22	3	3	3.6	5.3	2.3	1387.2	18.1	4.9	2.4	1
45973	2025	11	12	23	3	3	3.7	5.3	3.2	1297.5	18.1	5.2	2.216667	1
45973	2025	11	12	24	3	3	3.7	5.1	4.5	1186.9	18.1	5.4	2.033333	1
45974	2025	11	13	1	4	4	3.8	5.4	6	1168.7	9.0	5.6	1.975	1
45974	2025	11	13	2	4	4	3.9	4.9	6.5	1132.5	9.0	5.7	2.075	1
45974	2025	11	13	3	4	4	4.0	4.6	6.5	1101.1	9.0	5.6	2.341667	1
45974	2025	11	13	4	4	4	4.1	4.5	6.1	1079.9	9.0	5.4	2.683333	1
45974	2025	11	13	5	4	4	4.2	4.6	5.4	1074.2	9.0	5.3	3.066667	1
45974	2025	11	13	6	4	4	4.3	4.6	5.6	1085.9	9.0	5.1	3.45	1
45974	2025	11	13	7	4	4	4.4	5	5.5	1206.5	9.0	5.1	3.766667	1
45974	2025	11	13	8	4	4	4.6	4.9	5.3	1285.2	9.0	5.0	4.108333	1
45974	2025	11	13	9	4	4	4.8	4.7	5.3	1362.1	9.0	5.0	4.55	1
45974	2025	11	13	10	4	4	4.9	4.8	5.3	1378.5	9.0	4.9	4.891667	1
45974	2025	11	13	11	4	4	5.0	5.2	5.1	1362.2	9.0	4.9	5.183333	1
45974	2025	11	13	12	4	4	5.1	5.5	5.4	1360.4	9.0	4.9	5.433333	1
45974	2025	11	13	13	4	4	5.2	4.9	4.9	1352.3	9.0	4.9	5.591667	1
45974	2025	11	13	14	4	4	5.3	5	4.6	1344.6	9.0	4.9	5.666667	1
45974	2025	11	13	15	4	4	5.2	4.8	4.5	1340.1	9.0	4.9	5.575	1
45974	2025	11	13	16	4	4	5.1	4.9	4.6	1340.6	9.0	4.9	5.416667	1
45974	2025	11	13	17	4	4	5.1	4.7	4.6	1369.3	9.0	4.9	5.25	1
45974	2025	11	13	18	4	4	5.0	4	5	1432.4	9.0	4.9	5.125	1
45974	2025	11	13	19	4	4	5.0	3.4	4.9	1494.7	9.0	4.9	5.058333	1
45974	2025	11	13	20	4	4	4.9	3.5	4.7	1464.4	9.0	4.7	5.008333	1
45974	2025	11	13	21	4	4	4.8	3.3	4.8	1425.0	9.0	4.6	4.958333	1
45974	2025	11	13	22	4	4	4.7	3	5.2	1380.7	9.0	4.5	4.908333	1
45974	2025	11	13	23	4	4	4.6	3	5.5	1312.2	9.0	4.4	4.866667	1
45974	2025	11	13	24	4	4	4.5	2.9	4.9	1212.3	9.0	4.2	4.858333	1
45975	2025	11	14	1	5	5	4.4	2.8	5	1181.1	17.4	4.0	4.891667	1
45975	2025	11	14	2	5	5	4.3	2.8	4.8	1129.1	17.4	3.8	4.85	1
45975	2025	11	14	3	5	5	4.2	2.5	4.9	1093.7	17.4	3.6	4.858333	1
45975	2025	11	14	4	5	5	4.1	2.6	4.7	1061.4	17.4	3.4	4.875	1
45975	2025	11	14	5	5	5	4.1	2.5	4	1063.0	17.4	3.2	4.908333	1
45975	2025	11	14	6	5	5	4.0	2.9	3.4	1094.0	17.4	3.0	4.916667	1
45975	2025	11	14	7	5	5	3.9	3	3.5	1126.9	17.4	2.9	4.866667	1
45975	2025	11	14	8	5	5	3.8	3	3.3	1247.5	17.4	2.9	4.733333	1
45975	2025	11	14	9	5	5	3.7	3.7	3	1336.2	17.4	2.9	4.616667	1
45975	2025	11	14	10	5	5	3.7	3.7	3	1435.6	17.4	2.9	4.5	1
45975	2025	11	14	11	5	5	3.7	4.8	2.9	1393.7				

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLag	Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLag	Weekdays	
45975	2025	11	14	14	24	5	3.3	1.5	5.2	1298.2	17.4	3.5	3.1	1
45976	2025	11	15	15	1	6	3.3	1	5.2	1259.6	10.5	3.2	3.275	0
45976	2025	11	15	15	2	6	3.2	0.3	4.6	1218.7	10.5	2.9	3.475	0
45976	2025	11	15	15	3	6	3.1	-0.2	4.3	1195.4	10.5	2.5	3.675	0
45976	2025	11	15	15	4	6	3.0	-0.5	4	1168.0	10.5	2.1	3.85	0
45976	2025	11	15	15	5	6	2.8	-0.5	2.4	1160.8	10.5	1.7	3.991667	0
45976	2025	11	15	15	6	6	2.7	-0.2	2.2	1163.5	10.5	1.3	4.116667	0
45976	2025	11	15	15	7	6	2.6	-0.1	2.6	1197.3	10.5	1.1	4.075	0
45976	2025	11	15	15	8	6	2.5	0	2.5	1258.5	10.5	0.9	4.008333	0
45976	2025	11	15	15	9	6	2.3	0	2.3	1334.6	10.5	0.7	3.975	0
45976	2025	11	15	15	10	6	2.2	-0.1	2.1	1411.0	10.5	0.5	3.875	0
45976	2025	11	15	15	11	6	2.0	0.3	1.5	1499.6	10.5	0.3	3.758333	0
45976	2025	11	15	15	12	6	1.8	0.5	1	1454.5	10.5	0.1	3.533333	0
45976	2025	11	15	15	13	6	1.6	1.1	0.3	1436.1	10.5	0.0	3.241667	0
45976	2025	11	15	15	14	6	1.5	2.1	-0.2	1396.4	10.5	0.1	2.891667	0
45976	2025	11	15	15	15	6	1.3	2.8	-0.5	1347.3	10.5	0.2	2.483333	0
45976	2025	11	15	15	16	6	1.3	3.3	-0.5	1327.5	10.5	0.5	2.083333	0
45976	2025	11	15	15	17	6	1.2	3.6	-0.2	1393.3	10.5	0.8	1.683333	0
45976	2025	11	15	15	18	6	1.2	2.3	-0.1	1455.4	10.5	1.1	1.308333	0
45976	2025	11	15	15	19	6	1.2	1.9	0	1532.4	10.5	1.3	1.091667	0
45976	2025	11	15	15	20	6	1.2	2	0	1495.4	10.5	1.5	0.9	0
45976	2025	11	15	15	21	6	1.2	1.6	-0.1	1412.5	10.5	1.7	0.683333	0
45976	2025	11	15	15	22	6	1.1	1.5	0.3	1387.7	10.5	1.8	0.475	0
45976	2025	11	15	15	23	6	1.1	1.4	0.5	1377.2	10.5	1.9	0.275	0
45976	2025	11	15	15	24	6	1.1	1.1	1.1	1313.3	10.5	2.0	0.125	0
45977	2025	11	16	16	1	7	1.1	1.6	2.1	1257.8	16.6	2.1	0.041667	0
45977	2025	11	16	16	2	7	1.1	1.9	2.8	1205.7	16.6	2.1	0.05	0
45977	2025	11	16	16	3	7	1.1	3	3.3	1165.5	16.6	2.1	0.2	0
45977	2025	11	16	16	4	7	1.3	3.2	3.6	1203.3	16.6	2.1	0.45	0
45977	2025	11	16	16	5	7	1.4	3.3	2.3	1191.7	16.6	2.1	0.766667	0
45977	2025	11	16	16	6	7	1.6	3.4	1.9	1142.3	16.6	2.1	1.108333	0
45977	2025	11	16	16	7	7	1.7	3.5	2	1162.9	16.6	2.2	1.316667	0
45977	2025	11	16	16	8	7	1.9	4.2	1.6	1202.2	16.6	2.3	1.483333	0
45977	2025	11	16	16	9	7	2.1	6.3	1.5	1244.8	16.6	2.5	1.65	0
45977	2025	11	16	16	10	7	2.3	6.5	1.4	1253.8	16.6	2.9	1.783333	0
45977	2025	11	16	16	11	7	2.6	6.9	1.1	1325.9	16.6	3.3	1.916667	0
45977	2025	11	16	16	12	7	2.9	7.1	1.6	1374.9	16.6	3.7	2.008333	0
45977	2025	11	16	16	13	7	3.2	7.9	1.9	1403.5	16.6	4.2	2.058333	0
45977	2025	11	16	16	14	7	3.4	8	3	1406.5	16.6	4.8	2.1	0
45977	2025	11	16	16	15	7	3.7	8.4	3.2	1386.9	16.6	5.3	2.083333	0
45977	2025	11	16	16	16	7	3.9	8.9	3.3	1369.8	16.6	5.7	2.1	0
45977	2025	11	16	16	17	7	4.1	9.6	3.4	1372.2	16.6	6.2	2.091667	0
45977	2025	11	16	16	18	7	4.4	10.3	3.5	1432.5	16.6	6.7	2.066667	0
45977	2025	11	16	16	19	7	4.7	9.7	4.2	1459.3	16.6	7.3	2.158333	0
45977	2025	11	16	16	20	7	5.1	9.3	6.3	1394.1	16.6	7.8	2.291667	0
45977	2025	11	16	16	21	7	5.4	8.3	6.5	1344.6	16.6	8.2	2.475	0
45977	2025	11	16	16	22	7	5.6	7.9	6.9	1286.5	16.6	8.4	2.866667	0
45977	2025	11	16	16	23	7	5.9	7.8	7.1	1217.8	16.6	8.5	3.283333	0
45977	2025	11	16	16	24	7	6.2	6.4	7.9	1128.7	16.6	8.6	3.741667	0
45978	2025	11	17	17	1	1	6.4	5.6	8	1055.4	23.4	8.5	4.241667	1
45978	2025	11	17	17	2	1	6.6	5	8.4	1008.0	23.4	8.4	4.766667	1
45978	2025	11	17	17	3	1	6.7	4	8.9	992.7	23.4	8.1	5.275	1
45978	2025	11	17	17	4	1	6.7	3.7	9.6	993.8	23.4	7.7	5.725	1
45978	2025	11	17	17	5	1	6.8	3.3	10.3	1005.4	23.4	7.3	6.2	1
45978	2025	11	17	17	6	1	6.8	3.1	9.7	1031.5	23.4	6.8	6.725	1
45978	2025	11	17	17	7	1	6.7	2.8	9.3	1118.8	23.4	6.2	7.3	1
45978	2025	11	17	17	8	1	6.7	2.4	8.3	1264.1	23.4	5.6	7.816667	1
45978	2025	11	17	17	9	1	6.6	2.9	7.9	1379.7	23.4	5.0	8.241667	1
45978	2025	11	17	17	10	1	6.5	3	7.8	1417.2	23.4	4.6	8.408333	1
45978	2025	11	17	17	11	1	6.3	2.6	6.4	1427.3	23.4	4.2	8.525	1
45978	2025	11	17	17	12	1	6.2	3.2	5.6	1436.9	23.4	3.7	8.6	1
45978	2025	11	17	17	13	1	6.0	3.2	5	1447.9	23.4	3.5	8.541667	1
45978	2025	11	17	17	14	1	5.8	3.8	4	1452.3	23.4	3.3	8.35	1
45978	2025	11	17	17	15	1	5.6	4.3	3.7	1432.0	23.4	3.2	8.1	1
45978	2025	11	17	17	16	1	5.5	4.3	3.3	1415.3	23.4	3.2	7.733333	1
45978	2025	11	17	17	17	1	5.3	4.2	3.1	1435.9	23.4	3.2	7.3	1
45978	2025	11	17	17	18	1	5.0	3.9	2.8	1555.3	23.4	3.3	6.775	1
45978	2025	11	17	17	19	1	4.8	3.9	2.4	1580.8	23.4	3.4	6.175	1
45978	2025	11	17	17	20	1	4.5	3.9	2.9	1510.0	23.4	3.5	5.6	1
45978	2025	11	17	17	21	1	4.3	3.7	3	1465.5	23.4	3.6	5.025	1
45978	2025	11	17	17	22	1	4.1	3.4	2.6	1437.7	23.4	3.7	4.575	1
45978	2025	11	17	17	23	1	3.9	3.5	3.2	1371.4	23.4	3.7	4.166667	1
45978	2025	11	17	17	24	1	3.8	3.2	3.2	1280.9	23.4	3.8	3.733333	1
45979	2025	11	18	18	1	2	3.6	2.9	3.8	1216.8	17.3	3.8	3.466667	1
45979	2025	11	18	18	2	2	3.5	3.1	4.3	1166.4	17.3	3.8	3.266667	1
45979	2025	11	18	18	3	2	3.4	2.9	4.3	1131.0	17.3	3.7	3.166667	1
45979	2025	11	18	18	4	2	3.4	2.9	4.2	1102.3	17.3	3.6	3.191667	1
45979	2025	11	18	18	5	2	3.4	2.9	3.9	1103.7	17.3	3.5	3.241667	1
45979	2025	11	18	18	6	2	3.3	3	3.9	1118.7	17.3	3.4	3.316667	1
45979	2025	11	18	18	7	2	3.3	3	3.9	1175.9	17.3	3.3	3.383333	1
45979	2025	11	18	18	8	2	3.3	3	3.7	1307.9	17.3	3.2	3.475	1
45979	2025	11	18	18	9	2	3.4	3.1	3.4	1417.7	17.3	3.1	3.6	1
45979	2025	11	18	18	10	2	3.4	3.3	3.5	1445.9	17.3	3.1	3.666667	1
45979	2025	11	18	18	11	2	3.4	4.5	3.2	1408.4	17.3	3.1	3.7	1
45979	2025	11	18	18	12	2	3.5	4	2.9	1394.6	17.3	3.2	3.775	1
45979	2025	11	18	18	13	2	3.5	4.3	3.1	1380.5	17.3	3.2	3.775	1
45979	2025	11	18	18	14	2	3.5	4.1	2.9	1373.0	17.3	3.3	3.75	1
45979	2025	11	18	18	15	2	3.6	4.1	2.9	1373.8	17.3	3.4	3.691667	1
45979	2025	11	18	18	16	2	3.5	4.3	2.9	1372.3	17.3	3.5	3.575	1
45979	2025	11	18	18	17	2	3.5	4.3	3	1449.0	17.3	3.6	3.458333	1
45979	2025	11	18	18	18	2	3.6	3.6	3	1512.2	17.3	3.8	3.35	1
45979	2025	11	18	18	19	2	3.5	3.6	3	1577.9	17.3	3.8	3.275	1
45979	2025	11	18	18	20	2	3.5	3.5	3.1	1538.2	17.3	3.9	3.2	1
45979	2025	11	18	18	21	2	3.5	3.3	3.3	1504.6	17.3	3.9	3.125	1
45979	2025	11	18	18	22	2	3.5	3.4	4.5	1437.1	17.3	3.9	3.075	1
45979	2025	11	18	18	23	2	3.5	3.2	4	1371.9	17.3	3.9	3.066667	1
45979														

DATE	Year	Month	Day	HOUR	DOW	24hrAvgLag	Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLag	Weekdays	
45980	2025	11	19	19	12	3	3.3	6.4	3.3	1320.2	10.8	2.7	3.808333	1
45980	2025	11	19	19	13	3	3.4	7	2.9	1258.8	10.8	3.0	3.741667	1
45980	2025	11	19	19	14	3	3.5	6.9	2.6	1221.7	10.8	3.3	3.658333	1
45980	2025	11	19	19	15	3	3.6	7.5	2.4	1235.4	10.8	3.6	3.558333	1
45980	2025	11	19	19	16	3	3.7	6.4	2.2	1238.1	10.8	4.0	3.433333	1
45980	2025	11	19	19	17	3	3.8	6.2	1.8	1319.2	10.8	4.4	3.275	1
45980	2025	11	19	19	18	3	3.9	5.5	1.6	1427.1	10.8	4.7	3.1	1
45980	2025	11	19	19	19	3	4.0	5.4	1.8	1489.0	10.8	5.0	2.95	1
45980	2025	11	19	19	20	3	4.1	4.5	2.2	1480.3	10.8	5.3	2.783333	1
45980	2025	11	19	19	21	3	4.1	3.8	3.5	1465.2	10.8	5.6	2.641667	1
45980	2025	11	19	19	22	3	4.1	2.9	5.2	1433.3	10.8	5.7	2.55	1
45980	2025	11	19	19	23	3	4.1	2.8	6.4	1376.6	10.8	5.6	2.558333	1
45980	2025	11	19	19	24	3	4.1	2.4	7	1343.7	10.8	5.4	2.725	1
45981	2025	11	20	1	4	4	4.1	1.7	6.9	1306.7	5.3	5.1	2.991667	1
45981	2025	11	20	2	4	4	4.0	1.1	7.5	1275.6	5.3	4.7	3.3	1
45981	2025	11	20	3	4	4	3.9	0.5	6.4	1252.2	5.3	4.2	3.633333	1
45981	2025	11	20	4	4	4	3.8	0.5	6.2	1235.8	5.3	3.6	4.041667	1
45981	2025	11	20	5	4	4	3.7	0.5	5.5	1244.0	5.3	3.1	4.375	1
45981	2025	11	20	6	4	4	3.7	-0.4	5.4	1354.8	5.3	2.6	4.708333	1
45981	2025	11	20	7	4	4	3.6	0	4.5	1369.0	5.3	2.1	5.016667	1
45981	2025	11	20	8	4	4	3.5	-0.8	3.8	1502.9	5.3	1.7	5.333333	1
45981	2025	11	20	9	4	4	3.4	0.5	2.9	1613.5	5.3	1.3	5.558333	1
45981	2025	11	20	10	4	4	3.3	2.5	2.8	1587.2	5.3	1.0	5.691667	1
45981	2025	11	20	11	4	4	3.3	3.2	2.4	1484.7	5.3	0.9	5.641667	1
45981	2025	11	20	12	4	4	3.2	3.9	1.7	1398.9	5.3	1.0	5.441667	1
45981	2025	11	20	13	4	4	3.1	6.2	1.1	1331.0	5.3	1.1	5.108333	1
45981	2025	11	20	14	4	4	3.1	6.5	0.5	1281.2	5.3	1.5	4.666667	1
45981	2025	11	20	15	4	4	3.1	7.3	0.5	1253.2	5.3	1.9	4.183333	1
45981	2025	11	20	16	4	4	3.0	7.3	0.5	1256.2	5.3	2.5	3.6	1
45981	2025	11	20	17	4	4	3.1	6	-0.4	1306.1	5.3	3.1	3.108333	1
45981	2025	11	20	18	4	4	3.1	3.9	0	1423.2	5.3	3.5	2.633333	1
45981	2025	11	20	19	4	4	3.0	3.4	-0.8	1533.9	5.3	3.9	2.141667	1
45981	2025	11	20	20	4	4	2.9	2.4	0.5	1538.3	5.3	4.2	1.691667	1
45981	2025	11	20	21	4	4	2.8	2.7	2.5	1543.6	5.3	4.4	1.25	1
45981	2025	11	20	22	4	4	2.8	1.8	3.2	1531.6	5.3	4.6	0.975	1
45981	2025	11	20	23	4	4	2.7	1.6	3.9	1486.8	5.3	4.6	0.941667	1
45981	2025	11	20	24	4	4	2.7	1.4	6.2	1424.2	5.3	4.4	0.975	1
45982	2025	11	21	1	5	5	2.7	0.7	6.5	1386.4	6.9	4.2	1.1	1
45982	2025	11	21	2	5	5	2.6	0.4	7.3	1348.8	6.9	3.8	1.475	1
45982	2025	11	21	3	5	5	2.6	-0.3	7.3	1327.7	6.9	3.2	1.925	1
45982	2025	11	21	4	5	5	2.6	-0.3	6	1307.2	6.9	2.6	2.491667	1
45982	2025	11	21	5	5	5	2.5	0.5	3.9	1311.5	6.9	2.0	3.058333	1
45982	2025	11	21	6	5	5	2.5	-0.3	3.4	1331.5	6.9	1.5	3.516667	1
45982	2025	11	21	7	5	5	2.5	0	2.4	1394.8	6.9	1.2	3.875	1
45982	2025	11	21	8	5	5	2.5	0.3	2.7	1514.9	6.9	0.9	4.158333	1
45982	2025	11	21	9	5	5	2.6	0.8	1.8	1613.6	6.9	0.7	4.425	1
45982	2025	11	21	10	5	5	2.6	2.3	1.6	1590.3	6.9	0.6	4.608333	1
45982	2025	11	21	11	5	5	2.6	3.6	1.4	1459.6	6.9	0.6	4.55	1
45982	2025	11	21	12	5	5	2.6	5.4	0.7	1411.3	6.9	0.8	4.416667	1
45982	2025	11	21	13	5	5	2.7	6.4	0.4	1366.1	6.9	1.1	4.208333	1
45982	2025	11	21	14	5	5	2.7	6.9	-0.3	1311.3	6.9	1.6	3.75	1
45982	2025	11	21	15	5	5	2.7	7.1	-0.3	1310.9	6.9	2.1	3.241667	1
45982	2025	11	21	16	5	5	2.7	7.1	0.5	1325.5	6.9	2.7	2.608333	1
45982	2025	11	21	17	5	5	2.7	7.1	-0.3	1355.5	6.9	3.3	1.975	1
45982	2025	11	21	18	5	5	2.7	6.1	0	1412.1	6.9	3.9	1.516667	1
45982	2025	11	21	19	5	5	2.8	4.6	0.3	1498.0	6.9	4.4	1.166667	1
45982	2025	11	21	20	5	5	2.8	3.6	0.8	1483.5	6.9	4.8	0.883333	1
45982	2025	11	21	21	5	5	2.9	3.4	2.3	1458.6	6.9	5.1	0.708333	1
45982	2025	11	21	22	5	5	2.9	3	3.6	1379.2	6.9	5.3	0.55	1
45982	2025	11	21	23	5	5	3.0	3	5.4	1361.3	6.9	5.4	0.591667	1
45982	2025	11	21	24	5	5	3.0	2.7	6.4	1299.8	6.9	5.3	0.758333	1
45983	2025	11	22	1	6	6	3.1	2.4	6.9	1248.7	8.5	5.1	1.091667	0
45983	2025	11	22	2	6	6	3.2	2.1	7.1	1198.0	8.5	4.8	1.566667	0
45983	2025	11	22	3	6	6	3.2	2.6	7.1	1150.7	8.5	4.4	2.108333	0
45983	2025	11	22	4	6	6	3.4	3.9	7.1	1107.3	8.5	4.0	2.725	0
45983	2025	11	22	5	6	6	3.5	4.8	6.1	1080.7	8.5	3.7	3.341667	0
45983	2025	11	22	6	6	6	3.7	5.4	4.6	1071.7	8.5	3.5	3.891667	0
45983	2025	11	22	7	6	6	3.9	6.7	3.6	1086.9	8.5	3.5	4.425	0
45983	2025	11	22	8	6	6	4.2	6.7	3.4	1133.2	8.5	3.6	4.808333	0
45983	2025	11	22	9	6	6	4.5	6.5	3	1203.6	8.5	3.9	5.083333	0
45983	2025	11	22	10	6	6	4.7	7.2	3	1301.2	8.5	4.2	5.3	0
45983	2025	11	22	11	6	6	4.9	8	2.7	1345.3	8.5	4.5	5.358333	0
45983	2025	11	22	12	6	6	5.1	8.7	2.4	1326.0	8.5	4.9	5.308333	0
45983	2025	11	22	13	6	6	5.3	9.4	2.1	1316.8	8.5	5.4	5.083333	0
45983	2025	11	22	14	6	6	5.4	8.7	2.6	1316.8	8.5	6.0	4.75	0
45983	2025	11	22	15	6	6	5.5	8.5	3.9	1297.8	8.5	6.6	4.35	0
45983	2025	11	22	16	6	6	5.5	8.2	4.8	1347.4	8.5	7.0	3.975	0
45983	2025	11	22	17	6	6	5.6	6.8	5.4	1386.2	8.5	7.4	3.708333	0
45983	2025	11	22	18	6	6	5.5	6.1	6.7	1418.5	8.5	7.6	3.516667	0
45983	2025	11	22	19	6	6	5.5	5.8	6.7	1443.5	8.5	7.6	3.458333	0
45983	2025	11	22	20	6	6	5.6	5.1	6.5	1352.4	8.5	7.6	3.633333	0
45983	2025	11	22	21	6	6	5.7	4.7	7.2	1314.3	8.5	7.4	3.891667	0
45983	2025	11	22	22	6	6	5.7	4.7	8	1308.8	8.5	7.3	4.15	0
45983	2025	11	22	23	6	6	5.8	4.5	8.7	1270.9	8.5	7.1	4.5	0
45983	2025	11	22	24	6	6	5.8	3.4	9.4	1217.4	8.5	6.8	4.916667	0
45984	2025	11	23	1	7	7	5.9	2.3	8.7	1168.5	7.7	6.3	5.416667	0
45984	2025	11	23	2	7	7	5.9	1.2	8.5	1135.1	7.7	5.7	6	0
45984	2025	11	23	3	7	7	5.8	0.4	8.2	1124.2	7.7	5.1	6.55	0
45984	2025	11	23	4	7	7	5.7	-0.1	6.8	1119.6	7.7	4.4	7.041667	0
45984	2025	11	23	5	7	7	5.6	-0.4	6.1	1128.1	7.7	3.7	7.4	0
45984	2025	11	23	6	7	7	5.4	0	5.8	1150.4	7.7	3.1	7.566667	0
45984	2025	11	23	7	7	7	5.1	0	5.1	1184.6	7.7	2.6	7.625	0
45984	2025	11	23	8	7	7	4.9	-0.1	4.7	1243.6	7.7	2.2	7.55	0
45984	2025	11	23	9	7	7	4.6	0.4	4.7	1309.5	7.7	1.7	7.416667	0
45984	2025	11	23	10	7	7	4.3	1.7	4.5	1345.6	7.7	1.4	7.266667	0
45984	2025	11	23	11	7	7	4.1	2.4	3.4	1338.8	7.7	1.1	7.058333	0
45984	2025	11	23	12	7	7	3.9	2.8	2.3	1310.0	7.7	0.9	6.76666	

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLag	Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLag	Weekdays	
45984	2025	11	11	23	24	7	2.1	1.8	3.8	1300.1	7.7	3.3	0.933333	0
45985	2025	11	11	24	1	1	2.0	1.7	5.1	1263.3	6.9	3.2	0.883333	1
45985	2025	11	11	24	2	1	2.0	1.9	5.7	1206.5	6.9	3.0	1.008333	1
45985	2025	11	11	24	3	1	2.0	1.9	4.6	1183.0	6.9	2.8	1.333333	1
45985	2025	11	11	24	4	1	2.1	1.7	4.4	1173.4	6.9	2.4	1.775	1
45985	2025	11	11	24	5	1	2.2	1.4	3.4	1175.9	6.9	2.2	2.166667	1
45985	2025	11	11	24	6	1	2.3	1.6	2.4	1267.0	6.9	2.0	2.566667	1
45985	2025	11	11	24	7	1	2.3	1.5	1.9	1293.5	6.9	1.8	2.85	1
45985	2025	11	11	24	8	1	2.4	1.9	1.5	1403.9	6.9	1.7	3.05	1
45985	2025	11	11	24	9	1	2.5	2.1	2.3	1509.3	6.9	1.7	3.216667	1
45985	2025	11	11	24	10	1	2.5	2.7	1.5	1533.2	6.9	1.8	3.308333	1
45985	2025	11	11	24	11	1	2.6	2.9	1.8	1499.3	6.9	1.8	3.358333	1
45985	2025	11	11	24	12	1	2.6	3.1	1.7	1470.3	6.9	1.9	3.283333	1
45985	2025	11	11	24	13	1	2.6	2.9	1.9	1450.4	6.9	2.0	3.2	1
45985	2025	11	11	24	14	1	2.6	3.3	1.9	1441.1	6.9	2.1	3.025	1
45985	2025	11	11	24	15	1	2.5	2.5	1.7	1374.3	6.9	2.3	2.758333	1
45985	2025	11	11	24	16	1	2.4	2	1.4	1402.6	6.9	2.3	2.441667	1
45985	2025	11	11	24	17	1	2.3	2.1	1.6	1440.3	6.9	2.3	2.2	1
45985	2025	11	11	24	18	1	2.2	2.2	1.5	1532.6	6.9	2.4	1.95	1
45985	2025	11	11	24	19	1	2.1	2.2	1.9	1594.6	6.9	2.4	1.8	1
45985	2025	11	11	24	20	1	2.1	1.4	2.1	1565.4	6.9	2.5	1.725	1
45985	2025	11	11	24	21	1	2.1	1.1	2.7	1510.8	6.9	2.5	1.725	1
45985	2025	11	11	24	22	1	2.1	0.6	2.9	1526.0	6.9	2.4	1.775	1
45985	2025	11	11	24	23	1	2.0	0.3	3.1	1421.6	6.9	2.2	1.808333	1
45985	2025	11	11	24	24	1	2.0	-0.1	2.9	1384.7	6.9	2.0	1.925	1
45986	2025	11	11	25	1	2	1.9	-0.4	3.3	1350.5	9.5	1.7	2.033333	1
45986	2025	11	11	25	2	2	1.8	-0.7	2.5	1317.9	9.5	1.4	2.133333	1
45986	2025	11	11	25	3	2	1.7	-0.5	2	1290.1	9.5	1.1	2.25	1
45986	2025	11	11	25	4	2	1.6	-1	2.1	1266.2	9.5	0.9	2.3	1
45986	2025	11	11	25	5	2	1.5	-1.1	2.2	1261.5	9.5	0.6	2.325	1
45986	2025	11	11	25	6	2	1.4	-1.4	2.2	1288.9	9.5	0.3	2.383333	1
45986	2025	11	11	25	7	2	1.2	-1.9	1.4	1404.7	9.5	0.0	2.433333	1
45986	2025	11	11	25	8	2	1.1	-1.1	1.1	1515.4	9.5	-0.3	2.491667	1
45986	2025	11	11	25	9	2	1.0	-0.5	0.6	1602.0	9.5	-0.5	2.45	1
45986	2025	11	11	25	10	2	0.9	0.7	0.3	1572.6	9.5	-0.7	2.366667	1
45986	2025	11	11	25	11	2	0.8	2.4	-0.1	1482.3	9.5	-0.6	2.191667	1
45986	2025	11	11	25	12	2	0.8	4.4	-0.4	1419.3	9.5	-0.5	1.975	1
45986	2025	11	11	25	13	2	0.8	5.3	-0.7	1397.5	9.5	-0.1	1.708333	1
45986	2025	11	11	25	14	2	0.9	5.5	-0.5	1394.5	9.5	0.4	1.433333	1
45986	2025	11	11	25	15	2	1.0	5.6	-1	1391.7	9.5	0.9	1.1	1
45986	2025	11	11	25	16	2	1.1	5.7	-1.1	1389.9	9.5	1.4	0.85	1
45986	2025	11	11	25	17	2	1.3	6.1	-1.4	1470.2	9.5	2.0	0.6	1
45986	2025	11	11	25	18	2	1.5	6.3	-1.9	1474.4	9.5	2.6	0.333333	1
45986	2025	11	11	25	19	2	1.6	6.3	-1.1	1543.2	9.5	3.2	0.033333	1
45986	2025	11	11	25	20	2	1.8	6.5	-0.5	1487.3	9.5	3.9	-0.30833	1
45986	2025	11	11	25	21	2	2.0	6.8	0.7	1391.5	9.5	4.5	-0.51667	1
45986	2025	11	11	25	22	2	2.2	6.4	2.4	1397.1	9.5	5.1	-0.65	1
45986	2025	11	11	25	23	2	2.5	6.2	4.4	1360.6	9.5	5.6	-0.64167	1
45986	2025	11	11	25	24	2	2.7	6.3	5.3	1275.8	9.5	5.9	-0.46667	1
45987	2025	11	11	26	1	3	3.0	6.5	5.5	1211.1	8.9	6.1	-0.09167	1
45987	2025	11	11	26	2	3	3.3	6.8	5.6	1149.7	8.9	6.2	0.383333	1
45987	2025	11	11	26	3	3	3.6	7.2	5.7	1108.4	8.9	6.3	0.9	1
45987	2025	11	11	26	4	3	3.9	7.3	6.1	1070.8	8.9	6.4	1.408333	1
45987	2025	11	11	26	5	3	4.3	7.3	6.3	1056.1	8.9	6.6	1.966667	1
45987	2025	11	11	26	6	3	4.6	7.9	6.3	1063.0	8.9	6.7	2.566667	1
45987	2025	11	11	26	7	3	5.0	8.5	6.5	1189.8	8.9	6.8	3.208333	1
45987	2025	11	11	26	8	3	5.4	8.1	6.8	1246.6	8.9	7.0	3.891667	1
45987	2025	11	11	26	9	3	5.8	8.1	6.4	1333.6	8.9	7.1	4.525	1
45987	2025	11	11	26	10	3	6.2	8.6	6.2	1341.4	8.9	7.2	5.133333	1
45987	2025	11	11	26	11	3	6.5	8.7	6.3	1341.2	8.9	7.4	5.608333	1
45987	2025	11	11	26	12	3	6.8	9.1	6.5	1325.6	8.9	7.6	5.925	1
45987	2025	11	11	26	13	3	7.0	9.1	6.8	1300.0	8.9	7.8	6.083333	1
45987	2025	11	11	26	14	3	7.1	9.3	7.2	1322.0	8.9	8.1	6.183333	1
45987	2025	11	11	26	15	3	7.3	9.6	7.3	1299.9	8.9	8.3	6.291667	1
45987	2025	11	11	26	16	3	7.4	10.1	7.3	1281.1	8.9	8.5	6.425	1
45987	2025	11	11	26	17	3	7.6	11.3	7.9	1346.6	8.9	8.7	6.558333	1
45987	2025	11	11	26	18	3	7.8	11.1	8.5	1363.0	8.9	9.0	6.658333	1
45987	2025	11	11	26	19	3	8.0	10.7	8.1	1404.8	8.9	9.3	6.791667	1
45987	2025	11	11	26	20	3	8.2	11	8.1	1347.4	8.9	9.5	6.975	1
45987	2025	11	11	26	21	3	8.4	10.9	8.6	1298.3	8.9	9.7	7.108333	1
45987	2025	11	11	26	22	3	8.6	10.6	8.7	1255.2	8.9	10.0	7.216667	1
45987	2025	11	11	26	23	3	8.8	10.4	9.1	1162.0	8.9	10.1	7.4	1
45987	2025	11	11	26	24	3	8.9	10.1	9.1	1118.0	8.9	10.3	7.608333	1
45988	2025	11	11	27	1	4	9.1	9.7	9.3	1057.4	9.6	10.4	7.841667	1
45988	2025	11	11	27	2	4	9.2	9.4	9.6	1004.5	9.6	10.4	8.058333	1
45988	2025	11	11	27	3	4	9.3	9.2	10.1	965.6	9.6	10.4	8.266667	1
45988	2025	11	11	27	4	4	9.4	9.3	11.3	940.6	9.6	10.4	8.466667	1
45988	2025	11	11	27	5	4	9.5	9.3	11.1	931.7	9.6	10.3	8.7	1
45988	2025	11	11	27	6	4	9.6	9.2	10.7	930.9	9.6	10.1	9.033333	1
45988	2025	11	11	27	7	4	9.6	9.2	11	1019.6	9.6	10.0	9.3	1
45988	2025	11	11	27	8	4	9.7	10.2	10.9	1117.7	9.6	9.9	9.483333	1
45988	2025	11	11	27	9	4	9.8	11.2	10.6	1180.2	9.6	9.8	9.725	1
45988	2025	11	11	27	10	4	9.9	11.1	10.4	1198.8	9.6	9.8	9.958333	1
45988	2025	11	11	27	11	4	10.0	11	10.1	1146.0	9.6	9.9	10.125	1
45988	2025	11	11	27	12	4	10.1	11.4	9.7	1168.4	9.6	9.9	10.26667	1
45988	2025	11	11	27	13	4	10.2	11.8	9.4	1124.3	9.6	10.0	10.35	1
45988	2025	11	11	27	14	4	10.3	11.5	9.2	1160.2	9.6	10.2	10.4	1
45988	2025	11	11	27	15	4	10.4	12.5	9.3	1144.3	9.6	10.4	10.40833	1
45988	2025	11	11	27	16	4	10.5	11.6	9.3	1131.1	9.6	10.6	10.375	1
45988	2025	11	11	27	17	4	10.6	9.3	9.2	1164.1	9.6	10.8	10.30833	1
45988	2025	11	11	27	18	4	10.5	7.5	9.2	1309.1	9.6	10.8	10.14167	1
45988	2025	11	11	27	19	4	10.3	6.3	10.2	1341.3	9.6	10.7	9.983333	1
45988	2025	11	11	27	20	4	10.2	5.5	11.2	1326.3	9.6	10.5	9.858333	1
45988	2025	11	11	27	21	4	9.9	5.1	11.1	1315.9	9.6	10.1	9.791667	1
45988	2025	11	11	27	22	4	9.7	5.1	11	1320.0	9.6	9.6	9.816667	1
45988	2025	11	11	27	23	4	9.5	4.2	11.4	1244.1	9.6	9.1		

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLag	Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLag	Weekdays	
45989	2025	11	11	28	12	5	6.5	5.4	3.2	1448.1	9.4	4.4	8.483333	1
45989	2025	11	11	28	13	5	6.2	5.8	3.9	1402.7	9.4	4.6	7.858333	1
45989	2025	11	11	28	14	5	6.0	5.9	4.1	1394.8	9.4	4.8	7.141667	1
45989	2025	11	11	28	15	5	5.7	6	4.7	1400.5	9.4	5.0	6.508333	1
45989	2025	11	11	28	16	5	5.5	5.3	4.3	1418.2	9.4	5.1	5.808333	1
45989	2025	11	11	28	17	5	5.2	3.9	4.5	1410.6	9.4	5.2	5.233333	1
45989	2025	11	11	28	18	5	5.0	3.7	4.8	1497.0	9.4	5.1	4.816667	1
45989	2025	11	11	28	19	5	4.8	2.2	4.7	1505.5	9.4	5.1	4.566667	1
45989	2025	11	11	28	20	5	4.6	2.5	5	1471.1	9.4	4.8	4.441667	1
45989	2025	11	11	28	21	5	4.5	2.1	4.5	1433.4	9.4	4.7	4.375	1
45989	2025	11	11	28	22	5	4.4	1.8	5.7	1452.1	9.4	4.4	4.366667	1
45989	2025	11	11	28	23	5	4.3	1.6	5.4	1393.2	9.4	4.2	4.316667	1
45989	2025	11	11	28	24	5	4.1	1.9	5.8	1332.7	9.4	3.9	4.441667	1
45990	2025	11	11	29	1	6	4.1	1.8	5.9	1296.0	15.4	3.6	4.566667	0
45990	2025	11	11	29	2	6	4.0	1.3	6	1248.7	15.4	3.2	4.783333	0
45990	2025	11	11	29	3	6	3.9	1.2	5.3	1217.4	15.4	2.8	4.95	0
45990	2025	11	11	29	4	6	3.8	0.8	3.9	1187.9	15.4	2.4	5.108333	0
45990	2025	11	11	29	5	6	3.6	0.6	3.7	1185.4	15.4	2.1	5.158333	0
45990	2025	11	11	29	6	6	3.5	0.3	2.2	1188.9	15.4	1.8	5.125	0
45990	2025	11	11	29	7	6	3.3	0	2.5	1221.4	15.4	1.5	5.058333	0
45990	2025	11	11	29	8	6	3.1	-0.1	2.1	1285.8	15.4	1.3	4.841667	0
45990	2025	11	11	29	9	6	2.9	0.2	1.8	1440.0	15.4	1.1	4.658333	0
45990	2025	11	11	29	10	6	2.7	0.9	1.6	1472.6	15.4	1.0	4.416667	0
45990	2025	11	11	29	11	6	2.5	1.4	1.9	1512.7	15.4	0.9	4.191667	0
45990	2025	11	11	29	12	6	2.4	1.6	1.8	1507.7	15.4	0.9	3.85	0
45990	2025	11	11	29	13	6	2.2	1.8	1.3	1475.2	15.4	0.8	3.558333	0
45990	2025	11	11	29	14	6	2.0	1.6	1.2	1488.5	15.4	0.8	3.225	0
45990	2025	11	11	29	15	6	1.9	1.6	0.8	1421.5	15.4	0.9	2.841667	0
45990	2025	11	11	29	16	6	1.7	1.5	0.6	1402.2	15.4	0.9	2.441667	0
45990	2025	11	11	29	17	6	1.5	1.3	0.3	1451.9	15.4	1.0	2.066667	0
45990	2025	11	11	29	18	6	1.4	1.3	0	1535.1	15.4	1.0	1.791667	0
45990	2025	11	11	29	19	6	1.3	1.2	-0.1	1578.4	15.4	1.1	1.508333	0
45990	2025	11	11	29	20	6	1.3	1.1	0.2	1569.9	15.4	1.2	1.325	0
45990	2025	11	11	29	21	6	1.2	1.2	0.9	1552.2	15.4	1.3	1.108333	0
45990	2025	11	11	29	22	6	1.2	1.1	1.4	1523.9	15.4	1.4	0.95	0
45990	2025	11	11	29	23	6	1.1	1	1.6	1428.9	15.4	1.4	0.875	0
45990	2025	11	11	29	24	6	1.1	1	1.8	1378.9	15.4	1.4	0.858333	0
45991	2025	11	11	30	1	7	1.1	0.7	1.6	1328.0	9.7	1.3	0.833333	0
45991	2025	11	11	30	2	7	1.0	0.4	1.6	1271.4	9.7	1.2	0.833333	0
45991	2025	11	11	30	3	7	1.0	0.3	1.5	1245.8	9.7	1.1	0.858333	0
45991	2025	11	11	30	4	7	1.0	0.2	1.3	1234.2	9.7	1.0	0.891667	0
45991	2025	11	11	30	5	7	0.9	0	1.3	1230.9	9.7	0.9	0.95	0
45991	2025	11	11	30	6	7	0.9	-1	1.2	1253.0	9.7	0.8	1.008333	0
45991	2025	11	11	30	7	7	0.8	-1.4	1.1	1330.7	9.7	0.6	1.091667	0
45991	2025	11	11	30	8	7	0.8	-2.3	1.2	1405.6	9.7	0.4	1.191667	0
45991	2025	11	11	30	9	7	0.7	-2.1	1.1	1440.8	9.7	0.1	1.291667	0
45991	2025	11	11	30	10	7	0.6	-0.8	1	1500.9	9.7	-0.2	1.375	0
45991	2025	11	11	30	11	7	0.5	-0.1	1	1520.1	9.7	-0.3	1.391667	0
45991	2025	11	11	30	12	7	0.5	0.8	0.7	1500.4	9.7	-0.4	1.358333	0
45991	2025	11	11	30	13	7	0.4	0.8	0.4	1474.7	9.7	-0.4	1.308333	0
45991	2025	11	11	30	14	7	0.4	1.5	0.3	1477.7	9.7	-0.4	1.216667	0
45991	2025	11	11	30	15	7	0.4	1.3	0.2	1476.4	9.7	-0.3	1.116667	0
45991	2025	11	11	30	16	7	0.4	1.6	0	1490.3	9.7	-0.3	1.008333	0
45991	2025	11	11	30	17	7	0.4	1.9	-1	1531.0	9.7	-0.1	0.9	0
45991	2025	11	11	30	18	7	0.4	2.9	-1.4	1614.5	9.7	0.0	0.791667	0
45991	2025	11	11	30	19	7	0.5	3.7	-2.3	1660.7	9.7	0.3	0.6	0
45991	2025	11	11	30	20	7	0.6	4.3	-2.1	1602.8	9.7	0.8	0.383333	0
45991	2025	11	11	30	21	7	0.7	4.5	-0.8	1552.2	9.7	1.3	0.1	0
45991	2025	11	11	30	22	7	0.8	5	-0.1	1426.7	9.7	1.9	-0.175	0
45991	2025	11	11	30	23	7	1.0	6.3	0.8	1372.3	9.7	2.4	-0.33333	0
45991	2025	11	11	30	24	7	1.2	6.8	0.8	1285.6	9.7	2.9	-0.425	0
45992	2025	12	1	1	1	1	1.5	7.3	1.5	1192.1	17.5	3.4	-0.44167	1
45992	2025	12	1	2	2	1	1.7	7.7	1.3	1108.8	17.5	3.9	-0.43333	1
45992	2025	12	1	3	3	1	2.1	8.1	1.6	1056.4	17.5	4.4	-0.34167	1
45992	2025	12	1	4	4	1	2.4	8.3	1.9	1025.9	17.5	5.0	-0.25833	1
45992	2025	12	1	5	5	1	2.7	8.5	2.9	1007.4	17.5	5.6	-0.14167	1
45992	2025	12	1	6	6	1	3.1	8.4	3.7	1014.9	17.5	6.1	0.016667	1
45992	2025	12	1	7	7	1	3.5	9	4.3	1068.6	17.5	6.6	0.341667	1
45992	2025	12	1	8	8	1	3.9	9.5	4.5	1230.1	17.5	7.0	0.766667	1
45992	2025	12	1	9	9	1	4.4	9.7	5	1296.6	17.5	7.5	1.316667	1
45992	2025	12	1	10	10	1	4.9	9.9	6.3	1314.2	17.5	7.9	1.866667	1
45992	2025	12	1	11	11	1	5.3	8.6	6.8	1301.4	17.5	8.3	2.35	1
45992	2025	12	1	12	12	1	5.7	8.3	7.3	1326.7	17.5	8.5	2.883333	1
45992	2025	12	1	13	13	1	6.0	8.3	7.7	1339.4	17.5	8.6	3.383333	1
45992	2025	12	1	14	14	1	6.3	7.6	8.1	1346.2	17.5	8.7	3.925	1
45992	2025	12	1	15	15	1	6.6	5.7	8.3	1335.4	17.5	8.7	4.441667	1
45992	2025	12	1	16	16	1	6.7	6.5	8.5	1370.7	17.5	8.5	5.008333	1
45992	2025	12	1	17	17	1	7.0	5.6	8.4	1411.1	17.5	8.3	5.566667	1
45992	2025	12	1	18	18	1	7.1	4.3	9	1480.4	17.5	8.1	6.116667	1
45992	2025	12	1	19	19	1	7.2	3.6	9.5	1548.5	17.5	7.8	6.575	1
45992	2025	12	1	20	20	1	7.2	2.3	9.7	1537.0	17.5	7.3	7.016667	1
45992	2025	12	1	21	21	1	7.1	1.8	9.9	1519.9	17.5	6.7	7.45	1
45992	2025	12	1	22	22	1	7.0	1.1	8.6	1458.0	17.5	6.0	7.883333	1
45992	2025	12	1	23	23	1	6.8	0.1	8.3	1452.9	17.5	5.3	8.291667	1
45992	2025	12	1	24	24	1	6.5	-0.2	8.3	1386.7	17.5	4.6	8.483333	1
45993	2025	12	2	1	2	2	6.3	-0.4	7.6	1360.4	8.6	3.9	8.608333	1
45993	2025	12	2	2	2	2	5.9	-1.5	5.7	1336.5	8.6	3.2	8.691667	1
45993	2025	12	2	3	3	2	5.5	-2.7	6.5	1319.7	8.6	2.4	8.683333	1
45993	2025	12	2	4	4	2	5.1	-3.4	5.6	1308.1	8.6	1.7	8.483333	1
45993	2025	12	2	5	5	2	4.6	-4.3	4.3	1324.3	8.6	0.9	8.333333	1
45993	2025	12	2	6	6	2	4.1	-4.9	3.6	1413.3	8.6	0.1	8.091667	1
45993	2025	12	2	7	7	2	3.5	-5.5	2.3	1490.0	8.6	-0.7	7.75	1
45993	2025	12	2	8	8	2	2.9	-5.4	1.8	1621.2	8.6	-1.5	7.3	1
45993	2025	12	2	9	9	2	2.3	-5	1.1	1712.2	8.6	-2.1	6.7	1
45993	2025	12	2	10	10	2	1.7	-3.6	0.1	1718.1	8.6	-2.7	6.041667	1
45993	2025	12	2	11	11	2	1.1	-2.1	-0.2	1678.4	8.6	-3.1	5.308333	1
45993														

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLa	gTemp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLa	gWeekdays
45993	2025	12	2	24	2	-0.3	4.3	1.8	1391.3	8.6	2.6	-3.25	1
45994	2025	12	3	1	3	-0.1	6.7	2.5	1337.0	24.5	3.0	-3.31667	1
45994	2025	12	3	2	3	0.2	7.2	3.2	1275.0	24.5	3.4	-3.13333	1
45994	2025	12	3	3	3	0.5	6.6	3.7	1231.6	24.5	3.8	-2.8	1
45994	2025	12	3	4	3	0.9	6	3.7	1194.3	24.5	4.1	-2.30833	1
45994	2025	12	3	5	3	1.3	5.4	3.3	1178.9	24.5	4.3	-1.71667	1
45994	2025	12	3	6	3	1.7	3.3	3.3	1201.0	24.5	4.5	-1.05	1
45994	2025	12	3	7	3	2.0	2.4	2.5	1337.4	24.5	4.5	-0.36667	1
45994	2025	12	3	8	3	2.4	1	2.4	1372.4	24.5	4.4	0.366667	1
45994	2025	12	3	9	3	2.6	1	2.6	1473.9	24.5	4.3	1.025	1
45994	2025	12	3	10	3	2.9	1.2	3.1	1528.3	24.5	4.1	1.641667	1
45994	2025	12	3	11	3	3.1	1.3	4.3	1565.6	24.5	4.0	2.158333	1
45994	2025	12	3	12	3	3.2	1.7	6.7	1569.8	24.5	3.9	2.591667	1
45994	2025	12	3	13	3	3.3	2.5	7.2	1605.7	24.5	3.7	3.033333	1
45994	2025	12	3	14	3	3.4	2.7	6.6	1596.6	24.5	3.3	3.441667	1
45994	2025	12	3	15	3	3.4	2.7	6	1563.1	24.5	2.9	3.833333	1
45994	2025	12	3	16	3	3.4	2.6	5.4	1553.7	24.5	2.6	4.116667	1
45994	2025	12	3	17	3	3.3	1.9	3.3	1570.5	24.5	2.3	4.308333	1
45994	2025	12	3	18	3	3.2	1	2.4	1676.2	24.5	2.0	4.45	1
45994	2025	12	3	19	3	3.1	0.8	1	1735.4	24.5	1.8	4.45	1
45994	2025	12	3	20	3	3.0	0.2	1	1697.0	24.5	1.7	4.375	1
45994	2025	12	3	21	3	2.9	-0.4	1.2	1664.1	24.5	1.6	4.25	1
45994	2025	12	3	22	3	2.8	-0.6	1.3	1635.4	24.5	1.5	4.133333	1
45994	2025	12	3	23	3	2.7	-1.1	1.7	1567.6	24.5	1.4	4.016667	1
45994	2025	12	3	24	3	2.5	-1.3	2.5	1467.5	24.5	1.2	3.866667	1
45995	2025	12	4	1	4	2.3	-1.6	2.7	1435.0	11.6	0.9	3.65	1
45995	2025	12	4	2	4	1.9	-1.5	2.7	1380.6	11.6	0.6	3.3	1
45995	2025	12	4	3	4	1.6	-1.5	2.6	1281.5	11.6	0.2	2.925	1
45995	2025	12	4	4	4	1.2	-1.6	1.9	1297.0	11.6	-0.1	2.6	1
45995	2025	12	4	5	4	0.9	-1.3	1	1308.4	11.6	-0.5	2.316667	1
45995	2025	12	4	6	4	0.6	-0.9	0.8	1354.0	11.6	-0.7	2.025	1
45995	2025	12	4	7	4	0.5	-0.6	0.2	1470.5	11.6	-0.9	1.833333	1
45995	2025	12	4	8	4	0.3	-0.4	-0.4	1507.1	11.6	-1.0	1.7	1
45995	2025	12	4	9	4	0.3	0.3	-0.6	1581.7	11.6	-1.1	1.633333	1
45995	2025	12	4	10	4	0.3	1.8	-1.1	1606.3	11.6	-1.0	1.516667	1
45995	2025	12	4	11	4	0.3	2.6	-1.3	1606.3	11.6	-0.8	1.366667	1
45995	2025	12	4	12	4	0.3	4	-1.6	1549.5	11.6	-0.5	1.166667	1
45995	2025	12	4	13	4	0.4	5.1	-1.5	1552.2	11.6	-0.1	0.916667	1
45995	2025	12	4	14	4	0.5	4.9	-1.5	1566.5	11.6	0.5	0.575	1
45995	2025	12	4	15	4	0.6	4.4	-1.6	1591.6	11.6	1.0	0.225	1
45995	2025	12	4	16	4	0.7	4.6	-1.3	1566.7	11.6	1.5	-0.125	1
45995	2025	12	4	17	4	0.8	4.5	-0.9	1580.1	11.6	2.0	-0.475	1
45995	2025	12	4	18	4	0.9	3.9	-0.6	1641.8	11.6	2.5	-0.74167	1
45995	2025	12	4	19	4	1.0	4	-0.4	1692.7	11.6	2.9	-0.9	1
45995	2025	12	4	20	4	1.1	3.7	0.3	1646.9	11.6	3.3	-1.01667	1
45995	2025	12	4	21	4	1.3	1.9	1.8	1644.4	11.6	3.7	-1.06667	1
45995	2025	12	4	22	4	1.4	-1.3	2.6	1644.5	11.6	3.8	-1.00833	1
45995	2025	12	4	23	4	1.4	-3.2	4	1577.5	11.6	3.5	-0.80833	1
45995	2025	12	4	24	4	1.3	-3.9	5.1	1516.1	11.6	3.0	-0.5	1
45996	2025	12	5	1	5	1.2	-5.2	4.9	1547.5	18.3	2.4	-0.05833	1
45996	2025	12	5	2	5	1.0	-7.2	4.4	1549.2	18.3	1.5	0.5	1
45996	2025	12	5	3	5	0.8	-8.7	4.6	1571.0	18.3	0.5	1.033333	1
45996	2025	12	5	4	5	0.5	-10.6	4.5	1593.2	18.3	-0.6	1.525	1
45996	2025	12	5	5	5	0.1	-11.6	3.9	1640.6	18.3	-1.8	2.041667	1
45996	2025	12	5	6	5	-0.3	-12.1	4	1734.0	18.3	-3.2	2.525	1
45996	2025	12	5	7	5	-0.8	-11.6	3.7	1811.1	18.3	-4.5	2.925	1
45996	2025	12	5	8	5	-1.3	-12	1.9	1938.6	18.3	-5.8	3.308333	1
45996	2025	12	5	9	5	-1.7	-11.6	-1.3	2020.7	18.3	-7.1	3.65	1
45996	2025	12	5	10	5	-2.2	-10.5	-3.2	2057.0	18.3	-8.3	3.783333	1
45996	2025	12	5	11	5	-2.7	-8.9	-3.9	2009.1	18.3	-9.0	3.525	1
45996	2025	12	5	12	5	-3.2	-7.4	-5.2	1954.8	18.3	-9.5	3.041667	1
45996	2025	12	5	13	5	-3.7	-6.5	-7.2	1908.9	18.3	-9.8	2.383333	1
45996	2025	12	5	14	5	-4.2	-5.4	-8.7	1875.0	18.3	-9.9	1.525	1
45996	2025	12	5	15	5	-4.6	-5.2	-10.6	1888.0	18.3	-9.7	0.516667	1
45996	2025	12	5	16	5	-5.0	-5.6	-11.6	1892.7	18.3	-9.5	-0.575	1
45996	2025	12	5	17	5	-5.4	-6.3	-12.1	1924.5	18.3	-9.0	-1.84167	1
45996	2025	12	5	18	5	-5.9	-7	-11.6	1973.3	18.3	-8.6	-3.18333	1
45996	2025	12	5	19	5	-6.3	-7.2	-12	2053.9	18.3	-8.2	-4.51667	1
45996	2025	12	5	20	5	-6.8	-7.1	-11.6	2019.3	18.3	-7.8	-5.81667	1
45996	2025	12	5	21	5	-7.3	-6.9	-10.5	1987.5	18.3	-7.4	-7.125	1
45996	2025	12	5	22	5	-7.6	-6.7	-8.9	1946.0	18.3	-7.0	-8.25	1
45996	2025	12	5	23	5	-7.9	-6.9	-7.4	1889.2	18.3	-6.7	-9.01667	1
45996	2025	12	5	24	5	-8.0	-6.4	-6.5	1822.5	18.3	-6.5	-9.49167	1
45997	2025	12	6	1	6	-8.1	-5.9	-5.4	1784.8	5.4	-6.4	-9.78333	0
45997	2025	12	6	2	6	-8.1	-5.8	-5.2	1733.3	5.4	-6.4	-9.89167	0
45997	2025	12	6	3	6	-8.1	-5.5	-5.6	1686.9	5.4	-6.4	-9.74167	0
45997	2025	12	6	4	6	-7.9	-5.1	-6.3	1657.0	5.4	-6.4	-9.45	0
45997	2025	12	6	5	6	-7.7	-5.7	-7	1640.3	5.4	-6.4	-9.03333	0
45997	2025	12	6	6	6	-7.5	-5.7	-7.2	1633.9	5.4	-6.4	-8.59167	0
45997	2025	12	6	7	6	-7.2	-5.8	-7.1	1654.6	5.4	-6.2	-8.16667	0
45997	2025	12	6	8	6	-7.0	-5.3	-6.9	1709.8	5.4	-6.1	-7.8	0
45997	2025	12	6	9	6	-6.7	-5.1	-6.7	1773.9	5.4	-6.0	-7.39167	0
45997	2025	12	6	10	6	-6.4	-4.7	-6.9	1838.5	5.4	-5.8	-7	0
45997	2025	12	6	11	6	-6.2	-3.5	-6.4	1871.1	5.4	-5.7	-6.68333	0
45997	2025	12	6	12	6	-5.9	-2	-5.9	1850.1	5.4	-5.4	-6.51667	0
45997	2025	12	6	13	6	-5.7	-0.3	-5.8	1822.8	5.4	-5.0	-6.43333	0
45997	2025	12	6	14	6	-5.5	1	-5.5	1774.5	5.4	-4.5	-6.38333	0
45997	2025	12	6	15	6	-5.2	1.8	-5.1	1728.3	5.4	-4.0	-6.41667	0
45997	2025	12	6	16	6	-4.9	1.9	-5.7	1701.8	5.4	-3.4	-6.44167	0
45997	2025	12	6	17	6	-4.6	1.6	-5.7	1701.8	5.4	-2.8	-6.4	0
45997	2025	12	6	18	6	-4.3	1.2	-5.8	1769.7	5.4	-2.2	-6.35	0
45997	2025	12	6	19	6	-3.9	0.8	-5.3	1805.3	5.4	-1.6	-6.24167	0
45997	2025	12	6	20	6	-3.6	0	-5.1	1757.4	5.4	-1.1	-6.125	0
45997	2025	12	6	21	6	-3.3	-0.1	-4.7	1691.0	5.4	-0.6	-5.975	0
45997	2025	12	6	22	6	-3.0	0.1	-3.5	1674.2	5.4	-0.2	-5.825	0
45997	2025	12	6	23	6	-2.7	0.5	-2	1574.9	5.4	0.2	-5.65833	0
45997	2025	12	6	24	6	-2.4	0.4	-0.3	1549.6	5.4	0.5	-5.375	0
45998	2025	12	7	1	7	-2.1	-0.3	1	1490.0	6.7	0.7	-5.00833	0
45998	2025	12	7	2	7	-1.9	-1.2	1.8	1387.3	6.7	0.7	-4.54167	0
45998	2025	12	7	3	7	-1.7	-0.1	1.9	1402.7	6.7	0.6	-3.975	0
45998	2025	12	7	4	7	-1.5	-0.4	1.6	1377.8	6.7	0.4	-3.36667	0
45998	2025	12	7	5	7	-1.3	-0.1	1.2	1370.1	6.7	0.2	-2.78333	0
45998	2025	12	7	6	7	-1.1	-0.9	0.8	1403.2				

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLa	gTemp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLa	gWeekdays	
45998	2025	12	7	12	12	7	0.3	2.7	-0.3	1535.8	6.7	0.0	0.541667	0
45998	2025	12	7	13	13	7	0.5	3.7	-1.2	1496.2	6.7	0.2	0.741667	0
45998	2025	12	7	14	14	7	0.6	2.9	-0.1	1505.5	6.7	0.5	0.741667	0
45998	2025	12	7	15	15	7	0.7	2.7	-0.4	1468.7	6.7	0.9	0.558333	0
45998	2025	12	7	16	16	7	0.8	2.8	-0.1	1523.9	6.7	1.1	0.4	0
45998	2025	12	7	17	17	7	0.8	2.3	-0.9	1547.9	6.7	1.4	0.208333	0
45998	2025	12	7	18	18	7	0.8	1	-0.4	1655.2	6.7	1.6	0.066667	0
45998	2025	12	7	19	19	7	0.8	0.2	0.4	1750.3	6.7	1.7	-0.10833	0
45998	2025	12	7	20	20	7	0.8	-0.5	0.5	1734.2	6.7	1.8	-0.20833	0
45998	2025	12	7	21	21	7	0.8	-1.2	0.8	1702.9	6.7	1.7	-0.175	0
45998	2025	12	7	22	22	7	0.7	-1.6	1.4	1691.9	6.7	1.6	-0.125	0
45998	2025	12	7	23	23	7	0.7	-1.6	2.7	1634.8	6.7	1.4	-0.06667	0
45998	2025	12	7	24	24	7	0.6	-2.1	3.7	1507.3	6.7	1.1	0.008333	0
45999	2025	12	8	1	1	1	0.5	-2.7	2.9	1473.7	16.7	0.7	0.2	1
45999	2025	12	8	2	1	1	0.4	-2.8	2.7	1424.3	16.7	0.2	0.533333	1
45999	2025	12	8	3	1	1	0.3	-3.3	2.8	1403.9	16.7	-0.3	0.875	1
45999	2025	12	8	4	1	1	0.2	-3.8	2.3	1404.2	16.7	-0.8	1.108333	1
45999	2025	12	8	5	1	1	0.0	-4	1	1414.3	16.7	-1.3	1.375	1
45999	2025	12	8	6	1	1	-0.1	-4.7	0.2	1486.3	16.7	-1.9	1.575	1
45999	2025	12	8	7	1	1	-0.3	-4.9	-0.5	1569.4	16.7	-2.3	1.733333	1
45999	2025	12	8	8	1	1	-0.5	-4.3	-1.2	1657.8	16.7	-2.8	1.783333	1
45999	2025	12	8	9	1	1	-0.7	-4.3	-1.6	1761.3	16.7	-3.1	1.708333	1
45999	2025	12	8	10	1	1	-0.9	-3.6	-1.6	1812.8	16.7	-3.3	1.566667	1
45999	2025	12	8	11	1	1	-1.1	-4.8	-2.1	1837.9	16.7	-3.5	1.366667	1
45999	2025	12	8	12	1	1	-1.3	-4.8	-2.7	1868.6	16.7	-3.8	1.116667	1
45999	2025	12	8	13	1	1	-1.6	-6.3	-2.8	1895.7	16.7	-4.0	0.716667	1
45999	2025	12	8	14	1	1	-2.1	-6.8	-3.3	1942.3	16.7	-4.3	0.183333	1
45999	2025	12	8	15	1	1	-2.5	-7.3	-3.8	1895.6	16.7	-4.6	-0.29167	1
45999	2025	12	8	16	1	1	-2.9	-7.9	-4	1873.8	16.7	-5.0	-0.79167	1
45999	2025	12	8	17	1	1	-3.3	-7.9	-4.7	1914.4	16.7	-5.3	-1.34167	1
45999	2025	12	8	18	1	1	-3.8	-8.6	-4.9	2036.9	16.7	-5.6	-1.86667	1
45999	2025	12	8	19	1	1	-4.2	-9.2	-4.3	2128.3	16.7	-6.0	-2.34167	1
45999	2025	12	8	20	1	1	-4.5	-9.5	-4.3	2096.3	16.7	-6.3	-2.76667	1
45999	2025	12	8	21	1	1	-4.9	-10.1	-3.6	2066.4	16.7	-6.8	-3.08333	1
45999	2025	12	8	22	1	1	-5.3	-10.3	-4.8	2030.8	16.7	-7.2	-3.34167	1
45999	2025	12	8	23	1	1	-5.7	-10.2	-4.8	1959.3	16.7	-7.8	-3.50833	1
45999	2025	12	8	24	1	1	-6.0	-10.2	-6.3	1849.1	16.7	-8.2	-3.775	1
46000	2025	12	9	1	2	2	-6.3	-10.5	-6.8	1772.9	10.6	-8.7	-4	1
46000	2025	12	9	2	2	2	-6.7	-10.4	-7.3	1791.7	10.6	-9.0	-4.3	1
46000	2025	12	9	3	2	2	-7.0	-9.8	-7.9	1764.9	10.6	-9.3	-4.63333	1
46000	2025	12	9	4	2	2	-7.3	-9.5	-7.9	1743.5	10.6	-9.6	-4.96667	1
46000	2025	12	9	5	2	2	-7.5	-9.6	-8.6	1744.3	10.6	-9.7	-5.30833	1
46000	2025	12	9	6	2	2	-7.7	-9.7	-9.2	1805.7	10.6	-9.8	-5.63333	1
46000	2025	12	9	7	2	2	-7.9	-9.7	-9.5	1856.4	10.6	-9.9	-5.95833	1
46000	2025	12	9	8	2	2	-8.1	-9.5	-10.1	1972.6	10.6	-10.0	-6.31667	1
46000	2025	12	9	9	2	2	-8.4	-9.6	-10.3	2073.3	10.6	-10.0	-6.75	1
46000	2025	12	9	10	2	2	-8.6	-8.1	-10.2	2075.0	10.6	-9.9	-7.23333	1
46000	2025	12	9	11	2	2	-8.8	-5.8	-10.2	1980.5	10.6	-9.7	-7.79167	1
46000	2025	12	9	12	2	2	-8.8	-4.6	-10.5	1872.3	10.6	-9.4	-8.24167	1
46000	2025	12	9	13	2	2	-8.8	-3.1	-10.4	1807.4	10.6	-8.9	-8.69167	1
46000	2025	12	9	14	2	2	-8.7	-2.4	-9.8	1760.1	10.6	-8.3	-9.04167	1
46000	2025	12	9	15	2	2	-8.5	-2.9	-9.5	1722.1	10.6	-7.6	-9.34167	1
46000	2025	12	9	16	2	2	-8.3	-3	-9.6	1722.2	10.6	-7.0	-9.55	1
46000	2025	12	9	17	2	2	-8.1	-4	-9.7	1783.4	10.6	-6.5	-9.68333	1
46000	2025	12	9	18	2	2	-7.9	-4.9	-9.7	1923.6	10.6	-6.0	-9.825	1
46000	2025	12	9	19	2	2	-7.8	-5.4	-9.5	2040.4	10.6	-5.6	-9.91667	1
46000	2025	12	9	20	2	2	-7.6	-5.9	-9.6	2031.5	10.6	-5.3	-9.95833	1
46000	2025	12	9	21	2	2	-7.5	-6.2	-8.1	2014.1	10.6	-5.0	-9.95833	1
46000	2025	12	9	22	2	2	-7.3	-6.3	-5.8	1982.5	10.6	-4.7	-9.91667	1
46000	2025	12	9	23	2	2	-7.1	-6.4	-4.6	1918.6	10.6	-4.5	-9.73333	1
46000	2025	12	9	24	2	2	-7.0	-5.5	-3.1	1809.7	10.6	-4.6	-9.36667	1
46001	2025	12	10	1	3	3	-6.8	-5.5	-2.4	1710.5	10.1	-4.7	-8.9	1
46001	2025	12	10	2	3	3	-6.6	-5.4	-2.9	1716.8	10.1	-4.9	-8.28333	1
46001	2025	12	10	3	3	3	-6.4	-4.8	-3	1694.6	10.1	-5.1	-7.61667	1
46001	2025	12	10	4	3	3	-6.2	-5	-4	1663.1	10.1	-5.3	-7.04167	1
46001	2025	12	10	5	3	3	-6.0	-4.1	-4.9	1635.7	10.1	-5.4	-6.5	1
46001	2025	12	10	6	3	3	-5.7	-4.6	-5.4	1632.6	10.1	-5.5	-6.03333	1
46001	2025	12	10	7	3	3	-5.5	-4.4	-5.9	1672.7	10.1	-5.4	-5.63333	1
46001	2025	12	10	8	3	3	-5.3	-2.5	-6.2	1789.7	10.1	-5.3	-5.275	1
46001	2025	12	10	9	3	3	-5.0	0.4	-6.3	1862.9	10.1	-5.1	-4.975	1
46001	2025	12	10	10	3	3	-4.6	2.1	-6.4	1862.1	10.1	-4.5	-4.69167	1
46001	2025	12	10	11	3	3	-4.2	3.7	-5.5	1805.7	10.1	-3.8	-4.54167	1
46001	2025	12	10	12	3	3	-3.8	5.1	-5.5	1787.3	10.1	-3.0	-4.59167	1
46001	2025	12	10	13	3	3	-3.4	6.3	-5.4	1776.5	10.1	-2.1	-4.66667	1
46001	2025	12	10	14	3	3	-3.0	6.6	-4.8	1744.4	10.1	-1.1	-4.86667	1
46001	2025	12	10	15	3	3	-2.6	6.2	-5	1697.0	10.1	-0.1	-5.11667	1
46001	2025	12	10	16	3	3	-2.2	6.7	-4.1	1671.5	10.1	0.8	-5.275	1
46001	2025	12	10	17	3	3	-1.8	6.1	-4.6	1666.8	10.1	1.8	-5.44167	1
46001	2025	12	10	18	3	3	-1.4	4.8	-4.4	1748.3	10.1	2.6	-5.45	1
46001	2025	12	10	19	3	3	-1.0	5.1	-2.5	1748.1	10.1	3.4	-5.425	1
46001	2025	12	10	20	3	3	-0.6	5	0.4	1670.8	10.1	4.2	-5.34167	1
46001	2025	12	10	21	3	3	-0.1	5.2	2.1	1582.8	10.1	4.8	-5.05833	1
46001	2025	12	10	22	3	3	0.4	5.6	3.7	1534.3	10.1	5.2	-4.50833	1
46001	2025	12	10	23	3	3	0.9	5.2	5.1	1470.8	10.1	5.5	-3.80833	1
46001	2025	12	10	24	3	3	1.3	6.3	6.3	1368.4	10.1	5.7	-2.96667	1
46002	2025	12	11	1	4	4	1.8	6.7	6.6	1278.9	19.5	5.8	-2.08333	1
46002	2025	12	11	2	4	4	2.3	6.8	6.2	1234.0	19.5	5.8	-1.1	1
46002	2025	12	11	3	4	4	2.9	7.7	6.7	1166.4	19.5	5.8	-0.1	1
46002	2025	12	11	4	4	4	3.4	7.8	6.1	1123.6	19.5	5.9	0.816667	1
46002	2025	12	11	5	4	4	3.9	8.3	4.8	1107.7	19.5	6.0	1.791667	1
46002	2025	12	11	6	4	4	4.4	7.8	5.1	1113.7	19.5	6.2	2.641667	1
46002	2025	12	11	7	4	4	4.9	7.8	5	1159.8	19.5	6.5	3.425	1
46002	2025	12	11	8	4	4	5.5	7.7	5.2	1303.3	19.5	6.7	4.216667	1
46002	2025	12	11	9	4	4	5.9	8.5	5.6	1381.0	19.5	6.9	4.841667	1
46002	2025	12	11	10	4	4	6.2	8.1	5.2	1422.4	19.5	7.2	5.241667	1
46002	2025	12	11	11	4	4	6.5	8.3	6.3	1433.0	19.5	7.4	5.533333	1
46002	2025	12	11	12	4	4	6.7	8.9	6.7	1406.4	19			

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLag	Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLag	Weekdays	
46002	2025	12	11	24		4	6.8	1.2	9.2	1409.4	19.5	5.9	7.65	1
46003	2025	12	12	1		5	6.6	-0.1	9.7	1381.7	23.2	5.3	7.866667	1
46003	2025	12	12	2		5	6.3	-1.3	8.6	1361.6	23.2	4.5	8.075	1
46003	2025	12	12	3		5	6.0	-2.1	7.6	1354.5	23.2	3.6	8.316667	1
46003	2025	12	12	4		5	5.5	-1.8	6.3	1350.1	23.2	2.7	8.391667	1
46003	2025	12	12	5		5	5.1	-3.8	5.2	1349.0	23.2	1.9	8.375	1
46003	2025	12	12	6		5	4.6	-4.2	4.2	1390.4	23.2	1.1	8.208333	1
46003	2025	12	12	7		5	4.1	-4.4	3.3	1474.1	23.2	0.3	7.991667	1
46003	2025	12	12	8		5	3.6	-4.9	3	1660.0	23.2	-0.4	7.691667	1
46003	2025	12	12	9		5	3.1	-4.7	2.7	1745.9	23.2	-1.1	7.325	1
46003	2025	12	12	10		5	2.6	-4.4	2.4	1792.4	23.2	-1.8	6.866667	1
46003	2025	12	12	11		5	2.0	-4	1.2	1790.0	23.2	-2.3	6.416667	1
46003	2025	12	12	12		5	1.5	-3.2	-0.1	1785.2	23.2	-2.9	5.925	1
46003	2025	12	12	13		5	1.0	-1.7	-1.3	1793.5	23.2	-3.2	5.283333	1
46003	2025	12	12	14		5	0.6	-2.2	-2.1	1803.4	23.2	-3.4	4.508333	1
46003	2025	12	12	15		5	0.1	-2.2	-1.8	1792.0	23.2	-3.5	3.591667	1
46003	2025	12	12	16		5	-0.4	-3.1	-3.8	1795.4	23.2	-3.5	2.7	1
46003	2025	12	12	17		5	-0.8	-2.4	-4.2	1866.0	23.2	-3.6	1.916667	1
46003	2025	12	12	18		5	-1.2	-2.6	-4.4	1915.4	23.2	-3.5	1.075	1
46003	2025	12	12	19		5	-1.5	-2.8	-4.9	1943.2	23.2	-3.3	0.291667	1
46003	2025	12	12	20		5	-1.8	-2.9	-4.7	1891.6	23.2	-3.2	-0.425	1
46003	2025	12	12	21		5	-2.1	-3.2	-4.4	1825.7	23.2	-3.0	-1.10833	1
46003	2025	12	12	22		5	-2.3	-3.7	-4	1782.9	23.2	-2.9	-1.75	1
46003	2025	12	12	23		5	-2.6	-4	-3.2	1681.5	23.2	-2.8	-2.34167	1
46003	2025	12	12	24		5	-2.9	-3.9	-1.7	1652.9	23.2	-2.8	-2.875	1
46004	2025	12	13	1		6	-3.1	-3.8	-2.2	1634.7	13.8	-2.9	-3.24167	0
46004	2025	12	13	2		6	-3.2	-3.4	-2.2	1581.5	13.8	-3.1	-3.375	0
46004	2025	12	13	3		6	-3.3	-3.1	-3.1	1536.6	13.8	-3.2	-3.45	0
46004	2025	12	13	4		6	-3.4	-2.8	-2.4	1488.5	13.8	-3.2	-3.45833	0
46004	2025	12	13	5		6	-3.4	-2.8	-2.6	1467.2	13.8	-3.2	-3.56667	0
46004	2025	12	13	6		6	-3.4	-2.7	-2.8	1467.7	13.8	-3.3	-3.45	0
46004	2025	12	13	7		6	-3.3	-2.7	-2.9	1492.3	13.8	-3.3	-3.31667	0
46004	2025	12	13	8		6	-3.2	-2.6	-3.2	1601.3	13.8	-3.3	-3.18333	0
46004	2025	12	13	9		6	-3.1	-2.8	-3.7	1630.2	13.8	-3.2	-3.01667	0
46004	2025	12	13	10		6	-3.0	-1.9	-4	1731.5	13.8	-3.2	-2.89167	0
46004	2025	12	13	11		6	-2.9	-1	-3.9	1793.3	13.8	-3.0	-2.83333	0
46004	2025	12	13	12		6	-2.8	-1.3	-3.8	1705.9	13.8	-2.8	-2.83333	0
46004	2025	12	13	13		6	-2.7	-1.4	-3.4	1693.6	13.8	-2.6	-2.89167	0
46004	2025	12	13	14		6	-2.7	-0.2	-3.1	1654.1	13.8	-2.4	-3.06667	0
46004	2025	12	13	15		6	-2.6	-0.7	-2.8	1592.2	13.8	-2.1	-3.16667	0
46004	2025	12	13	16		6	-2.6	-1	-2.8	1616.9	13.8	-1.9	-3.24167	0
46004	2025	12	13	17		6	-2.5	-1.1	-2.7	1704.3	13.8	-1.8	-3.21667	0
46004	2025	12	13	18		6	-2.4	-0.8	-2.7	1772.8	13.8	-1.6	-3.25	0
46004	2025	12	13	19		6	-2.4	-0.9	-2.6	1830.3	13.8	-1.5	-3.25833	0
46004	2025	12	13	20		6	-2.3	-1	-2.8	1790.5	13.8	-1.3	-3.25	0
46004	2025	12	13	21		6	-2.2	-0.8	-1.9	1746.3	13.8	-1.2	-3.225	0
46004	2025	12	13	22		6	-2.1	-0.8	-1	1716.9	13.8	-1.0	-3.19167	0
46004	2025	12	13	23		6	-2.0	-1.1	-1.3	1646.2	13.8	-0.9	-3.04167	0
46004	2025	12	13	24		6	-1.9	-1.5	-1.4	1522.3	13.8	-0.9	-2.79167	0
46005	2025	12	14	1		7	-1.8	-0.9	-0.2	1452.5	11.5	-0.9	-2.575	0
46005	2025	12	14	2		7	-1.6	-0.3	-0.7	1431.2	11.5	-0.9	-2.375	0
46005	2025	12	14	3		7	-1.5	0.1	-1	1406.2	11.5	-0.9	-2.10833	0
46005	2025	12	14	4		7	-1.4	1.5	-1.1	1378.9	11.5	-0.8	-1.90833	0
46005	2025	12	14	5		7	-1.2	2.5	-0.8	1351.9	11.5	-0.6	-1.75833	0
46005	2025	12	14	6		7	-1.0	2	-0.9	1355.7	11.5	-0.3	-1.61667	0
46005	2025	12	14	7		7	-0.8	1.8	-1	1373.4	11.5	-0.1	-1.45833	0
46005	2025	12	14	8		7	-0.6	0.9	-0.8	1470.6	11.5	0.1	-1.30833	0
46005	2025	12	14	9		7	-0.4	0.4	-0.8	1557.1	11.5	0.3	-1.175	0
46005	2025	12	14	10		7	-0.3	0.5	-1.1	1588.2	11.5	0.4	-1.00833	0
46005	2025	12	14	11		7	-0.2	0.4	-1.5	1666.0	11.5	0.5	-0.91667	0
46005	2025	12	14	12		7	-0.2	0.5	-0.9	1689.9	11.5	0.6	-0.925	0
46005	2025	12	14	13		7	-0.1	0.5	-0.3	1711.8	11.5	0.8	-0.94167	0
46005	2025	12	14	14		7	0.0	0.4	0.1	1718.4	11.5	0.9	-0.9	0
46005	2025	12	14	15		7	0.0	0.3	1.5	1705.4	11.5	1.0	-0.90833	0
46005	2025	12	14	16		7	0.1	0.1	2.5	1707.0	11.5	1.0	-0.84167	0
46005	2025	12	14	17		7	0.1	0	2	1723.3	11.5	0.9	-0.63333	0
46005	2025	12	14	18		7	0.2	-0.3	1.8	1797.5	11.5	0.7	-0.33333	0
46005	2025	12	14	19		7	0.2	-0.7	0.9	1855.5	11.5	0.5	-0.1	0
46005	2025	12	14	20		7	0.2	-1.4	0.4	1823.8	11.5	0.3	0.125	0
46005	2025	12	14	21		7	0.2	-1.8	0.5	1771.6	11.5	0.1	0.283333	0
46005	2025	12	14	22		7	0.1	-2.1	0.4	1726.0	11.5	-0.1	0.383333	0
46005	2025	12	14	23		7	0.1	-2	0.5	1637.1	11.5	-0.3	0.491667	0
46005	2025	12	14	24		7	0.0	-2	0.5	1534.6	11.5	-0.5	0.616667	0
46006	2025	12	15	1		1	0.0	-2.1	0.4	1486.6	22.6	-0.8	0.783333	1
46006	2025	12	15	2		1	0.0	-2.3	0.3	1425.6	22.6	-1.0	0.9	1
46006	2025	12	15	3		1	-0.1	-2.4	0.1	1398.2	22.6	-1.2	0.958333	1
46006	2025	12	15	4		1	-0.2	-2.7	0	1389.4	22.6	-1.4	0.975	1
46006	2025	12	15	5		1	-0.4	-2.9	-0.3	1397.2	22.6	-1.7	0.858333	1
46006	2025	12	15	6		1	-0.6	-2.9	-0.7	1424.8	22.6	-1.9	0.65	1
46006	2025	12	15	7		1	-0.8	-3.2	-1.4	1497.1	22.6	-2.1	0.458333	1
46006	2025	12	15	8		1	-1.0	-3.8	-1.8	1621.6	22.6	-2.3	0.25	1
46006	2025	12	15	9		1	-1.2	-4.7	-2.1	1716.3	22.6	-2.5	0.058333	1
46006	2025	12	15	10		1	-1.4	-4.6	-2	1792.9	22.6	-2.8	-0.125	1
46006	2025	12	15	11		1	-1.7	-5.5	-2	1887.3	22.6	-3.0	-0.34167	1
46006	2025	12	15	12		1	-1.9	-5.8	-2.1	1857.1	22.6	-3.3	-0.54167	1
46006	2025	12	15	13		1	-2.2	-6	-2.3	1873.5	22.6	-3.6	-0.75	1
46006	2025	12	15	14		1	-2.4	-6.7	-2.4	1946.1	22.6	-3.9	-0.96667	1
46006	2025	12	15	15		1	-2.7	-6.6	-2.7	1956.3	22.6	-4.3	-1.19167	1
46006	2025	12	15	16		1	-3.0	-6.6	-2.9	2012.4	22.6	-4.6	-1.41667	1
46006	2025	12	15	17		1	-3.3	-6.6	-2.9	2032.5	22.6	-4.9	-1.65	1
46006	2025	12	15	18		1	-3.6	-6.6	-3.2	2076.6	22.6	-5.3	-1.89167	1
46006	2025	12	15	19		1	-3.8	-6.5	-3.8	2122.1	22.6	-5.6	-2.10833	1
46006	2025	12	15	20		1	-4.1	-6.4	-4.7	2071.7	22.6	-5.8	-2.31667	1
46006	2025	12	15	21		1	-4.3	-6.5	-4.6	1996.2	22.6	-6.1	-2.51667	1
46006	2025	12	15	22		1	-4.5	-6.8	-5.5	1975.0	22.6	-6.2	-2.75833	1
46006	2025	12	15	23		1	-4.7	-7	-5.8	1905.4	22.6	-6.4	-2.96667	1
46006	2025	12	15	24		1	-4.9	-7.1	-6	1773.0	22.6	-6.5	-3.25833	1
46007	2025	12	16	1		2	-5.1	-7.3	-6.7	1744.7	11.1	-6.6	-3.575	1
46007	2025	1												

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLag	Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLag	Weekdays	
46007	2025	12	12	16	12	2	-7.1	-5	-7.3	1924.0	11.1	-7.7	-6.50833	1
46007	2025	12	16	13	13	2	-7.1	-3.8	-7.5	1867.7	11.1	-7.6	-6.61667	1
46007	2025	12	16	14	14	2	-7.0	-2.5	-7.7	1827.2	11.1	-7.3	-6.725	1
46007	2025	12	16	15	15	2	-6.8	-2.1	-8.1	1807.2	11.1	-6.9	-6.79167	1
46007	2025	12	16	16	16	2	-6.6	-2.1	-8.2	1786.4	11.1	-6.4	-6.88333	1
46007	2025	12	16	17	17	2	-6.4	-2.7	-8.3	1826.7	11.1	-5.9	-7.00833	1
46007	2025	12	16	18	18	2	-6.3	-3.3	-8.5	1919.6	11.1	-5.4	-7.14167	1
46007	2025	12	16	19	19	2	-6.1	-3.4	-8.5	2014.4	11.1	-5.0	-7.28333	1
46007	2025	12	16	20	20	2	-6.0	-2.9	-8.7	1957.7	11.1	-4.6	-7.45	1
46007	2025	12	16	21	21	2	-5.9	-3.6	-6.9	1919.3	11.1	-4.1	-7.625	1
46007	2025	12	16	22	22	2	-5.8	-4.3	-6	1886.5	11.1	-3.7	-7.80833	1
46007	2025	12	16	23	23	2	-5.6	-4.1	-5	1817.2	11.1	-3.5	-7.81667	1
46007	2025	12	16	24	24	2	-5.5	-1.7	-3.8	1670.0	11.1	-3.3	-7.73333	1
46008	2025	12	17	1	1	3	-5.3	-0.2	-2.5	1634.5	20.0	-3.0	-7.55833	1
46008	2025	12	17	2	2	3	-5.0	1	-2.1	1609.5	20.0	-2.7	-7.26667	1
46008	2025	12	17	3	3	3	-4.7	1.8	-2.1	1493.2	20.0	-2.5	-6.85	1
46008	2025	12	17	4	4	3	-4.3	2.6	-2.7	1446.9	20.0	-2.1	-6.38333	1
46008	2025	12	17	5	5	3	-3.8	3.1	-3.3	1406.5	20.0	-1.7	-5.88333	1
46008	2025	12	17	6	6	3	-3.3	3.4	-3.4	1412.3	20.0	-1.3	-5.425	1
46008	2025	12	17	7	7	3	-2.9	3.7	-2.9	1431.4	20.0	-0.7	-5.00833	1
46008	2025	12	17	8	8	3	-2.3	4.2	-3.6	1536.0	20.0	-0.1	-4.58333	1
46008	2025	12	17	9	9	3	-1.8	4.4	-4.3	1637.1	20.0	0.5	-4.11667	1
46008	2025	12	17	10	10	3	-1.3	4.8	-4.1	1643.3	20.0	1.2	-3.69167	1
46008	2025	12	17	11	11	3	-0.8	5.3	-1.7	1654.6	20.0	1.9	-3.475	1
46008	2025	12	17	12	12	3	-0.3	5.6	-0.2	1650.8	20.0	2.7	-3.31667	1
46008	2025	12	17	13	13	3	0.1	6.6	1	1610.4	20.0	3.3	-3.04167	1
46008	2025	12	17	14	14	3	0.6	7.2	1.8	1548.7	20.0	3.9	-2.74167	1
46008	2025	12	17	15	15	3	1.0	6.1	2.6	1507.1	20.0	4.4	-2.45	1
46008	2025	12	17	16	16	3	1.3	6.7	3.1	1480.0	20.0	4.8	-2.125	1
46008	2025	12	17	17	17	3	1.7	5.9	3.4	1515.6	20.0	5.1	-1.73333	1
46008	2025	12	17	18	18	3	2.0	5.5	3.7	1624.7	20.0	5.3	-1.25	1
46008	2025	12	17	19	19	3	2.4	5.8	4.2	1676.5	20.0	5.5	-0.69167	1
46008	2025	12	17	20	20	3	2.8	5.9	4.4	1623.0	20.0	5.7	-0.1	1
46008	2025	12	17	21	21	3	3.2	6.3	4.8	1582.0	20.0	5.8	0.491667	1
46008	2025	12	17	22	22	3	3.6	6.3	5.3	1549.1	20.0	6.0	1.158333	1
46008	2025	12	17	23	23	3	4.0	5.9	5.6	1513.4	20.0	6.1	1.916667	1
46008	2025	12	17	24	24	3	4.4	5.4	6.6	1379.0	20.0	6.2	2.7	1
46009	2025	12	18	1	1	4	4.7	5.5	7.2	1305.0	10.8	6.1	3.308333	1
46009	2025	12	18	2	2	4	5.0	5.4	6.1	1216.6	10.8	6.0	3.875	1
46009	2025	12	18	3	3	4	5.1	4.9	6.7	1202.9	10.8	5.9	4.391667	1
46009	2025	12	18	4	4	4	5.3	4.7	5.9	1185.3	10.8	5.8	4.75	1
46009	2025	12	18	5	5	4	5.4	3.7	5.5	1198.4	10.8	5.6	5.091667	1
46009	2025	12	18	6	6	4	5.4	3	5.8	1228.7	10.8	5.4	5.325	1
46009	2025	12	18	7	7	4	5.4	2.8	5.9	1336.3	10.8	5.2	5.5	1
46009	2025	12	18	8	8	4	5.3	2.3	6.3	1499.7	10.8	5.0	5.675	1
46009	2025	12	18	9	9	4	5.3	1.8	6.3	1575.8	10.8	4.7	5.816667	1
46009	2025	12	18	10	10	4	5.1	2.5	5.9	1590.1	10.8	4.3	5.975	1
46009	2025	12	18	11	11	4	5.0	3.3	5.4	1535.5	10.8	4.0	6.1	1
46009	2025	12	18	12	12	4	5.0	4.5	5.5	1469.3	10.8	3.8	6.15	1
46009	2025	12	18	13	13	4	4.9	5	5.4	1417.0	10.8	3.7	6.133333	1
46009	2025	12	18	14	14	4	4.9	5.7	4.9	1373.3	10.8	3.7	6.041667	1
46009	2025	12	18	15	15	4	4.8	6.8	4.7	1342.4	10.8	3.7	5.891667	1
46009	2025	12	18	16	16	4	4.8	7	3.7	1366.2	10.8	3.8	5.791667	1
46009	2025	12	18	17	17	4	4.8	5.2	3	1449.2	10.8	4.0	5.625	1
46009	2025	12	18	18	18	4	4.8	2.6	2.8	1520.4	10.8	4.2	5.441667	1
46009	2025	12	18	19	19	4	4.7	1.9	2.3	1646.9	10.8	4.1	5.233333	1
46009	2025	12	18	20	20	4	4.5	1.3	1.8	1627.8	10.8	4.1	4.983333	1
46009	2025	12	18	21	21	4	4.3	2	2.5	1619.5	10.8	4.0	4.683333	1
46009	2025	12	18	22	22	4	4.1	2.3	3.3	1600.4	10.8	4.0	4.308333	1
46009	2025	12	18	23	23	4	4.0	2.8	4.5	1470.6	10.8	4.0	3.991667	1
46009	2025	12	18	24	24	4	3.9	3.1	5	1411.2	10.8	3.9	3.775	1
46010	2025	12	19	1	1	5	3.8	4.3	5.7	1359.5	19.5	3.8	3.7	1
46010	2025	12	19	2	2	5	3.7	4.5	6.8	1306.0	19.5	3.8	3.658333	1
46010	2025	12	19	3	3	5	3.7	4.2	7	1254.2	19.5	3.7	3.683333	1
46010	2025	12	19	4	4	5	3.6	5.5	5.2	1241.1	19.5	3.4	3.841667	1
46010	2025	12	19	5	5	5	3.7	6.3	2.6	1227.9	19.5	3.3	4.033333	1
46010	2025	12	19	6	6	5	3.8	6.7	1.9	1190.8	19.5	3.4	4.158333	1
46010	2025	12	19	7	7	5	3.9	7.1	1.3	1210.1	19.5	3.7	4.125	1
46010	2025	12	19	8	8	5	4.1	7.3	2	1293.4	19.5	4.2	4.05	1
46010	2025	12	19	9	9	5	4.3	7.3	2.3	1427.4	19.5	4.7	3.966667	1
46010	2025	12	19	10	10	5	4.6	8.2	2.8	1427.3	19.5	5.1	3.983333	1
46010	2025	12	19	11	11	5	4.8	8.6	3.1	1444.1	19.5	5.6	3.966667	1
46010	2025	12	19	12	12	5	5.0	9	4.3	1395.0	19.5	6.1	3.925	1
46010	2025	12	19	13	13	5	5.2	9.5	4.5	1424.9	19.5	6.6	3.808333	1
46010	2025	12	19	14	14	5	5.4	8.7	4.2	1431.9	19.5	7.0	3.75	1
46010	2025	12	19	15	15	5	5.5	8.8	5.5	1453.7	19.5	7.4	3.65	1
46010	2025	12	19	16	16	5	5.6	9.5	6.3	1449.4	19.5	7.8	3.433333	1
46010	2025	12	19	17	17	5	5.7	9.4	6.7	1445.2	19.5	8.1	3.308333	1
46010	2025	12	19	18	18	5	5.9	9.8	7.1	1428.7	19.5	8.3	3.4	1
46010	2025	12	19	19	19	5	6.2	9.9	7.3	1404.5	19.5	8.6	3.741667	1
46010	2025	12	19	20	20	5	6.5	9.9	7.3	1338.3	19.5	8.8	4.175	1
46010	2025	12	19	21	21	5	6.9	10.2	8.2	1243.9	19.5	9.1	4.675	1
46010	2025	12	19	22	22	5	7.2	11.5	8.6	1176.9	19.5	9.3	5.116667	1
46010	2025	12	19	23	23	5	7.6	10.8	9	1152.9	19.5	9.6	5.608333	1
46010	2025	12	19	24	24	5	7.9	11.2	9.5	1066.3	19.5	9.8	6.091667	1
46011	2025	12	20	1	1	6	8.3	11.6	8.7	931.6	22.3	9.9	6.583333	0
46011	2025	12	20	2	2	6	8.6	9.9	8.8	842.5	22.3	10.1	7.016667	0
46011	2025	12	20	3	3	6	8.8	8.5	9.5	818.5	22.3	10.2	7.366667	0
46011	2025	12	20	4	4	6	9.0	7.7	9.4	824.4	22.3	10.2	7.75	0
46011	2025	12	20	5	5	6	9.1	6.7	9.8	834.0	22.3	10.0	8.083333	0
46011	2025	12	20	6	6	6	9.1	5.4	9.9	864.8	22.3	9.8	8.341667	0
46011	2025	12	20	7	7	6	9.0	5.6	9.9	908.6	22.3	9.4	8.6	0
46011	2025	12	20	8	8	6	9.0	3.8	10.2	987.3	22.3	9.1	8.833333	0
46011	2025	12	20	9	9	6	8.8	2.8	11.5	1112.4	22.3	8.6	9.05	0
46011	2025	12	20	10	10	6	8.6	2.9	10.8	1243.6	22.3	8.0	9.291667	0
46011	2025	12	20	11	11	6	8.4	2.2	11.2	1361.4	22.3	7.2	9.566667	0</

DATE	Year	Month	Day	HOURL	DOW	24hrAvgLag	Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLag	Weekdays	
46011	2025	12	12	20	24	6	3.3	-1.9	0.3	1492.7	22.3	0.0	6.525	0
46012	2025	12	21	1	1	7	2.7	-2.1	0.7	1444.9	14.0	-0.2	5.65	0
46012	2025	12	21	2	7	7	2.2	-1.3	1.2	1382.8	14.0	-0.4	4.708333	0
46012	2025	12	21	3	7	7	1.7	-0.3	1.4	1354.0	14.0	-0.6	3.941667	0
46012	2025	12	21	4	7	7	1.3	0.6	0.9	1318.0	14.0	-0.7	3.333333	0
46012	2025	12	21	5	7	7	1.0	1.4	-0.3	1285.8	14.0	-0.7	2.808333	0
46012	2025	12	21	6	7	7	0.8	1.8	-0.5	1278.8	14.0	-0.7	2.325	0
46012	2025	12	21	7	7	7	0.7	2.6	-0.8	1272.6	14.0	-0.5	1.85	0
46012	2025	12	21	8	7	7	0.5	3.4	-0.9	1310.4	14.0	-0.3	1.341667	0
46012	2025	12	21	9	7	7	0.5	4	-0.9	1401.3	14.0	0.1	0.958333	0
46012	2025	12	21	10	7	7	0.6	4.6	-1.4	1439.2	14.0	0.5	0.65	0
46012	2025	12	21	11	7	7	0.6	5.8	-1.9	1503.8	14.0	1.0	0.333333	0
46012	2025	12	21	12	7	7	0.8	6.1	-2.1	1519.5	14.0	1.6	0.033333	0
46012	2025	12	21	13	7	7	1.0	6.6	-1.3	1528.1	14.0	2.2	-0.18333	0
46012	2025	12	21	14	7	7	1.3	7.2	-0.3	1503.8	14.0	2.9	-0.38333	0
46012	2025	12	21	15	7	7	1.6	7.2	0.6	1489.9	14.0	3.7	-0.55	0
46012	2025	12	21	16	7	7	1.8	7.2	1.4	1464.9	14.0	4.3	-0.675	0
46012	2025	12	21	17	7	7	2.0	7.2	1.8	1454.4	14.0	4.8	-0.74167	0
46012	2025	12	21	18	7	7	2.3	6.1	2.6	1516.6	14.0	5.3	-0.7	0
46012	2025	12	21	19	7	7	2.6	5.5	3.4	1593.6	14.0	5.7	-0.525	0
46012	2025	12	21	20	7	7	2.8	4.3	4	1551.9	14.0	5.9	-0.26667	0
46012	2025	12	21	21	7	7	3.0	3.6	4.6	1538.7	14.0	6.0	0.083333	0
46012	2025	12	21	22	7	7	3.2	3	5.8	1518.8	14.0	6.0	0.491667	0
46012	2025	12	21	23	7	7	3.4	2.2	6.1	1471.2	14.0	5.8	0.95	0
46012	2025	12	21	24	7	7	3.5	0.8	6.6	1416.9	14.0	5.5	1.55	0
46013	2025	12	22	1	1	1	3.6	0	7.2	1325.2	18.6	5.1	2.216667	1
46013	2025	12	22	2	1	1	3.7	-0.1	7.2	1300.2	18.6	4.5	2.941667	1
46013	2025	12	22	3	1	1	3.8	-0.7	7.2	1291.1	18.6	3.9	3.65	1
46013	2025	12	22	4	1	1	3.8	-0.9	7.2	1286.7	18.6	3.3	4.275	1
46013	2025	12	22	5	1	1	3.7	-1.5	6.1	1284.0	18.6	2.6	4.825	1
46013	2025	12	22	6	1	1	3.6	-1.1	5.5	1352.4	18.6	1.9	5.308333	1
46013	2025	12	22	7	1	1	3.5	-2.2	4.3	1381.2	18.6	1.3	5.666667	1
46013	2025	12	22	8	1	1	3.3	-2.4	3.6	1518.9	18.6	0.6	5.908333	1
46013	2025	12	22	9	1	1	3.0	-3.6	3	1643.9	18.6	0.1	5.983333	1
46013	2025	12	22	10	1	1	2.7	-4.7	2.2	1727.0	18.6	-0.5	5.95	1
46013	2025	12	22	11	1	1	2.3	-4.9	0.8	1760.1	18.6	-1.2	5.816667	1
46013	2025	12	22	12	1	1	1.9	-4.8	0	1773.8	18.6	-1.8	5.516667	1
46013	2025	12	22	13	1	1	1.4	-5.4	-0.1	1773.0	18.6	-2.2	5.075	1
46013	2025	12	22	14	1	1	0.9	-4.8	-0.7	1787.9	18.6	-2.7	4.525	1
46013	2025	12	22	15	1	1	0.4	-5.1	-0.9	1763.6	18.6	-3.1	3.916667	1
46013	2025	12	22	16	1	1	-0.1	-5.5	-1.5	1845.4	18.6	-3.5	3.258333	1
46013	2025	12	22	17	1	1	-0.6	-5.8	-1.1	1866.4	18.6	-3.8	2.583333	1
46013	2025	12	22	18	1	1	-1.2	-6.2	-2.2	1954.2	18.6	-4.2	1.858333	1
46013	2025	12	22	19	1	1	-1.7	-6.4	-2.4	2003.7	18.6	-4.6	1.258333	1
46013	2025	12	22	20	1	1	-2.2	-6.8	-3.6	1976.7	18.6	-5.0	0.616667	1
46013	2025	12	22	21	1	1	-2.6	-7.3	-4.7	1928.4	18.6	-5.3	0.058333	1
46013	2025	12	22	22	1	1	-3.1	-7.6	-4.9	1923.8	18.6	-5.6	-0.54167	1
46013	2025	12	22	23	1	1	-3.5	-7.9	-4.8	1867.7	18.6	-5.9	-1.18333	1
46013	2025	12	22	24	1	1	-4.0	-8.1	-5.4	1760.3	18.6	-6.1	-1.775	1
46014	2025	12	23	1	2	2	-4.3	-8.6	-4.8	1741.4	14.8	-6.4	-2.24167	1
46014	2025	12	23	2	2	2	-4.7	-9.2	-5.1	1700.7	14.8	-6.7	-2.69167	1
46014	2025	12	23	3	2	2	-5.1	-9.8	-5.5	1689.3	14.8	-7.0	-3.08333	1
46014	2025	12	23	4	2	2	-5.4	-10.5	-5.8	1686.8	14.8	-7.4	-3.45	1
46014	2025	12	23	5	2	2	-5.8	-10.4	-6.2	1682.4	14.8	-7.9	-3.83333	1
46014	2025	12	23	6	2	2	-6.2	-9.7	-6.4	1701.2	14.8	-8.2	-4.19167	1
46014	2025	12	23	7	2	2	-6.6	-9.2	-6.8	1795.1	14.8	-8.5	-4.61667	1
46014	2025	12	23	8	2	2	-6.9	-9	-7.3	1890.0	14.8	-8.8	-4.96667	1
46014	2025	12	23	9	2	2	-7.1	-9.7	-7.6	1945.8	14.8	-8.9	-5.33333	1
46014	2025	12	23	10	2	2	-7.4	-9.1	-7.9	2009.1	14.8	-9.1	-5.64167	1
46014	2025	12	23	11	2	2	-7.6	-8.5	-8.1	1982.5	14.8	-9.3	-5.88333	1
46014	2025	12	23	12	2	2	-7.7	-7.6	-8.6	1912.9	14.8	-9.3	-6.13333	1
46014	2025	12	23	13	2	2	-7.8	-7.2	-9.2	1810.6	14.8	-9.3	-6.40833	1
46014	2025	12	23	14	2	2	-7.9	-6.6	-9.8	1826.9	14.8	-9.2	-6.675	1
46014	2025	12	23	15	2	2	-8.0	-6.4	-10.5	1828.1	14.8	-8.9	-7.04167	1
46014	2025	12	23	16	2	2	-8.0	-5.9	-10.4	1848.4	14.8	-8.7	-7.43333	1
46014	2025	12	23	17	2	2	-8.1	-6.8	-9.7	1858.3	14.8	-8.3	-7.85	1
46014	2025	12	23	18	2	2	-8.1	-7.9	-9.2	1968.5	14.8	-8.0	-8.23333	1
46014	2025	12	23	19	2	2	-8.2	-8.8	-9	2067.4	14.8	-7.8	-8.525	1
46014	2025	12	23	20	2	2	-8.3	-8.5	-9.7	2049.4	14.8	-7.8	-8.75833	1
46014	2025	12	23	21	2	2	-8.3	-9.6	-9.1	2028.6	14.8	-7.8	-8.94167	1
46014	2025	12	23	22	2	2	-8.4	-10.3	-8.5	2017.0	14.8	-7.7	-9.14167	1
46014	2025	12	23	23	2	2	-8.6	-11.4	-7.6	2001.1	14.8	-7.8	-9.26667	1
46014	2025	12	23	24	2	2	-8.7	-11.2	-7.2	1968.4	14.8	-8.1	-9.31667	1
46015	2025	12	24	1	3	3	-8.8	-11.1	-6.6	1875.6	16.3	-8.4	-9.275	1
46015	2025	12	24	2	3	3	-8.9	-11.2	-6.4	1793.9	16.3	-8.7	-9.15833	1
46015	2025	12	24	3	3	3	-9.0	-11	-5.9	1736.9	16.3	-9.1	-8.94167	1
46015	2025	12	24	4	3	3	-9.1	-10.4	-6.8	1717.8	16.3	-9.5	-8.65833	1
46015	2025	12	24	5	3	3	-9.1	-10.4	-7.9	1734.0	16.3	-9.9	-8.275	1
46015	2025	12	24	6	3	3	-9.1	-10.2	-8.8	1741.0	16.3	-10.2	-7.975	1
46015	2025	12	24	7	3	3	-9.1	-10.1	-8.5	1755.6	16.3	-10.3	-7.825	1
46015	2025	12	24	8	3	3	-9.1	-9.5	-9.6	1811.9	16.3	-10.5	-7.79167	1
46015	2025	12	24	9	3	3	-9.1	-9.1	-10.3	1854.0	16.3	-10.5	-7.75	1
46015	2025	12	24	10	3	3	-9.1	-8	-11.4	1924.9	16.3	-10.5	-7.74167	1
46015	2025	12	24	11	3	3	-9.1	-7.4	-11.2	1985.4	16.3	-10.3	-7.84167	1
46015	2025	12	24	12	3	3	-9.0	-6.4	-11.1	2009.2	16.3	-10.0	-8.08333	1
46015	2025	12	24	13	3	3	-9.0	-5.9	-11.2	1994.4	16.3	-9.6	-8.38333	1
46015	2025	12	24	14	3	3	-8.9	-5.7	-11	1972.7	16.3	-9.1	-8.70833	1
46015	2025	12	24	15	3	3	-8.9	-5.3	-10.4	1939.7	16.3	-8.7	-9.09167	1
46015	2025	12	24	16	3	3	-8.8	-4.9	-10.4	1897.9	16.3	-8.2	-9.475	1
46015	2025	12	24	17	3	3	-8.8	-5	-10.2	1896.3	16.3	-7.7	-9.85	1
46015	2025	12	24	18	3	3	-8.7	-5.1	-10.1	1926.0	16.3	-7.3	-10.15	1
46015	2025	12	24	19	3	3	-8.6	-4.9	-9.5	1919.5	16.3	-6.9	-10.3417	1
46015	2025	12	24	20	3	3	-8.4	-5.1	-9.1	1837.4	16.3	-6.4	-10.45	1
46015	2025	12	24	21	3	3	-8.3	-5.1	-8	1782.8	16.3	-6.1	-10.5333	1
46015	2025	12	24	22	3	3	-8.1	-5.1	-7.4	1749.8	16.3	-5.7	-10.4917	1
46015	2025	12	24	23	3	3	-7.9	-5	-6.4	1708.7	16.3	-5.5	-10.3	1
46015	2025	12												

DATE	Year	Month	Day	HOUR	DOW	24hrAvgLa	g Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLa	g Weekdays	
46016	2025	12	25	25	12	4	-5.3	-4.9	-5.2	1784.2	12.5	-5.3	-5.29167	0
46016	2025	12	25	25	13	4	-5.2	-4.9	-5.5	1815.5	12.5	-5.2	-5.18333	0
46016	2025	12	25	25	14	4	-5.2	-5.3	-5.1	1844.6	12.5	-5.2	-5.125	0
46016	2025	12	25	25	15	4	-5.2	-5.3	-5.1	1834.4	12.5	-5.2	-5.10833	0
46016	2025	12	25	25	16	4	-5.2	-5.4	-5.1	1817.8	12.5	-5.2	-5.09167	0
46016	2025	12	25	25	17	4	-5.2	-5.3	-5.3	1809.6	12.5	-5.2	-5.10833	0
46016	2025	12	25	25	18	4	-5.2	-5.6	-5.4	1812.8	12.5	-5.3	-5.11667	0
46016	2025	12	25	25	19	4	-5.2	-5.7	-5.4	1790.1	12.5	-5.3	-5.13333	0
46016	2025	12	25	25	20	4	-5.2	-5.7	-5.4	1735.7	12.5	-5.3	-5.175	0
46016	2025	12	25	25	21	4	-5.3	-5.7	-5.4	1710.8	12.5	-5.3	-5.2	0
46016	2025	12	25	25	22	4	-5.3	-5.7	-5	1693.9	12.5	-5.4	-5.225	0
46016	2025	12	25	25	23	4	-5.3	-5.7	-4.9	1655.8	12.5	-5.4	-5.25	0
46016	2025	12	25	25	24	4	-5.3	-5.6	-4.9	1597.8	12.5	-5.4	-5.25	0
46017	2025	12	26	26	1	5	-5.4	-5.6	-5.3	1562.7	23.9	-5.5	-5.23333	0
46017	2025	12	26	26	2	5	-5.4	-5.6	-5.3	1531.2	23.9	-5.6	-5.20833	0
46017	2025	12	26	26	3	5	-5.4	-5.7	-5.4	1505.1	23.9	-5.6	-5.19167	0
46017	2025	12	26	26	4	5	-5.4	-5.9	-5.3	1486.0	23.9	-5.6	-5.20833	0
46017	2025	12	26	26	5	5	-5.4	-6.1	-5.6	1481.5	23.9	-5.7	-5.23333	0
46017	2025	12	26	26	6	5	-5.5	-5.8	-5.7	1492.1	23.9	-5.7	-5.25	0
46017	2025	12	26	26	7	5	-5.5	-5.7	-5.7	1531.7	23.9	-5.7	-5.275	0
46017	2025	12	26	26	8	5	-5.5	-5.8	-5.7	1583.1	23.9	-5.7	-5.3	0
46017	2025	12	26	26	9	5	-5.5	-5.9	-5.7	1633.6	23.9	-5.7	-5.325	0
46017	2025	12	26	26	10	5	-5.6	-6.1	-5.7	1672.1	23.9	-5.8	-5.35	0
46017	2025	12	26	26	11	5	-5.6	-6.1	-5.6	1759.8	23.9	-5.8	-5.375	0
46017	2025	12	26	26	12	5	-5.6	-6.1	-5.6	1801.5	23.9	-5.8	-5.43333	0
46017	2025	12	26	26	13	5	-5.7	-6.5	-5.6	1822.5	23.9	-5.9	-5.49167	0
46017	2025	12	26	26	14	5	-5.7	-6.4	-5.7	1878.5	23.9	-5.9	-5.55	0
46017	2025	12	26	26	15	5	-5.8	-6.5	-5.9	1851.8	23.9	-6.0	-5.575	0
46017	2025	12	26	26	16	5	-5.8	-6.8	-6.1	1845.7	23.9	-6.1	-5.60833	0
46017	2025	12	26	26	17	5	-5.9	-7.3	-5.8	1879.8	23.9	-6.2	-5.65	0
46017	2025	12	26	26	18	5	-6.0	-7.5	-5.7	1931.1	23.9	-6.3	-5.71667	0
46017	2025	12	26	26	19	5	-6.1	-7.8	-5.8	1978.9	23.9	-6.4	-5.73333	0
46017	2025	12	26	26	20	5	-6.2	-7.8	-5.9	1997.4	23.9	-6.6	-5.73333	0
46017	2025	12	26	26	21	5	-6.2	-8.1	-6.1	1909.8	23.9	-6.7	-5.74167	0
46017	2025	12	26	26	22	5	-6.3	-8.1	-6.1	1876.6	23.9	-6.9	-5.75833	0
46017	2025	12	26	26	23	5	-6.4	-8.2	-6.1	1826.6	23.9	-7.1	-5.79167	0
46017	2025	12	26	26	24	5	-6.5	-8	-6.5	1724.1	23.9	-7.3	-5.825	0
46018	2025	12	27	27	1	6	-6.6	-8.2	-6.4	1714.7	21.5	-7.4	-5.86667	0
46018	2025	12	27	27	2	6	-6.8	-8	-6.5	1682.8	21.5	-7.6	-5.94167	0
46018	2025	12	27	27	3	6	-6.9	-7.9	-6.8	1647.7	21.5	-7.7	-6.00833	0
46018	2025	12	27	27	4	6	-6.9	-7.9	-7.3	1627.2	21.5	-7.8	-6.075	0
46018	2025	12	27	27	5	6	-7.0	-7.4	-7.5	1608.1	21.5	-7.9	-6.15	0
46018	2025	12	27	27	6	6	-7.1	-7.4	-7.8	1600.9	21.5	-7.9	-6.25	0
46018	2025	12	27	27	7	6	-7.1	-7.3	-7.8	1623.4	21.5	-7.9	-6.39167	0
46018	2025	12	27	27	8	6	-7.2	-6.8	-8.1	1727.6	21.5	-7.9	-6.56667	0
46018	2025	12	27	27	9	6	-7.3	-6.8	-8.1	1781.1	21.5	-7.8	-6.73333	0
46018	2025	12	27	27	10	6	-7.3	-6.2	-8.2	1813.4	21.5	-7.7	-6.91667	0
46018	2025	12	27	27	11	6	-7.3	-5.3	-8	1866.1	21.5	-7.5	-7.08333	0
46018	2025	12	27	27	12	6	-7.3	-5	-8.2	1881.8	21.5	-7.3	-7.25833	0
46018	2025	12	27	27	13	6	-7.2	-4.6	-8	1889.3	21.5	-7.0	-7.41667	0
46018	2025	12	27	27	14	6	-7.1	-4.4	-7.9	1870.3	21.5	-6.7	-7.55833	0
46018	2025	12	27	27	15	6	-7.1	-4.5	-7.9	1866.0	21.5	-6.4	-7.69167	0
46018	2025	12	27	27	16	6	-7.0	-4.5	-7.4	1827.6	21.5	-6.1	-7.80833	0
46018	2025	12	27	27	17	6	-6.9	-5.4	-7.4	1853.1	21.5	-5.9	-7.9	0
46018	2025	12	27	27	18	6	-6.8	-5.9	-7.3	1963.4	21.5	-5.7	-7.90833	0
46018	2025	12	27	27	19	6	-6.7	-6.3	-6.8	1997.9	21.5	-5.6	-7.9	0
46018	2025	12	27	27	20	6	-6.7	-6.5	-6.8	1967.0	21.5	-5.5	-7.85833	0
46018	2025	12	27	27	21	6	-6.6	-7.4	-6.2	1930.8	21.5	-5.5	-7.775	0
46018	2025	12	27	27	22	6	-6.6	-7.6	-5.3	1893.0	21.5	-5.5	-7.66667	0
46018	2025	12	27	27	23	6	-6.6	-7.4	-5	1830.0	21.5	-5.6	-7.50833	0
46018	2025	12	27	27	24	6	-6.5	-7.4	-4.6	1702.4	21.5	-5.8	-7.26667	0
46019	2025	12	28	28	1	7	-6.5	-7.6	-4.4	1685.0	17.9	-6.0	-7.01667	0
46019	2025	12	28	28	2	7	-6.5	-8.4	-4.5	1656.2	17.9	-6.2	-6.71667	0
46019	2025	12	28	28	3	7	-6.5	-7.9	-4.5	1615.7	17.9	-6.6	-6.41667	0
46019	2025	12	28	28	4	7	-6.5	-7.9	-5.4	1596.6	17.9	-6.9	-6.13333	0
46019	2025	12	28	28	5	7	-6.5	-7.8	-5.9	1595.4	17.9	-7.1	-5.85	0
46019	2025	12	28	28	6	7	-6.5	-7.6	-6.3	1613.7	17.9	-7.3	-5.68333	0
46019	2025	12	28	28	7	7	-6.5	-7.5	-6.5	1633.6	17.9	-7.5	-5.55833	0
46019	2025	12	28	28	8	7	-6.5	-7.3	-7.4	1691.1	17.9	-7.6	-5.475	0
46019	2025	12	28	28	9	7	-6.6	-6.3	-7.6	1789.1	17.9	-7.7	-5.45	0
46019	2025	12	28	28	10	7	-6.5	-5.3	-7.4	1812.0	17.9	-7.6	-5.5	0
46019	2025	12	28	28	11	7	-6.5	-4.9	-7.4	1846.3	17.9	-7.4	-5.61667	0
46019	2025	12	28	28	12	7	-6.5	-4.2	-7.6	1832.9	17.9	-7.2	-5.79167	0
46019	2025	12	28	28	13	7	-6.4	-2.9	-8.4	1794.4	17.9	-6.9	-5.99167	0
46019	2025	12	28	28	14	7	-6.4	-1.1	-7.9	1732.8	17.9	-6.5	-6.24167	0
46019	2025	12	28	28	15	7	-6.2	-0.5	-7.9	1674.7	17.9	-5.9	-6.575	0
46019	2025	12	28	28	16	7	-6.1	0	-7.8	1629.5	17.9	-5.3	-6.85833	0
46019	2025	12	28	28	17	7	-5.9	-0.6	-7.6	1651.6	17.9	-4.6	-7.14167	0
46019	2025	12	28	28	18	7	-5.7	-1.5	-7.5	1763.3	17.9	-4.0	-7.34167	0
46019	2025	12	28	28	19	7	-5.5	-2	-7.3	1874.6	17.9	-3.5	-7.48333	0
46019	2025	12	28	28	20	7	-5.3	-2.5	-6.3	1852.9	17.9	-3.1	-7.58333	0
46019	2025	12	28	28	21	7	-5.2	-2.4	-5.3	1819.9	17.9	-2.7	-7.65	0
46019	2025	12	28	28	22	7	-4.9	-3.2	-4.9	1782.3	17.9	-2.3	-7.55833	0
46019	2025	12	28	28	23	7	-4.8	-3.3	-4.2	1723.5	17.9	-2.2	-7.36667	0
46019	2025	12	28	28	24	7	-4.6	-3.4	-2.9	1607.5	17.9	-2.0	-7.15833	0
46020	2025	12	29	29	1	1	-4.4	-3.6	-1.1	1579.0	8.3	-2.0	-6.89167	1
46020	2025	12	29	29	2	1	-4.3	-3.9	-0.5	1530.1	8.3	-2.0	-6.5	1
46020	2025	12	29	29	3	1	-4.1	-4.6	0	1496.6	8.3	-2.2	-5.89167	1
46020	2025	12	29	29	4	1	-3.9	-4.7	-0.6	1489.7	8.3	-2.6	-5.275	1
46020	2025	12	29	29	5	1	-3.8	-5.2	-1.5	1503.6	8.3	-3.0	-4.61667	1
46020	2025	12	29	29	6	1	-3.7	-5.7	-2	1580.0	8.3	-3.4	-4.01667	1
46020	2025	12	29	29	7	1	-3.6	-5.2	-2.5	1643.5	8.3	-3.7	-3.50833	1
46020	2025	12	29	29	8	1	-3.5	-5.4	-2.4	1681.4	8.3	-4.0	-3.05	1
46020	2025	12	29	29	9	1	-3.4	-4.4	-3.2	1746.4	8.3	-4.2	-2.65	1
46020	2025	12	29	29	10	1	-3.4	-3.8	-3.3	1844.8	8.3	-4.4	-2.325	1
46020	2025	12	29	29	11	1	-3.3	-2.7	-3.4	1838.1	8.3	-4.4	-2.15	1
46020														

DATE	Year	Month	Day	HOUR	DOW	24hrAvgLa	g Temp	LagTemp	12 Load	Wind	12hrAvg	12hrAvgLa	g Weekdays
46020	2025	12	29	24	1	-2.4	3.1	-1.8	1480.4	8.3	-0.5	-4.38333	1
46021	2025	12	30	1	2	-2.2	4.6	-1.9	1422.8	24.2	-0.1	-4.23333	1
46021	2025	12	30	2	2	-1.8	6.3	-1.8	1364.7	24.2	0.5	-4.08333	1
46021	2025	12	30	3	2	-1.4	6.8	-1.7	1292.3	24.2	1.1	-3.91667	1
46021	2025	12	30	4	2	-0.9	6.7	-0.7	1222.0	24.2	1.9	-3.68333	1
46021	2025	12	30	5	2	-0.4	7.1	-0.4	1197.3	24.2	2.6	-3.43333	1
46021	2025	12	30	6	2	0.1	6.7	0	1180.4	24.2	3.2	-3.05833	1
46021	2025	12	30	7	2	0.6	5.7	0.3	1247.5	24.2	3.8	-2.61667	1
46021	2025	12	30	8	2	1.0	3.7	0.6	1293.1	24.2	4.3	-2.18333	1
46021	2025	12	30	9	2	1.4	2.8	1.3	1375.5	24.2	4.6	-1.70833	1
46021	2025	12	30	10	2	1.7	2.3	2	1446.4	24.2	4.7	-1.29167	1
46021	2025	12	30	11	2	2.0	1.1	3.1	1503.6	24.2	4.8	-0.86667	1
46021	2025	12	30	12	2	2.1	1.7	4.6	1535.2	24.2	4.7	-0.475	1
46021	2025	12	30	13	2	2.3	1.4	6.3	1551.3	24.2	4.6	-0.08333	1
46021	2025	12	30	14	2	2.4	1.4	6.8	1573.8	24.2	4.4	0.45	1
46021	2025	12	30	15	2	2.5	1	6.7	1618.6	24.2	4.0	1.133333	1
46021	2025	12	30	16	2	2.7	-0.6	7.1	1645.9	24.2	3.5	1.85	1
46021	2025	12	30	17	2	2.7	-1.3	6.7	1744.8	24.2	2.9	2.55	1
46021	2025	12	30	18	2	2.7	-2.2	5.7	1771.4	24.2	2.2	3.2	1
46021	2025	12	30	19	2	2.6	-2.7	3.7	1849.6	24.2	1.4	3.791667	1
46021	2025	12	30	20	2	2.5	-3.1	2.8	1805.1	24.2	0.7	4.266667	1
46021	2025	12	30	21	2	2.4	-3.5	2.3	1786.7	24.2	0.2	4.55	1
46021	2025	12	30	22	2	2.2	-3.6	1.1	1757.7	24.2	-0.4	4.733333	1
46021	2025	12	30	23	2	2.0	-3.8	1.7	1662.5	24.2	-0.9	4.816667	1
46021	2025	12	30	24	2	1.7	-4.1	1.4	1632.5	24.2	-1.3	4.741667	1
46022	2025	12	31	1	3	1.4	-4.5	1.4	1601.6	8.9	-1.8	4.625	1
46022	2025	12	31	2	3	1.1	-4.4	1	1527.8	8.9	-2.3	4.358333	1
46022	2025	12	31	3	3	0.6	-4.9	-0.6	1519.3	8.9	-2.7	3.95	1
46022	2025	12	31	4	3	0.1	-5.7	-1.3	1516.7	8.9	-3.2	3.466667	1
46022	2025	12	31	5	3	-0.4	-6.2	-2.2	1504.6	8.9	-3.7	2.858333	1
46022	2025	12	31	6	3	-1.0	-5.9	-2.7	1523.2	8.9	-4.1	2.158333	1
46022	2025	12	31	7	3	-1.5	-6.3	-3.1	1632.0	8.9	-4.4	1.416667	1
46022	2025	12	31	8	3	-2.0	-6.4	-3.5	1694.5	8.9	-4.7	0.716667	1
46022	2025	12	31	9	3	-2.4	-7	-3.6	1717.2	8.9	-4.9	0.15	1
46022	2025	12	31	10	3	-2.8	-6	-3.8	1775.8	8.9	-5.2	-0.375	1
46022	2025	12	31	11	3	-3.2	-4.1	-4.1	1768.6	8.9	-5.4	-0.86667	1
46022	2025	12	31	12	3	-3.4	-2.5	-4.5	1718.6	8.9	-5.5	-1.275	1
46022	2025	12	31	13	3	-3.5	-1.9	-4.4	1667.6	8.9	-5.3	-1.75833	1
46022	2025	12	31	14	3	-3.7	-2.2	-4.9	1698.2	8.9	-5.1	-2.25	1
46022	2025	12	31	15	3	-3.8	-1.3	-5.7	1702.7	8.9	-4.9	-2.73333	1
46022	2025	12	31	16	3	-3.9	-1.4	-6.2	1688.4	8.9	-4.6	-3.225	1
46022	2025	12	31	17	3	-4.0	-1.9	-5.9	1764.7	8.9	-4.3	-3.65	1
46022	2025	12	31	18	3	-4.0	-2.4	-6.3	1800.1	8.9	-3.9	-4.05833	1
46022	2025	12	31	19	3	-4.0	-2.9	-6.4	1866.5	8.9	-3.6	-4.36667	1
46022	2025	12	31	20	3	-4.0	-1.7	-7	1805.2	8.9	-3.3	-4.66667	1
46022	2025	12	31	21	3	-3.9	-1.9	-6	1729.4	8.9	-2.9	-4.94167	1
46022	2025	12	31	22	3	-3.9	-1.7	-4.1	1626.9	8.9	-2.5	-5.23333	1
46022	2025	12	31	23	3	-3.8	-2.1	-2.5	1604.9	8.9	-2.2	-5.43333	1
46022	2025	12	31	24	3	-3.7	-1.6	-1.9	1552.6	8.9	-2.0	-5.45833	1

SUMMARY OUTPUT

Regression Statistics	
Multiple R	0.81801092
R Square	0.66914186
Adjusted R Square	0.66905068
Standard Error	143.091653
Observations	14520

ANOVA					
	df	SS	MS	F	Significance F
Regression	4	601065795.8	150266449	7338.94	0
Residual	14515	297197835	20475.221		
Total	14519	898263630.8			

	Coefficients	Standard Error	t Stat	P-value	Lower 95%	Upper 95%	Lower 95.0%	Upper 95.0%
Intercept	1419.85441	3.586090102	395.93384	0	1412.825217	1426.8836	1412.82522	1426.8836
Wind	3.37828423	0.197618379	17.09499	7E-65	2.990927026	3.76564144	2.99092703	3.76564144
12hrAvg	-35.1057294	0.35488133	-98.92245	0	-35.801342	-34.4101168	-35.801342	-34.4101168
12hrAvgLag	-2.86370325	0.353258208	-8.106544	5.6E-16	-3.55613436	-2.17127215	-3.55613436	-2.17127215
Weekdays	41.4298405	2.545256524	16.277275	4.8E-59	36.44081338	46.4188677	36.4408134	46.4188677

	MW
2025 Forecast Peak	2,403
Interruptible	-45
Weather (-12.1C 12hr lag avg, -11.0C 24hr lag avg)	-83
Wind (14.1 km/h daily avg)	-16
Morning peak impact (est)	-75
Unexplained	83
2026 Actual Peak	2,267

Year	Month	Day	Temp_HE0800	Temp_HE1800	Load_HE0800	Load_HE1800
2022	2	1	-11.9	-6.7	1,680	1,602
2022	2	2	-13	1.2	1,781	1,420
2022	2	3	3.5	5.9	1,165	1,238
2022	2	4	0	0.6	1,183	1,201
2022	2	7	-4.5	0.7	1,604	1,514
2022	2	8	3.2	5.6	1,319	1,331
2022	2	9	1.9	3.5	1,247	1,301
2022	2	10	-1.2	2.6	1,277	1,247
2022	2	11	2.4	6	1,277	1,128
2022	2	14	-7	-6.5	1,480	1,561
2022	2	15	-12.1	-10.5	1,645	1,748
2022	2	16	-12.6	-4.8	1,830	1,479
2022	2	17	4.7	7.1	1,259	1,207
2022	2	18	8.9	6.4	988	1,166
2022	2	22	-1.1	0.4	1,311	1,359
2022	2	23	7.6	7.4	1,144	1,175
2022	2	24	-7.3	-3.7	1,461	1,446
2022	2	25	-9.9	-9.1	1,674	1,670
2022	2	28	-9.7	-9	1,520	1,607
2023	2	1	-11.3	-7.1	1,561	1,520
2023	2	2	-13.1	-2.8	1,689	1,507
2023	2	3	1.3	-12.2	1,320	1,715
2023	2	6	3.7	4.4	1,257	1,343
2023	2	7	-4.4	-1.1	1,496	1,428
2023	2	8	-1.1	3.5	1,408	1,371
2023	2	9	-4.7	-0.7	1,453	1,416
2023	2	10	1.2	7.9	1,344	1,282
2023	2	13	-1.5	-0.2	1,393	1,439
2023	2	14	-3.5	-2.4	1,351	1,477
2023	2	15	-9.7	1.8	1,537	1,320
2023	2	16	5.9	12.4	1,167	1,072
2023	2	17	3.6	5.7	1,141	1,288
2023	2	21	1.7	2	1,225	1,285
2023	2	22	-4.7	3.9	1,397	1,240
2023	2	23	-8	-6.3	1,479	1,576
2023	2	24	-8.9	-7.6	1,508	1,637
2023	2	27	-12.7	-5.2	1,683	1,469
2023	2	28	-12.4	-4.7	1,690	1,478
2024	2	1	-1.8	0.8	1,446	1,410
2024	2	2	0.5	0.7	1,297	1,383
2024	2	5	0	1.1	1,284	1,448

Year	Month	Day	Temp_HE0800	Temp_HE1800	Load_HE0800	Load_HE1800
2024	2	6	0	0.1	1,323	1,429
2024	2	7	-2.5	-1.4	1,366	1,420
2024	2	8	-4.7	1.5	1,410	1,307
2024	2	9	-6.6	-0.2	1,472	1,279
2024	2	12	1.8	5.8	1,228	1,189
2024	2	13	-2.9	0.1	1,324	1,396
2024	2	14	-5.8	-5.3	1,393	1,521
2024	2	15	-4.2	0.2	1,460	1,396
2024	2	16	-7.9	-2	1,516	1,434
2024	2	20	-9.2	-4.1	1,638	1,482
2024	2	21	-15.5	-4.4	1,713	1,425
2024	2	22	-4.5	-0.1	1,559	1,433
2024	2	23	-3.6	1.4	1,425	1,343
2024	2	26	-8.3	1.2	1,593	1,412
2024	2	27	-1	2.6	1,345	1,148
2024	2	28	6.8	5.4	1,098	1,168
2024	2	29	8.2	-4.3	1,005	1,445

AM


-29.2196381	1311.268
1.35519898	9.523987
0.892490223	63.41001
464.8828582	56
1869214.828	225166.5

PM

-26.6197726	1386.2361
1.613272508	8.1986509
0.829406576	62.382894
272.2658772	56
1059556.804	217931.02

MW difference

-74.9683




REDACTED (CONFIDENTIAL INFORMATION REMOVED)


REDACTED 2026 Load Forecast Report Synapse IR-1 Attachment 1 Page 186 of 196

	Year	Heat	WaterHt	Cooking	Misc	Lighting	TV	Dryer	Refrig	Freezer	Dish	Washer	EV	Total
2026 Residential End Use Peak Shares	2026	1071.91	128.67	90.70	78.15	82.30	22.01	50.24	21.94	11.68	2.23	1.91	7.0	1568.73
2035 Residential End Use Peak Shares	2035	1145.99	149.78	97.60	87.85	85.33	18.84	47.25	19.30	10.77	2.14	1.34	79.3	1745.49
	2026	68.3%	8.2%	5.8%	5.0%	5.2%	1.4%	3.2%	1.4%	0.7%	0.1%	0.1%	0.4%	
	2035	65.7%	8.6%	5.6%	5.0%	4.9%	1.1%	2.7%	1.1%	0.6%	0.1%	0.1%	4.5%	
d		-2.7%	0.4%	-0.2%	0.1%	-0.4%	-0.3%	-0.5%	-0.3%	-0.1%	0.0%	0.0%	4.1%	

2026 Residential End Use Peak Shares




2035 Residential End Use Peak Shares




	Year	Heat	Misc	Light	Vent	Refrig	Office	EWHeat	Cooking	EV	Total
2026 Commercial End Use Peak Shares	2026	226.43	96.65	132.74	52.58	24.77	18.42	4.00	12.61	1.30	569.5
2035 Commercial End Use Peak Shares	2035	282.43	103.61	110.22	51.80	23.81	25.41	4.01	11.19	73.60	686.1
	2026	39.8%	17.0%	23.3%	9.2%	4.3%	3.2%	0.7%	2.2%	0.2%	
	2035	41.2%	15.1%	16.1%	7.5%	3.5%	3.7%	0.6%	1.6%	10.7%	
d		1.4%	-1.9%	-7.2%	-1.7%	-0.9%	0.5%	-0.1%	-0.6%	10.5%	


2026 Commercial End Use Peak Shares




2035 Commercial End Use Peak Shares



Year	Bottom-up Model System Peak	Current System Peak Model (top-down)
2026	2,410	2,484
2027	2,438	2,497
2028	2,470	2,526
2029	2,488	2,549
2030	2,509	2,563
2031	2,545	2,593
2032	2,592	2,620
2033	2,633	2,652
2034	2,692	2,689
2035	2,761	2,730
2036	2,828	2,765
growth rate	1.6%	1.1%




Non-large customer classes		
Year	Peak (MW)	annual sales (GWh)
2016	1,911	7,696
2017	1,857	7,804
2018	1,896	8,048
2019	1,844	8,173
2020	1,850	7,989
2021	1,784	7,957
2022	1,968	8,304
2023	2,302	8,387
2024	1,908	8,530
2025	2,084	8,655



Item	2026 NSR Energy (GWh)	2026 Firm Peak (MW)	2036 NSR Energy (GWh)	2036 Firm Peak (MW)
2025 Load Forecast	11,403	2,263	11,635	2,560
2026 Load Forecast	11,556	2,346	12,010	2,590
Evergreen IRP E1 – Current Policy and Trends	11,289	2,098	12,150	2,602
Evergreen IRP E2 – Hybrid Peak Mitigation	11,235	2,000	12,040	2,488
Evergreen IRP E3 – Accelerated Electrification	11,275	2,155	12,842	3,014



Year	Interruptible Contribution to Peak (MW)	Demand Response (reduction in Firm Peak only, MW)	Firm Contribution to Peak (MW)	Net System Peak (MW)	Growth (%)	Temp at Peak (deg C)	12hr Lag Temp (deg C)	24hr Lag Temp (deg C)	Notes
2016	98	-	2,013	2,111	4.8	-14	-15	-13	December 16 weekday evening
2017	67	-	1,951	2,018	-4.4	-13	-13	-13	December 28 weekday evening (between holidays)
2018	80	-	1,993	2,073	2.7	-12	-13	-14	January 7 weekend evening
2019	111	-	1,949	2,060	-0.6	-15	-14	-12	February 27 weekday morning (min lighting load)
2020	96	-	1,954	2,050	-0.5	-13	-10	-8	January 17 weekday evening
2021	94	-	1,875	1,968	-4	-10	-10	-5	March 2 weekday evening
2022	155	-	2,061	2,216	12.6	-15	-14	-12	January 11 weekday evening
2023	58	-	2,397	2,455	10.8	-22	-23	-15	February 4 weekend noon
2024	87	-	2,001	2,088	-14.9	-16	-11	-9	February 21 weekday morning (min lighting load)
2025	87	-	2,180	2,267	8.6	-12	-12	-12	February 6 weekday morning (min lighting load)
2026	130	8	2,346	2,484	9.6		-15	-15	Forecast
2027	129	11	2,356	2,497	1.5		-14	-12	Forecast
2028	135	14	2,377	2,526	1.2		-14	-12	Forecast
2029	142	17	2,390	2,549	0.9		-14	-12	Forecast
2030	141	20	2,402	2,563	0.6		-14	-12	Forecast
2031	140	24	2,429	2,593	1.2		-13	-12	Forecast
2032	140	34	2,446	2,620	1		-13	-12	Forecast
2033	139	36	2,477	2,652	1.2		-13	-12	Forecast
2034	139	37	2,514	2,689	1.4		-13	-12	Forecast
2035	138	37	2,555	2,730	1.5		-13	-12	Forecast
2036	138	37	2,590	2,765	1.3		-13	-12	Forecast

NSR				
Year	2026	2025	2024	2023
2016	10,809	10,809	10,809	10,809
2017	10,873	10,873	10,873	10,873
2018	11,250	11,250	11,250	11,250
2019	11,077	11,077	11,077	11,077
2020	10,723	10,723	10,723	10,723
2021	10,902	10,902	10,902	10,902
2022	11,134	11,134	11,134	11,134
2023	11,131	11,131	11,131	11,288
2024	11,326	11,326	11,490	11,168
2025	11,469	11,607	11,409	11,199
2026	11,575	11,403	11,306	11,327
2027	11,424	11,193	11,347	11,416
2028	11,525	11,226	11,416	11,531
2029	11,556	11,159	11,448	11,616
2030	11,568	11,130	11,514	11,720
2031	11,621	11,125	11,523	11,838
2032	11,689	11,169	11,585	11,998
2033	11,722	11,168	11,605	12,113
2034	11,815	11,236		
2035	11,939	11,365		
2036	12,097			



Firm Peak				
Year	2026	2025	2024	2023
2016	2013	2013	2013	2013
2017	1951	1951	1951	1951
2018	1993	1993	1993	1993
2019	1949	1949	1949	1949
2020	1954	1954	1954	1954
2021	1875	1875	1875	1875
2022	2061	2061	2061	2061
2023	2397	2397	2397	2105
2024	2001	2001	2219	2111
2025	2180	2267	2259	2119
2026	2346	2263	2267	2148
2027	2356	2268	2265	2198
2028	2377	2274	2283	2259
2029	2390	2285	2306	2325
2030	2402	2303	2360	2395
2031	2429	2332	2397	2468
2032	2446	2364	2438	2545
2033	2477	2402	2485	2627
2034	2514	2449	2542	
2035	2555	2503		
2036	2590			

System Peak				
Year	2026	2025	2024	2023
2016	2111	2111	2111	2111
2017	2018	2018	2018	2018
2018	2073	2073	2073	2073
2019	2060	2060	2060	2060
2020	2050	2050	2050	2050
2021	1968	1968	1968	1968
2022	2216	2216	2216	2216
2023	2455	2455	2455	2256
2024	2088	2088	2365	2271
2025	2267	2403	2408	2291
2026	2484	2408	2428	2340
2027	2497	2423	2437	2395
2028	2526	2443	2466	2454
2029	2549	2458	2493	2520
2030	2563	2474	2547	2589
2031	2593	2503	2583	2662
2032	2620	2535	2623	2738
2033	2652	2573	2670	2819
2034	2689	2618	2727	
2035	2730	2672		
2036	2765			



REDACTED (CONFIDENTIAL INFORMATION REMOVED)

REDACTED 2026 Load Forecast Report Synapse IR-1 Attachment 1 Page 192 of 196

Forecast Issued	Forecast <u>2016</u>	Forecast <u>2017</u>	Forecast <u>2018</u>	Forecast <u>2019</u>	Forecast <u>2020</u>	Forecast <u>2021</u>	Forecast <u>2022</u>	Forecast <u>2023</u>	Forecast <u>2024</u>	Forecast <u>2025</u>
2015	10,013	10,036	10,020	9,986	9,918	9,833	9,769	9,731	9,681	9,611
2016		10,156	10,180	10,202	10,233	10,216	10,235	10,254	10,282	10,248
2017			9,931	9,896	9,920	9,891	9,902	9,927	9,954	9,924
2018				9,944	9,947	9,860	9,825	9,779	9,746	9,684
2019					10,168	10,171	10,146	10,108	10,088	10,003
2020						10,056	10,109	10,152	10,200	10,157
2021							10,011	10,049	10,121	10,085
2022								10,117	10,213	10,241
2023									10,266	10,297
2024										10,596
Percent Error										
2015	2.1%	1.7%	-1.4%	-2.2%	0.7%	-1.0%	-4.0%	-7.0%	-8.3%	-10.8%
2016		2.9%	0.2%	-0.1%	3.9%	2.8%	0.6%	-2.0%	-2.6%	-4.9%
2017			-2.3%	-3.1%	0.7%	-0.5%	-2.7%	-5.1%	-5.7%	-7.9%
2018				-2.6%	1.0%	-0.8%	-3.5%	-6.5%	-7.7%	-10.2%
2019					3.3%	2.4%	-0.3%	-3.4%	-4.5%	-7.2%
2020						1.2%	-0.7%	-3.0%	-3.4%	-5.8%
2021							-1.6%	-3.9%	-4.2%	-6.4%
2022								-3.3%	-3.3%	-5.0%
2023									-2.8%	-4.5%
2024										-1.7%
Statistics										
Lead Time (Years)	1	2	3	4	5	6	7	8	9	10
No. Observations	10	9	8	7	6	5	4	3	2	1
Average percent Error	-0.5%	-1.1%	-1.7%	-2.2%	-2.7%	-4.1%	-5.5%	-5.8%	-6.6%	-10.8%
MAPE	2.4%	2.3%	1.9%	3.3%	3.8%	4.3%	5.5%	5.8%	6.6%	10.8%

REDACTED (CONFIDENTIAL INFORMATION REMOVED)

REDACTED 2026 Load Forecast Report Synapse IR-1 Attachment 1 Page 193 of 196

Forecast Issued	Forecast 2016	Forecast 2017	Forecast 2018	Forecast 2019	Forecast 2020	Forecast 2021	Forecast 2022	Forecast 2023	Forecast 2024	Forecast 2025
2015	1892	1896	1897	1889	1878	1859	1847	1837	1854	1842
2016		1987	2009	2023	2033	2041	2051	2057	2060	2062
2017			1993	2010	2029	2038	2054	2073	2080	2084
2018				2001	2015	2016	2021	2028	2034	2030
2019					2070	2073	2078	2080	2086	2086
2020						2085	2053	2059	2064	2070
2021							2062	2065	2060	2053
2022								2035	2057	2076
2023									2105	2119
2024										2259
Actuals Firm Peak:	2,014	1,951	1,993	1,949	1,954	1,875	2,061	2,397	2,001	2,180
Percent Error										
2015	-6.0%	-2.8%	-4.8%	-3.1%	-3.9%	-0.8%	-10.4%	-23.4%	-7.3%	-15.5%
2016		1.8%	0.8%	3.8%	4.0%	8.9%	-0.5%	-14.2%	2.9%	-5.4%
2017			0.0%	3.1%	3.8%	8.7%	-0.3%	-13.5%	3.9%	-4.4%
2018				2.7%	3.1%	7.5%	-1.9%	-15.4%	1.6%	-6.9%
2019					5.9%	10.6%	0.8%	-13.2%	4.2%	-4.3%
2020						11.2%	-0.4%	-14.1%	3.1%	-5.0%
2021							0.1%	-13.9%	2.9%	-5.8%
2022								-15.1%	2.8%	-4.8%
2023									5.2%	-2.8%
2024										3.6%
Statistics										
Lead Time (Years)	1	2	3	4	5	6	7	8	9	10
No. Observations	10	9	8	7	6	5	4	3	2	1
Average percent Error	0.9%	0.1%	-0.6%	-1.2%	-1.9%	-3.5%	-6.9%	-8.3%	-6.4%	-15.5%
MAPE	5.2%	4.5%	5.3%	5.7%	6.3%	4.2%	8.8%	10.2%	6.4%	15.5%

REDACTED (CONFIDENTIAL INFORMATION REMOVED)

REDACTED 2026 Load Forecast Report Synapse IR-1 Attachment 1 Page 194 of 196

Forecast Issued	Forecast 2016	Forecast 2017	Forecast 2018	Forecast 2019	Forecast 2020	Forecast 2021	Forecast 2022	Forecast 2023	Forecast 2024	Forecast 2025
2015	2031	2035	2036	2028	2016	1997	1985	1975	1992	1980
2016		2130	2156	2170	2180	2188	2197	2203	2205	2208
2017			2149	2166	2184	2193	2208	2227	2234	2238
2018				2157	2172	2174	2178	2184	2191	2187
2019					2234	2243	2248	2249	2255	2255
2020						2237	2212	2220	2230	2236
2021							2225	2240	2247	2257
2022								2185	2215	2253
2023									2256	2291
2024										2408
Actuals System Peak:	2,111	2,018	2,073	2,060	2,050	1,968	2,216	2,455	2,088	2,267
Percent Error										
2014	-3.8%	0.9%	-1.8%	-1.6%	-1.7%	1.5%	-10.4%	-19.6%	-4.6%	-12.7%
2015		5.6%	4.0%	5.3%	6.3%	11.2%	-0.8%	-10.3%	5.6%	-2.6%
2016			3.7%	5.1%	6.5%	11.4%	-0.3%	-9.3%	7.0%	-1.3%
2017				4.7%	5.9%	10.4%	-1.7%	-11.0%	4.9%	-3.5%
2018					9.0%	14.0%	1.5%	-8.4%	8.0%	-0.5%
2019						13.6%	-0.2%	-9.6%	6.8%	-1.4%
2020							0.4%	-8.8%	7.6%	-0.4%
2021								-11.0%	6.1%	-0.6%
2022									8.0%	1.1%
2023										6.2%
Statistics										
Lead Time (Years)	1	2	3	4	5	6	7	8	9	10
No. Observations	10	9	8	7	6	5	4	3	2	1
Average percent Error	3.6%	3.1%	2.4%	1.8%	0.8%	-0.9%	-4.3%	-5.1%	-3.6%	-12.7%
MAPE	6.6%	5.1%	5.4%	5.2%	5.6%	3.4%	7.8%	8.8%	3.6%	12.7%

Sensitivity: 2027 Peak

Assumptions	ContributionToVariance	RankCorrelation
↑ Temperature at Peak (Peak HDDs)	0.574	0.55
↑ Monthly HDD	0.364	0.6
↑ Economics	0.008	0.12
Wind at Peak	0.051	0.2


Sensitivity: 2027 No DSM Total Sales

Assumptions	ContributionToVariance	RankCorrelation
↑ Monthly HDD	0.774	0.84
↑ Monthly CDD	0.162	0.4
↑ Economics	0.065	0.24


Sensitivity: 2036 No DSM Total Sales

Assumptions	ContributionToVariance	RankCorrelation
↑ Monthly HDD	0.544	0.67
↑ Monthly CDD	0.145	0.53
↑ Economics	0.311	0.39


Sensitivity: 2027 Peak



Sensitivity: 2027 No DSM Total Sales



Sensitivity: 2036 No DSM Total Sales



REDACTED (CONFIDENTIAL INFORMATION REMOVED)

REDACTED 2026 Load Forecast Report Synapse IR-1 Attachment 1 Page 196 of 196

Item	2026 Energy (GWh)	2026 Peak (MW)	2036 Energy (GWh)	2036 Peak (MW)
Included in Forecast				
DSM (base case)	-116	-19	-1150	-248
Solar PV	-169	0	-710	0
EV (current forecast)	54	9	1072	157
Other Possible Scenarios				
EV (maximum non-coincident peak)	54	12	1072	218
2 Hydrogen Production Facilities (firm supply portion)	0	0	650	130
Battery (5% share by 2036)	0	0	0	-140
Weather/Economics P10/P90	+/-244	+/-176	+/-292	+/-196
Price Elasticity of -0.3 (2x current elasticity of -0.15)	-18	-6	-88	-26

**2026 Load Forecast Report Synapse IR-1 Attachment 2 has
been filed electronically.**

**2026 Load Forecast Report Synapse IR-1 Attachment 3 has
been filed electronically.**

**2026 Load Forecast Report Synapse IR-1 Attachment 4 has
been filed electronically.**

2026 Load Forecast Report (NSEB M12861)
NSPI Responses to Synapse Energy Economics Inc. Information Requests

NON-CONFIDENTIAL

Request IR-2:

System Peak

(a) Refer to Table 1 in the Board Decision regarding NS Power’s 2025 Load Forecast (M12349). Please explain the main factors causing the low accuracy in the peak demand forecast between 2019-2024.

(b) Beyond those discussed in the 2026 Load Forecast, please note any changes in the model specification relative to the 2025 peak forecast model, and please further quantify the impact of any such changes in specification to the extent possible.

Response IR-2:

(a) The main factors affecting the peak demand forecast accuracy are temperature, wind, timing (in terms of both weekday/weekend and morning/evening), and large customer/interruptible load. Figure 67 of the Report demonstrates that normalizing peaks for these factors results in a more linear fit, especially on a multi-year timescale.

Each year the load forecast evaluates the accuracy of the previous year’s peak forecast and attempts to correct for the factors mentioned above, with the remaining error being termed “unexplained.” The table below summarizes this unexplained error in absolute and percentage terms for the 2019-2024 peak forecasts. 2023 has the greatest unexplained error owing to the extreme nature of that peak (documented in the 2024 Load Forecast Report), while 2020 and 2021 were COVID years where customer behaviour was unusual. The unexplained error is within 1.6 percent for the other years.

Peak Year	LFR analyzed	Unexplained Error (MW)	Unexplained Error (%)
2019	2021 LFR	+28	+1.3%
2020	2021 LFR	-85	-3.8%

2026 Load Forecast Report (NSEB M12861)
NSPI Responses to Synapse Energy Economics Inc. Information Requests

NON-CONFIDENTIAL

Peak Year	LFR analyzed	Unexplained Error (MW)	Unexplained Error (%)
2021	2022 LFR	-71	-3.2%
2022	2023 LFR	+34	+1.6%
2023	2024 LFR	+191	+8.5%
2024	2025 LFR	+33	+1.4%

- 1
- 2 (b) Binary variables and a first-order moving average variable that were included in the 2025
- 3 peak model were removed from the 2026 peak model. These were introduced to improve
- 4 model fit in 2025 but did not improve the model fit this year.

NON-CONFIDENTIAL

Request IR-3:

System Peak – Lagged Temperature Variables

- (a) Please provide the results of the “iterative testing” that determined the weightings to apply to the 12-hour and 24-hour variables.
- (b) Please provide the results of the sensitivity analysis of 36-hour and 48-hour lag temperature variables in the peak equation.
- (c) Please explain how NS Power is able to conclude that it is the duration of cold rather than the minimum temperature that resulted in record-setting peak in January 2026, given that electrification is also contributing to greater peaks.
- (d) In NS Power’s view, are the dynamics of energy use changing in such a way that the duration of very cold conditions is now a more important factor in driving the peak than it previously was? Please explain in detail.
- (e) Are there alternative approaches to modeling the duration of cold as a variable in the peak equation separate from introducing different lagged variables, as discussed in the forecast? Please explain in detail.

Response IR-3:

- (a-b) Please refer to the table below. Model variants were evaluated in terms of their accuracy at predicting the extreme peaks in February 2023 and January 2026, as well as their explanatory power (R^2 value) and mean absolute percentage error (MAPE). As can be seen from the table below, the peak model variant used in the 2026 load forecast (*Peak Day Temperature = 0.8*(12-hour lag temperature) + 0.2*(24-hour lag temperature)*, as outlined in Section 10.1 of the Report) provides the closest forecast on average to the two

2026 Load Forecast Report (NSEB M12861)
NSPI Responses to Synapse Energy Economics Inc. Information Requests

NON-CONFIDENTIAL

extreme peaks (while a couple of the variants considered forecast one peak better than the version used in the 2026 Load Forecast, no variant managed to forecast both peaks as closely), and the model stats are not materially different between model variants considered.

		Peak forecast (MW)		Peak forecast error (MW)			Peak forecast error (%)			Peak model stats	
		Feb-23	Jan-26	Feb-23	Jan-26	Avg	Feb-23	Jan-26	Avg	R ²	MAPE
Actual peak		2,455	2,459	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
LFR 2026 ¹	C ₁ = 0.8, C ₂ = 0.2	2,436	2,447	-19	-12	16	-0.8%	-0.5%	0.7%	0.98	3.13
Weighting sensitivity ²	C ₁ = 0.9, C ₂ = 0.1	2,479	2,428	24	-31	27	1.1%	-1.2%	1.2%	0.98	3.04
	C ₁ = 0.7, C ₂ = 0.3	2,379	2,453	-76	-6	41	-3.3%	-0.2%	1.8%	0.97	3.34
	C ₁ = 0.6, C ₂ = 0.4	2,316	2,445	-139	-14	76	-6.1%	-0.6%	3.3%	0.97	3.57
	C ₁ = 0.5, C ₂ = 0.5	2,251	2,426	-204	-33	118	-8.8%	-1.4%	5.1%	0.96	3.79
Lag-T	36-hour	2,470	2,439	15	-20	17	0.7%	-0.8%	0.7%	0.98	3.07
sensitivity ³	48-hour	2,477	2,444	22	-15	19	1.0%	-0.6%	0.8%	0.98	3.05

(c) The analysis outlined in the Report, and subsequent model tests, provided evidence to suggest that the magnitude of the January 2026 peak was at least in part due to the prolonged period of cold, as opposed to just the temperature in the 12-hours leading up to the peak, as was previously assumed. Electrification will also contribute to the peak magnitude; this is why the peak is forecast to increase in future years. The effect of electrification is incorporated into the peak model via heat use, cool use, and other use variables from the class sales models which are used as inputs, as outlined in Section 10 and Appendix B of the Report, as well as through the addition of peak contributions of various growth programs discussed in the End-Use Trends section of the Report (Section 4.5).

¹ This row corresponds to the peak model as presented in the 2026 load forecast report.

² C₁ corresponds to the weighting applied to the 12-hour lag temperature, C₂ corresponds to the weighting applied to the 24-hour lag temperature. In the version of the peak model presented in 2026 load forecast report, C₁ = 0.8 and C₂ = 0.2.

³ The sensitivity tests were performed on the second temperature in the Peak Day Temperature equation. In the version of the peak model presented in 2026 load forecast report, this was the 24-hour lag temperature. The first temperature in the equation was always the 12-hour lag temperature.

2026 Load Forecast Report (NSEB M12861)
NSPI Responses to Synapse Energy Economics Inc. Information Requests

NON-CONFIDENTIAL

1 (d) Not necessarily. Analysis performed on the January 2026 peak, presented in Section 10 of
2 the Report, suggests that sustained periods of very cold conditions were a contributing
3 factor to the peak magnitude. Figure 59 of the Report shows that the 24-hour lag
4 temperature was historically low for peak days. Conclusions about changing dynamics of
5 energy use cannot be made based on this event alone.

6
7 (e) Given the high explanatory power of the peak model ($R^2 = 0.98$) and low error, NS Power
8 did not consider additional approaches to modelling the duration of extreme cold.
9 However, NS Power is always exploring alternative methods to further improve forecast
10 accuracy.

NON-CONFIDENTIAL

Request IR-4:

System Peak – Bottom-up Approach

(a) Please reconcile the statement that “NS Power currently forecasts system peak at the aggregate level....the system peak is disaggregated into rate class contributions based on historic load factors, losses, and load research data,” on page 98 of the report, with the formal peak model specification on page 30 of Appendix D and the statement there that “The model variables...incorporate changes in heating, cooling, and base-use energy requirements (what are derived from the class sales forecast models)...”

(b) Please explain in detail any alternative approaches to class-level peak forecasting considered by NS Power, including any alternatives that:

(i) Did not apply growth factors based upon changes in sales.

(ii) Applied growth factors based upon changes in sales but adjusted for confounding factors affecting the growth and/or affecting the translatability of sales growth into peak growth.

(iii) Were not based upon a single historical peak (i.e., from 2024).

Response IR-4:

(a) While the system peak forecast is estimated using an aggregate regression model, the explanatory variables within that model (heating, cooling, and base load requirements) are constructed using class-level sales forecast outputs. This approach allows the model to capture underlying structural changes in customer behaviour (e.g., electrification, efficiency) while maintaining a top-down modeling framework. The resulting system peak

2026 Load Forecast Report (NSEB M12861)
NSPI Responses to Synapse Energy Economics Inc. Information Requests

NON-CONFIDENTIAL

forecast is therefore not derived by aggregating class-level peaks but rather reflects system-level demand informed by bottom-up drivers. This is the system peak forecast.

To determine individual class contributions to peak, the system peak is disaggregated into rate class contributions using historical load factors, as described on page 98 of the report. Accordingly, the two descriptions refer to different stages of the forecasting process and are not inconsistent.

(b) NS Power evaluated several regression-based approaches to forecast class-level coincident peak demand that did not apply growth factors based upon changes in sales and were not based upon a single historical peak. The following model types were tested:

- System Model (2015-2024): The system peak model, as specified in Appendix B of the Report, but estimated with class-level coincident peak demand as the dependent variable (as opposed to coincident peak demand aggregated across all non-large customer classes, as is done for the system peak forecast).
- Class-Tailored Model: This model retains the system model structure but only uses class-specific Heat, Cool, and Other variables. Each class peak is therefore modeled using only its own usage components, allowing assessment of whether isolating class-level drivers improves model performance.

Both model types were estimated using different training periods, to evaluate whether using only recent years of data (2021-2024) or winter months only (December-March) improve model performance. Model R-squared values are shown below, for Residential and General Demand classes:

Class	2015–2024 all months		2021–2024 all months		2015–2024 winter only	
	System	Class-tailored	System	Class-tailored	System	Class-tailored
Residential	92.5%	92.9%	96.6%	96.6%	81.5%	81.7%

2026 Load Forecast Report (NSEB M12861)
NSPI Responses to Synapse Energy Economics Inc. Information Requests

NON-CONFIDENTIAL

Class	2015–2024 all months		2021–2024 all months		2015–2024 winter only	
	System	Class-tailored	System	Class-tailored	System	Class-tailored
General Demand	48.8%	57.9%	69.7%	68.9%	38.0%	42.3%

As can be seen, models perform very well for Residential class, but not for General Demand, even in class-tailored form. Restricting the training period to more recent years lead to minor model improvements, but using winter months only did not. The relatively poor performance of the non-residential class coincident peak regression models meant that they did not provide a strong basis for use in a bottom-up coincident peak estimate.

NON-CONFIDENTIAL

Request IR-5:

Economic Information (Section 4.4, p. 28-34)

(a) Why did NS Power not consider the impact of trade tariffs in its load forecast?

(b) Please explain in detail how NS Power understands the potential impacts of trade tariffs on the load forecast.

(c) Refer to the statement that “the magnitude of the potential impact of economics on the long-term forecast is illustrated in Figure 75.” How much of the uncertainty about future economic conditions is related to tariffs? Provide a quantitative response to the extent possible.

(d) How did NS Power’s projection for new customer additions in 2025 compare with 2025 actuals?

(e) What is the quantitative basis for reducing the projected decline in the rate of housing completions in Signal49’s forecast from 24 percent to 10 percent? Is this a judgement call based upon announcements of new housing developments, or has NS Power converted the total from these announcements, which is reported in the load forecast to be 40-50,000 units over the next 10-20 years, into a forecast rate of customer additions?

Response IR-5:

(a-b) The impact of trade tariffs is included in the historic data for 2025. For the forecast period no specific impact from trade tariffs is included as the sectors most affected are the auto sector and aluminum and steel manufacturing, which are not large direct drivers of the Nova Scotia economy. The relative uncertainty in the economic variables is reflected in

2026 Load Forecast Report (NSEB M12861)
NSPI Responses to Synapse Energy Economics Inc. Information Requests

NON-CONFIDENTIAL

1 the P10/P90 sensitivity provided in Section 11 of the Report. This represents 20 years of
2 economic fluctuations which would include the impact from significant changes in drivers
3 like tariffs, inflation, commodity prices, or recessions.
4

5 (c) The uncertainty attributed to trade tariffs was not calculated explicitly.
6

7 (d) The 2025 Load Forecast had an estimate of 7,726 new residential customers while actual
8 residential customer additions were 6,811.
9

10 (e) The change relative to the forecast from Signal49 aligns projected customer additions with
11 the announced new projects. The average to 2030 is around 6,790 additions per year, while
12 post 2030 is around 3,820 per year, which is in line with historic values (the average for
13 the 20-year period pre-COVID is around 3,860 per year).

NON-CONFIDENTIAL

Request IR-6:

New Technologies (Section 4.5.6, p. 51)

(a) Refer to Section 4.5.6 of the 2026 Load Forecast Report, which states that “[t]he 2026 Load Forecast does not assume a significant amount of distributed solar/battery storage combinations or storage only deployments.” Please confirm whether NS Power assumes any distributed solar-plus-storage or storage-only deployment in the 2026 Load Forecast. If so, please provide the assumed number of customers, installed battery capacity in kW and kWh, annual energy impact in GWh, and coincident winter peak impact in MW for each forecast year from 2026 through 2036. If not, please explain the basis for excluding these resources from the forecast.

(b) Please explain whether NS Power considered projected battery cost declines over the 2026–2036 forecast period. If so, please provide the assumed cost decline trajectory and explain how the projected cost reductions are reflected in the forecasted adoption of batteries. If not, please explain why not.

(c) Refer to NS Power’s 2025 Load Forecast Report, Figure 33, “Potential Peak Impacts from Batteries,” which presented illustrative peak impacts from residential battery uptake scenarios, and to Section 4.5.6 of the 2026 Load Forecast Report, which does not include a comparable battery peak-impact sensitivity. Please explain why NS Power did not include an updated version of the 2025 battery peak-impact sensitivity in the 2026 Load Forecast Report.

(d) Please explain whether NS Power has quantified the potential winter peak reduction from customer-sited batteries, solar-plus-storage, or V2G resources. If so, please provide all workpapers, assumptions, and results. If not, please explain why not.

NON-CONFIDENTIAL

1 (e) Refer to the statement in Section 4.5.6 that V2G technology is “still early in
2 commercialization” and “not widely available at the moment in Canada.” Please
3 explain whether NS Power assumes any V2G, vehicle-to-home, vehicle-to-building, or
4 bidirectional EV charging impacts in the 2026 Load Forecast. If so, please provide
5 the assumed annual energy and coincident winter peak impacts for each forecast year
6 from 2026 through 2036. If not, please explain the basis for excluding these impacts
7 from the forecast.
8

9 Response IR-6:
10

11 (a) NS Power confirms that the 2026 Load Forecast does not assume any distributed solar-
12 plus-storage or storage-only deployment over the forecast period from 2026 through 2036.
13

14 While battery storage technology continues to evolve, residential and commercial battery
15 storage adoption in Nova Scotia remains in its early stages. Current market penetration is
16 minimal, with very few customer installations documented in NS Power's service territory.
17 As of 2026, the economics of standalone battery storage or solar-plus-storage systems for
18 residential and small commercial customers in Nova Scotia do not support widespread
19 voluntary adoption without significant subsidies or incentive programs. However, there are
20 currently no provincial programs or mandates, and limited incentive structures in place to
21 drive significant battery storage deployment. Given the lead time required to develop
22 programs, establish interconnection standards, and achieve meaningful market penetration,
23 NS Power does not anticipate material impacts from distributed storage on the load forecast
24 within the 2026-2036 timeframe.
25

26 (b) NS Power has monitored battery cost decline trends but has not explicitly incorporated
27 projected battery cost reductions into specific adoption forecasts for the 2026 Load
28 Forecast. NS Power acknowledges that battery storage technology costs are declining and
29 that future load forecasts may need to incorporate storage impacts as market conditions,
30 policy frameworks, and customer economics evolve.

2026 Load Forecast Report (NSEB M12861)
NSPI Responses to Synapse Energy Economics Inc. Information Requests

NON-CONFIDENTIAL

1 While battery costs are declining globally, the relationship between cost reduction and
2 customer adoption in Nova Scotia is uncertain and depends on multiple factors beyond
3 upfront capital cost, including but not limited to:

- 4
- 5 • Availability of financing mechanisms
- 6 • Customer awareness and education
- 7 • Value proposition under current rate structures
- 8 • Installation and soft costs (which may not decline at the same rate as equipment
9 costs)
- 10 • Regulatory frameworks for interconnection and compensation
- 11

12 Currently, Nova Scotia does not have enough historical data on battery storage adoption to
13 establish a reliable cost-elasticity relationship. Global cost declines alone are insufficient
14 to drive adoption without complementary policies, programs, or rate structures that create
15 value for storage. Even significant cost reductions may not translate to meaningful adoption
16 without corresponding value propositions and compensation frameworks. NS Power will
17 continue to track trends and revisit storage adoption assumptions in future load forecasts.

18

19 (c) NS Power did not include an updated battery peak-impact sensitivity in the 2026 Load
20 Forecast Report as there is no material change in assumptions or market conditions. As
21 noted in response to part (a), the 2026 Load Forecast does not assume significant battery
22 deployment. NS Power recognizes stakeholder interest in understanding potential battery
23 impacts and commits to including updated battery sensitivity scenarios in future load
24 forecasts if market conditions change. The illustrative scenarios presented in the 2025 Load
25 Forecast remain relevant for understanding the potential magnitude of battery impacts
26 under various adoption scenarios.

27

28 (d) NS Power has not developed detailed quantified estimates of potential winter peak
29 reduction from customer-sited batteries, solar-plus-storage, or vehicle-to-grid (V2G)
30 resources for inclusion in the 2026 Load Forecast.

2026 Load Forecast Report (NSEB M12861)
NSPI Responses to Synapse Energy Economics Inc. Information Requests

NON-CONFIDENTIAL

1 Regarding batteries and solar-plus-storage, as discussed in parts (a) through (c), current
2 market penetration is negligible and no incentive programs exist to drive deployment. The
3 illustrative scenarios presented in the 2025 Load Forecast (Figure 33) provided order-of-
4 magnitude estimates of potential impacts under various adoption scenarios. Without a
5 credible baseline adoption forecast, developing detailed peak reduction quantification
6 would be speculative.

7
8 V2G technology remains in early commercialization stages globally and is not yet widely
9 available in Canada. No V2G-capable vehicles are currently deployed in meaningful
10 numbers in Nova Scotia and there is a lack of supporting infrastructure, including
11 bidirectional charging equipment and interconnection and compensation frameworks.
12 Regulatory and technical barriers related to interconnection standards, vehicle warranty
13 implications, and grid integration protocols remain unresolved.

14
15
16 While detailed quantification is not included in the 2026 Load Forecast, NS Power is
17 monitoring V2G pilot programs and deployments in other jurisdictions as well as EV model
18 availability and bidirectional charging capability.

19
20 (e) NS Power confirms that the 2026 Load Forecast does not include any assumptions
21 regarding V2G (vehicle-to-grid), V2H (vehicle-to-home), V2B (vehicle-to-building), or
22 other bidirectional EV charging impacts for the forecast period from 2026 through 2036.

23
24 As of 2026, V2G-capable vehicles represent a small fraction of the EV market in Canada,
25 most EVs currently sold in Nova Scotia do not have bi-directional charging capability (or
26 specifically this capability enabled in the Canadian market), and bi-directional charging
27 equipment (e.g., bidirectional wallboxes, inverters, integration systems) is not widely
28 available or certified in Canada.

2026 Load Forecast Report (NSEB M12861)
NSPI Responses to Synapse Energy Economics Inc. Information Requests

NON-CONFIDENTIAL

1 No provincial or federal programs supporting V2G deployment currently exist and
2 compensation mechanisms for vehicle discharge services have not been established.
3
4 NS Power will continue to monitor V2G technology development and will incorporate bi-
5 directional charging impacts in future load forecasts as market conditions, policy
6 frameworks, and technology deployment warrant inclusion.

NON-CONFIDENTIAL

Request IR-7:

Heat Pumps (Section 4.5.1, pp. 36-37 and 66-67)

(a) The Report provides a residential heat pump forecast, including annual cumulative new installations, the percentage installed in non-electric and electric-heat homes, overall heating saturation, and overall heating intensity. Figure 46 also provides illustrative system-level heat pump heating and cooling loads, including HP Heat increasing from 1,157 GWh in 2026 to 1,635 GWh in 2036.

(i) Please define what NS Power considers to be a “full heat pump” for purposes of the 2026 Load Forecast, including whether this term refers to non-hybrid heat pumps, all-electric heat pumps, heat pumps without retained non-electric backup, or another category.

(ii) Please provide the annual forecast, from 2026 through 2036, of annual heating energy use, cooling energy use, and coincident winter peak demand associated with full heat pump customers/households, separately identifying impacts for homes that previously used electric resistance heating and homes that previously used non-electric heating.

(iii) Please explain how the “overall heating intensity” values in Figure 22 were developed and how they relate to the HP Heat values shown in Figure 46.

(iv) Please provide any AMI, billing, or other empirical validation NS Power has conducted for full heat pump annual energy and peak impacts. If no such validation has been conducted, please explain why not.

(b) Refer to Figure 22. Please provide the following data for all forecast years:

2026 Load Forecast Report (NSEB M12861)
NSPI Responses to Synapse Energy Economics Inc. Information Requests

NON-CONFIDENTIAL

- 1 **(i) Total number of residential customers;**
2
3 **(ii) Number of customers using heat pumps, hybrid heat pumps, electric**
4 **resistance heating, wood heating, and fossil fuel heating systems;**
5
6 **(iii) Number of customers using heat pumps as the sole heating technology. If NS**
7 **Power assumes that none of the customers use heat pumps as the sole heating**
8 **technology, please explain the basis for that assumption and provide any**
9 **supporting evidence;**
10
11 **(iv) Number of customers using heat pumps as the primary heating system with**
12 **supplemental electric resistance heating;**
13
14 **(v) Number of customers using hybrid heat pumps, with a breakdown of**
15 **customers by backup heating fuel type; and**
16
17 **(vi) Number of customers using oil, natural gas, propane, and wood as their**
18 **primary heating fuel;**
19
20 **(c) Refer to the overall heating intensity and cooling intensity values for residential heat**
21 **pumps provided in Figure 22. Please provide the following information for all forecast**
22 **years:**
23
24 **(i) Average heating electricity consumption per household with heat pumps,**
25 **excluding households that do not have heat pumps;**
26
27 **(ii) Average cooling electricity consumption per household with heat pumps,**
28 **excluding households that do not have heat pumps;**
29

NON-CONFIDENTIAL

1 **(iii) Average heating efficiency of heat pumps, expressed as coefficient of**
2 **performance (COP), and average cooling efficiency of heat pumps, expressed**
3 **as COP. If NS Power assumes improvements in COP over time, please explain**
4 **how NS Power developed those assumptions and provide all supporting**
5 **evidence. If not, please explain why not;**

6
7 **(iv) The key assumptions used to estimate heat pump energy and peak impacts,**
8 **including heat pump efficiency, backup heat use, customer behavior, building**
9 **shell efficiency, weather normalization, and differences between electric-**
10 **heated and non-electric-heated homes; and**

11
12 **(v) An explanation of how NS Power estimated average heating electricity**
13 **consumption for heat pumps for (1) households that switch their primary**
14 **heating systems from fossil fuel-based heating to heat pumps and (2)**
15 **households that switch their primary heating systems from electric resistance**
16 **heating to heat pumps. Please provide all workpapers supporting this analysis.**

17
18 Response IR-7:

19
20 (a)

21 (i) Aside from hybrid heat pumps, there is no other differentiation between heat pump
22 types in the load forecast.

23
24 (ii) The load forecast does not track heating/cooling energy use on a household level
25 and therefore there is no annual forecast that differentiates between heat pump
26 households that previously used electric resistance heating and that previously used
27 non-electric heating. This is because the SAE model works on a population level.
28 However, the annual intensity associated with electric resistance (EFurn) heating
29 and heat pump heating, as well as heat pump cooling, can be found in the 2026

2026 Load Forecast Report (NSEB M12861)
NSPI Responses to Synapse Energy Economics Inc. Information Requests

NON-CONFIDENTIAL

1 Load Forecast Attachment 1, Intensities tab (Columns B, C, and G respectively).
2 End use impacts to peak are not modeled individually.
3

- 4 (iii) The overall heating intensity for heat pumps presented in Figure 22 of the report is
5 the combined intensity for non-hybrid and hybrid heat pumps. The calculation for
6 non-hybrid heat pumps is as follows. The year 2020 is used as the base year, and
7 Unit Energy Consumption (UEC) values are set to match the heat use attributed to
8 heat pump use only, established from a rigorous study of actual heat pump load in
9 Nova Scotia¹. To calculate the raw intensity, the UEC is multiplied by Nova
10 Scotia's share percentage. This raw intensity is then adjusted using a factor based
11 on overall actual usage per customer, resulting in the adjusted intensity for 2020.
12 The heating intensity for year x is estimated using the following formula:
13

$$Intensity_x = \frac{adjusted\ intensity_{2020} \times (\frac{share_x}{efficiency_x})}{(\frac{share_{2020}}{efficiency_{2020}})}$$

15
16 The method is the same for hybrid heat pumps, except the base year is 2028 – the
17 assumed start date of a hybrid heating program. Full calculations can be found in
18 the 2026 Load Forecast Attachment 1, Intensities tab.
19

20 The relationship between Figure 22 and Figure 46 is that Figure 22 represents the
21 average customer-level heating load due to heat pumps (averaged across the entire
22 population), while Figure 46 represents the aggregated population-level load.
23

- 24 (iv) A study has previously been undertaken to evaluate the load and sales impact of the
25 NS Power heat pump on-bill financing program.¹ The study's objective was to
26 design a heat pump sample that was representative of program participants, install

¹ Itron, Cold Climate Heat Pump Load Study (July 8, 2022), filed as Appendix A to NS Power's On-Bill Financing Final Report, NSUARB Matter No. M09321 (July 12, 2022).

2026 Load Forecast Report (NSEB M12861)
NSPI Responses to Synapse Energy Economics Inc. Information Requests

NON-CONFIDENTIAL

1 and collect heat pump and total house hourly load data, and measure heat-pump
2 average energy use and demand impacts from the program. The results of that study
3 inform the modelled heating intensity, as outlined in part (a) subpart (iii) above. NS
4 Power has not yet conducted a dedicated analysis of AMI data to evaluate these
5 findings using a larger (potentially population-level) sample of customers. Progress
6 has been made using disaggregation methods to quantify total electric heating load
7 (as was used in the hybrid heating modelling documented in Section 4.5.2 of the
8 Report), but disaggregating the contribution of specific heating appliances is
9 complex. NS Power is working on techniques for using AMI data to better evaluate
10 heating loads in the province.
11

- 12 (b)
13 (i-vi) The forecast total number of residential customers can be found in Attachment 4 of
14 the report, “Residential” tab (column G, “Forecasted Customer Count”). The
15 forecast number of customers using heat pumps, hybrid heat pumps, and electric
16 resistance heating can be found in Attachment 1 of the report, “HP” tab (columns
17 P, “Efurn”, through T, “hybrid HP (cumulative)”). NS Power does not forecast the
18 number of customers using other heating fuel types. Consistent with previous
19 reports,² it is assumed that all residential heat pump customers have a backup heat
20 source; however, NS Power does not have information on breakdown of backup
21 heat source by fuel type.
22

- 23 (c)
24
25 (i) Refer to Attachment 1 of the Report, “calibration” tab, for the input heat pump
26 heating intensity per household (“HPHeat”).
27
28 (ii) Refer to Attachment 1 of the Report, “calibration” tab, for the input heat pump
29 cooling intensity per household (“HPCool”).
30

² See response to Synapse IR-26 in M12349, NSPI (Synapse) RIR 1 to 29, filed August 19, 2025

2026 Load Forecast Report (NSEB M12861)
NSPI Responses to Synapse Energy Economics Inc. Information Requests

NON-CONFIDENTIAL

- 1 (iii) Refer to Attachment 1 of the Report, “Efficiencies” tab, for forecast heat pump
2 heating and cooling efficiencies. Both are assumed to improve over time, based on
3 EIA data for New England that is calibrated to fit existing Nova Scotia data from
4 NRCan.
5
- 6 (iv) All information relevant to heat pump and secondary heat intensity calculations,
7 used as inputs to the residential energy SAE regression model, are provided in
8 Attachment 1 of the Report. The forecast does not break out the heating/cooling
9 impacts of specific appliances (although an approximation is provided in Figure 46
10 of the report), neither does it differentiate between electric and non-electric heated
11 homes. Similarly, no specific heat pump peak impact is assumed in the load
12 forecast; it will instead be implicit in the heating load component from the energy
13 SAE forecasts that are used as inputs into the peak forecast model. Building shell
14 efficiency is provided in Figure 44 of the Report.
15
- 16 (v) Heat pump heating consumption is not differentiated in the load forecast between
17 heat pumps that replace electric heat sources and heat pumps that replace non-
18 electric heat sources.

NON-CONFIDENTIAL

Request IR-8:

Residential Hybrid Heating (Section 4.5.2, p. 37-42)

(a) Refer to the following statements in the 2026 Load Forecast Report: “The 2026 residential SAE regression model has been updated to include peak and energy reductions related to potential hybrid programs which have been modelled by NS Power,” and “The modelling ... is being used to assess the cost impacts of the hybrid approach as part of Department of Energy-led hybrid heating working group with Net Zero Atlantic, provincial staff and other stakeholders.” (p. 37)

(i) Please provide all workpapers, reports, and other documentation associated with the analysis of the peak and energy impacts of residential hybrid heating, including all formula and key assumptions in native, machine-readable format with formulas intact.

(ii) Please provide any analysis of “the cost impacts of the hybrid approach as part of Department of Energy-led hybrid heating working group with Net Zero Atlantic, provincial staff and other stakeholders.” If no such analysis is available, please explain the status of this work and when NS Power expects the analysis to be completed.

(b) Refer to Figure 23, “Baseline Residential Electric Heating Load Shape and Example Hybrid Modification” and the following statement: “The modelling uses a baseline residential electric-heating load shape derived from AMI data for the year 2022.”

(i) Please provide the share of the 22,130 customers identified as owning a heat pump with high confidence by the following heating system categories: (1) heat pump with electric backup heating and (2) heat pump with non-electric backup heating.

- (ii) Please explain how NS Power developed the load shapes shown in Figure 23, including whether the load shape represents the average hourly load shape for the 22,130 customers.
 - (iii) Please describe the scope of the AMI data NS Power used for its hybrid heating analysis, including whether NS Power collected hourly load data for each of the 22,130 customers.
 - (iv) Please provide the date, time, and duration of each Critical Peak Event reflected in Figure 23.
 - (v) Please provide the date, time, and duration of each event reflected in Figure 23 during which the outdoor air temperature was below -10°C.
- (c) Refer to E3’s residential hybrid peak-mitigation estimate of -48 MW by 2036 and the 20 percent to 50 percent participation range used for this estimate, as mentioned on page 40 of the NS Power 2026 load forecast Report and NS Power’s assumption of a 50 percent participation rate (27,000 customers by 2036).
 - (i) Please provide the rationale and all evidence E3 used to establish the 20 percent to 50 percent participation range.
 - (ii) Please explain NS Power’s rationale and all evidence supporting the assumed 50 percent participation rate (27,000 customers by 2036).
- (d) Refer to the following statement on pages 40 to 41 of the NS Power 2026 Load Forecast Report:

“a comparison of energy and peak values predicted by the SAE models with and without the residential hybrid heating representation showed

NON-CONFIDENTIAL

1 **that the hybrid-reduction did not fully match the model results**
2 **discussed above, because of differences in modelling approaches.”**
3

4 **(i) Please explain how the residential SAE model incorporates hybrid heating.**

5 **(ii) Please explain in detail the “differences in modelling approaches.”**
6

7 **(e) Please explain how NS Power calculated the additional energy and peak adjustments**
8 **shown in Figure 25 that were required to match the total residential hybrid heating**
9 **impacts.**
10

11 Response IR-8:

12
13 (a)

14 (i) Please refer to Attachment 1.
15

16 (ii) The analysis of system cost impacts will be provided in the Net Zero Atlantic
17 (NZA) Hybrid Heating Study which is expected to be released later in 2026.
18

19 (b)

20 (i) This level of breakdown by backup heating type is not available. The hourly load
21 shape in Figure 23 represents the hourly average heating load for the 22,130
22 customers, for the year 2022.
23

24 (ii) The load shape was created by applying a disaggregation methodology to 15-
25 minute AMI data for each customer, to isolate specific appliance signatures. The
26 load attributed to electric heating each hour for each customer was averaged to
27 create the hourly load shape. The same disaggregation methodology applies a
28 probabilistic heat pump detection; the load shape used for analysis was created from
29 data only for customers which fell in the highest heat pump detection probability
30 bin (P > 90 percent).

2026 Load Forecast Report (NSEB M12861)
NSPI Responses to Synapse Energy Economics Inc. Information Requests

NON-CONFIDENTIAL

1 (iii) Please refer to part (b)(ii).

2
3 (iv) Please refer to Attachment 1, tab “Event dt summary”.

4
5 (v) Please refer to Attachment 1, tab “Event dt summary”.

6
7 (c)

8 (i) To clarify, the 20 to 50 percent participation value is a range established by NS
9 Power from the hybrid modelling work, not an assumption from E3. This was the
10 range within which the -48 MW peak mitigation estimate falls, based on NS
11 Power’s hybrid heating modelling work. The -48 MW value is consistent with the
12 hybrid peak reduction incorporated into the 2024 and 2025 Load Forecasts, which
13 comes from E3’s Hybrid Peak Mitigation electrification scenario studied for the
14 Evergreen IRP (adjusted for a later hybrid program start date of 2028). Because this
15 value fell within the NS Power-modelled peak mitigation range, it was retained for
16 the 2026 Load Forecast.

17
18 (ii) NS Power’s hybrid heating modelling considered different customer participation
19 rates, hence there being a range of modelled hybrid peak and energy reductions
20 presented in Figure 24 of the report. This approach was necessary to establish the
21 achievable potential of programs with different participation levels – used to inform
22 system capacity modelling intended to identify system benefits of potential hybrid
23 programs and how they are related to program size. Since no concrete hybrid
24 heating program details were available at the time the load forecast was prepared,
25 the median model result was chosen for the energy reduction incorporated into the
26 forecast, which corresponds to the energy reduction achieved with around 50
27 percent participation (note that as this is a median value it does not correspond to
28 the exact value in any single modelled scenario/participation combination).
29 Potential customer participation rates are addressed via analysis of customer survey
30 responses in the NZA Hybrid Heating Study expected to be released later in 2026.

2026 Load Forecast Report (NSEB M12861)
NSPI Responses to Synapse Energy Economics Inc. Information Requests

NON-CONFIDENTIAL

1 (d)

2 (i-ii) This is outlined on page 40 of the Report. In brief, hybrid heating is incorporated
3 into the residential SAE model by splitting the segment of customers installing heat
4 pumps that do not already have primary electric heating (“NAE heat-pump
5 category”) into hybrid and non-hybrid portions, and the heat pump intensity
6 associated with the hybrid portion is reduced to account for the reduced usage
7 resulting from hybrid heating events (when the customers would rely on non-
8 electric heat sources).

9
10 The modelling approach used to establish the peak and energy reduction for
11 potential hybrid programs used an hourly load profile characterising heat usage
12 only, for a segment of customers that are most likely to have electric heating (by
13 virtue of the heat pump detection criteria applied, discussed in part(b) subpart (ii).
14 This allows for precise quantification of the energy reduction when electric heating
15 is restricted, as would be the case in a hybrid heating event. On the other hand, the
16 residential SAE model relies on annual heating intensities, averaged across the
17 entire customer population (with a range of different heating types), as an input.
18 Heating is just one component of the SAE model – cooling and other end use types
19 are also considered. The model then combines these inputs with weather and
20 calendar variables to historical sales in a regression framework to yield an average
21 load per customer, broken into heat, cool, and other usage on a monthly time scale.

22
23 (e) The method for calculating the additional energy and peak adjustments was as follows:
24 firstly, compare sales forecasted by the residential SAE model with and without hybrid
25 heating represented (i.e. in the non-hybrid model version, there was no differentiation
26 between hybrid and non-hybrid heat pump customers). The difference between these two
27 values, shown in Figure 25 of the report (columns “Included in peak model” and “Included
28 in the residential end use model”) was then compared to the target peak/energy reduction
29 ascertained from the hybrid heat modelling described previously (“Total” columns of
30 Figure 25 of the report), with the remainder being the additional peak and energy

2026 Load Forecast Report (NSEB M12861)
NSPI Responses to Synapse Energy Economics Inc. Information Requests

NON-CONFIDENTIAL

- 1 adjustment required to match the modelling results (“Adjustment required to match total”
- 2 columns of Report Figure 25).

**2026 Load Forecast Report Synapse IR-8 Attachment 1 has
been filed electronically.**

NON-CONFIDENTIAL

Request IR-9:

Commercial Hybrid Heating (Section 4.5.2, p. 42)

(a) Refer to Figure 26 and the following statement on page 42:

“As with previous load forecasts, the commercial energy values predicted from the commercial SAE model is higher than the E3 hybrid scenario model where some of the commercial heating requirements are handled by a secondary non-electric heat source. Adjustments are therefore applied to the commercial energy forecast to estimate the impact of the commercial hybrid scenario.”

(i) Please explain why the commercial energy values predicted by the commercial SAE model are higher than the E3 hybrid scenario model.

(ii) Please explain how NS Power developed the commercial hybrid energy adjustments shown in Figure 26 and provide all workpapers associated with this analysis in native, machine-readable format with all formulas and assumptions intact.

(b) The Report states that, unlike for residential hybrid heating, there has been no provincial planning or discussion around a commercial hybrid heating program. The Report further states that the 2026 Load Forecast continues to use assumptions from E3’s hybrid scenario for commercial hybrid heating, consistent with the 2025 Load Forecast, with the only modification being a change in the anticipated start date from 2026 to 2028. Figure 26 shows commercial energy adjustments of -7 GWh in 2028, -35 GWh in 2032, and -75 GWh in 2036.

(i) Please provide all E3 reports, workpapers, model files, spreadsheets, assumptions, and documentation supporting the commercial heat pump and commercial hybrid heating assumptions used in the 2026 Load Forecast.

NON-CONFIDENTIAL

- 1 **(ii) Please explain how E3 developed the commercial hybrid heating energy**
2 **adjustments shown in Figure 26 and provide the annual adjustment for each**
3 **year from 2026 through 2036.**
- 4
- 5 **(iii) Please provide the commercial hybrid heating peak demand impacts assumed**
6 **for each year from 2026 through 2036, including where those impacts are**
7 **reflected in the peak forecast.**
- 8
- 9 **(iv) Please provide the key assumptions underlying E3's commercial hybrid**
10 **scenario, including assumed building types, customer segments, fuel types,**
11 **participation levels, operating conditions, and whether the scenario**
12 **distinguishes between customers that previously used electric heating and**
13 **customers that previously used non-electric heating.**
- 14
- 15 **(v) Please explain whether NS Power has reviewed or validated E3's commercial**
16 **heat pump and hybrid heating assumptions using NS Power AMI data, billing**
17 **data, customer surveys, or other empirical information. If not, please explain**
18 **why NS Power determined it was reasonable to continue using E3's**
19 **assumptions in the 2026 Load Forecast.**
- 20

21 Response IR-9:

- 22
- 23 **(a)**
- 24 **(i) The commercial end use model does not account for hybrid heating directly,**
25 **therefore, it does not account for the times where heating is provided by non-**
26 **electric sources and has higher overall energy use.**
- 27
- 28 **(ii) The energy adjustment values are calculated by running the commercial model with**
29 **heating shares kept constant over the time period and comparing with the actual**
30 **model where heating increases over time. This growth in energy consumption (due**
-

2026 Load Forecast Report (NSEB M12861)
NSPI Responses to Synapse Energy Economics Inc. Information Requests

NON-CONFIDENTIAL

to heating) is then compared to the modeled increase in energy consumption from E3 over the same time period, and the difference between the two energy increases is found in Figure 26. Please refer to Attachment 1 for the calculations.

(b)

(i) E3's modeling is performed in their proprietary Reshape model and is described in Sections 3 and 7 of their report entitled "The Economics of Electrification in Nova Scotia."¹ Please refer to Attachment 2 for the corresponding heating load shapes.

(ii) Please refer to part (a).

(iii) The annual hybrid peak demand impact (compared to E3's current trends scenario) are provided in the following table. A model adjustment is calculated in the same manner as energy adjustment (heating impact from E3's space heating electrification compared with NS Power's modeled impact) and is provided in the table as well (these values can also be found in Attachment 1). The adjustments are added to the firm peak values in the forecast.

Year	E3 Hybrid Peak Impact (MW)	Model Adjustment (MW)
2026	0	0
2027	0	0
2028	-17	4
2029	-34	7
2030	-51	11
2031	-68	14
2032	-85	18
2033	-105	19
2034	-124	19
2035	-144	20
2036	-164	20

(iv) Please refer to part (i) for E3's methodology.

¹ [The Economics of Electrification in Nova Scotia](#)

2026 Load Forecast Report (NSEB M12861)
NSPI Responses to Synapse Energy Economics Inc. Information Requests

NON-CONFIDENTIAL

- 1 (v) NS Power has not undertaken an analysis of commercial hybrid heating using AMI
2 data, as disaggregated loads are not available for the commercial class at this time.
3 E3's analysis provides the current best estimate of the impact of commercial hybrid
4 heating loads on the system.

**2026 Load Forecast Report Synapse IR-9 Attachment 1 has
been filed electronically.**

**2026 Load Forecast Report Synapse IR-9 Attachment 2 has
been filed electronically.**

NON-CONFIDENTIAL

Request IR-10:

Residential Water Heaters (WH) (Section 4.5.3, p. 43-44).

(a) Refer to the following statement on page 43 of the NS Power 2026 Load Forecast Report: “This equates to an overall residential saturation of approximately 1.4 percent. This is forecast to increase to approximately 2 percent of the total residential households by 2030. The same rate of growth is assumed for the 2030s and 2040s, resulting in a forecast population share of 3.2 percent in 2036.”

(i) Please explain the rationale and provide all the evidence NS Power used to develop its assumption for the annual growth rate of heat pump water heater uptake.

(b) Refer to the following statement on page 43 of the NS Power 2026 Load Forecast Report: “To represent the efficiency improvements of heat pump water heaters, their modelled intensity is set to 40 percent of standard electric water heaters, based on estimates provided by E1.”

(i) Please provide the estimates provided by E1.

(ii) Does NS Power assume energy efficiency improvements for heat pump water heaters over time? If so, please provide such assumptions in terms of Uniform Energy Factor (UEF). If not, please explain why not.

Response IR-10:

(a) Assumptions behind the heat pump water heater forecast were developed in consultation with EfficiencyOne (E1), based on research for their market transformation heat pump water heater pilot study.

2026 Load Forecast Report (NSEB M12861)
NSPI Responses to Synapse Energy Economics Inc. Information Requests

NON-CONFIDENTIAL

1 (b)

2 (i) Information on the efficiency improvements of heat pump water heaters over
3 standard electric water heaters was obtained from the E1 website¹ (please also refer
4 to page 43 of the Report).

5
6 (ii) Energy efficiency improvements for heat pump water heaters are assumed to occur
7 at the same rate as for standard electric water heaters. This information can be found
8 on Attachment 1 of the Report, “Efficiencies” tab, “EWHeat” column. The source
9 of efficiency data is the US Energy Information Administration (EIA). Note that
10 efficiency changes are represented as the fractional improvement in the raw
11 efficiency value with respect to a base year of 2020.

¹ <https://www.energycyns.ca/products/heat-pump-water-heaters>

NON-CONFIDENTIAL

Request IR-11:

Electric Vehicles (EVs) (Section 4.5.4, p. 44-47)

- (a) Please provide the source data and calculations behind Figures 28-30.**
- (b) Please specify the share of EVs in the forecast which are light-duty, non-plug-in hybrids, plug-in hybrids, and/or battery-electric.**
- (c) Generally, please describe how the load forecast takes into account the differences between battery electric vehicles (BEVs) and plug-in hybrid electric vehicles (PHEVs).**
- (d) Please describe how Canada's current EV mandate distinguishes between BEV and PHEVs both in 2026 and in 2035. Please describe how Nova Scotia Power's forecast accounts for this difference.**
- (e) Please describe how the values in Figures 29 and 30 incorporated differences between BEVs and PHEVs.**
- (f) Please describe the assumptions regarding non-PHEV ICE LDVs in forecast year 2036.**
 - (i) For example, please describe the quantity of non-PHEV ICE LDVs and the percent of all vehicle miles that are driven by non-PHEV ICE LDVs.**
 - (ii) Please compare these assumptions to the most recent available data.**
 - (iii) Please also compare the assumptions regarding non-PHEV ICE LDVs in 2036 to comparable assumptions of PHEV LDVs and BEV LDVs in 2036.**
- (g) Please provide the method for estimating the total number of EVs.**

2026 Load Forecast Report (NSEB M12861)
NSPI Responses to Synapse Energy Economics Inc. Information Requests

NON-CONFIDENTIAL

1 **(h) Please provide assumptions for federal light-duty vehicle sales incentives and state**
2 **whether these changed between the 2025 and 2026 forecasts.**

3
4 **(i) How did the cancellation of the EV Availability Standard and the revision of the**
5 **federal government mandate affect the EV forecast?**

6
7 **(j) How was the forecast adjusted to account for the higher sales figures in 2025**
8 **compared to the 2025 Load Forecast?**

9
10 **(k) Besides the changes to sales mandates and the upward adjustment for 2025, were**
11 **there any other changes driving the differences between the 2025 and 2026 EV sales**
12 **forecasts?**

13
14 **(l) Will the AMI data analysis used to estimate the effect of EV charging at home in the**
15 **2025 and 2026 load forecasts be updated for future forecasts?**

16
17 **(m) Please confirm whether managed charging is incorporated into the EV forecast for**
18 **each category, including light-duty vehicles. If it is not, please explain. If NS Power**
19 **has forecasted managed charging, please provide all assumptions.**

20
21 Response IR-11:

22
23 **(a) Please refer to NSEB IR-6 Attachment 1.**

24
25 **(b) Please refer to NSEB IR-6 Attachment 1 (“2026 EV Load Forecast” tab). Light duty**
26 **vehicles are broken into battery EVs (BEVs) and plug-in hybrid EVs (PHEVs).**

27
28 **(c) PHEVs are assumed to use 50 percent of the energy of BEVs, because they only drive a**
29 **portion of their annual kilometres on electricity. However, their peak contribution is**
30 **assumed to be the same as BEVs.**

2026 Load Forecast Report (NSEB M12861)
NSPI Responses to Synapse Energy Economics Inc. Information Requests

NON-CONFIDENTIAL

(d) Currently there is no federal EV mandate in Canada following the cancellation of the EV Availability Standard in February 2026. The shift away from this policy toward tighter greenhouse gas emissions (GHG) emissions standards has an implied electrification outcome as it contemplates a 75 percent EV sales policy goal by 2035, but as of writing, no regulations have been published in Canada Gazette. The Federal government has announced that compliance will be technology-neutral, and so it can be achieved via BEVs, PHEVs, or more efficient Internal Combustion Engine (ICE) vehicles.

The 2026 Load Forecast accounted for this by setting the current year forecast to the current historical value (approximately 55 percent of ZEV sales are BEV) and the 2036 endpoint to 75 percent ZEV sales where 80 percent of which are BEV. During the forecast period, the share of BEVs to PHEVs rises between 5 and 6 percent per year until 2030 (68 percent of ZEV sales are BEV) to account for the Federal incentive regime, and tapers off, rises more slowly in 2031 to 2036, gradually reaching the “80 percent of ZEV sales are BEV” end point.

(e) Please refer to NSEB IR-6 Attachment 1 (“2026 EV Load Forecast” tab). For Figure 30, The PHEV and BEV contributions to energy and peak are calculated separately according to the distinction outlined in response to part (c). For Figure 29, the energy and peak values in the light-duty vehicles (LDV) row only correspond to BEVs. This is an error. An updated version of Figure 29, to highlight the differentiation between BEVs and PHEVs, is provided below.

Vehicle Type	Avg kWh/year	Avg kW/vehicle on Peak
BEV	4,202	0.6
PHEV	2,101	0.6
MDV	8,205	1.6
HDV	113,890	7.3

(f) Generally, NS Power has made no assumptions regarding non-PHEV ICE LDVs in forecast year 2036.

2026 Load Forecast Report (NSEB M12861)
NSPI Responses to Synapse Energy Economics Inc. Information Requests

NON-CONFIDENTIAL

1 (i) The forecast assumes 75 percent ZEV sales in 2036 on a total LDV sales of 57,351,
2 therefore the total non-PHEV ICE vehicle sales forecast in 2036 could be computed
3 as 25 percent of 57,351 or ~14,338 new non-PHEV ICE vehicles. As a total fleet,
4 NS Power does not forecast non-PHEV ICE retirements but forecasts the total ZEV
5 stock to be 240,778 in 2036. As the LDV fleet in NS today is about 650,000 –
6 675,000 vehicles (total fleet size no longer reported; was 651,000 in 2023), this
7 could reasonably imply an internal non-PHEV ICE fleet in 2036 of about 500,000
8 vehicles, or 67 percent of vehicles.
9

10 On average, an LDV driver in Nova Scotia is said to complete 17,421 km/year, so,
11 assuming driving habits remain consistent, the total non-PHEV ICE mileage from
12 the 2036 cohort could be computed as $17,421 \text{ km/yr} * 14,338 =$ approximately 250
13 million km/yr and from the implied fleet as $17,421 \text{ km/yr} * 500,000 = 8.7$ billion
14 km / year. Assuming that in 2036, driving habits are consistent among all
15 drivetrains, then 67% of all kilometers driven will be driven by the implied internal
16 non-PHEV ICE LDV fleet.
17

18 (ii) Most recently, in 2025, there were 55,265 LDVs sold in NS, and 2,425 were ZEVs,
19 meaning that the total non-PHEV ICE vehicle sales in 2025 could be computed as
20 52,840. At 17,421 km / year, the total miles driven by this cohort of vehicles would
21 be approximately 920.5 million kms / year. Holding mileage consistent means that
22 both vehicles sold and mileage driven by the calculated 2025 non-PHEV ICE
23 cohort is 269% higher than the 2036 forecasted net additions of non-PHEV ICE
24 LDVs assumed in 2036 from part (f)(i).
25

26 In terms of the total fleet, at the end of 2025, there was a ZEV stock of 9,650 in a
27 total LDV fleet of about 650,000-675,000 vehicles. Although today, ZEV drivers
28 generally drive more than average, to simplify the calculation by allowing for the
29 average LDV mileage, the non-PHEV ICE fleet accounts for 98.5% of all vehicles,
30 and therefore all kilometers driven.

2026 Load Forecast Report (NSEB M12861)
NSPI Responses to Synapse Energy Economics Inc. Information Requests

NON-CONFIDENTIAL

1 (iii) Refer to (f) parts (i) and (ii), and (d).

2
3 (g) The method to estimate total LDV ZEV additions is as follows:

4
5 • Forecast total LDV vehicle sales based on historical trends. Outside of COVID
6 related downturns 2020-2023, between 50,000 and 60,000 LDVs are sold in NS
7 each year. Allow for low population growth to drive small increase from 53,116 in
8 2026 to 57,351 in 2036.

9
10 • Set start and end points for ZEV sales:

11 • Set 2036 to 75 percent ZEV sales as per stated federal policy goal.

12 • Forecast 2026 ZEV additions as a percentage of total sales based on
13 historical ZEV sales trends. Historical trends are volatile and are adjusted
14 for policy environment. At the end of 2025, ZEV as a percentage of LDV
15 sales were ~4.4 percent, roughly where Nova Scotia ended at the end of
16 2023. 2026 was set to 6.2 percent of sales, allowing for a return to 2024
17 levels, and historical growth patterns.
18

19
20 • Assume a curve in between to be flatter in the first half of the forecast period with
21 a steeper ramp up in second half, as in previous forecasts, to account for no local
22 policy drivers drawing adoption forward.
23

24 (h) The federal government reintroduced consumer EV incentives through the Electric Vehicle
25 Affordability Program (EVAP), with eligible purchases and leases starting February 16,
26 2026 (formal program running to March 31, 2031). The program provides point-of-sale
27 rebates of up to \$5,000 for battery-electric vehicles and \$2,500 for plug-in hybrids,
28 typically applied directly at dealerships, with eligibility tied to vehicle price caps (generally
29 MSRP <= \$50,000) and manufacturing in Canada or countries with free-trade agreements.
30 The incentives are designed to encourage early adoption and therefore decline annually

2026 Load Forecast Report (NSEB M12861)
NSPI Responses to Synapse Energy Economics Inc. Information Requests

NON-CONFIDENTIAL

1 over time, falling from \$5,000 in 2026 to roughly \$2,000 by 2030 for battery EVs (and
2 proportionally for plug-in hybrids), before the program is fully phased out at the end of its
3 funding window. NS Power adjusted its forecast up to account for the reintroduction of
4 these rebates by setting a higher growth rate on ZEV sales.

5
6 (i) The cancellation of the EV Availability Standard and revision of the federal government
7 mandate affected the end point of the forecast as described in part (g). The net effect was
8 lower additions in 2036, but this is balanced by a higher total stock given higher than
9 forecast additions in 2025 and a higher growth rate due to the return of point-of-sale
10 rebates.

11
12 (j) The forecast was adjusted upwards for higher than forecast additions in 2025 by
13 compounding growth from the higher than anticipated sales rate (ZEVs as a percent of total
14 LDVs) rather than the higher than anticipated ZEV addition volume. This allows
15 normalization for the fact that total vehicle sales were also higher in 2025 than 2024.

16
17 (k) No.

18
19 (l) It is NS Power's intention to evaluate the AMI-derived at-home charging parameters for
20 EVs once sufficient new data are available.

21
22 (m) For LDV at-home charging, managed charging is not explicitly incorporated; the peak
23 impact is derived from NS Power's AMI data analysis, outlined in detail in the 2025 Load
24 Forecast Report and carried forward into this forecast. That analysis identified a coincident
25 peak impact of 0.39 kW/vehicle for at-home charging, reflecting the observed charging
26 behaviour of NS Power's actual EV customer population without any direct management
27 programs in place. An additional 0.2 kW/vehicle is added for public and commercial LDV
28 charging based on E3's EV Load Shaping Tool load shapes, for a combined LDV peak
29 impact of 0.6 kW/vehicle. A sensitivity showing potential peak impact based on the

2026 Load Forecast Report (NSEB M12861)
NSPI Responses to Synapse Energy Economics Inc. Information Requests

NON-CONFIDENTIAL

1 maximum non-coincident residential peak calculated in the AMI analysis referenced
2 above, which was 0.5 kW/vehicle, was included in the report (Figure 30).
3 For MDV and HDV, managed charging assumptions continue to be drawn from E3's EV
4 Load Shaping Tool, as AMI-based validation has not yet been undertaken for these vehicle
5 categories. E3's tool uses a bottom-up simulation of driving and charging behaviour to
6 produce managed and unmanaged load shapes. The assumed coincident peak contributions
7 are 1.62 kW/vehicle (managed) and 1.06 kW/vehicle (unmanaged) for MDV, and 7.33
8 kW/vehicle (managed) and 27.70 kW/vehicle (unmanaged) for HDV (as presented in
9 Figure 29 of the report). Note that for MDV, the managed figure is higher than the
10 unmanaged figure; this is because cost-minimizing managed charging for MDV shifts load
11 toward times that coincide with NS Power's winter evening peak, whereas unmanaged
12 MDV charging peaks in morning hours. For further detail on E3's managed charging
13 methodology and assumptions, please refer to NS Power's response to Synapse IR-9 part
14 (d) in the 2024 Load Forecast proceeding (M11689).

NON-CONFIDENTIAL

Request IR-12:

Solar Generation (PV) (Section 4.5.5, p. 47-50)

- (a) Please provide supporting data for the average capacity and capacity factor for the PV installations used in the forecast.
- (b) How was the forecast adjusted to account for the lower solar installations in 2025 compared to the 2025 Load Forecast?
- (c) Did NS Power use AMI data to validate its solar assumptions? If so, please provide the methodology, sample size, and key findings from this analysis. If not, please explain why AMI data was not used.

Response IR-12:

- (a) Please refer to Attachment 1 for full calculations outlining the average solar capacity (“Nameplate capacity calculations” tab) and capacity factor (“2025 Net Metering Summary” tab) stated in Section 4.5.5 of the Report.¹ For the purposes of the Load Forecast, information from the Net Metering and Commercial Net Metering Programs are combined to most accurately model the system impact of solar generation taking place under both programs.
- (b) To reflect that the actual number of solar installations has been below forecast in recent years, combined with removal of financial incentives on the residential side, as discussed in Section 4.5.5 of the Report, the rate of growth in incremental residential installations was reduced to 10 percent, down from 15 percent in previous years. However, there was no change to the rate of growth in incremental commercial installations, reflective of

¹ Attachment 1 combines data from Attachment 1 to the 2025 Commercial Net Metering (M12782) and 2025 Net Metering (M12783) Reports.

2026 Load Forecast Report (NSEB M12861)
NSPI Responses to Synapse Energy Economics Inc. Information Requests

NON-CONFIDENTIAL

- 1 continued commercial incentives and strong growth in the Commercial Net Metering
2 Program (CNMP), as described in the 2025 CNMP Report (M12782).
3
4 (c) Energy forecast assumptions are based on data from the net metering reports, while peak
5 assumptions are based on analysis of two years of hourly data from six solar arrays, as
6 outlined in Section 10.2 of the Report.

**2026 Load Forecast Report Synapse IR-12 Attachment 1 has
been filed electronically.**

2026 Load Forecast Report (NSEB M12861)
NSPI Responses to Synapse Energy Economics Inc. Information Requests

NON-CONFIDENTIAL

Request IR-13:

Solar Impact to Peak (Section 10.5, p. 95-96)

(a) Please refer to Figure 70. Explain how the average coincidence factors were developed and provide all underlying data and calculations.

(b) Please explain why updated coincidence factor data was not available for 2025.

(c) Does NS Power expect to update the solar coincidence factors in the 2027 forecast?

Response IR-13:

(a) Please refer to Attachment 1 for calculations. Hourly generation data from six solar sites participating in the Solar Electricity for Community Buildings program was analyzed across two years (2022 and 2024). For each site, the generation at hour of system peak each month was compared to the maximum generation for that site/month to establish a coincidence factor. Coincidence factors were then averaged across all sites for every month of the year.

(b) Hourly generation data were not available for the sites discussed above owing to the cyber incident.

(c) NS Power intends to evaluate the solar coincidence factors in the 2027 load forecast, pending the availability of hourly data.

**2026 Load Forecast Report Synapse IR-13 Attachment 1 has
been filed electronically.**

2026 Load Forecast Report (NSEB M12861)
NSPI Responses to Synapse Energy Economics Inc. Information Requests

NON-CONFIDENTIAL

Request IR-14:

Price Data (Section 4.6, p. 56-57)

(a) Why are electricity prices forecast to increase by 5 percent in 2028 and 2029? Please describe NS Power's internal forecasting process.

Response IR-14:

(a) The forecast for future rate increases is inherently uncertain and subject to change. NS Power continues to work collaboratively with stakeholders to find ways to reduce costs and help alleviate rate pressure on customers. The Company's current understanding of future rate impacts do not represent a future rate filing as forecast revenue requirement is revised as inputs are refined. This is evidenced by the expected increase of 5 percent for the 2026 and 2027 period included in the 2025 Load Forecast Report, with actual approved rate increases being significantly lower at 1.2 percent in 2026 and 2.5 percent in 2027.

The increase in electricity prices is based on NS Power's internal forecasting and includes both fuel and non-fuel costs. NS Power's internal forecasting is developed through a process that determines the Company's current understanding and best estimate of the following primary inputs for future periods:

- Electric Sales and Revenue
- Other Revenue
- Fuel and Purchased Power expense
- Operating expenses
- Capital Investment
- Working Capital requirements
- Depreciation and Amortization expense

2026 Load Forecast Report (NSEB M12861)
NSPI Responses to Synapse Energy Economics Inc. Information Requests

NON-CONFIDENTIAL

- Interest rates and financing expenses
- Income Taxes and Grants in Lieu of Property Taxes
- Capital Structure and Allowed Return on Equity

NS Power begins by forecasting its revenue for the future period using current approved rates. It then calculates the total revenue requirement (i.e., the cost of service) needed to operate during that period using the inputs listed above.

The difference between the required revenue and the forecasted revenue at current approved rates represents the required increase in revenue. This increase is then translated into a percentage by comparing it to the forecasted revenue under current rates.

NON-CONFIDENTIAL

Request IR-15:

Demand Side Management (Section 4.7, p. 57-60)

Refer to the following statement on pages 58 to 59 of the NS Power 2026 Load Forecast Report: “to introduce cumulative historical DSM savings as reported by E1 to the regression model as a load modifying variable and allow the model to determine what level of DSM is already included in other variables.”

(a) Please provide the cumulative historical DSM savings, expressed as both annual energy savings in GWh and peak load savings in MW, as reported by E1 and used by NS Power to adjust historical loads.

(b) Please explain how E1 or NS Power developed the cumulative historical DSM savings, including whether E1 or NS Power assumed any DSM savings decays. If savings decay was assumed, please explain how E1 or NS Power determined the savings decay effects.

(c) Please identify the first year included in the cumulative historical DSM savings and explain how E1 or NS Power determined the starting year for these cumulative DSM savings estimates.

Response IR-15:

(a) Please refer to Attachment 1 for annual energy savings in GWh. This approach is not used in the peak forecast; it is instead assumed that the portion of peak DSM embedded in model variables is the same as for energy. Therefore, the DSM coefficients established in the energy models are also applied to peak DSM.

2026 Load Forecast Report (NSEB M12861)
NSPI Responses to Synapse Energy Economics Inc. Information Requests

NON-CONFIDENTIAL

- 1 (b) The cumulative historical DSM savings series is derived from E1's annually reported
2 savings figures. Savings decay is assumed implicitly rather than through an explicit year-
3 by-year decay function. Specifically, the 10-year window over which savings are
4 accumulated serves as a proxy for measure-life expiry – savings from programs whose
5 installed measures have largely reached end-of-life are excluded from the series entirely.
6 Any residual savings from longer-lived measures pre-dating this window are treated as
7 embedded in the historical sales data used to estimate the regression, avoiding the double-
8 counting of DSM savings. The regression coefficient on the DSM variable then further
9 calibrates the portion of the remaining cumulative savings already captured in other model
10 variables. This approach is consistent with the methodology described in the Itron white
11 paper filed in the 2016 10-Year System Outlook Report proceeding.¹
12
- 13 (c) The first year included in the cumulative historical DSM savings series is 10 years prior to
14 the start of the forecast period. This starting year was selected as a conservative
15 approximation reflecting the lower end of the NS DSM portfolio's average measure life
16 range (approximately 11 to 13 years).² Savings from programs delivered more than 10
17 years before the forecast start are excluded on the basis that their installed measures are
18 most likely to have reached or be reaching end-of-life, while any residual savings from
19 longer-lived measures are treated as embedded in the historical sales baseline. This
20 approach is consistent with prior load forecast proceedings.

¹ M07540, N-2, NS Power 2016 10 Year System Outlook, NSPI to NSUARB IR-2, Attachment 1, Itron White Paper: Incorporating DSM into the Load Forecast, October 19, 2016.

² Based on Navigant's Energy Efficiency Resource Assessment Model, as reported in E1's 2015 Rate and Impact Model, M07149 Exhibit E-2.

**2026 Load Forecast Report Synapse IR-15 Attachment 1 has
been filed electronically.**

NON-CONFIDENTIAL

Request IR-16:

Renewable to Retail (Section 4.8, p. 61):

(a) Please explain the basis for the shift in this year's RTR forecast relative to last year's that increases migration for commercial and industrial customers but decreases migration for residential customers.

(b) Refer to Section 4.8 Renewable to Retail. Please describe if any energy from Goose Harbour Lake Wind Farm is captured within the Renewable to Retail forecast. If not, please describe how the energy from the Goose Harbour Lake Wind Farm is treated in the broader load forecast, if at all.

Response IR-16:

(a) The values were updated based on new information provided by the Licensed Retail Supplier, Renewall, indicating a forecast shift in class sales from the information provided for the 2025 Load Forecast Report.

(b) Goose Harbour Lake Wind Farm is not included in the RTR load forecast. It is accounted for in terms of overall energy supply in the province.

2026 Load Forecast Report (NSEB M12861)
NSPI Responses to Synapse Energy Economics Inc. Information Requests

NON-CONFIDENTIAL

1 **Request IR-17:**

2
3 **Net System Requirement (Section 9.0).**

4
5 **(a) Please provide the source data and the calculations used to produce the values in**
6 **Figures 56-58.**

7
8 **Response IR-17:**

9
10 **(a) Please refer to Attachment 4 of the report, tab “Graphs”, in the following locations:**

- 11 • Figure 56: Cells A120 to G127
- 12 • Figure 57: Cells E15 to F35
- 13 • Figure 58: Cells A138 to G152

NON-CONFIDENTIAL

Request IR-18:

Model Specifications (Appendix B)

(a) Please note any changes in the residential model specification relative to the 2025 forecast residential model, and please further quantify the impact of any such changes in specification to the extent possible.

(b) Please note any changes in the commercial model specification relative to the 2025 forecast residential model, and please further quantify the impact of any such changes in specification to the extent possible.

(c) Please note any changes in the industrial model specification relative to the 2025 forecast residential model, and please further quantify the impact of any such changes in specification to the extent possible.

Response IR-18:

(a) The 2026 Residential model includes updates to the binary variables, with March 16 and March 22 added to address large residuals observed during the affected periods, and February 18, April 15, May 15, and July 20 removed. In addition, the COVID-related variable has been updated. The COVID variable is a binary that starts in July 2020 with a value of 1, is reduced to 0.5 in August 2022, and zero in 2025. As discussed in the Load forecast report, this variable was used to explain changes in consumption patterns during the pandemic and subsequent years but is removed from the forecast period.

(b) The 2026 model for the Small General class remains unchanged. For the General class model, binary variables for Year 2021, Year 2022 onward, and December 2025 have been added to account for shifts in usage since 2021 (post COVID) and improve the model fit,

2026 Load Forecast Report (NSEB M12861)
NSPI Responses to Synapse Energy Economics Inc. Information Requests

NON-CONFIDENTIAL

1 while those for December, Year 2023 onward, August 2022, and June 2021, previously
2 included in the 2025 model, have been removed.

3
4 (c) Compared to the 2025 model, the 2026 model for the Small Industrial class includes one
5 additional binary variable for June 2025 to account for billing issues due to the cyber
6 incident. For the Medium Industrial class, three new binary variables, June 2025,
7 September 2025, and October 2025, have been added to account for impacts from the cyber
8 incident. Moreover, and as discussed in the report, the Medium Industrial model is now
9 estimated using a historical period from 2016 to 2025, consistent with the approach applied
10 to all other modelled classes. This represents a change from previous forecasts, which used
11 a longer historical timeframe. Consequently, the binary variable previously applied to the
12 period from 2016 onward has been removed. In addition, the MIVar variable has been
13 updated to a weighted combination of manufacturing GDP and manufacturing
14 employment, replacing the prior specification based solely on manufacturing employment.
15 This change was also discussed in the report. These modifications have improved overall
16 model fit relative to previous specifications.

NON-CONFIDENTIAL

Request IR-19:

Sensitivity Analysis (Section 11.0 and Appendix D)

(a) Please provide in electronic format the data and calculations used to create Figures 75 and 76.

(b) Please provide the actual statistical distributions used for the sensitivity variables and how they were determined.

(c) What other variables were considered but not chosen? Please explain.

(d) Please describe if and/or how the P10/P90 probability analysis is used in decision making regarding system planning.

Response IR-19:

(a) Please refer to Attachment 1.

(b) All the variables used in the Monte Carlo simulation exhibit a normal distribution behavior. Generally, the mean values will be the deterministic forecast values used in the SAE models. In the case of weather, they are weather normal and in the case of economics, they are the year-to-year growth rates. Please refer to NSEB IR-10, Attachment 1, for the inputs used.

(c) Inputs for end uses are being considered for inclusion in future P10/P90 probability models. At present, they are more difficult to model, as they have more limited historical datasets and present challenges in the probabilistic approach being used.

2026 Load Forecast Report (NSEB M12861)
NSPI Responses to Synapse Energy Economics Inc. Information Requests

NON-CONFIDENTIAL

- 1 (d) The P10/P90 probability analysis is not currently being used in decision making regarding
2 system planning.

Year	Actuals	p10	p50	p90
2016	2,111			
2017	2,018			
2018	2,073			
2019	2,060			
2020	2,050			
2021	1,968			
2022	2,216			
2023	2,455			
2024	2,088			
2025	2,267			
2026		2,350	2,513	2,702
2027		2,368	2,533	2,724
2028		2,397	2,564	2,756
2029		2,418	2,587	2,783
2030		2,428	2,599	2,795
2031		2,455	2,628	2,826
2032		2,478	2,650	2,849
2033		2,509	2,685	2,888
2034		2,545	2,723	2,928
2035		2,585	2,766	2,974
2036		2,618	2,799	3,009

Year	Actuals	p10	p50	p90
2016	10,809			
2017	10,873			
2018	11,249			
2019	11,077			
2020	10,723			
2021	10,902			
2022	11,134			
2023	11,131			
2024	11,326			
2025	11,469			
2026		11,338	11,584	11,827
2027		11,157	11,405	11,651
2028		11,268	11,519	11,773
2029		11,292	11,546	11,803
2030		11,294	11,552	11,812
2031		11,345	11,608	11,873
2032		11,409	11,678	11,947
2033		11,440	11,715	11,993
2034		11,536	11,814	12,101
2035		11,664	11,947	12,238
2036		11,827	12,116	12,411

NON-CONFIDENTIAL

Request IR-20:

Appendix B: Residential Model

(a) For the XHeat variable please provide the underlying factors (penetration, usage, etc.) driving the change of percentage for HP Heat.

(b) For the XCool variable please provide the underlying factors (penetration, usage, etc.) driving the change of percentage for HP Cool.

(c) For the XOther variable please provide the underlying factors (penetration, usage, etc.) driving the change of percentage for Other.

Response IR-20:

(a) The HP Heat share forecast is approximately 49.9 percent in 2026 and approximately 73.4 percent in 2036; this measure is the main driver for growth in HP Heat. Please refer to 2026 Load Forecast Report Attachment 1 - Residential Intensities, filed electronically, tab “Intensities” and “Shares” for details and calculations.

(b) The HP Cool share forecast in 2026 is approximately 63 percent, and in 2036 is forecast to be approximately 89 percent; this measure is the main driver for the growth in HP Cool Intensity. Please refer to 2026 Load Forecast Report Attachment 1 - Residential Intensities, filed electronically, tab “Intensities” and “Shares” for details and calculations.

(c) There are no significant changes for the OtherUse variable in a 10-year span. As shown in Appendix B: page 3, the drivers within OtherUse are Household Size, Price, Seasonal Use Patterns and the economic indicator (Employment Compensation being the economic indicator for 2026).

2026 Load Forecast Report (NSEB M12861)
NSPI Responses to Synapse Energy Economics Inc. Information Requests

NON-CONFIDENTIAL

Request IR-21:

ELCC Study

(a) Refer to the following statement from the 2025 Load Forecast: “On February 6, 2025, NS Power distributed to stakeholders for review and comment a draft study scope document for the next ELCC study.”

(i) Please describe the anticipated timeline for completion of the ELCC study.

(ii) Please indicate if NS Power expects to include the results of the ELCC study in the 2027 Load Forecast.

Response IR-21:

(a)

(i) The IESO-NS published the final ELCC study on its website on June 24, 2026.¹

(ii) Yes, NS Power will be incorporating the results of the ELCC study in the 2027 Load Forecast.

¹ <https://ieso-ns.ca/system-planning/>